



West Chester Office 1450 E. Boot Road Bldg. 100-B West Chester, PA 19380 O 610.495.2118 M 484.995.7137

March 07, 2019

Richard Taylor, Laboratory Manager Valley Forge Sewer Authority 333 Pawling Road Phoenixville, PA 19460

RE: Easttown Township 2018 Chapter 94 Report ARRO #5080.82

Dear Mr. Taylor:

On behalf of our client, Easttown Municipal Authority, please find enclosed the Authority's 2018 Annual Report for inclusion within the 2018 VFSA Chapter 94 Report. We trust that you will find the enclosed information satisfactory.

As always, if you have any questions or require any additional information, please feel free to contact me via email at <u>brady.flaharty@arroconsulting.com</u> or telephone at 610.495.2118.

Sincerely,

Brady & Flaharty, P.E. 79 ARRO Consulting, Inc., Easttown Municipal Authority Engineer

BLF:car

Enclosure

c: Donald C. Curley, Administrator - Easttown Municipal Authority (w/ encl.)



### CHAPTER 94 MUNICIPAL WASTELOAD MANAGEMENT ANNUAL REPORT

# **2018**

### EASTTOWN MUNICIPAL AUTHORITY CHESTER COUNTY, PENNSYLVANIA

**Prepared by:** 

### ARRO CONSULTING, INC. 1450 East Boot Road Building 100-B West Chester, Pennsylvania 19380 (484) 999-6150

**Prepared for:** 

EASTTOWN MUNCIPAL AUTHORITY 566 Beaumont Road Devon, Pennsylvania 19333 (610) 687-3000

Preparer

. i

, 1

aharty Signature/

Brady L. Flaharty, P.E. ARRO Consulting, Inc. Authority Engineer

#### EASTTOWN MUNICIPAL AUTHORITY CHESTER COUNTY, PENNSYLVANIA

#### CHAPTER 94 MUNICIPAL WASTELOAD MANAGEMENT ANNUAL REPORT OPERATING YEAR 2018

Table of Contents

Page

1.	INTRODUCTION	1
2.	HYDRAULIC LOADINGS	1
3.	5-YEAR HYDRAULIC AND ORGANIC LOADING PROJECTIONS	2
4.	SEWER EXTENSIONS	3
5.	PROGRAM FOR SANITARY SEWER MONITORING, MAINTENANCE,	3
	AND REPAIR	
6.	CONDITION OF THE SEWER SYSTEM	4
7.	SEWAGE PUMPING STATIONS	5
8.	PUMPING STATION FLOW DURING MAJOR STORM EVENTS	6
9.	INDUSTRIAL WASTES	7
10.	CORRECTIVE ACTION PLAN	7
11.	CALIBRATION REPORTS	8

#### **EXHIBITS**

- A. EMA Past and Present Hydraulic Loading Data
- B. EMA Past, Present and Projected EDUs, Flows and Organic Loadings
- C. Easttown Township Approved and Projected Connections
- D. EMA Flow Information for Each Pump Station
- E. EMA Monthly Flow Total to VFSA Versus Rainfall Graph
- F. EMA Pump Stations Flow to VFSA Versus Rainfall Summary and Graphs
- G. EMA Small Metered Pump Stations Flow Versus Rainfall Summary and Graphs
- H. EMA 1-Inch Plus Rainfall Versus Flow at Metered Pump Stations Summary
- I. EMA 1-Inch Plus Rainfall Versus Flow at Large Metered Pump Stations Graphs
- J. EMA 1-Inch Plus Rainfall Versus Flow at Small Metered Pump Stations Graphs
- K. EMA Pump Station Flow Meter Calibration Reports

#### 1. INTRODUCTION

This Municipal Wasteload Management Annual Report is prepared in accordance with the Pennsylvania Department of Environmental Protection (Department) Chapter 94 for the Easttown Municipal Authority sewerage collection and conveyance system tributary to the Valley Forge Sewer Authority Wastewater Treatment Plant.

Easttown Municipal Authority (Authority) owns the sanitary sewer collection and conveyance systems within Easttown Township under Water Quality Management Permit No. 1503401. Easttown Township operates and maintains the facilities.

The sanitary sewer collection system is comprised of approximately 1673 manholes and 327,035 lineal feet of gravity sewer. There are approximately 2846 residential homes and 322 small businesses connected to the collection system. The conveyance systems are comprised of twelve (12) sewage pump stations with approximately 39,974 lineal feet of force main.

The Authority sanitary sewer collection system provides for collection of domestic sewage from Easttown Township, a suburban residential area encompassing several watersheds. Wastewater from each of these watersheds flows by gravity to one of twelve pumping stations, which ultimately convey the wastewater to a wastewater treatment plant operated by the Valley Forge Sewer Authority via the Aqua Resources, Inc.'s Valley Creek Trunk Sewer (VCTS) collection system. There is a small portion of the system, consisting of approximately 50 homes in the Valley Forge Road area that drains through the Tredyffrin Township collection system into the Radnor-Haverford-Marple Authority system. There is also a small portion of the system, comprised of approximately 177.4 EDUs, that drains through Tredyffrin Township to Upper Merion Township's Trout Run Water Pollution Control Center.

#### 2. <u>HYDRAULIC LOADINGS</u>

Sewage flow from the Authority system is measured at three pumping stations, Berwyn, Daylesford and Saybrook, which each convey wastewater directly into the Tredyffrin Township collection system.

Exhibit 'A' contains a summary of Easttown total monthly flow to VFSA for 2018 and the previous 4 years, along with the 2018 monthly rainfall. The 2018 monthly flow and rainfall is charted in Exhibit 'E'.

During 2018 the measured sewage flow from the Authority sewer system averaged 1,340,600 gallons-per-day. This represents an increase of approximately 431,498 gallons-per-day versus 2017 flows. The higher than normal flow is attributed to the excessive rainfall recorded in 2018. In 2018 a total of 71.13 inches of rain was recorded at USGS *Site 01473169 Valley Creek* near Valley Forge, PA, as compared to the yearly average of 44.87 inches of rain recorded from 2010 to 2017.

#### 3. 5-YEAR HYDRAULIC AND ORGANIC LOADING PROJECTIONS

The total number of EDUs connected at the end of 2018 was 3841.7, which produced an average annual flow of 1.341 MGD and 349.0 gpd/EDU.

The number of EDUs and total average daily flow over the next five (5) years are both projected to increase as follows:

		Additional # of EDUs	<u>Total # of EDUs</u>	<u>Total Flow (MGD)*</u>
Actual	2018	37.0	3,841.7	1.341
Projected	2019	45.0	3,886.7	1.356
Projected	2020	45.0	3,931.7	1.372
Projected	2021	45.0	3,976.7	1.388
Projected	2022	45.0	4,021.7	1.403
Projected	2023	45.0	4,066.7	1.419

\* Projected flows are based on 2018 average gpd/EDU.

The increase in the number of connections was derived by interpolation of the Year 2040 Easttown Projected Flow, specified as 1.686 MGD, which is contained in the Act 537 Supplement for Wilson Road Force Main, Table 3-3, Average Daily Wastewater Flow Projections.

A summary of the EDUs, flows and organic loadings over the last five years and those projected for the next five years, along with graphs depicting the past and projected flows and loadings, are included in Exhibit 'B'. The 2018 average annual loading was

estimated to be 2,516 lbs/day based on an assumed BOD5 concentration of 225 mg/l. The maximum 1-month loading was estimated to be 3,336 lbs/day. The average 5-year ratio organic peaking factor is 1.41.

#### 4. <u>SEWER EXTENSIONS</u>

There was one sewer extension in 2018, which was constructed in the Berwyn Pump Station drainage area.

Exhibit 'C' contains an updated Easttown Township Approved and Projected EDU map and an accompanying tracking list for the sanitary sewer system. EDUs are tracked by both Authority pump station drainage area and unmetered drainage area to the Valley Forge Sewer Authority wastewater treatment plant, by unmetered drainage area to the Radnor-Haverford-Marple Sewer Authority wastewater treatment plant and by unmetered drainage area to the Upper Merion Township Trout Run water pollution control plant. There are currently 4,098.2 EDUs connected to the Easttown Township sanitary sewer system with 5,146 projected to be connected by 2040. The tracking list and map is updated periodically as requests for connections are made and the Department approves EDUs.

### 5. <u>PROGRAM FOR SANITARY SEWER MONITORING, MAINTENANCE, AND</u> <u>REPAIR</u>

The sewer system is maintained by the Township Sewer Crew. The basic operation force consists of one (1) Crew Chief, and three (3) Pump Station Operators. This group is responsible for routine sewer and pump station maintenance and repairs. The Sewer Crew personnel on a daily basis check all pump stations with various readings and notations made for each station as well as conditions and status of major operational components. Each pump station is equipped with various alarms and an automatic dialer to notify Sewer Crew personnel in the event of an equipment malfunction or an unusual system condition. The Sewer Crew also has computer software installed at the Municipal Garage and at the Crew Chief's home that allow real-time monitoring of each pump

station. Additionally, a weekly "on-call" rotation is in place whereby two of the four-man crew is available at any given time to handle emergency situations.

The Township contracts with Municipal Maintenance Company (MMC) to provide monthly detailed inspections of each station within the system. MMC generates a report detailing specific conditions and suggested corrective measures. Township personnel formulate a plan to perform the necessary maintenance and repair, either in-house or contracted services. All necessary repairs are made in a timely manner.

#### 6. <u>CONDITION OF THE SEWER SYSTEM</u>

During 2018 one sanitary sewer overflow event was reported within the Authority's collection system.

A total of 4.25 inches of rain fell over June 10 and June 11, 2018. On June 11 the sewer crew arrived at the Berwyn Pump Station after receiving a high water alarm. The crew found the wet well at extreme high level condition and sewage was emanating from manhole #1267A adjacent to the pump station. After the rain lessened the pump station was able to maintain the incoming flow normally.

The Authority has televised certain portions of the sanitary sewer system in the Berwyn, Daylesford, Devon Hunt, Exeter, Millbrook, Newtown, Pinecroft, Saybrook and Spring Knoll Pump Station drainage areas. From 2012 through 2018 approximately 79,369 ft. of sanitary sewer has been televised. The televising found 80 pipe segment defects, 72 lateral defects and 23 manhole defects that were allowing or had potential to allow infiltration into the sanitary sewer system. Inflow/Infiltration (I/I) mitigation repair activities to correct defects found during the televising were started in July 2011 and continued through 2018.

During 2018 the Daylesford drainage area was designated for I/I investigation. Sewer crew staff conducted night flow metering in select manholes to identify sewer areas of I/I concern. Based on the metering observation data a contractor was engaged to televise portions of the sewer. Based on results of the televising the contractor grout-repaired pipe joints in approximately 1,150 LF of sewer, installed one mechanical seal, and grout-

injected five manholes. The Township estimated a reduction of 836,000 gallons per year of infiltration was removed from the Daylesford drainage area. The Township will conduct I/I investigations and repair work within portions of the whole sewer system as it sees the need through 2019.

During 2018 the Tredyffrin Township Municipal Authority sold the VCTS to Aqua Resources, Inc. Easttown, as a participant in the Valley Creek Trunk Sewer Asset Purchase Agreement, was accorded a portion of the sale proceeds. Some of the proceeds are being used to fund the Argyle Road Sewer Replacement project in 2019 after it was found by Authority operating personnel that certain manholes and sewer piping in Argyle Road downstream of The Greens Pump Station were highly deteriorated.

#### 7. <u>SEWAGE PUMPING STATIONS</u>

The Township operates twelve (12) pumping stations owned by the Municipal Authority. All pumping stations are equipped with magnetic flow meters that measure the flows. Exhibit 'D' contains the 2018 flow information for each pump station.

During 2018 no overflow event was reported at any of the Authority pumping stations. However, on December 26, 2018, an existing clamp on the Berwyn Pump Station's buried 14-inch AC force main pipe broke and allowed wastewater to leak from the break. The pump station was taken offline while clamp was removed and replaced, then the pump station was placed back online.

During 2017 the Daylesford Pump Station upgrade construction was completed. The station's Sharps Woods Gravity and Force Main Replacement project was restarted at the end of 2018 and is expected to be put out to bid in 2019.

As a result of completed and planned I/I reduction work it is anticipated that there will be no need to upgrade or expand the Saybrook Pump Station.

### 8. PUMPING STATION FLOW DURING MAJOR STORM EVENTS

The Department requires Chapter 94 reports to include a discussion of metered flow data for the collection and conveyance systems, specifically during major storm events (greater than 1.0 inch of rain).

Exhibit 'F' contains a summary of Easttown total monthly flow versus rainfall to VFSA from its three major pump stations – Berwyn, Daylesford and Saybrook – and also the charts of the monthly and average yearly flow for these pump stations.

Exhibit 'G' contains a summary of monthly flow versus rainfall at the nine (9) small metered satellite pump stations – Berwyn Estates, Devon Hunt, Exeter, Fox Creek, Millbrook, Newtown, Pinecroft, Spring Knoll, and The Greens – and also the charts of the monthly and average yearly flow for these pump stations.

Exhibit 'H' contains a summary of the rainfall and the metered flows at all twelve (12) of the Authority's pump stations for the twenty-five (25) days in 2018 where rain fell more than 1-inch plus in a 24-hour period. The charts in Exhibits 'I' and 'J' were developed from this data.

Exhibit 'I' contains a chart for the Berwyn, Daylesford, and Saybrook Pump Stations during the twenty-five (25) rain events. As related to yearly average flow, the peaking factors for the three pump station meters during the rain events are as follows:

Pump Station	Yearly Avg. Flow	Rain Events Peaking Factor			
-	(MGD)	<u>High</u>	<u>Average</u>		
Berywn	0.836	2.43	1.42		
Daylesford	0.303	2.01	1.22		
Saybrook	0.115	1.56	1.12		

In conclusion, the peaking factors for Berwyn, Daylesford and Saybrook Pump Stations during the high rain event are within the Department's current peaking factor guidelines. However, as part of its CMP program, the Authority will continue to actively pursue I/I in the drainage areas of contributing upstream pump stations to Berwyn Pump Station, especially Devon Hunt and Exeter.

Exhibit 'J' contains the charts of peak rain event flows at the nine (9) small metered satellite pump stations – Berwyn Estates, Devon Hunt, Exeter, Fox Creek, Millbrook, Newtown, Pinecroft, Spring Knoll, and The Greens. As related to yearly average flow, the peaking factors for the nine (9) pump stations during the rain events are as follows:

Pump Station	Yearly Avg. Flow	Rain Event	s Peaking Factor
•	<u>(MGD)</u>	<u>High</u>	<u>Average</u>
Berwyn Estates	0.007	1.38	1.09
Devon Hunt	0.072	2.19	1.40
Exeter	0.009	3.49	1.56
Fox Creek	0.012	2.86	1.53
Millbrook	0.004	1.54	1.08
Newtown	0.157	3.18	1.63
Pinecroft	0.003	2.11	1.41
Spring Knoll	0.043	3.00	1.54
The Greens	0.019	1.56	1.22

Based on the 2018 flow meter readings and the preceding rain event peaking factors, the current 4.19 peaking factor is sufficient for Millbrook and the station is not considered by the Authority for upgrade to meet current peaking factor guidance.

The peaking factor of 2.86 experienced at Fox Creek, also a station not considered by the Authority for upgrade, is believed to be caused by high flow from its contributing upstream pump station, Pinecroft, which has a peaking factor of 2.11.

#### 9. INDUSTRIAL WASTES

There are no known industrial waste dischargers within Easttown Township.

#### 10. CORRECTIVE ACTION PLAN

The Department mandated the Authority to develop a CMP/CAP in December 2010. ARRO Consulting, Inc. prepared a Capacity Management Plan (CMP) and an associated Strategic I/I Reduction Plan, which collectively makes up the Corrective Action Plan (CAP) that sets forth the actions the Authority would take over the next five years to reduce overloads and provide additional capacity in its sanitary sewer system. The CAP/CMP that was submitted to PADEP by transmittal letter dated February 10, 2011

and, after minor revisions, was approved by PADEP by letter, dated October 25, 2011. Quarterly updates are submitted to the Department. The first quarterly update was submitted in January 2012.

All of Easttown's CAP milestone work within the Berwyn Pump Station and Saybrook Pump Station drainage areas is complete. The Valley Creek Trunk Sewer gravity system upgrade in Tredyffrin Township and the Wilson Road Force Main Rehabilitation, into which flow the effluent from Berywn Pump Station and Saybrook Pump Station, are also complete. However, PADEP has still not granted the Township authorization to allow any of the recently upgraded pump stations to pump at full design peak flow capacity. The Daylesford Pump Station upgrade construction is complete. The station's Sharps Woods Gravity and Force Main Replacement project was restarted at the end of 2018 and is expected to be put out to bid in 2019. The Authority will continue its CAP work and continue managing capacity within the Daylesford Pump Station drainage area.

#### 11. CALIBRATION REPORTS

The flow meters at Berwyn, Daylesford and Saybrook Pump Stations were calibrated during 2018. Copies of the calibration reports are included in Exhibit 'K'.

# **EXHIBITS**

!

.

## Exhibit A

# **Easttown Municipal Authority**

# Past & Present Hydraulic Loading Data

### <u>Table 1</u>

		70T4	2014 - 2018			2010
						20102
Month	2014	2015	2016	2017	2018	Rainfall (in.)
January	1.235542	1.066465	1.049568	0.966575	0.869454	2.43
February	1.422990	1, 01178644	56.5.5417417	0.911219	1.219988	6.20
March	Legisland	1 3850000	1.28318830	0.966853	1.440283	4.09
April	102421	A. B. S. Second	1.2(0) 526	4.155713	1.301480	3.76
May	11.6951607	0.953631	1.175391	1.316055	1.292485	6.36
June	1.135987	0.947148	0.981711	0,27.1.4.13	1.316415	6.04
July	0.903484	0.945913	0.859479	0.879162	1.066002	6.13
August	0.825636	0.797012	0.810786	0.816475	1.197483	9.82
September	0.817695	0.783948	0.787647	0.760021	1.534737	9.53
October	0.837325	0.857556	0.790326	0.765258	1.39(993%)	2.48
November	0.882250	0.861203	0.799209	0.799465	1. 764.1.52	8.32
December	1.019266	1.011020	0.931850	0.796040	1.577738	5.97
Average Annual Flow (MGD)	1.147154	0.979029	1.010343	0.909103	1.340600	
Max. 3 Month Ave. Flow (MGD)		の変換し		(antigeral)		Total 71.13
PEAKING FACTOR Max. 3 Month Ave. Flow / Ave. Annual Flow	1.360	1.200	1.300	1.190	1.210	
Flow Peaking Factor: Average 5 Year Ratio	1.252					

Jan - Dec 2018: Rain Data from USGS Site 01473169 Valley Creek near Valley Forge.

# **TABLE 1**

ļ

i

٠

# **EASTTOWN MUNICIPAL AUTHORITY** 2018 ANNUAL CHAPTER 94 REPORT HYDRAULIC LOADING DATA (MGD) 2014 - 2018

÷

# <u>Exhibit B</u>

## **Easttown Municipal Authority**

# <u>Past, Present & Projected</u> <u>EDUs, Flows and Organic Loadings</u>

Table 2 & Table 3 and Graph 1 & Graph 2

2
Ξ
Γ
A

# **EASTTOWN MUNICIPAL AUTHORITY 2018 ANNUAL CHAPTER 94 REPORT** ORGANIC LOADING DATA (lbs/Day) 2014 - 2018

Month	2014	2015	2016	2017	2018
January	2,318	2,001	1,970	1,814	1,632
February	2,670	1,910	2,917	1,710	2,289
March	2,660	2,591	2,405	1,814	2,703
April	2,954	2,112	2,067	2,172	2,442
May	3,178	1,789	2,206	2,094	2,425
June	2,132	1,777	1,842	1,828	2,470
July	1,695	1,775	1,613	1,650	2,000
August	1,549	1,496	1,521	1,532	2,247
September	1,534	1,471	1,478	1,426	2,880
October	1,571	1,609	1,483	1,436	2,458
November	1,656	1,616	1,500	1,500	3,305
December	1,913	1,897	1,749	1,494	3,336
Average Annual BOD (lbs/Day)	2,153	1,837	1,896	1,706	2,516
Max. 1 Month BOD5 Loading (lbs/Day)	3,178	2,591	2,917		
RATIO: Max. 1 Month BOD5 / Ave. Annual BOD5	1.48	1.41	1.54	1.27	1.33
Organic Peaking Factor: Average 5 Year Ratio	1.41				

E

ł i.

- .|

. !

Year	EDUs	Connected Population	Average Total Flow (mgd)	Max. 3 Month Ave. Flow (mgd)	Per Capita Flow (gpcd)	Average Total BOD5 (lbs/day)	Per Capita BOD5 (Ibs/day)
2014	3,751.4	10,837	1.147	1.56	106	2,153	0.199
2015	3,753.2	10,878	0.979	1.17	90	1,837	0.169
2016	3,786.7	10,918	1.010	1.31	93	1,896	0.174
2017	3,804.7	10,959	0.909	1.08	83	1,706	0.156
2018	3,841.7	10,999	1.341	1.62	122	2,516	0.229
Average		10,918	1.077		66	2,021	0.185
<b>Projected Loadings</b>	Loadings						
2019	3,886.7	11,128	1.356	1.70	122	2,060	0.185
2020	3,931.7	11,257	1.372	1.72	122	2,084	0.185
2021	3,976.7	11,385	1.388	1.74	122	2,108	0.185
2022	4,021.7	11,514	1.403	1.76	122	2,131	0.185
2023	4,066.7	11,643	1.419	1.78	122	2,155	0.185

# **TABLE 3**

ר י ו

A STATE OF A STATE OF

• •

1

۰ ۱ ۱

------ a


. . ...

# **EASTTOWN MUNICIPAL AUTHORITY** 2018 ANNUAL CHAPTER 94 REPORT PAST AND PROJECTED LOADINGS

GRAPH - #1


Į

# EASTTOWN MUNICIPAL AUTHORITY 2018 ANNUAL CHAPTER 94 REPORT HYDRAULIC LOADING



# GRAPH - #2

# EASTTOWN MUNICIPAL AUTHORITY 2018 ANNUAL CHAPTER 94 REPORT ORGANIC LOADING



# <u>Exhibit C</u>

# Easttown Township

**Approved and Projected Connections** 

# EASTTOWN TOWNSHIP APPROVED and PROJECTED EDU TRACKING LIST.

Map Development ID Name	Development Address	Development Tax Parcel	Total EDUs Approved	Total EDUs Connected Thru 2016	Approved EDUs Aiready Connected Third 2018	Connected 2019 - 2020	Potential EDite Connected 2020 - 2060	Total Potential EDUs Connectad 2016 - 2010	Total EDUs .2040
erwyn Estalias Pump Stalios Drainsop Area Profested Posanial Connectione Miscellaneous EDUs				60.0 <b>%</b>	0,00 0,00	0.00	7.00 7.00 0.00	7.59	67.00
erwyn Pump Siation Drahage Area Boaihouse Really Assoc. (222 Walerioo Rd) M Boaihouse Really Assoc. (222 Walerioo Rd) Boaihouse Raily Assoc. (222 Walerioo Rd) N SD 498/Gorrbach U Darise Lehmann & Andrew Holder Midland Are. Dowelopment, LLC John & Parkica Imbeal 2016 Children's Trust Stonehaven Homes (Ameirong) Tarda Babby Bison Head Parinares Purdy Investment Parinares, LP. Daniel & Susan Schufer Keech Property Ludin White LLC Daggell Property Ludin White LLC Projected/Potential: Berwyn Village (Mack Oli) Projected/Potential: Berwyn Village (Mack Oli) Projected/Potential: Char Connections Misosetaneous EU/S	220 Barkisy Avenus 216 Walarko Road 210 Barkisy Avenus 207 S. Washoo Road 19 Woodkis Avenus 4 Midland Ave. 1080 Newtown Road 218 Francis Avenus 26 South Faitheld 749 First Avenus 218 Barkisy Avenus 200 Church Road 729 First Avenus 200 Church Road 501 S. Washoo Road 729 First Avenus 500 S. Washoo Road 50 Price Avenus 631 Lanceaser Avenus	55-3,1-64,4 55-3,1-64,6 55-3,1-70,1 55-2,1-79 55-2,2-43 55-2,1-79 55-30 55-2,1-79 55-30 55-2,1-73 55-30-54 55-2,1-39,1 55-3,0-64,9 55-2,1-39,1 55-3,0-64,9 55-2,1-39,1 55-3,0-64,9 55-2,0-64,2 55-2,0-42	5,00 1.00 1.00 1.00 12,00 12,00 1,00 1.00 1.00 1.00 1.00 3.00 4.00	1,532-20	4.00 4.00 0.00 0.00 0.00 0.00 0.00 0.00	57.00 1.00 1.00 1.00 1.00 12.00 12.00 12.00 12.00 1.00 1	12.00 75.00 28.00 157.24 11,30	341.64	1,873.7
<ul> <li>Muscessinous ECUs</li> <li>arby Pump Sistion Drainage Area</li> <li>Projected/Potential Connections</li> <li>Miscellaneous EDUs</li> </ul>			128.17	135,50	0.00 0 00	4.00 4.00	109.22 14.00 185,22	203.22	338.7
aylesford Pump Station Drsinage Area - Kelly Group Builders, Inc. - Moser Land Development - Rear Property - Rear Property - Projected/Poinnial Connections - Miscelianeous EDUs	2291 S. Valley Road 616 Leopard Road 616 Leopard Road 549 Monte Lane	54-04-0008 55-4-55 55-4-55 55-4-66.7	4,00 1,00 1,00 1,00	65B <i>4</i> 0	0.00 0.00 0.00 0.00 0.00	7.00 4.00 1.00 1.00 1.00	157.80 63.00 94,80	164.80	623.2
avon Hunt Pump Sisilon Dreinege Aree B Lewis Subdivision - Projected/Potential Connections - Miscellaneous EDUs	120 South Devon Avenue	55-3-63.1	3,00	186.10	0.00 0.00	3.00 3.00	91.00 91.00 0.00	94.00	280.
teler Pump Stallorb Prainage Area D Hill Custom Homes I Keyes - Projected/Potential Connections - Miscellaneous EDUs	550 Waledos Avenue 393 Church Road	55-3-43 55-5-55	8.00 -1.00	31.20	4.00 4.00 0.00	5.00 4.00 1.00	<b>4.00</b> 4.00 0.00	<b>9.</b> 00	40.
x Creek Pump Stallon Drainage Aran Projected/Polenial Connections Miscellaneous EDUs				44.60	0.00	0.00 0.00	00.0 00.0 00.0	0.00	44.
Illbrook Pump Station Drainage Area - Projected/Potential Connections - Miscelianeous EDUs				36.00	0.00 0.00	0.00 0.00	0.00 0.00 0.00	0,00	36.
wtown Pump Station Drainage Area A South Leopard Road Associates*** Tm and DeDe Vaale Projected/Potential Connections Miscelaneous EDUs	1220 S. Leopard Rd	55-4-118.2A	9,00 1.00	393,60	<b>6.00</b> 5.00 1.0D	4.00 4.00 0.00	<b>47.00</b> 43 00 4 <b>,</b> 00	<b>51.00</b>	444
necroft Pump Station Drainage Area - William & Kathy Craper - Projected/Polential Connections - Miscellaneous EDUs	2040 Buttonwood Rd	55-4-184.1	1.00	16,00	<b>1.00</b> 1.00	0.00 0.00	0.00 0.00 0.00	0.00	16
aybrook Pump Station Drainage Area T Alessandra Nicolas - Mary Nixon - Projected/Potential: Benson Homes & Development - Projected/Potential Connections - Miscetareous EDUs	49 Wahut Av. 1135 Sugartown Roed 15 Leopard Road	55-2L-29 55-2-143 55-2L-11	2 00 3,00	320,10	0.00 0.00 0.00	5.00 2.00 3,00	<b>55,94</b> 25,00 30,94 <b>0,</b> 00	60 <b>,94</b>	38
pring Knoll Pump Station Drainage Area - John & Pairicla Imbesi - Projected/Potential Connections - Miscellaneous EDUs	1016 Newtown Rd	55-5-30	12 00	220.00	0.00 0.00	12.00 12 <b>.0</b> 0	24.00 6,00 16 DD	36.00	25
e Greens Pump Station Drainage Area - Projected/Potential Connections - Miscellaneous EDUs				116.00	0.00	0.00 0.00	13.00 13,00 0,00	13.00	12
F9A Únntstered Drokinge Ann F Peler A. Taiman - YMCA - Projected/Potential Connections - Miscelaneous EDUs	435 Conesloga Road Berwyn Paoli Road	55-2H-49	1.00 2.00	112.00	0.00 0.00 0_00	3.00 1.00 2.00	9.65 0.00 0.00 4.00 5,65	12.65	12
	VFS	FSA Total EDUs = A Malazed EDUs = nmstered EDUs =		3,841.70 3,594.20 247,50	15.00 15.00 0.00	100.00 93.00 7.00	893,15 684,28 208,87	993.15 777.28 215.87	4,8
HM Unmetered Dreinage Area - Projected/Potenital Connections - Miscellaneous EDUs	At M Granters	i Siziolei iDVe =	0.00	80,10 80,10		0.00 0.00 0.00	3,00 3,00 0,00 0,00	3,00	8
rout Run Unmelered Drainage Area - Projected/Potential Connections - Miscelaneous EDUs	Trout Run Unmetere	i Subiciel EDU	. 0.00	176.40 176.40		0.00 0.00 0.00	2.00 2.00 0.00 0.00	2.00	17 17
		d Total EDUs =		4,098.20		100.00	893.15	993,15	5,0

Í