

Damage Prevention Committee Meeting Case List September 15, 2026

Omnibus Session

Case Number	Stakeholders	Summary	Violations & Recommendation
62056	Facility Owner: COMCAST Facility Owner: PPL ELECTRIC UTILITIES CORP Contractor/Excavator: Calico Construction	<u>On 1/15/2026 9:00:00 AM at 499 FROGTOWN RD, MARTIC TWP, LANCASTER</u> The incident occurred on Thursday, January 15, 2026, at 499 Frogtown Road, in Martic Township, Lancaster County. Multiple lines were damaged, electric and cable tv. PPL Electric Utilities stated in their Alleged Violation Report (AVR), "On January 15, 2026, at approximately 16:10, we received notification from dispatch, regarding damage to an electric facility. Calico Construction was performing barn construction at 499 Frogtown Road when, during excavation with an excavator, a marked single-phase primary electric line was severed." PPL Electric pictures show the locate marks were not preserved. Comcast reported a facility owner issue as, no response to an excavation notification. Comcast stated in their AVR, "backhoe digging footers hit cable, phone, electric lines in multiple locations". Calico Construction reported a facility owner issue as, marked incorrectly. Calico Construction stated in their AVR, one call was placed. Lines were marked. Power was mismarked slightly. Cables located by hand. Starting digging with machine and just nicked with outside tooth of bucket, just nicked cable. No cables were marked 12in underground. This cable had sharp bend. 12-16in underground. Completely unmarked. There was splice 2ft from hit which came apart. 20260130484- Excavation Insufficient ticket was placed on Tuesday 1/13/2026 at 8:28am, response due date- 1/15/2026, and start dates- 1/16/2026 - 1/28/2026. Remarks-- [CALLER STATES THEY WILL MARK THE SITE IS IN WHITE TODAY JANUARY 13TH.] Comcast responded as Clear No Facilities. 20260151635- Damage Emergency ticket was placed on Thursday 1/15/2026. Comcast responded as Clear No Facilities. On Monday 4/13/26, an email and letter were sent requesting an AVR from Calico Construction, and the AVR was submitted on 4/16/2026, not within 30 days of the Thursday 1/15/2026 incident. The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, Responsibilities Of The Excavator, Section 5(16) states: To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or	COMCAST: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 Calico Construction: \$1,000.00 Section 5(3) 1st Offense \$500.00 Section 5(16) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. The report of an alleged violation shall be in a form and manner as required by the commission. Violations: *Calico Construction is in violation of sections: 5(3) – Excavator failed to preserve mark-outs or request a remark. 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalties applied with 50% reduction for section 5(16) and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements. *Comcast is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalty applied	
61999	Facility Owner: UGI UTILITIES INC Contractor/Excavator: Refined Scaping Project Owner: Homeowner Other: Deer Ridge Construction LLC Other: HAMPDEN TOWNSHIP/HAMPDEN TWP SEWER AUTHORITY	On 1/19/2026 8:56:00 AM at 132 Prowell Dr, <u>HAMPDEN TWP, CUMBERLAND</u> The incident occurred on Monday, January 19, 2026, at 192 Prowell Drive, in Hampden Township, Cumberland County. A gas line owned by UGI Utilities was damaged. UGI Utilities reported an excavator issue as, failed to submit a locate request through the One Call System before beginning excavation. UGI stated in their Alleged Violation Report (AVR), “Deer Ridge Construction LLC was digging to install a retaining wall at 132 Prowell Dr in Camp Hill. Deer Ridge Construction was excavating without prior notification to the PA-1 Call Center. As a result, they struck and damaged the 1/2" plastic gas service. Please note, Deer Ridge Construction LLC was found to be digging without a PA-1 Call back in October when they nearly hit a gas service. This No One Call was reported (S#20252840078) and a separate AVR was filed (AVR2025OCT170021).” “Gas service was not marked as excavator failed to notify PA-1 Call prior to excavation.” (20252840078- No One Call Emergency, placed on 10/11/25. Not related to this Case 61999, but from Non-Damage No One Call Case 59454) PA One Call compliance commented that the contractor Deer Ridge Construction LLC has placed One Call notifications with PA One Call in the past. On Monday 3/30/2026, a letter and an email were sent requesting an AVR from Deer Ridge Construction LLC, and the Homeowner. On the same day an email was sent to UGI requesting additional information, “In the AVR it’s mentioned that 911 was called. Who called 911, was it Deer Ridge Construction LLC, the Homeowner, or someone else? Was Deer Ridge Construction LLC billed for the damage and if so, did they pay? Also, provide any	Refined Scaping: \$1,500.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		additional information that UGI Utilities believe is important for the PAPUC Damage Prevention to know.” On Thursday 4/2/2026, UGI replied to the email, “We do not know who called 911, they were on scene when our first responder arrived. We are trying to get that information for you from the 911 center in the area, but they have not gotten back to us yet. We did bill this contractor, but that bill only went out about 2 weeks ago. We have no yet received payment.” Deer Ridge Construction responded to the AVR request by calling and sending an email (attachments Deer Ridge Construction-audio VM, and EX email info). The Homeowner did not respond to the request. Deer Ridge Construction submitted their AVR on 4/7/2026, reporting an excavation issue as, failed to provide One Call System with the exact information to identify the work site. Deer Ridge Construction stated in their AVR, “There was a gas line hit during excav. Gas line has since been repaired.” Attached to the AVR was routine ticket, 20260221724 that was placed by Refined Scaping, on 1/22/2026 (damage occurred on 1/19/2026), worksite 132 Prowell Drive, type of work- BUILD DECK AND SMALL RETAINING WALL, and equipment type- MINI EXCAVATOR. On Monday 4/13/2026, an email was sent to Deer Ridge Construction requesting additional information, “Attached is Deer Ridge Construction LLC Alleged Violation Report (AVR). In the AVR Deer Ridge Construction LLC listed their role as the Project Owner, and excavation work was done by Paul Esh of Refined Scaping. Did Deer Ridge Construction subcontract work to Refined Scaping? Since Deer Ridge Construction hired Refined Scaping to do the actual excavation work, Refined Scaping is required to call in the one call ticket before excavating. Refined Scaping must submit an AVR also. Also, provide any additional information that Deer Ridge Construction believe is important for the PAPUC Damage Prevention to know.” They never replied to the email. On Wednesday 4/29/2026, another email was sent to Deer Ridge Construction requesting additional information, ‘If the excavation work was actually done by Paul Esh of Refined Scaping, please have that company complete an Allege Violation Report (AVR), the same way that Deer Ridge Construction did. Have Refined Scaping mention their role in the project.” (see attachment Deer Ridge Constr- requesting additional info). They never replied to the email. Refine Scaping submitted an AVR on 5/1/2026, reporting an excavation issue as, failed to provide One Call System with the exact information to identify the work site. Refine Scaping stated in their AVR, “Hit a gas line when digging for retaining wall. Gas line has since been repaired.”	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Hampden Township/Hampden Township Sewer Authority submitted an AVR on 4/29/2026 stating, “the contractor was installing a wall and deck and hit a water line that is not owned by Hampden Township. We own the sewer line in the street only.” On Tuesday 5/5/2026, an email was sent to Hampden Twp requesting additional information, “routine ticket 20260221724, Does the Township SA have any pictures of the damage water line?” They replied on the same day, “the locator went out determined, he needed more information, so he called the contractor and talked to him if he can remark his big area because of the snow . The contractor called him back stating that he hit a line, and there's clear water coming out and the locator told him it is not Hampden Township's line that it could be pa water line and he would have to call them. So we have no pictures or any more information on that one call on what happened.” Refine Scaping submitted their AVR on 5/1/2026, not within 30 days of the Monday 1/19/2026 incident. The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, Responsibilities Of The Excavator, Section 5(16) states: To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. The report of an alleged violation shall be in a form and manner as required by the commission. Violations: Refine Scaping is in violation of sections: 5(2.1) – Excavator failed to submit a location request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalties applied with 50% reduction (from \$1,000 to \$500) for section 5(16), and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
62209	Facility Owner: Columbia Gas of PA Contractor/Excavator: CHARLEROI AUTHORITY OF THE BOROUGH OF	On 2/2/2026 3:30:00 PM at CASTNER AVE, DONORA BORO, WASHINGTON Incident occurred on February 2nd, 2026, at 3:30pm along Castner Avenue, Donora Boro, Washington County. A gas line owned by Columbia Gas was damaged. Charleroi Borough Authority's Alleged Violation Report (AVR) states, "Nicked coating on unmarked gas line." Emergency Damage ticket, 20260333104: PER CALLER THEY HAVE FOUND A 10IN COLUMBIA GAS MAIN WHICH WAS MIS MARKED IN THEIR DITCH, PER CALLER LINE IS SCRAPPED BUT NOT	Columbia Gas of PA: \$2,500.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(10) 2nd Offense \$1,500.00 Section 2(14) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		BROKEN. SCRAPE IS APPX 2IN LONG ON 3FT OF EXPOSED PIPE. FACILITY TYPE: NATURAL GAS-COLUMBIA GAS EXCAVATION EQUIPMENT: EXCAVATOR HAZARDOUS RELEASE: NO Ticket notes from Columbia Gas, "JOB WAS MARKED BY PREVIOUS LOCATOR DIDNT MARK UNKNOWN LINE BECAUSE IT WAS UNMAPPED AND UNKNOWN STATUS/OWNER." Emergency Dig ticket, 20260332473: Columbia Gas responded, "516 9TH ST. COULD NOT LOCATE CURB BOX WIRE AT METER LOCATED TO THE GUIDE RAIL BUT SLD INFORMATION IS INCORRECT. WILL NOT BE INVOLVED.800 CASTNER AVE. LOCATED AT THE CURB BOX RM THE SERVICE TO THE 10 STEEL MAIN. INDUCED ON THE 10 STEEL MAIN EAST AND WEST ON CASTNER AVE. MARKE" An AVR was due from Columbia Gas was due on 3/17/26. A courtesy AVR request was sent on 3/13/26 and no AVR or information was provided within 30 days. Columbia Gas was made aware of the damage on Emergency damage ticket 20260333104. Recommended violations, penalties, and education: Columbia Gas Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260332473. Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. 20260333104. Section 2(14) - Failed to comply with all requests for information by the commission relating to the commission’s enforcement authority under this act within thirty days of receipt of the request. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). -PUC compliance education is required for the person responsible for submitting AVR or their replacement.	
62269	Facility Owner: PPL Electric Contractor/Excavator: ROCK ROAD CONSTRUCTION Project Owner: Panther Run LLC Project Owner: Panther Run, LLC Project Owner: SNYDER ROAD LLC Project Owner: Snyder	<u>On 2/4/2026 9:50:00 AM at SNYDER RD, MANHEIM TWP, LANCASTER</u> Incident occurred on February 4th, 2026, at 9:50am, Snyder Road, Manheim Township, Lancaster County. Alleged: An electric line was damaged. Alleged Violation Reports (AVRs): Facility Owner - PPL Electric's Alleged Violation Report (AVR) states, "On Wednesday February 4th, 2026, Rock Road Construction was installing a sewer	ROCK ROAD CONSTRUCTION: \$1,000.00 Section 5(4) 1st Offense \$500.00 Section 5(22) 1st Offense \$500.00 Snyder Road, LLC: \$500.00 Section 6.1(3) 1st Offense

Case Number	Stakeholders	Summary	Violations & Recommendation
	Road, LLC Designer: Hershey Surveying Inc Designer: RGS Associates	main when they hit a marked electric primary line in the tolerance zone, no one was hurt or injured. PPL was notified and sent a crew to the site. Once the crew arrived, they were able to make the area safe and begin their repair, the crew noticed that the conduit was broken and the wire inside was damaged. The crew was able to make a small repair to the line to make the area safe for the contractor to continue working." Excavator - Rock Road Construction's AVR states, "When the snow was removed in the easement area, the site supervisor mistakenly placed stakes for the gas line and not the electric line. The electric company did not respond to the emergency ticket." Snyder Road LLC and Panther Run, LLC were sent requests for AVRs. Their AVRs were submitted 30 days after the incident. Project owner - Snyder Road, LLC's AVR states, "I was made aware by my Contractor, Rock Road Construction, that a drilling subcontractor had mistakenly hit a Comcast Cable line. I was not on site when this occurred. Rock Road addressed the issue, dug up the impacted area and contact the cable company and PPL for repair." Former owner - Panther Run, LLC's AVR states, "I was made aware a drilling company (subcontractor) for Rock Road hit a cable line. The drill also nicked a PPL line. I was not present at the time nor involved. The line was dug up and repaired Designer - RGS Associates' AVR states, "When the snow was removed in the easement area, the site supervisor mistakenly placed stakes for the gas line and not the electric line. The electric company did not respond to the emergency ticket." Findings: Images show a red flag in the snow on 2/3/26 at 5:01pm prior to the dig that lines up with the damage in the tolerance zone. Note that the snow is undisturbed near the red flag. Boring was done prior to potholing the lines within the tolerance zone. Routine ticket 20260150347 was placed on Thursday 1/15/26 with a dig date of Wednesday 1/21/26. Mark outs were due by 1/20/26. PPL responded Field Marked on Tuesday 1/20/26. Emergency New Excavation ticket 20260200152 was placed on Tuesday 1/20/26. PPL responded Field Marked on Tuesday 1/20/26. This ticket does not meet the definition of an emergency ticket. Emergency damage ticket was placed on 2/4/26, PPL gave a response and date stamped images from PPL show a crew responded in person to the damage on 2/4/26 before 11:06am. Rock Road Construction's	\$500.00 Section 6.1(7) 1st Offense \$0.00 RGS Associates: \$750.00 Section 4(2) 1st Offense \$500.00 Section 4(5) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		images are date stamped 2/3/26 at 6:41pm, but the emergency damage ticket was placed the following day at 9:48am. A preliminary design ticket was placed by Hershey Surveying, Inc and no final design tickets have been found. Work for on pre-design tickets show the project owner as Panther Run, LLC. Routine tickets from the excavator show the work is being done for Snyder Road, LLC. Both companies are owned by individuals with the same last name. Design documents that are attached were created by RGS Associates. Snyder Road, LLC is listed on the designs as the project owner. Designs do not show design ticket serial numbers. The telecom cable was hit the day prior. Recommended violations, penalties, and education: Rock Road Construction Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Section 5(22) – Excavator provided a misrepresentation of an emergency excavation, subject to an administrative penalty imposed under section 7(10). -PUC compliance education is required for the excavators working onsite of this excavation or their replacements. RGS Associates Section 4(2) – Designer failed to request the line and facility information prescribed by section 2(4) from the One Call System not less than ten nor more than ninety business days before final design is to be completed. Section 4(5) – Designer’s drawing does not include One Call’s toll-free number and the serial number of the ticket. -PUC compliance education is required for the designer(s) who worked on this project or their replacement(s). Snyder Road LLC Section 6.1(3) – Released a project to bid or construction before final design was complete. Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. Reduced to \$0 for 1st offense and submitting after courtesy request was sent. -PUC compliance education is required.	
62334	Facility Owner: Comcast Contractor/Excavator: CARR AND DUFF Other: BOHEM CONTRACTING Other: PECO Other: Verizon	On 2/9/2026 11:00:00 AM at 72 APPLE DR, WEST WHITELAND TWP, CHESTER PECO submitted additional information advising they are not the project owner. Violations withdrawn. ***** The incident occurred on February 9th, 2026, at approximately 11:00 AM, at 72 Apple Drive, located in West Whiteland Township, Chester County, Pennsylvania.	Comcast: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 PECO: \$0.00 Verizon: \$4,000.00 Section 2(5)(vii) 3rd Offense \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		A communication line owned by Comcast was damaged. Comcast, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “Carr and Duff reported cable was damaged behind apartment building”. Carr and Duff, the excavator, submitted an AVR. Their AVR states, “Utilizing mechanical means within the tolerance zone even though line was not installed at proper depth”. Photos were submitted. PECO is the project owner. An AVR has not been received as of 06/10/2026. An AVR request letter was sent 03/30/2026. There are photos of the damaged line. Comcast had timely responded to the initial emergency ticket (20260400055) as “Field Marked”. No orange mark outs/ paint/ flags are seen in any of the submitted photos which included the damaged line and surrounding area. The line that was damaged was not marked. The new damage emergency ticket 20260400055 was requested 02/09/2026 at 6:30 AM and had a response due date of 02/09/2026. - Verizon responded 02/10/2026 at 3:15 PM. The new excavation emergency ticket 20260401783 was requested 02/09/2026 at 12:48 PM and had a response due date of 02/09/2026. - Verizon responded on 02/10/2026 at 3:17 PM. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each facility owner: - To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines. This shall be done to the extent such information is available in the facility owner's records or by use of standard locating techniques other than excavation. Standard locating techniques shall include, at the utility owner's discretion, the option to choose available technologies suitable to each type of line or facility being located at the work site, topography or soil conditions or to assist the facility owner in locating its lines or facilities, based on accepted engineering and operational practices. Facility owners shall make reasonable efforts during the excavation phase to locate or notify excavators of the existence of any known lines and abandoned lines. - To respond to emergency notifications as soon as practicable following receipt of notification of such emergency. The response by the facility owner shall be	Section 2(5)(vii) 3rd Offense \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		consistent with the nature of the emergency information received by the facility owner. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each project owner who engages in excavation or demolition work to be done within this Commonwealth: - To submit a report of alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition work activities, after a project owner's contracted excavator strikes or damages a facility owner's line during excavation or demolition activities or if the project owner believes a violation of this act has been committed in association with excavation or demolition. The report of alleged violation shall be in a form and manner as required by the commission. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of receipt of the written request. Violations: Comcast- - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. PECO - - Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. - Withdrawn - Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of written request. - Withdrawn Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s). Verizon- - Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260401783. - Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260400055. Recommendation: The penalty is applied.	
62453	Facility Owner: PECO Contractor/Excavator: DELMONT UTILITIES COMPANY Project Owner: AQUA PENNSYLVANIA INC Designer: BRANDYWINE CAD DESIGN INC	<u>On 2/9/2026 11:30:00 AM at W FORGE RD, MIDDLETOWN TWP, DELAWARE</u> Incident occurred on February 9th, 2026, at 11:30pm along West Forge Road, Middletown Township, Delaware County. A gas line was damaged. Case is related to 60727. PECO's Alleged Violation Reports (AVR) state, "GFR puts the service tapping in on Valley rd service taps on	PECO: \$1,500.00 Section 2(5)(i) 3rd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		forge and is 25' east of the east house." Both AVRs had identical summaries. Delmont Utilities Company's AVR states, "WORKING AT 356 VALLEY RD. SPENT 2 FULL DAYS LOOKING FOR A GAS SERVICE FOR 356 VALLEY RD. FIRST DAY WE SOFT DUG IT 5 FEET DEEP AND 2 FOOT WIDE ON BOTH SIDES OF THE MARK. THE PECO SENT A CREW OUT TO SOFT DIG AS WELL AND THEY DID NOT FIND THE SERVICE. DAY 2 STARTING DIGGING WITH A TRACKHOE. WE DIG 25 FEET AWAY FROM THE MARK UNTIL WE DID END UP HITTING THE LINE, WHICH WAS 25 FOOT OFF THE MARK. IT WAS A 1/2" PLASTIC LINE. 2 FOOT DEEP." Aqua's AVR states, "Aqua Contractor Delmont Utilities, working at 356 Valley Rd. Crew spent 2 full days looking for a gas service for 356 Valley Rd. First day, they soft dug it 5 feet deep and 2 foot wide on both sides of the mark. PECO sent a crew out to soft dig as well and they did not find the service. Day 2 started digging with a trackhoe. They dug 25 feet away from the mark until they did end up hitting the line, which was 25 feet off the mark. It was a plastic line, 2 foot deep" AVR notes that 911 was notified. Images show that the line was not marked within the tolerance. Recommended violations, penalties, and education: PECO Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260120827 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
62391	Facility Owner: Peoples Natural Gas Contractor/Excavator: Stefanik's Next Generation Contracting Company, Inc. Project Owner: Watermark Classical Academy Designer: GATEWAY ENGINEERS	<u>On 2/10/2026 8:20:00 AM at DUFF RD, OHIO TWP, ALLEGHENY</u> Stefanik's Next Generation Contracting Company, Inc. violation withdrawn. Additional information and details were submitted with a written dispute. Watermark Classical Academy violations withdrawn. Both Watermark Classical Academy and Stefanik's Next Generation Contracting Company both reported by email that Stefanik's Next Generation Contracting Company, Inc. represented them. ***** The incident occurred on February 10th, 2026, at approximately 8:20 AM, on Duff Road located in Ohio Township, Allegheny County, Pennsylvania. A gas line owned by Peoples Gas was damaged. 911 was called.	Stefanik's Next Generation Contracting Company, Inc.: \$0.00 Watermark Classical Academy: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Peoples Gas, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “On 2/10/2025, Stefaniks Next Gen Constracting was digging to install sewer along Duff road in ohio twp when they struck an accuratley marked PNG SL (main to curb). The PNG SL marks were not maintained by excavator causing digging to take place within tolerance zone. PNG crews were called and repairs were made.” Photos were submitted. Stefanik's Next Generation Contracting Company, Inc., the excavator, submitted an AVR. Their AVR states, “Excavating for a sanitary extension on Duff Rd for the Watermark Classical Academy Project. Gas service line struck approx 10 ft from closest marking on roadway (Waterline and Columbia Gas Line Markings). Emergency services were notified and Ohio Twp Fire Dept arrived onsite. PA one call was called and documented the strike. Gas companies were also notified. Peoples Natural Gas came out and made the repair.” Photos were submitted. Watermark Classical Academy is the project owner. An AVR request letter was sent 03/30/2026. An AVR has not been filed as of 05/07/2026. Peoples Gas responded to routine ticket 20260352760 timely on 02/06/2026, with a response of “Field Marked”. They also responded “Field Marked” to routine ticket 20260062758, on 01/08/2026. There were two photos (PEOPLES -101_4136 & PEOPLES -101_4137) that show mark outs prior to excavation. Both photos were date stamped 01/08/2026, which aligns with routine ticket 20260062758 that was responded to on 01/08/2026. Additionally, no snow is seen in those two photos. The submitted photos of the damage show snow in the background. There is salt on the street (from snow removal) making it difficult to verify if the damaged gas line was properly marked. In some of the photos, Columbia Gas’ mark out can be seen, but is very light colored and difficult to see. Due to the condition of the street (salt covered), a renotify to have the lines remarked should have been requested. Violations: Stefanik's Next Generation Contracting Company, Inc.- - Section 5(3) – Excavator failed to preserve mark-outs or request a remark. - Withdrawn Watermark Classical Academy- - Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. - Withdrawn - Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating	

Case Number	Stakeholders	Summary	Violations & Recommendation
		to the commission's enforcement authority under this act within 30 days of receipt of written request. - Withdrawn	
62848	Facility Owner: Blank Family Communities Facility Owner: PENCOR SERVICESBLUE RIDGE COMMUNICATION Facility Owner: Valley Community Management Contractor/Excavator: COMMANDO ENERGY Project Owner: PPL Electric	<u>On 2/11/2026 3:00:00 PM at Jessup Ct, WASHINGTON TWP, LEHIGH</u> PPL was not notified of the damage in order to file an AVR. Removed violation and penalty. **** Blank Community agrees to pay. **** Incident occurred on February 11th, 2026, at 3pm at 6240 Jessup Court, Washington Township, Lehigh County. Multiple unmarked coax lines were damaged. Alleged Violation Reports (AVR) Facility Owner: Blue Ridge Communications/Pencore Services' AVR states, "On 2/11/26 at approximately 1800, contractor Commando Energy was replacing primary electric lines in the right of way near Glencrest Boulevard. While excavating, they severed 6 coax lines and a feeder. USIC mark out did not mark out all lines." AVR submission date: 3/4/26 Excavator: Commando Energy's AVR states, "It was identified that there were unmarked underground utilities in the work area. Our crew performed potholing at all known crossing utilities; however, due to the affected lines not being marked, its presence was not known at the time of excavation. Throughout the project, additional unmarked lines were encountered that were not identified by USIC, some of which were discovered in close proximity to our work operations." AVR submission date: 3/19/26 Project Owner: PPL Electric's AVR states, "PPL was notified of this damage by the PUC AVR Request Letter. An unmarked communications line was damaged. We do not have any further information. Contractor was replacing failed primary." AVR submission date: 5/4/26 Was the AVR submitted after 30 days from the incident date? Yes AVR courtesy letter was sent on 4/27/26. PPL and Valley Community Management were asked if Valley Community Management / Glencrest Mobile Home Park own or control underground utilities and are they mapped with PA1call? Valley Community Management sent out raised this inquiry to Blank Community Homes who stated by email that they have As-Built Designs for the utilities within the Glencrest Mobile Home Park. DPI advised them to meet with PA1call for mapping and complete an AVR. Alleged conclusion: Tickets 20260302385 & 20260302388 cover the site of the damage. Images show that the lines were not marked accurately. Incident occurred on 2/11/26 with an AVR due date of 3/13/26 for the Excavator and Project Owner. Both parties	Blank Family Communities: \$250.00 Section 2(1)(ii)(A) 1st Offense \$250.00 PENCOR SERVICESBLUE RIDGE COMMUNICATION: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 COMMANDO ENERGY: \$500.00 Section 5(16) 1st Offense \$500.00 PPL Electric: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		submitted their AVRs after 30 days. Tickets also show that Blank Family Communities / Glencrest Mobile Home Park is not a member of PA1call. Damage Prevention Investigator advised BFC to work with PA1call to become members by mapping their facilities. Recommended violations, penalties, and education: Facility Owner: Blue Ridge / Pencor Service Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260302388 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Excavator: Commando Energy Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or other violation. AVR penalty reduced by 50% from \$1,000 to \$500 for providing AVR after request as a 1st offense. -PUC compliance education is required for the person responsible for submitting AVR or their replacement. Project Owner: Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. -PUC compliance education is required for the person responsible for submitting AVR or their replacement. Facility Owner Other: Blank Family Communities / Glencrest Mobile Home Park Section 2(1)(ii)(A) – Failed to provide the One Call System with the counties, municipalities, and wards in which it lines are located. -PUC education is required.	
63453	Facility Owner: COMCAST Contractor/Excavator: PLUG UTILITIES Project Owner: Verizon Other: PECO	<u>On 2/12/2026 9:23:00 AM at 147 Laurel Heights Rd., FRANKLIN TWP, CHESTER</u> PECO accepts. **** The incident occurred on February 12th, 2026, at approximately 9:23 AM, at 147 Laurel Heights Road, located in Franklin Township, Chester County, Pennsylvania. A cable TV line owned by Comcast was damaged. Comcast the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “Did not request locate. This damage that occurred to the cable line was due to Plug Utilities not calling for a locate request prior to excavation.” Photos were submitted. Plug Utilities is the excavator. An AVR has not been filed as of 05/29/2026. An AVR request letter was sent 04/01/2026. Verizon is the project owner. An AVR request letter was sent 04/01/2026. An AVR was submitted and states, “On	COMCAST: \$500.00 Section 2(5)(v) 2nd offense \$500.00 PLUG UTILITIES: \$1,750.00 Section 5(13) 1st Offense \$250.00 Section 5(16) 1st Offense \$1,000.00 Section 5(17) 1st Offense \$500.00 Verizon: \$3,500.00 Section 2(5)(v) 3rd Offense \$1,500.00 Section 2(5)(vii) 3rd Offense \$2,000.00 PECO: \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		02/12/2026, PLUG UTILITIES, allegedly hit a utility owned by Comcast at 147 Laurel Heights Rd, Franklin Twp, Chester.” Comcast documented in their Damage Investigation Report that there were no valid tickets for Plug Utilities. Routine ticket 20260271976 was requested by Plug Utilities on 01/27/2026. Comcast responded to this ticket as ‘Field Marked’ on 02/02/2026. However, this ticket did not include the location where the damage occurred (147). The ticket notes the location information as “Begin at pole 1AB2/P21932 located on the south side of the intersection of private driveway for 151 laurel heights dr, then continue with a 50 ft radius at the intersection and continue north marking the private driveway of 143, 141, and 139 laurel heights dr. Cross the road from the front of 141 to 145 Laurel Heights Dr. Mark from the edge to 25 ft behind the edge. And please use paint and flags.” Routine ticket 20260271976 listed the exact house numbers on that ticket that were to be marked out. The house address of 147 was not listed on this ticket. Routine ticket 20260271976 lists the method of excavation as ‘boring’ and the equipment type as ‘missile and hand tools’. Emergency ticket 20260431097 lists the method of excavation as hand digging and the equipment type as hand tools. Neither of the submitted AVRs specifically indicated what tool caused the damage. In the submitted photos, multiple areas of disturbed soil can be seen, consistent with pot holing when boring. Routine ticket 20260271976 had a response due date of 02/01/2026. - Comcast responded 02/02/2026. - PECO responded 02/02/2026. - Verizon responded 02/18/2026. Emergency ticket 20260431097 has a response due dated of 02/12/2026. - Verizon responded to this ticket on 02/29/2026. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: - If, after receiving information from the One Call System or directly from a facility owner, the excavator decides to change the location, scope or duration of a proposed excavation, the obligations imposed by this section shall apply to the new location. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work.	Section 2(5)(v) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		- To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of the receipt of the request. Violations: Plug Utilities- - Section 5(13) – Excavator changed the location, scope, or duration of a proposed excavation without notifying the One call System. -Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s). Verizon- - Section 2(5)(v) – Failed to respond to a routine One Call ticket. Routine ticket 20260271976. - Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260431097. Recommendation: The penalty is applied. Comcast- - Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Routine ticket 20260271976. Recommendation: The penalty is applied. PECO- - Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Routine ticket 20260271976. Recommendation: The penalty is applied.	
62520	Facility Owner: Peoples Gas Contractor/Excavator: NACCARATI CONTRACTING Project Owner: Incheon Ventures Other: FRANJO CONSTRUCTION	On 2/12/2026 12:58:00 PM at FOSTER ST, PITTSBURGH CITY, ALLEGHENY FRANJO CONSTRUCTION submitted a dispute on behalf of Incheon Ventures. They advised that their AVR represents Incheon Ventures as well. Violations withdrawn. Peoples Gas Accepts. ***** The incident occurred on February 12th, 2026, at approximately 1:00 PM, on Foster Street, located in Pittsburgh City, Allegheny County, Pennsylvania. A gas line owned by Peoples Gas was damaged.	Peoples Gas: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 Incheon Ventures: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Peoples Gas, the facility owner, submitted two Alleged Violation Reports (AVR). - Their AVR (AVR2026FEB130004) for a 02/12/2026 incident states, "On 2/12/2026, Naccarati Contracting was digging to install a sewer main when they struck an accurately marked PNG SL. PNG crews were called and repairs were made." Photos were submitted with this AVR. - Their AVR (AVR2026FEB180014) for a 02/13/2026 incident states, "Naccarati Contracting working for Pittsburgh Water and Sewer failed to support a Peoples Gas service line during sewer excavation and part of the ditch collapsed pulling the Peoples Gas service line that Naccarati Contracting struck the day before." Photos were submitted with this AVR but none showed a clear image of a collapsed ditch. (Pittsburgh Water and Sewer advised by email that they are not a project owner or associated with the work related to the PA One Call tickets for this case.) Naccarati Contracting, the excavator, submitted an AVR. Their AVR states, "Digging to install new sanitary line, hit an unmarked 1" lateral gas line. Peoples Gas came to repair line on 2/11, however the repair was pulled apart on 2/12 due to sandy soil, requiring a new repair. The soil collapsed causing the repair to fail." Photos were submitted. Incheon Ventures is the project owner. An AVR request letter was sent 04/08/2026. An AVR has not been filed as of 06/08/2026. The AVRs for Naccarati Contracting and Franjo Construction both reported Incheon Ventures as the project owner. Franjo Construction submitted an AVR, listing themselves as the General Contractor. Their AVR states, " Naccarati Excavating was digging to install new sanitary line and hit a 1" lateral gas line on Foster Ave between 38th and 39th street in Lawrenceville, Pittsburgh Pa 15222. Gas line was not marked. Peoples arrived onsite and made repair, however repair failed the next day when the sandy soil collapsed and caused the repair to fail." Photos were submitted. Submitted photo (TC_06044.jpeg) shows the damaged line, in correlation to the front of house number 3805. The gas line is close to the center of the window, that is closest to the front door. The gas line marked out in the road cannot be seen as it is covered by steel plates. The photo (107_6223/.jpg) shows the mark outs, prior to excavation, in front of house number 3805. When comparing the center of the window (closest to the front door), the gas marking is outside of the tolerance zone. The gas line was not accurately marked. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each facility owner: - To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site	

Case Number	Stakeholders	Summary	Violations & Recommendation
		within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines. This shall be done to the extent such information is available in the facility owner's records or by use of standard locating techniques other than excavation. Standard locating techniques shall include, at the utility owner's discretion, the option to choose available technologies suitable to each type of line or facility being located at the work site, topography or soil conditions or to assist the facility owner in locating its lines or facilities, based on accepted engineering and operational practices. Facility owners shall make reasonable efforts during the excavation phase to locate or notify excavators of the existence of any known lines and abandoned lines. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each project owner who engages in excavation or demolition work to be done within this Commonwealth: - To submit a report of alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition work activities, after a project owner's contracted excavator strikes or damages a facility owner's line during excavation or demolition activities or if the project owner believes a violation of this act has been committed in association with excavation or demolition. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of receipt of the written request. Violations: Peoples Gas- - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. Incheon Ventures- - Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. - Withdrawn. - Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of written request. - Withdrawn. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
62477	Facility Owner: Citizen Electric Contractor/Excavator:	On 2/13/2026 12:45:00 PM at 118 N 5TH ST, LEWISBURG BORO, UNION The incident occurred on February 13th, 2026, at approximately 12:45 PM, at 118	Citizen Electric: \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Gutelius Excavating Project Owner: PA American Water Other: LEWISBURG BOROUGH OF	North 5th Street, located in Lewisburg Boro, Union County, Pennsylvania. An electrical line owned by Citizen Electric was damaged. Citizen Electric, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, "On Friday, February 13th, an excavator was digging with a backhoe when the underground streetlight service conduit was hit and damaged. There was no damage to the electric wire, so a sleeve was installed to repair the broken conduit and work resumed. The opposite side of the street was marked, but the side where the secondary wire is located was not marked. USIC was on site and made new markings while Citizens' crew was on-site making repairs." Gutelius Excavating, the excavator, submitted an AVR. Their AVR states, "The Locator was on site and told the crew we were clear and left. One hour later we hit an unmarked conduit with wires in it." Photos were submitted. PA American Water, the project owner, submitted an AVR. Their AVR states, "PAWC was excavating for a water main break in the cart way of the borough street. The Citizen Electric company uses a contract locator, USIC. When the locator arrived he marked lines on the opposite side of the street PAWC was going to work on. He then explained tot he on site crew that as long as we don't dig behind the pole line they are clear. The conduit that was hit was several feet out in the roadway from the curb. The poles he was referring to are behind the curb line. The contractor placed another one call after the hit. When USIC locator arrived he very quickly marked the obvious hit conduit and then left. We were unable to get any names or contact information from him. Citizen Electric repaired the conduit. The wires inside the conduit are for the street lights and were not hit." Photos were submitted. Lewisburg Borough submitted an AVR. Their AVR states, "Water company had a water main break at 118 north 5th street in the borough of Lewisburg. USIC marked the electric lines for Citizens Electric as they do all the time in the Borough. We responded clear to the lines that we mark that include storm sewer lines. We were not involved with the digging or repairs of the hit electric line in the street. The Borough technically owns the electric lines that run our streetlights but citizens does all the maintenance work to them and contracts out the line marking for them." The submitted photos show the damaged electrical line was not accurately marked and the damage occurred outside of the tolerance zone. In the photos, red paint is seen on the opposite side of the street.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each facility owner: - To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines. This shall be done to the extent such information is available in the facility owner's records or by use of standard locating techniques other than excavation. Standard locating techniques shall include, at the utility owner's discretion, the option to choose available technologies suitable to each type of line or facility being located at the work site, topography or soil conditions or to assist the facility owner in locating its lines or facilities, based on accepted engineering and operational practices. Facility owners shall make reasonable efforts during the excavation phase to locate or notify excavators of the existence of any known lines and abandoned lines. Violations: Citizen Electric- -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
62602	Facility Owner: PPL ELECTRIC UTILITIES CORPORATION Contractor/Excavator: A K Petersheim Builders LLC Project Owner: Homeowner	<u>On 2/13/2026 1:12:00 PM at 329 JACOBS RD, SALISBURY TWP, LANCASTER</u> The incident occurred on Friday, February 13, 2026, at 329 Jacobs Road, in Salisbury Township, Lancaster County. An electric line owned by PPL Electric Utilities was damaged. PPL reported a facility owner issue as marked incorrectly. PPL stated in their Alleged Violation Report (AVR), On Friday, February 13, 2026, at 1:12 pm, PPL was notified of damage to an unmarked service line leading to the residence at 329 Jacobs Road. A PPL crew was dispatched to the location, where they secured the area. After their investigation, they repaired the service wire to the home and restored power. On Thursday, 4/16/2026, a letter and an email were sent to the contractor, A K Petersheim Builders LLC requesting an AVR. They did not respond to the request and no AVR was submitted. The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, Responsibilities Of The Excavator, Section 5(16) states: To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking	PPL ELECTRIC UTILITIES CORPORATION: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 A K Petersheim Builders LLC: \$500.00 Section 5(16) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. The report of an alleged violation shall be in a form and manner as required by the commission. Violations: *PPL Electric Utilities is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalty applied *A K Petersheim Builders LLC is in violation of section: 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalty reduced to \$500 from \$1,000, and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
62518	Facility Owner: PEOPLES NATURAL GAS COMPANY LLC Contractor/Excavator: D M CONTRACTING Project Owner: PEOPLES NATURAL GAS COMPANY LLC	On 2/16/2026 7:46:00 AM at <u>PARKVIEW DR, WESTMONT BORO, CAMBRIA</u> The incident occurred on Monday, February 16, 2026, on Parkview Drive, in Westmont Borough, Cambria County. A gas line owned by Peoples Natural Gas Company (PNG) was damaged. PNG reported a facility owner issue as marked incorrectly. PNG stated in their Alleged Violation Report (AVR), “D and M Contracting was digging to install new mains and services when they struck a mismarked 1" plastic service to 740 Parkview Dr Johnstown. Locator received a trace on the service but traced the old steel. Wire issue, PNG repaired the service.” PNG provided photos, one showing the miss-marked line. D M Contracting reported a facility owner issue as marked incorrectly. D M Contracting submitted an AVR but did not provide a summary of what led up to the damaged gas line, and no photos. Violation: Peoples Natural Gas Company is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: zero penalty but keep the violation. (because “Locator received a trace on the service but traced the old steel. Wire issue...”)	PEOPLES NATURAL GAS COMPANY LLC: \$0.00 Section 2(5)(i) Subsequent \$0.00
62936	Facility Owner: Comcast Contractor/Excavator: DOLI CONSTRUCTION Project Owner: Newtown Bucks County Joint Municipal Authority Designer: NAVE NEWELL INC Other: Verizon	On 2/16/2026 10:27:00 AM at <u>LIBERTY DR, NEWTOWN TWP, BUCKS</u> Verizon is disputing their "No Response" to routine ticket 20260411035 with the reasoning that they do not have to mark abandon lines. Verizon disputed 22 days too late. Verizon may not bring this case to the DPC in discussion. They were informed they will have to dispute post-DPC if they wish to do so. ***	Comcast: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Verizon: \$1,500.00 Section 2(5)(v) 3rd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Incident occurred on February 16th, 2026, at 10:27am along Liberty Drive, Newtown Township, Bucks County. Alleged: A telecom line was damaged, and refresh marks were not made. Case is related to 58615 & 61909. Alleged Violation Reports (AVR) Facility Owner: Comcast's AVR states, "Damaged wires in ground when installing new pavement." AVR submission date: 5/6/26 Was the AVR submitted after 30 business days? Yes AVR courtesy letter was sent on 4/29/26. Facility Owner: Verizon's AVR states, "comncast was hit by an excavator. An Alleged Violation Report (AVR) has been assigned for investigation by the PA PUC regarding BUCKS COUNTY, NEWTOWN TWP at LIBERTY DR for the affected operation Telecom. Your company may be involved related to the incident on February 16, 2026. Serial Number(s): 20241693529, 20252530652, 20260411035, 20260492253. Design was completed on time with records showing cable in area. Area was then marked with the proper locate markouts. Worked stopped the excavator then asked for a remark, we did not complete the remark on time. The excavator did have our design records and the original markings." AVR submission date: 3/25/26 Excavator: Doli Construction's AVR states, "Found 1 orange Verizon communication mark. There are 2 communication lines on the 1 mark present. One at 6 inch deep and one at 19 inch deep(3 lines in 18" tolerance zone of mark). Had just called for a refresh and no fresh paint marks are found in the area. Broke Comcast line that was not marked." Second AVR states, "Found a Verizon conduit not marked. Conduit came apart at coupler. One wire was broken." AVR submission date: 3/9/26 Was the AVR submitted after 30 days? Yes Project Owner: Newtown Bucks County Joint Municipal Authority's AVR states, "Verizon conduit not marked. conduit came apart at coupler one wire was broken." AVR submission date: Was the AVR submitted after 30 days? AVR courtesy letter was sent on Other Facility Owner: Verizon's AVR states, "comncast was hit by an excavator." Second AVR states, "An Alleged Violation Report (AVR) has been assigned for investigation by the PA PUC regarding BUCKS COUNTY, NEWTOWN TWP at LIBERTY DR for the affected operation Telecom. Your company may be involved related to the incident on February 16, 2026. Serial Number(s): 20241693529, 20252530652, 20260411035, 20260492253. Design was completed on	

Case Number	Stakeholders	Summary	Violations & Recommendation
		time with records showing cable in area. Area was then marked with the proper locate markouts. Worked stopped the excavator then asked for a remark, we did not complete the remark on time. The excavator did have our design records and the original markings." Alleged conclusion: A Comcast line was damaged. Verizon had a "No Response" on 2/13/26 followed by a "No Access" on 2/25/26 for ticket 20260411035. Recommended violations, penalties, and education: Facility Owner: Comcast Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260411035 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner: Verizon Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260411035 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
62605	Facility Owner: PPL Contractor/Excavator: KRIGER CONSTRUCTION Project Owner: CITY OF SCRANTON Other: Pennsylvania American Water (PAWC) Other: REILLY ASSOCIATES	<u>On 2/16/2026 2:30:00 PM at N WASHINGTON, SCRANTON CITY, LACKAWANNA</u> The incident occurred on 2/16/2026, at 2:30 PM, on N Washington, in Scranton City, Lackawanna County. An electric line owned by PPL was damaged. An emergency ticket was entered for the damage. PPL is the facility owner. Their Alleged Violation Report (AVR) states, “On Monday February 16th, 2026, at 2:47pm, Kriger Construction was installing conduits and setting manholes in the City of Scranton when they hit an unmarked concrete duct pack containing electric primary cables. No one was hurt or injured but power was lost. PPL was notified and a crew responded to the site, upon arrival the crew was able to make the area safe and begin their restoration process”. Kriger Construction Inc is the excavator. Their AVR states, “Kriger construction on site staff hit a electrical line while digging for a new communication vault. This was one called and a complex ticket meeting was had on site. A standard 3 day ticket was also called in. No lines were marked in the field and PPL responded with Clear on the ticket. 911 was called, 811 was called and a re notify of incorrect markings was submitted on the ticket”. City Of Scranton is the project owner. Their AVR states, “AT APPROXIMATELY 2:30PM ON MONDAY FEBRUARY 16, 2026, KRIGER CONSTRUCTION WAS HAMMERING AND DIGGING A MANGOLE PT ON WASHINGTON AVE, NEAR THE INTERSECTION OF MULBERRY ST. AT A DEPT	PPL: \$500.00 Section 2(5)(i) 1st Offense \$500.00 KRIGER CONSTRUCTION: \$750.00 Section 5(17) 1st Offense \$500.00 Section 5(3.1) 1st Offense \$250.00 CITY OF SCRANTON: \$250.00 Section 2(5)(v.2) 1st Offense \$250.00 Pennsylvania American Water (PAWC): \$250.00 Section 2(5)(v.2) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		OF 104" THE EXCAVATOR HIT AND DAMAGED AN ELECTRICAL SERVICE LINE. PPL WAS ON SITE AT 3:00PM TO DE-ENERGIZE THE SERVICE LINE AND RESTORE SERVICE TO MULBERRY TOWNERS (499 MULBERRY ST). THERE WERE NO VISIBLE MARKINGS ON THE ROAD TO SHOW WHERE THE ELECTRICAL SERVICE WAS.” Reilly Associates is the designer. Their AVR states, “The contractor encountered an underground electric line during excavation for a communication vault in a Scranton City street. Per Reilly Assoc. personnel on site, there was no visible underground electric markout on the pavement in the area of the excavation. Location: Scranton City, N. Washington Ave., across from the driveway between 404 and 406 N. Washington Ave., and adjacent to side of the 499 Mulberry Towers building.” Ticket # 20260162317 was the routine ticket entered for this excavation on 1/16/2026 at 3:24 PM. SCRANTON CITY and PENNSYLVANIA AMERICAN WATER did not enter a response of “Field Marked” or “Clear” for this ticket. This ticket is over 1200 feet and covers multiple intersections. American Water additionally notes this was not what was agreed upon during the Complex Project meeting. Images were requested from Kriger Construction but they did not respond to the request. On 5/1/2026 PPL was contacted for images of the incident. Images were provided by PPL that show the excavation and damaged line. No marks are seen to indicate the line. Violations: Facility – PPL: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Excavator – Kriger Construction: Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Section 5(3.1) – Scope of project exceeds the maximum area of a routine ticket. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement. Facility (other) – SCRANTON CITY: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket # 20260162317 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - PENNSYLVANIA AMERICAN WATER:	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket # 20260162317 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
62892	Facility Owner: Armstrong Contractor/Excavator: Wilson Excavating Project Owner: Aqua America Other: Verizon, PA LLC	<u>On 2/17/2026 10:12:00 AM at 355 PINE LANE, MERCER BORO, MERCER</u> The incident occurred on 2/17/2026 on 355 Pine Lane, in Mercer Boro, Mercer County. A communication line was damaged. An emergency ticket was entered for the damage. Verizon is the facility owner listed on the emergency ticket, and Armstrong is the facility owner listed on the AVRs. An Alleged Violation Report (AVR) was not filed by either of the facilities as of 04/02/2026 and an AVR request was sent to both of them the same day. Verizon did not respond or submit an AVR. Armstrong submitted an AVR 48 days after the incident (34 business days) that states, “This is our first time doing this. we were called to repair underground cable lines. We repaired it to get customers back on”. Wilson Excavating is the excavator. Their AVR states, “Wilson Excavating was performing work for Aqua at 355 Pine Lane. While excavating, an exposed, marked Armstrong line was struck with an excavator. Facility owner was notified and repairs were made.” Aqua is the project owner and designer. Their AVR states, “Wilson Excavating was performing work for Aqua Pennsylvania at 355 Pine Lane. While excavating, an exposed marked Armstrong line was struck with an excavator. Facility owner was notified and repairs were made.” Ticket # 20260332062 Renotify – Excavation – Insufficient -002 “ATTN PENN POWER YOU RESPONDED FIELD MARKED. CALLER STATES THERE ARE NO MARKINGS AT THE UG BOX FOR HOUSE 330 SPRUCE. JUST IN CASE HOMEOWNER IS REMOVING THE FLAGS PLEASE RETURN TO THE SITE MARK THE LINES WITH PAINT AND UPDATE YOUR RESPONSE ASAP. PLEASE BE SURE TO CONTACT JORDAN KRAUSE WHEN ARRIVING ON SITE TO MAKE SURE CORRECT AREA IS MARKED OUT. THANK YOU.” Images submitted show the site, marks/flags, excavation, and damaged line. The images support the statements in all AVRs that the line was marked within the tolerance zone, exposed, and then later damaged with an excavator. Violations: Facility Owner – Armstrong: Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System	Armstrong: \$1,000.00 Section 2(10) 1st Offense \$1,000.00 Wilson Excavating: \$500.00 Section 5(6)(ii) 1st Offense \$500.00 Verizon, PA LLC: \$1,000.00 Section 2(11) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		within 30 business days after receipt of notice that the facility owner's lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement. Excavator – Wilson Excavating: Section 5(6)(ii) – Excavator failed to provide support and mechanical protection for known facility owner's lines at the construction work site. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. Facility (other) – Verizon: Section 2(11) - Failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of receipt of the request. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement.	
62716	Facility Owner: National Fuel Contractor/Excavator: LIPINSKI LOGGING AND LUMBER INC	<u>On 2/18/2026 9:00:00 AM at 265 N Main Street, COOPERSTOWN BORO, VENANGO</u> The incident occurred on February 18th, 2026, at approximately 9:00 AM, at 265 North Main Street, located in Cooperstown Borough, Venango County, Pennsylvania. A gas line owned by National Fuel was damaged. National Fuel, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, "Excavator performing logging operations struck a natural gas distribution facility. Excavator did not have a POCS ticket submission. The damage caused a significant amount of mud inside the pipeline, creating a blockage for natural gas operation. Please see attachments." Photos were submitted. Lipinski Logging and Lumber Inc. is the excavator. An AVR request letter was sent 04/14/2026. An AVR has not been filed as of 05/20/2026. The project owner is unknown. The excavator did not provide the project owner's information. Pa One Call advised, "No tickets found placed by contractor related to [National Fuel's] AVR, but contractor has placed one calls in the past." National Fuel's AVR did not indicate if 911 was called. Lipinski Logging and Lumber Inc. did not have a Pa One Call ticket for this project. The submitted photos show the damaged utility line. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each	LIPINSKI LOGGING AND LUMBER INC: \$3,750.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(6)(i) 1st Offense \$250.00 Section 5(8) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$1,000.00 Section 5(17) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		excavator who intends to perform excavation or demolition work within this Commonwealth: - To submit a locate request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. Notification shall be not less than three nor more than ten business days in advance of beginning excavation or demolition work. No work shall begin earlier than the lawful start date which shall be on or after the third business day after notification. The lawful start date shall exclude the date upon which notification was received by the One Call System and notification received on a Saturday, Sunday or holiday, which shall be processed on the following business day. - Plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner's facilities in the construction area. Excavation or demolition work which requires temporary or permanent interruption of a facility owner's service shall be coordinated with the affected facility owner in all cases. - To immediately notify 911 and the facility owner if the damage results in the escape of any flammable, toxic or corrosive gas or liquid. The excavator shall take reasonable measures, based on its knowledge, training, resources, experience and understanding of the situation, to protect themselves and those in immediate danger, the general public, the property and the environment until the facility owner or emergency responders have arrived and completed their assessment and shall remain on the work site to convey any pertinent information to responders that may help them to safely mitigate the situation. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of the receipt of the request. Violations: Lipinski Logging and Lumber Inc.- - Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. - Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. - Section 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid which endangers life, health, or property. - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been	

Case Number	Stakeholders	Summary	Violations & Recommendation
		committed in association with excavation or demolition work. - Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
62858	Facility Owner: PECO An Exelon Company Contractor/Excavator: BRUBACHER EXCAVATING INC Project Owner: AQUA PENNSYLVANIA INC Designer: TOTAL ENGINEERING AND CONSULTING SERVICES LLC Other: Verizon PA LLC	<u>On 2/19/2026 7:30:00 AM at RIDGEWOOD LN, WEST GOSHEN TWP, CHESTER</u> The incident occurred on Thursday, February 19, 2026, on Ridgewood Lane, in West Goshen Township, Chester County. A gas line owned by PECO An Exelon Company was damaged. Brubacher Excavating Inc reported a facility owner issue as marked incorrectly. Brubacher Excavating stated in their Alleged Violation Report (AVR), While excavating the trench for new water main installation on Ridgewood Ln project, the crew encountered an unmarked gas service. A 1/2" diameter yellow conduit was found at 19" deep. The excavation was in the street at 1002 Ridgewood Ln. The work was being performed for Aqua PA. Original Ticket #2026 005 1690 and the damage ticket #2026 050 0350. 911 was contacted and fire was onsite. The line was not marked and was 6.5' off the mark. Brubacher Excavating provided photos for the mismarked gas line. Damage Emergency ticket, 20260500350, placed on 2/19/26 at 7:52am. Remarks-[CREW IS ON SITE. CALLER STATED CREW HIT AN UNMARKED GAS SVC LINE. CALLER STATED THE FIRE COMPANY IS CURRENTLY ON SITE. FACILITY TYPE: NATURAL GAS-PECO EXCAVATION EQUIPMENT: EXCAVATOR HAZARDOUS RELEASE: YES CALLER HAS NOTIFIED 911.] Aqua PA, the project owner, and Total Engineering and Consulting Services LLC reported a facility owner issue as marked incorrectly. They stated in their AVR's, "Aqua Contractor Brubacher Excavating, while excavating the trench for new water main installation on Ridgewood Ln project, the crew encountered an unmarked gas service. A 1/2" diameter yellow conduit was found at 19" deep. The excavation was in the street at 1002 Ridgewood Ln. 911 was contacted and fire onsite. The line was not marked and was 6.5' off the mark." On Thursday 4/23/2026 a letter and email were sent to PECO requesting an AVR. They did not respond to the request and no AVR was submitted. PECO was notified from the damage emergency ticket 20260500350. PECO responded field marked on routine ticket, 20260051690.	PECO An Exelon Company: \$2,500.00 Section 2(5)(i) 2nd Offense \$1,000.00 Section 2(10) 1st Offense \$1,000.00 Section 2(14) 1st Offense \$500.00 Verizon PA LLC: \$1,000.00 Section 2(5)(v) Subsequent \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Routine ticket, 20260051690, placed on 1/5/2026, response due date was 1/7/2026. Late response from Verizon PA LLC, they on 1/13/26 as field marked. Violations: *PECO An Exelon Company is in violation of sections: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. 2(14) - Failed to comply with all requests for information by the commission relating to the commission’s enforcement authority under this act within thirty days of receipt of the request. Recommendation: Penalties applied *Verizon PA LLC is in violation of section: 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20260051690 Recommendation: Penalties applied	
62562	Facility Owner: UGI UTILITIES, INC. Contractor/Excavator: PACT ONE, LLC Project Owner: LOWER SWATARA TOWNSHIP MUNICIPAL AUTHORITY Other: HERBERT ROWLAND AND GRUBIC INC	<u>On 2/19/2026 10:25:00 AM at 540 LUMBER STREET, LOWER SWATARA TWP, DAUPHIN</u> The incident occurred on 2/19/2026 at 540 Lumber St in Lower Swatara Township in Dauphin County. A gas line owned by UGI was damaged. 41 people were affected for 6-12 hours PACT CONSTRUCTION INC gave no summary on their Alleged Violation Report (AVR) but they did note that the project cost >\$400,000. It was 2000 LF and above Ground Survey was used; this is considered level “C” Subsurface Utility Engineering (SUE). 911 was notified. Picture was provided. HERBERT ROWLAND AND GRUBIC INC (HRG) stated in their AVR that, “PACT One crew damaged a mismarked gas distribution main. The end of the main was ~4 ft. off the mark. Nearby homes were evacuated by EMS”. Project length is listed at 2300LF. The project cost >\$400,000. and above Ground Survey was used. Pictures were provided. LOWER SWATARA TOWNSHIP MUNICIPAL AUTHORITY AVR was submitted by HERBERT ROWLAND AND GRUBIC INC with the exact same information provided in HRG AVR. They stated that “PACT One crew damaged a mismarked gas distribution main. The end of the main was ~4 ft. off the mark. Nearby homes were evacuated by EMS”. Please note that 1 AVR could be submitted for HRG and LOWER SWATARA TOWNSHIP MUNICIPAL AUTHORITY. Pictures were provided. Lower Swatara Township submitted an AVR which stated that, “The contractor (Pact One) damaged a gas	UGI UTILITIES, INC.: \$1,500.00 Section 2(5)(i) 3rd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		distribution main. The end of the main was ~4 ft. off the mark. Homes had to be evacuated by EMS.” Report was provided. UGI UTILITIES INC stated in their AVR that, “PACT Construction was digging in front of 540 Lumber St, Middletown, PA to install a new sewer lateral. They struck and damaged the dead end of a 2" steel gas main that was mismarked. The dead end of the gas main was marked but marked 4' short of the actual location. The damage resulted in a release of gas. UGI added that “PACT Construction struck it while excavating 4' away from the last yellow mark.” 911 was called by PACT Construction. 41 people were affected for 6-12 hours. On 3/05/2026 an email from UGI confirmed that no one was evacuated. Pictures and reports were provided. *Case is related by ticket to case 61807. VIOLATIONS: UGI is in violation of: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. This is a third time offense. Recommendation: The penalty is applied. PUC compliance education has been recently completed.	
62738	Facility Owner: AQUA PENNSYLVANIA Contractor/Excavator: D ANTONIO EXCAVATING Project Owner: DELMONT UTILITIES COMPANY Other: VERIZON	<u>On 2/21/2026 7:30:00 AM at 475 KEDRON AVE, RIDLEY TWP, DELAWARE</u> The incident occurred on 2/21/2026 at 475 KEDRON AVE in Ridley Township in Delaware Co. A water line owned by Aqua PA was damaged. DELMONT UTILITIES COMPANY, the project owner who hired D Antonio Excavating, stated in their Alleged Violation Report (AVR) that, “working at 475 Kedron Ave. Digging to make a wet tap from existing 16" main and removed a 3/4" corporation that was not marked. In the pictures if you see a mark, it was done after the fact by Aqua.” Pictures were provided. D ANTONIO EXCAVATING stated in their AVR that, “working at 475 Kedron Ave. Digging to make a wet tap from existing 16" main and removed a 3/4" corporation that was not marked. In the photos provided by Delmont Utilities AVR2026FEB280001, if you see a mark it was done after the fact by Aqua”. AQUA PENNSYLVANIA INC stated in their AVR that, “Aqua Contractor D'Antonio Excavating working at 475 Kedron Ave, digging to make a wet tap from existing 16" main and removed 3/4" corporation that was not marked. There is no record of this line. Line terminated into the creek where there is no house. They add that there are missing or incorrect facility line maps or records. Pictures were provided. VIOLATIONS: AQUA PA is in violation of:	AQUA PENNSYLVANIA: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 VERIZON: \$2,500.00 Section 2(5)(vii) Subsequent \$2,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. PUC compliance education has been recently completed. Verizon is in violation of: Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260520120 was submitted on 2/21/2026 at 10:13. Verizon did not respond “clear no facilities” until 2/23/2026 at 10:38. Recommendation: The penalty is applied. PUC compliance education has been recently completed.	
62747	Facility Owner: PITTSBURGH WATER Project Owner: Peoples Gas Company	<u>On 2/22/2026 1:30:00 PM at 6740 REYNOLDS ST, PITTSBURGH CITY, ALLEGHENY</u> Incident occurred on February 22nd, 2026, at 1:30pm on 6740 Reynolds Street, Pittsburgh City, Allegheny County. A water line was damaged. Peoples Gas Company's Alleged Violation Report (AVR) states, "Peoples Gas was working an emergency gas leak at 6740 Reynolds St. There was a threat to life and property. Pittsburgh Water never responded to the locate request. Peoples Gas Dispatch reached out to PWSA multiple times to ask for a response. Peoples crews ended up striking an unmarked service line. PWSA showed up and repaired the service." Pittsburgh Water's AVR was due within 30 business days. A late courtesy AVR request was mailed and emailed on 4/22/26. PWSA's AVR states, "Peoples Gas indicated that Pgh Water locators did not respond to emergency tickets that were placed. Pgh Water did respond and marked the main and service lines. Peoples gas placed emergency tickets and a renotify ticket. Pgh Water locators closed out all ticket FIELD MARKED. ALSO... Pgh Water has no records and no damage ticket of Peoples Gas hitting an unmarked or marked lines. Peoples Gas already started digging before the emergency ticket was cleared. Pgh Water locators were on time responding to these tickets and also wasted time due to Peoples Gas falsifying other emergency tickets that our water lines were not marked. 2/21 @ 6 pm. The note from the locator states the work has already begun, making access difficult, but it was marked out (photos attached) On 2/21 @ 11:30 am, the ticket was responded to as field marked without being on site since it was just marked the day before. On 2/21 @ 4 pm, the site was visited again, and all the markings were still visible. On the tickets, you are able to see when the pictures and notes were time stamped showing that are locators responded on time and accordingly. 2/21/2026 6:03:32 PM: Responded (Action Time: 2/21/2026 6:03:25 PM) DETAILS: PWSA - Field Marked: added by David Supinsky, Locate Time: 2/21/2026 6:03:00 PM, Units of Work: 0.01 NOTE: (R). Work began before mark out. Marked available 2/22/2026 11:32:31 AM: Responded (	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Action Time: 2/22/2026 11:32:16 AM) DETAILS: PWSA - Field Marked: added by David Supinsky, Locate Time: 2/22/2026 11:31:00 AM, Units of Work: 0.01 NOTE: (R). Already been field marked 2/22/2026 4:03:06 PM: Responded (Action Time: 2/22/2026 4:02:55 PM) DETAILS: PWSA - Field Marked: added by David Supinsky, Locate Time: 2/22/2026 4:00:00 PM, Units of Work: 0.01 NOTE: (R). All lines were clearly marked . Water lines and sewer lines clearly visibly marked when arrived. All curb stops in area have already been dug up and are inaccessible due to their own construction. This is unacceptable to say these lines were not marked. 4 emergency calls worth of emergency tickets prove this was marked out." Ticket 20260520078-01 notes: [ATTN PITTSBURGH WATER AND SEWER YOU RESPONDED FIELD MARKED. PER CALLER THE MARKS ARE NOT VISIBLE. PLEASE RETURN TO SITE ASAP TO REMARK. PER CALLER FOREMAN IS ON SITE. THANK YOU. ATTN DUQUESNE LIGHT YOU RESPONDED CLEAR NO FACILTITIES. PER FOREMAN HE IS SEEING TAPE INDICATING UG ELECTRIC AND IS CONCERNED ABOUT UG INVOLVEMENT. PLEASE GO TO SITE ASAP TO MARK. FOREMAN IS ON SITE. THANK YOU. ATTN PGH CITY DEPT OF MOBILITY AND INFRASTRUCTURE YOU DID NOT RESPOND AS REQUIRED FOR THIS EMERGENCY. FOREMAN IS ON SITE AND CONCERNED ABOUT UG LINE INVOLVEMENT. PLEASE GO TO SITE ASAP. THANK YOU. ATN COMCAST YOU HAVE NOT RESPONDED AS REQUIRED FOR THIS EMERGENCY. FOREMAN IS ON SITE AND IS CONCERNED REGARDING ANY LINE INVOLVEMENT. PLEASE GO TO SITE ASAP TO MARK. THANK YOU.] Peoples Gas was emailed for images on 4/24/26. No images were located by Peoples. Tickets were responded to with final responses by Pittsburgh Water. No violations.	
62966	Facility Owner: Verizon North Contractor/Excavator: RETTEW ASSOCIATES, INC Project Owner: Columbia Gas of PA	<u>On 2/23/2026 9:00:00 AM at KINGSTON RD, SPRINGETTSBURY TWP, YORK</u> Non-damage incident occurred on February 23rd, 2026 at 9am, along Kingston Road, Springettsbury Township, York County. Incident: Failed to provide information for designs. Alleged Violation Reports (AVR): Project Owner: Columbia Gas' AVR states, "Rettew, while designing an upcoming gas replacement project, submitted One Call Ticket #20253371020 on 12/3/2025. Verizon responded on 12/4/2025 with a clear/no conflict notification, issued by AAA-WEBSCB. Following completion of a SUE (Subsurface Utility Engineering) survey, Rettew identified evidence of Verizon facilities within the project's One Call scope. As a result, Rettew	Verizon North: \$3,000.00 Section 2(4) 2nd Offense \$500.00 Section 2(10) 2nd Offense \$1,500.00 Section 2(11) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		initiated direct communication with Verizon on 2/23/2026, requesting utility records needed to meet SUE requirements for the project plans. On 3/5/2026, Verizon provided mapping and documentation confirming that Verizon utilities were in conflict with the project area covered under the original ticket." Designer: Rettew Associates' AVR states, "OneCall Ticket #20253371020 submitted on 12/3/25 Verizon responded with clear/no conflict on 12/4/25 by AAA-WEBSBC. After completion of a SUE Survey RETTEW found evidence of Verizon utilities within the OneCall project area and then initiated separate line of communication with Verizon on 2/23/26 requesting record information. We received a response from Verizon including mapping on 3/5/26 that confirmed Verizon utilities in conflict with the project area." AVR submission date: 3/10/26 Conclusion: A request for information was mailed and emailed to Verizon on 5/1/26 and no response has been received. Verizon sent in line locations after the designer discovered lines in the SUE process. Verizon North was notified by the designer about the incorrect response and failed to file an AVR after being notified of the violation of the law. Recommended violations, penalties, and education: Facility Owner: Verizon North Section 2(4) – Failed to respond to designer’s request for information within 10 business days. 20253371020. Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. Section 2(11) – Facility Owner failed to comply with all requests for information by the Commission relation to the Commission’s enforcement authority under this act within thirty days of the receipt of the request. -PUC compliance education is required.	
62670	Facility Owner: Greater Johnstown Water Authority Facility Owner: Homeowner Contractor/Excavator: Peoples Gas Company Project Owner: Peoples Natural Gas PLACEHOLDER	On 2/24/2026 11:00:00 AM at 506 ORANGE AVE, JOHNSTOWN CITY, CAMBRIA Incident occurred on February 24th, 2026, at 11am on 506 Orange Avenue, Johnstown City, Cambria County. A water line was damaged. Peoples Gas Company's Alleged Violation Report (AVR) states, "Peoples Natural Gas was digging to renew a gas service at 506 orange Ave when they struck an unmarked customer's water service. Water service curb to meter is owned by the homeowner. 3/4" copper water service was 1 foot deep coming off of the adjacent st. PNG called a contractor (Laurel Management) to get it repaired."	Greater Johnstown Water Authority: \$250.00 Section 2(5)(i.1) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		The homeowner and Greater Johnston Water Authority were mailed and emailed a courtesy letter to file AVRs on 4/20/26. RDM submitted an AVR on 4/23/26. RDM Johnstown's AVR representing GJWA states, "Peoples Natural Gas was working at 506 Orange Avenue to repair a gas line when they encountered a private water service line causing damage. 1. The Customer was not charged for loss of water as the damage occurred prior to the meter inside or the residence. 2. The point of connection to the GJWA water main was not marked as the service connection occurs on Marbury Avenue (side street to Orange Avenue) and is outside of the request mark location. GJWA does not have any records of how the water line connects to the customer's meter and therefore, did not know that it crossed through the yard in front of the residence prior to entering. 3. GJWA became aware of the line damage on 4/21/2026, when we received a request to submit an overdue AVR report. GJWA did mark the water main location within the grass in-front of 506 Orange Ave as can be shown in the attached Document (20260210_survey_resp_20260413287-288). However, the service connection is located on Marbury Avenue, which was discussed directly with the excavator on 2/10/2026 during the emergency ticket request (20260413287 & 20260413288). This location was not requested to be marked, but was shown to the excavator. Attached is the tap card (curb box location record) showing the location of the service connection. GJWA was not contacted regarding the damage of the homeowner's line until receiving a letter from PAPUC regarding a missing AVR. Ticket mapping for 20260490438 includes the streets around the house Street--☒ Sidewalk--☒ Pub Prop--☒ Pvt Prop--☒ Other--☐ Private Front--☒ Rear--☐ Left--☒ Right--☒. Please see GoogleSV 506 Orange.png and Ticket Map 20260490438. Point of connection to the main was not marked. The prior tickets placed on 2/10/26 did not include the street, but the routine ticket on 2/18/26 did. Recommended violation, penalty, and education. Greater Johnstown Water Authority Section 2(5)(i.1) – Failed to locate an actually known facility's point of connection to its facilities. 20260490438. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
63536	Facility Owner: Met Ed / First Energy Contractor/Excavator: A AND E BUILDERS LLC Project Owner: Property Owner Other: Conewago	<u>On 2/24/2026 11:13:00 AM at 5313 RIDGE ROAD, CONEWAGO TWP, DAUPHIN</u> The incident occurred on February 24th, 2026, at approximately 11:13 AM, at 5313 Ridge Road, located in Conewago Township, Dauphin County, Pennsylvania. An electrical line owned by Met Ed was damaged.	Conewago Township - Dauphin County: \$1,000.00 Section 2(5)(v) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Township - Dauphin County	Met Ed, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, "On February 12, 2026, A and E Builders LLC, "Excavator," submitted POCS Routine Ticket 20260430285 to install footers for a home addition at 5313 Ridge Road, Conewago Township, Dauphin County, Pennsylvania. On February 24, 2026, Met-Ed was notified of an outage at this address. USIC, Met-Ed's Contract Locator, investigated and determined that an accurately marked electric line was damaged. The root cause of the damage was the Excavator failed to use prudent techniques in the tolerance zone." Photos were submitted. A and E Builders LLC, the excavator, submitted an AVR after an AVR request letter was sent 04/27/2026. Their AVR states, "Crew was excavating for a new addition at 5313 Ridge Road Elizabethtown PA 17022. A PA one call was submitted. Met/Ed responded and marked in red where their underground electrical lines were to be. We hit the line some 5 feet away from where they had marked. Met/Ed responded. the crew on site took pictures and verbally admitted that it was marked incorrectly. Repairs were made. They told us they would take care of the report. No 911 call placed. Homeowner was notified I have no clue what the total cost of repair was. Project, itself is 144,400.00. Contact Eli Esh of A&E Builders, LLC at [phone number]." Photos were submitted. The property owner was the project owner. Met Ed responded timely to the routine ticket as "Field Marked" on 02/16/2026. The submitted post mark out photos show red paint and flags were used to mark the electrical line. The remaining photos that were submitted made it difficult to identify the damaged electrical line with certainty. Most of the visible material appears to be roots. No insulation, conduct, or warning tape is seen in the photos. The image's resolution and photo distance make it difficult to distinguish utilities from roots or debris. Without being able to clearly identify the damaged line/ cause of the damaged line, no violations are being applied related to electrical damage. Routine ticket 20260430285 had a response due date of 02/17/2026. - Conewago Township - Dauphin County did not respond to this ticket until 02/25/2026. Violations: Conewago Township - Dauphin County- - Section 2(5)(v) – Failed to respond to a routine One Call ticket. Routine ticket 20260430285. Recommendation: The penalty is applied. PUC online Compliance Training was recently completed.	
62802	Facility Owner: National Fuel Gas	On 2/24/2026 1:05:00 PM at W BAYFRONT PKWY, ERIE CITY, ERIE This non-damage incident occurred	

Case Number	Stakeholders	Summary	Violations & Recommendation
	Contractor/Excavator: Konzel Construction Project Owner: ERIE-WESTERN PENNSYLVANIA PORT AUTHORITY Designer: PORTER CONSULTING ENGINEERS	on February 24th, 2026, at 1:05pm along West Bayfront Parkway, Erie City, Erie County. An unmarked gas line was discovered. Alleged Violation Reports (AVR) Facility Owner: National Fuel Gas' AVR states, "An excavator uncovered an abandoned utility case number 62802." AVR courtesy letter was sent on 4/27/26. Excavator: Konzel Construction's AVR states, "Near miss unmarked existing gas line." Project Owner: Erie-Western PA Port Authority's AVR states, "Uncovered what appeared to be a gas line just south of the outdoor restaurant seating area. NFG was notified, but did not arrive on-site to investigate. The gas line was not hit, was not in physical conflict with the project, and it is unknown whether it was an active line." AVR courtesy letter was sent on 4/27/26. Designer: Porter Consulting Engineers' AVR states, "Uncovered what appeared to be a gas line nearby a restaurant seating area. Gas line was not hit and is unknown if it is an active line." Alleged conclusion: Images show an unmarked yellow line in the excavation zone. Excavator claims they notified NFG and NFG did not arrive onsite to inspect. No ticket or documentation was provided of that notification. Emailed Konzel Construction who responded that, "This was a private gas line and the AVR was erroneously completed, Sorry for the inconvenience. " Replied to ask who owned the line, and the excavator claimed it was abandoned. No violations.	
62687	Facility Owner: Columbia Gas Contractor/Excavator: Lee's Plumbing and Excavating Project Owner: Pennsylvania American Water (PAWC) Other: BULLSKIN T CONNELLSVILLE T JT SEWER AUTH	<u>On 2/25/2026 8:05:00 AM at ROGERS AVE, CONNELLSVILLE TWP, FAYETTE</u> The incident occurred on 2/25/2026, at 8:05 AM, on Rogers Ave, in Connellsville Twp, Fayette County. A gas line owned by Columbia Gas was damaged. Columbia Gas is the facility owner. An Alleged Violation Report (AVR) was submitted that states, "Lee's Plumbing struck an accurately marked 1-inch gas service line during excavation. The impact caused damage to the pipe, leading to an uncontrolled release of natural gas. Cruise responded to the site and made the area safe, all necessary repairs were made to restore service." No images or documents were provided. An AVR request letter was sent to Columbia Gas but no additional information was provided. Lees Plumbing And Excavating Inc is the excavator. Their AVR states, "We were installing a new water service line at 708 E Crawford Ave Connellsville, PA	Columbia Gas: \$500.00 Section 2(5)(i) 1st Offense \$500.00 BULLSKIN T CONNELLSVILLE T JT SEWER AUTH: \$500.00 Section 2(5)(v) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		when we hit an mismarked gas service line. We damaged the line and contacted columbia gas/911.” Pennsylvania American Water is the project owner and designer. Their AVR states, “Lee's was digging to install a 3/4/" water service on Rodgers Ave. for 708 E. Crawford Ave. and hit an unmarked gas service. The gas company was called and so was 911.” Ticket #20260073419 New – Excavation – Routine had a response due date of 1/9/2026. BULLSKIN T CONNELLSVILLE T JT SEWER AUTH responded “Clear” on 2/9/2026. Images were only submitted by Lees Plumbing And Excavating. The images show the site, excavation, marks, and damaged gas line. The damaged line is not within the tolerance zone of the faded yellow marks. Violations: Facility – Columbia Gas: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - BULLSKIN T CONNELLSVILLE T JT SEWER AUTH: Section 2(5)(v) – Failed to respond to a routine One Call ticket. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Ticket #20260073419	
62725	Facility Owner: Uniontown City Contractor/Excavator: LEES PLUMBING AND EXCAVATING INC Project Owner: Pennsylvania American Water (PAWC) Other: Columbia Gas of PA	On 2/25/2026 9:00:00 AM at N BEESON AVE, UNIONTOWN CITY, FAYETTE Columbia Gas - Violations removed after showing documented proof. *** Incident occurred on February 25, 2026, at 9am, North Beeson Avenue, Uniontown City, Fayette County. A traffic signal was damaged, and two emergency tickets had no responses from Columbia Gas. Lee's Plumbing and Excavating Inc's Alleged Violation Report (AVR) states, "We were digging a water main break for Pa american water when we hit damaged a electric line that controlled the traffic lights. The line was mismarked." PAWC's AVR states, "Roughly 6:50 am Line Locator Kevin Lowry received a call stating water was pouring from the intersection of E. Main and N Beeson. We verified that it was a water main break and put emergency ticket in. Crew arrived on scene roughly around 7:50 am - 8 am. I got a call from Utility worker Jerry Calloway stating they hit a unmarked traffic signal line. Supervisor Eric Yarbrough and I arrived on scene roughly around 9:15am. We scanned the area looking for all utility marks and seen gas was marked a mark for the	Uniontown City: \$1,000.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(10) 1st Offense \$500.00 Columbia Gas of PA: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		what looks like the Traffic light was marked on one side of the pole going away from the work zone but not marked going towards the work zone. We met with the City Police Chief and discussed the damage. Power was shut of to the area and she stated that a company would come out and fix the issue." Uniontown City did not submit an AVR within 30 business days of the damage (2/25/26 - 4/8/26). An request for additional information was mailed and emailed out on 4/20/26 and Uniontown City responded by 4/23/26. Uniontown City's AVR states, "City locator responded to emergency one call Excavator told locator he didn't need any marks from him." Images do not show traffic signal mark outs. Uniontown City responded clear to tickets 20260560305, 20260541205, and 20260541344. Submitted an AVR after 30 business days. Columbia Gas failed to respond to tickets 20260541205 and 20260541344. Recommended violations, penalties, and education: Uniontown City Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260541205 Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner's lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. AVR penalty reduced by 50% from \$1,000 to \$500 for providing AVR after request. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Columbia Gas Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260541205 Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260541344 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
62686	Facility Owner: CONSOLIDATED COMMUNICATIONS-FIDUM Contractor/Excavator: SUPERIOR UTILITY EXCAVATING INC Project Owner:	<u>On 2/25/2026 1:51:00 PM at HILL RD, DEEMSTON BORO, WASHINGTON</u> The incident occurred on Monday, February 23, 2026, on Hill Road, in Deemston Borough, Washington County. A telecom line owned by Consolidated Communications/Fidium was damaged.	CONSOLIDATED COMMUNICATIONS-FIDUM: \$250.00 Section 2(5)(vi) 1st Offense \$250.00 SUPERIOR UTILITY EXCAVATING INC:

Case Number	Stakeholders	Summary	Violations & Recommendation
	PEOPLES NATURAL GAS COMPANY LLC Designer: THE EADS GROUP	Consolidated Communications/Fidium reported an excavation issue as, failed to exercise due care and take all reasonable steps necessary to avoid damaging the line. Consolidated Communications/Fidium stated in their Alleged Violation Report (AVR), Contractor [Superior Utility Excavating Inc] for Peoples Gas dug up our 12 pair copper telco line. Peoples Natural Gas Company (PNG), the project owner reported a facility owner issue as, failing to locate point of connection to facility lines (service or abandoned lines). PNG stated in their AVR, “on 2/23/26 Superior Utility Excavating Inc, working for PNG installing new gas main and services struck a unmarked cable/telecom line servicing 69 and 79 Hill Rd in Fredericktown. Consolidated Communications/Breezeline failed to mark the line. USIC locator arrived onsite to refresh marks due to heavy snow fall prior, shortly after damage occurred. USIC stated line was marked, Superior Utility Excavating stated line was not marked.” 20260353023- Routine Update, placed 2/4/26. REASON FOR UPDATE: WORK STOPPED, STARTING AGAIN REMARK LINES. 20260353023-001- Renotify Excavation Insufficient, placed on 2/12/26 at 10:11am. Remarks--[ONSITE MARKINGS ARE INCOMPLETE. PLEASE RETURN TO COMPLETE THE MARKINGS. THANK YOU.] 20260353023-002- Renotify Excavation Insufficient, placed on 2/23/26 at 10:02am. Remarks- [ONSITE MARKINGS ARE INCORRECT. PLEASE RETURN TO CORRECT THE MARKINGS. THANK YOU.] On Monday 4/13/2026, a letter and email were sent requesting an AVR from Superior Utility Excavating. They never responded to the request and no AVR was submitted. Violations: *Consolidated Communications (Fidium) is in violation of section: 2(5)(vi) – Lines were not marked in compliance with the Common Ground Alliance Best Practices for Temporary Marking set forth in ANSI standard Z535.1. (CGA chapter 4 section 4.08) Recommendation: Penalty applied and PUC Online Compliance Training is required for the Individual(s) responsible to respond to locate for this ticket, or their replacement(s). *Superior Utility Excavating Inc is in violation of sections: 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalty applied	\$1,000.00 Section 5(16) 1st Offense \$1,000.00
62932	Facility Owner: Aqua PA Contractor/Excavator:	On 2/27/2026 8:38:00 AM at 650 MOHAWK AVE, NORWOOD BORO, DELAWARE The incident	Utility Line Services: \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Utility Line Services Project Owner: PECO Designer: PECO _ Spacesaver Other: CONCRETE CUTTING SYSTEMS Other: PROSPECT PARK BOROUGH OF	occurred on 2/27/2026 on MOHAWK AVE in Norwood Borough in Delaware Co. A water line owned by AQUA was damaged. AQUA PENNSYLVANIA INC stated in their Alleged Violation Report (AVR) that, “Excavator hit a marked water service and pulled the service out of the corporation. 650 Mohawk Ave”. Picture was provided. Utility Line Services stated in their AVR that, “While the crew was trenching in the area of 650 Mohawk Ave. they were attempting to retrieve a 2’ X 3’ piece of concrete and damaged an AQUA water service that was 3’ off the markings. An emergency ticket to 811 was entered requesting a revision of the markings. All proper notifications were made”. On 5/18/2026 DPI Maki asked if ULS had any pictures. An email was responded to that they did not. PECO was sent an AVR request letter on 3/11/2026. PECO AN EXELON COMPANY stated in their AVR that, “UTILITY LINE SERVICES WORKING FOR PECO WAS DIGGING TO LOCATE THE MARKED UTILITIES WHEN THEY STRUCK A CABLE WHILE OPERATING A BACKHOE. ALL PROPER NOTIFICATIONS WERE MADE.” NORWOOD BOROUGH OF stated in their AVR that ,” received a pa one call for a damaged water service line. went out and marked out our sanitary sewer.” VIOLATIONS Utility Line Services are in violation of: Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Within the tolerance zone, the excavator shall employ prudent techniques, which may include hand-dug test holes, vacuum excavation or similar devices to ascertain the precise position of such facilities. Recommendation: The penalty is applied. PUC compliance education has been recently completed. PROSPECT PARK BOROUGH OF is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260512688 was submitted by Utility Line Services on 2/20/2026 with a response due by 2/24/2026. PROSPECT PARK BOROUGH OF did not respond “Field marked” until 2/25/2026. Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	Section 5(4) 1st Offense \$500.00 PROSPECT PARK BOROUGH OF: \$250.00 Section 2(5)(v) 1st Offense \$250.00
62875	Facility Owner: PECO An Exelon Company Contractor/Excavator: BRUBACHER EXCAVATING INC Project Owner: AQUA	<u>On 2/27/2026 8:40:00 AM at STEWARD LN, WEST GOSHEN TWP, CHESTER</u> The incident occurred on Friday, February 27, 2026, on Steward Lane, in West Goshen Township, Chester County.	PECO An Exelon Company: \$2,500.00 Section 2(14) 1st Offense \$500.00 Section 2(5)(i) 2nd

Case Number	Stakeholders	Summary	Violations & Recommendation
	PENNSYLVANIA INC Designer: TOTAL ENGINEERING AND CONSULTING SERVICES LLC Other: Verizon PA LLC	A gas line owned by PECO An Exelon Company was damaged. Brubacher Excavating Inc reported a facility owner issue as marked incorrectly. Brubacher Excavating stated in their Alleged Violation Report (AVR), While excavating the trench for new water main installation on Ridgewood Ln project, the crew encountered an unmarked gas line. A 1" diameter green conduit was found at '- 18" deep. The excavation was in the street at 802 Steward Ln. The work was being performed for Aqua PA. Original Ticket #2026 005 1738 and the damage ticket #2026 058 0753. 911 was contacted by Casey. No smell was noticed and nothing was blowing. Brubacher Excavating provided photos for the unmarked gas line. Damage Emergency ticket, 20260580753, placed on 2/27/2026 at 8:59am. Remarks-[CREW IS ON SITE. CALLER STATED THEY HIT AN UNMARKED GAS SVC LINE. FACILITY TYPE: NATURAL GAS-PECO EXCAVATION EQUIPMENT: EXCAVATOR HAZARDOUS RELEASE: YES CALLER HAS NOTIFIED 911.] Aqua PA, the project owner, and Total Engineering and Consulting Services LLC reported a facility owner issue as marked incorrectly. They stated in their AVR's, Aqua Contractor Brubacher Excavating while excavating the trench for new water main installation on Ridgewood Ln Project, the crew encountered an unmarked gas line. A 1" diameter green conduit was found a 18" deep. The excavation was in the street at 802 Steward Ln. 911 was contacted by Casey. No smell was noticed and nothing was blowing. On Thursday 4/23/2026 a letter and email were sent to PECO requesting an AVR. They did not respond to the request and no AVR was submitted. PECO was notified of the damage from the damage emergency ticket 20260580753. Routine ticket, 20260051738, placed on 1/5/2026, response due date was 1/7/2026. Late response from Verizon PA LLC on 1/16/26 as field marked. Violations: *PECO An Exelon Company is in violation of sections: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner's lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. 2(14) - Failed to comply with all requests for information by the commission relating to the	Offense \$1,000.00 Section 2(10) 1st Offense \$1,000.00 Verizon PA LLC: \$1,000.00 Section 2(5)(v) Subsequent \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		commission's enforcement authority under this act within thirty days of receipt of the request. Recommendation: Penalties applied *Verizon PA LLC is in violation of section: 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20260051690 Recommendation: Penalties applied	
63129	Facility Owner: UGI Utilities inc. Contractor/Excavator: No Bull Group	<u>On 2/27/2026 10:59:00 AM at 930 Madison Ave, SCRANTON CITY, LACKAWANNA</u> The incident occurred on February 27th, 2026, at approximately 11:00 AM, at 930 Madison Avenue, located in Scranton City, Lackawanna County, Pennsylvania. A gas line owned by UGI Utilities was damaged. Excavator failed to notify facility owner or 911 after the line was struck. UGI Utilities, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, "Excavator struck and damaged an unmarked gas facility while digging without a one call. Excavator failed to notify facility owner or 911 after the line was struck. Code enforcement official on site notified 911 when they smelled an odor of gas. Excavator removed equipment from the site prior to UGIs arrival. Pictures attached showing mechanized equipment used at time of damage." No Bull Group is the excavator. An AVR request letter was sent 04/15/2026. An AVR has not been filed as of 05/20/2026. The project owner is unknown. The excavator did not provide the project owner's information. No Bull Group did not have a Pa One Call ticket. Routine ticket 20260581856 was placed after the damage occurred. No Bull Group failed to notify facility owner or 911 after the line was struck. (Code enforcement official on site notified 911 when they smelled an odor of gas.) The submitted photos show the damaged utility line. No utility mark outs can be seen in the submitted photos. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: - To submit a locate request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. Notification shall be not less than three nor more than ten business days in advance of beginning excavation or demolition work. No work shall begin earlier than the lawful start date which shall be on or after the third business day after notification. The lawful start date shall exclude the date upon which notification was received by the One Call System and notification received on a Saturday, Sunday or holiday, which shall be processed on the following business day.	No Bull Group: \$3,750.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(6)(i) 1st Offense \$250.00 Section 5(8) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$1,000.00 Section 5(17) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		- Plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner's facilities in the construction area. Excavation or demolition work which requires temporary or permanent interruption of a facility owner's service shall be coordinated with the affected facility owner in all cases. - To immediately notify 911 and the facility owner if the damage results in the escape of any flammable, toxic or corrosive gas or liquid. The excavator shall take reasonable measures, based on its knowledge, training, resources, experience and understanding of the situation, to protect themselves and those in immediate danger, the general public, the property and the environment until the facility owner or emergency responders have arrived and completed their assessment and shall remain on the work site to convey any pertinent information to responders that may help them to safely mitigate the situation. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of the receipt of the request. Violations: No Bull Group- - Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. - Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. - Section 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid which endangers life, health, or property. - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
63130	Facility Owner: AQUA PENNSYLVANIA INC Contractor/Excavator: Roto Rooter Service Corp Project Owner: Homeowner	<u>On 3/3/2026 1:30:00 PM at 4106 VERNON RD, UPPER DARBY TWP. DELAWARE</u> The incident occurred on 3/3/2026, at 1:30 PM, on 4106 Vernon Rd, in Upper Darby Twp, Delaware County.	Roto Rooter Service Corp: \$1,500.00 Section 5(16) 1st Offense \$1,000.00 Section 5(17) 1st Offense

Case Number	Stakeholders	Summary	Violations & Recommendation
		A water line owned by Aqua was damaged. Aqua is the facility owner. Their Alleged Violation Report (AVR) states, "Excavator hit the customer side of the water line. Filed as no damage to Aqua's Facility". Aqua responded "Field Marked" to the ticket for this excavation but they state they do not have mark out images. Roto Rooter Service Corp is the excavator. An AVR was not filed as of 04/17/2026 and an AVR request was sent the same day which also requested additional documentation. No documents, statements, or AVRs were submitted as of 6/3/2026. Judith Fleming is the project owner. An AVR was not filed as of 04/17/2026. Stephen Fleming contacted the PUC to state they do not have any pictures but did not submit an AVR as required by the AVR request letter they were sent. Due to Roto Rooter and Judith Fleming not submitting an AVR, there was not enough information to determine the cause of the damaged line reported in Aqua's AVR. Violations: Excavator – Roto Rooter: Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement. Project Owner - Judith Fleming: Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of written request. This violation is reduced from \$500 to a warning of \$0.	\$500.00 Homeowner: \$500.00 Section 6.1(8) 1st Offense \$500.00
63718	Facility Owner: COMCAST Contractor/Excavator: Heritage Construction and Design Other: ARNEY BROTHERS	On 3/4/2026 11:07:00 AM at 158 Fisher St, JONESTOWN BORO, LEBANON The incident occurred on 3/04/2026 at 158 Fisher St. in JONESTOWN BORO in Lebanon Co. A Cable and active passive devices, owned by Comcast were damaged. 50 residential customers and 2 commercial customers were affected. COMCAST stated in their Alleged Violation Report (AVR) that, "Builder was digging trench, hit U/G cable and pulled lines out of ground. This also cause the active and passive device on either side to be pulled into the ground damaging the equipment." >51 people were affected. They added that "Builder claims we never	Heritage Construction and Design: \$2,250.00 Section 6.1(8) 1st Offense \$500.00 Section 5(2.1) 1st Offense \$1,500.00 Section 5(21) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		marked cable and PA-1 call was preformed, unable to locate a ticket”. Pictures were provided. Pictures were provided. On 4/21/20026 DPI sent an email asking for more information. Who is the excavator, project owner, and how many were affected by this damage. Comcast promptly responded that 52 customers were affected. 50 residential and 2 commercial customers. Compliance Research results: No records found for Heritage Construction and Design placing One Call notifications in the past. Heritage Construction and Design was mailed an AVR request letter on 4/23/2026.AVR was due by 4/8/2026. Heritage Construction and Design stated in their AVR that, “we were digging to install electrical conduit for house service. we had called to get it marked and were within our lawful start date. there were no markings where we were digging and they had not marked it after we hit it and called again. we were digging within our one call perimeter marked on the road. No Project owner is named, but Heritage Construction names themselves as a facility owner, project owner and excavator. Compliance research results: Only 1 ticket found for listed work site address. Ticket 20253031220 was submitted by Arney Bros and work was noted as being done for Heritage Construction (company submitting this AVR). No other tickets found for the listed work site address. On 6/01/2026 an AVR request letter was emailed and mailed to ARNEY BROTHERS, who submitted ticket 20253031220. DPI Maki returned a call to Bob from Arney Brothers who stated their ticket is from 2025 and they did not digging for this project after that. They also stated that Heritage Construction and Design do their own digging and should have their own ticket. VIOLATIONS: Heritage Construction and Design is in violation of: Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of written request. An AVR was submitted, but no questions were answered from the AVR request letter. DPI asked for project information. None was provided. No pictures or documents were provided. Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(21) – Excavator failed to pay the annual fee for service provided by the One Call System. Compliance Research results: No records found for Heritage Construction and Design placing One Call notifications in the past. Recommendation: The penalties are applied. Violation section 5(2.1) has an added fine factor of .5 as per the Bureau of Investigation and Enforcement Damage Prevention Section Fine Factor Determination chart. PUC project owner compliance education is required for the person responsible for submitting AVR or their	

Case Number	Stakeholders	Summary	Violations & Recommendation
		replacement and PUC compliance education is required for the excavators working onsite of this excavation or their replacements.	
63127	Facility Owner: Columbia Gas of PA Contractor/Excavator: Sanner Masonry and Excavation Project Owner: NORTH FAYETTE COUNTY MUNICIPAL AUTHORITY Other: DUNBAR TOWNSHIP Other: VANDERBILT MIDSTREAM II INC	On 3/4/2026 1:30:00 PM at 1702 W CRAWFORD AVE, DUNBAR TWP, FAYETTE The incident occurred on 3/4/2026 at 1702 W Crawford Ave in Dunbar Township in Fayette Co. A gas line owned by Columbia Gas was damaged. COLUMBIA GAS OF PA INC stated in their Alleged Violation Report (AVR) that, “Sanner Masonry and Excavating proceeded to drill into an active, properly marked gas main, resulting in damage to the line. The excavation crew stated that they believed the gas main was inactive; however, this assumption was made without verification and directly contradicted the information provided on the One Call ticket. The One Call documentation clearly indicated that the gas line was active and had been accurately located and marked in the field. In addition, the locator included a specific note on the ticket instructing the excavator to contact the locator directly if there were any questions or uncertainties regarding the markings or the status of the facility. Despite this explicit guidance, no outreach was made to the locator prior to drilling. The decision to proceed based on an unverified belief that the line was dead represents a deviation from required safe-digging practices and from the responsibilities outlined under One Call regulations. Proper procedure requires that any doubt about markings, facility status, or field conditions be resolved through direct communication with the facility owner or locator before excavation continues. Had this step been taken, the misunderstanding regarding the line’s status could have been addressed and the strike avoided. This incident underscores the importance of adhering to established communication protocols, especially when the One Call ticket provides clear instructions for resolving questions. It also highlights the need for excavators to rely on verified information rather than assumptions when working around underground utilities. Pictures were provided. 911 was notified by “the crew”. On 6/03/2026 DPI Maki sent an email to confirm who “the crew” worked for. NORTH FAYETTE COUNTY MUNICIPAL AUTHORITY were sent an AVR request letter on 3/23/2026. NORTH FAYETTE COUNTY MUNICIPAL AUTHORITY stated in their AVR that, “Our Contractor Sanner Masonry and Excavation that are currently installing a 6" water main for the Authority apparently hit a gas line at 1702 W Crawford Ave on 3/4/26 and never notified us”. Pictures were provided. Sanner Masonry and Excavation stated in their AVR that “Gas company changes the location and direction of the gas line. When our company was looking for the water line we punctured a small hole in the gas line, gas company came out and cut the line off and capped it, no	Sanner Masonry and Excavation: \$1,250.00 Section 5(4) 1st Offense \$500.00 Section 5(16) 1st Offense \$750.00 DUNBAR TOWNSHIP: \$250.00 Section 2(5)(v) 1st Offense \$250.00 VANDERBILT MIDSTREAM II INC: \$250.00 Section 2(5)(v) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		customers were out of service and no gas was lost”. No pictures were provided. . Sanner Masonry and Excavation was sent an AVR request letter on 3/23/2026, their AVR was submitted on 4/26/2026. Penalty reduced from \$1,000 to \$750 because this is their first 5(16) violation. The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, Responsibilities of The Excavator, Section 5(16) states: To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. The report of an alleged violation shall be in a form and manner as required by the commission. *Please note that Emergency ticket 20260632864 states that, “THEY ARE DIGGING IN FRONT OF ADDRESS 1702 W CRAWFORD AVE AND HAVE AN ODOR OF GAS.” VIOLATIONS Sanner Masonry and Excavation are in violation of: Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Within the tolerance zone, the excavator shall employ prudent techniques, which may include hand-dug test holes, vacuum excavation or similar devices to ascertain the precise position of such facilities. Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or damaging a facility owner’s line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. Sanner Masonry and Excavation was sent an AVR request letter on 3/23/2026, their AVR was submitted on 4/26/2026. Penalty reduced from \$1,000 to \$750 because this is their first 5(16) violation Recommendation: The penalty is applied. PUC compliance education is required for the excavators working onsite of this excavation or their replacements. DUNBAR TOWNSHIP is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260481805 was submitted by Sanner Masonry and Excavation on 2/17/2026 with a response due by 2/19/2026. DUNBAR TOWNSHIP DID NOT RESPOND “CLEAR” UNTIL 2/20/2026. Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). VANDERBILT MIDSTREAM II INC is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260481805 was submitted by Sanner Masonry and	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Excavation on 2/17/2026 with a response due by 2/19/2026. VANDERBILT MIDSTREAM II INC DID NOT RESPOND "ART-CLEAR. NO FACILITIES - FACILITIES NOT INVOLVED" UNTIL 2/20/2026. Recommendation: The penalty is applied. PUC compliance education is required for the excavators working onsite of this excavation or their replacements.	
63117	Facility Owner: PPL Electric Contractor/Excavator: Deck Decks Construction Project Owner: Homeowner Project Owner	<u>On 3/6/2026 8:45:00 AM at 810 Maplewood Ave, DAUPHIN BORO, DAUPHIN</u> Incident occurred on March 6th, 2026, at 8:45am on 810 Maplewood Avenue, Dauphin Boro, Dauphin County. Incident: No PA1call was placed prior to excavation. Alleged Violation Reports (AVR): Facility Owner: PPL's AVR states, "On Friday, March 6th, 2026, at 8:45 am, PPL received notice of damage to a service line leading to 810 Maplewood Ave. When the PPL crew arrived, they secured the area and began repairs, successfully restoring service for the customer. An investigation found that Decks Decks Construction, the contractor involved, was working without a valid PA One Call." Conclusion: Images only show hand tools being used on the dig site. No violation for using hand tools without a PA1call. Red and orange mark outs are visible, but no PA1call was provided by POCS after the initial review was completed. Images show that the line was mismarked. USIC damage report was included. An email was sent to PA1call requesting additional review to see if any tickets correlated with the mark outs in the photos. PA1call responded that no tickets were found. An email was also sent to PPL Electric requesting the USIC damage report document and locate ticket for the mark outs. PPL provided ticket number 20253421379 that was placed by the homeowner. A follow up email was sent to PPL to request the USIC Damage Report and original mark photos from the homeowner's ticket. Please note the homeowner's ticket stated, [SPECIAL ATTN ELEC. CALLER STATES THEY WILL BE WORK ALSO AT THE END OF THE HOUSE WHERE THERE IS AN ELEC OUTLET AND THE ELEC NEEDS MARKED HERE. CALLER STATES THEY HAVE NOT HIRED A CONTRACTOR YET.] AVR request were sent to the homeowner and contractor. Recommended violations, penalties, and education: Facility Owner: PPL Electric Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. -PUC Compliance education is required.	PPL Electric: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00
62986	Facility Owner: Verizon Contractor/Excavator: PITTSBURGH WATER Project Owner: PITTSBURGH WATER -	<u>On 3/6/2026 9:16:00 AM at 3201 SMALLMAN ST, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 3/06/2026 at 3201 SMALLMAN ST in PITTSBURGH CITY in Allegheny County. A communications line owned by Verizon was damaged.	Verizon: \$6,000.00 Section 2(10) Subsequent \$2,500.00 Section 2(14) 3rd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		PITTSBURGH WATER, the project owner and excavator, stated in their Alleged Violation Report(AVR) that, “PWSA digging water leak and hit Verizon line. The 1call ticket that we were digging for this day, Verizon came out and marked the lines. (IN THE SIDEWALK) On pictures IMG 0681, you can see an old, very faded marked line (IN THE STREET) that was from a previous 1call. Verizon did not remark/remark the faded line. PWSA didn't know this line was there until it was hit because it was very faded. PWSA painted white 1 call box was big enough to show Verizon the full location of what needs marked. Verizon responded and Zetolla came out and made repairs.” Pictures were provided. Verizon was sent an AVR request letter on 3/23/2026. No AVR or information has been received to date. Verizon responded “field marked” to emergency tickets 20260642727 and 20260650813. VIOLATIONS VERIZON is in violation of: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. This is a subsequent violation. Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. This is a subsequent violation. Section 2(14) - Failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of request. This is a third time offense. Please note that violation section 2(10) and violation section 2(14) are identical in ACT 127-2024. Recommendation: The penalties are applied. PUC compliance education has been recently completed.	Section 2(5)(i) Subsequent \$2,000.00
62948	Facility Owner: AQUA PA Facility Owner: COMCAST Facility Owner: PECO spacesaver Facility Owner: Verizon Contractor/Excavator: EMPOWER CONSTRUCTION Project Owner: PECO Designer: KONA ENGINEERING LLC	On 3/9/2026 8:00:00 AM at 203 HERMITAGE DR, RADNOR TWP, DELAWARE PECO disagrees. DPI Maki sent an email on 6/30/2026, responding to PECO's dispute statements and provided snippets supporting the violations that were cited. Please see attachment named "DPI responds to PECO dispute." On 7/21/2026 an email was received from PECO stating that they will accept the violations for Section 2(5)(iii.1), violation section 6.1(7) with the penalty of\$2000. reduced to \$1000. and violation section 6.1(8) with the \$500. penalty reduced to \$250. The 2 violations for section 2(5)(i) have been withdrawn. See attachment named "PECO accepts" for more information. ***** The incident occurred on 3/09/2026 on Hermitage Dr in Radnor Township in Delaware County.	COMCAST: \$4,000.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(5)(v.1) Subsequent \$2,000.00 Verizon: \$7,000.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$1,000.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(5)(i) Subsequent

Case Number	Stakeholders	Summary	Violations & Recommendation
		3 facility owners; Comcast, PECO and Verizon did not respond to PA OneCall ticket requests to mark out their facilities. *No damage EMPOWER CONSTRUCTION, the excavator, stated in their Alleged Violation Report (AVR) that, “ On Monday March 9th, 2026, an Empower Construction directional boring crew was tasked with installing new conduit on 204 Hermitage Dr in Wayne, PA on the Wayne-146 project WO#19650665. The crew began their day with conducting a job briefing and walking the project down for mark outs. It was noticed that Verizon has still not been marked out. The crew immediately stopped work, notified PECO Construction Management, PA One Call, and Empower Construction Management. Original PA1 Call Ticket #20260621413”. On 4/06/2026 DPI Maki asked Empower about Aqua’s statement in their AVR that the “Excavator advised that he couldn't see the markings. Locator showed the markings to the Excavator. Locator responded to the ticket as Marked on 3/9/2026 at 11:46 am.” Please see attachments named “No Verizon marks” and “Lines found - no Verizon marks”. Aqua, one of the facility owners, was sent an AVR request notice and Maureen called asking about this. On 4/02/2026 DPI Maki returned a call to Maureen stated that they only received one renotification notice and the original ticket which she stated that they responded to. DPI let her know that the excavator called out a number of facility owners as they noticed that the lines were not marked correctly or completely. Maureen stated that she will find out more about this and will file an AVR as required. Aqua stated in their AVR that “Aqua filing AVR at the direction of the PUC DPI. Aqua responded to New Routine Excavation ticket # 20260621413-000 as Marked on 3/6/2026. Ticket response due date was 3/8/2026. Aqua received ticket 20260521413-002 a Renotify Excavation Insufficient on 3/9/2026 at 10:23 am. Locator responded to the site, made direct contact with the Excavator regarding the issue of the lines being incomplete. Excavator advised that he couldn't see the markings. Locator showed the markings to the Excavator. Locator responded to the ticket as Marked on 3/9/2026 at 11:46 am. No damage to Aqua facilities.” Pictures were provided. Verizon, one of the facility owners, was sent an AVR request letter on 3/09/2026. On 3/16/2026 an email was received stating that “ We do not believe this to have been our cable, we marked our lines and were not affected by any damage for Case Number: 62948”. On 4/02/2026 DPI Maki clarified that his was not a damaged line, but a violation with the facility owner not marking their lines in a timely way.” VERIZON PENNSYLVANIA LLC, stated in their AVR that “Ticket 20260621413-000 was submitted by EMPOWER CONSTRUCTION on 3/03/2026 with a	\$2,000.00 PECO: \$2,250.00 Section 2(5)(iii.1) 3rd Offense \$1,000.00 Section 6.1(7) 3rd Offense \$1,000.00 Section 6.1(8) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		response due by 3/08/2026. Legal dig date is 3/09/2026. * Insufficient Ticket 20260621413-004 was submitted by EMPOWER CONSTRUCTION on 3/11/2026 with a response due by 3/11/2026. RNO Remarks [ATTN VERIZON YOU STILL HAVE NOT RESPONDED TO THIS RENOTIFICATION. PLEASE MARK OR CLEAR LINES ASAP.] A call out was performed and our facilities were called out on 3/11/2026 by Tim King. Comcast, one of the facility owners, was sent an AVR request letter on 3/19/2026. Comcast responded that they did not have any damage in the area. No AVR was submitted. On 4/02/2026 DPI Maki clarified that this was not a damaged line, but a violation with the facility owner not marking their lines in a timely way. COMCAST CABLE CHESTER COUNTY stated in their AVR that “No damage occurred”. Report was provided. PECO, the project owner, was sent an AVR request letter on 3/09/2026. No AVR has been received, no contact has been made, no questions asked in the AVR request letter have been responded to. *Ticket 20260621413-000 was submitted by EMPOWER CONSTRUCTION on 3/03/2026 with a response due by 3/08/2026. Legal dig date is 3/09/2026. Comcast responded “field marked” late, on 3/09/2025, but were called out to complete their markings on 3/09/2025, when the construction was about to begin. They did not respond until 3/25/2026 **Ticket 20260621413-001 reads that direct contact is required within 2 hours. This is a new construction area. VIOLATIONS COMCAST is in violation of : -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. See renotify ticket 20260621413-001 RNO remarks. . * Insufficient Ticket 20260621413-001 was submitted by EMPOWER CONSTRUCTION on 3/09/2026 asking for direct contact in 2 hours. RNO Remarks[ATTN COMCAST CABLE DELAWARE COUNTY YOU HAVE NOT RESPONDED TO THIS TICKET AND CALLER STATES THAT WORK SITE AND WORK FIELD CROSSES COMCAST SERVICE BOX AREA. PLEASE MARK YOUR LINES AND RESPOND IN THE KARL SYSTEM ASAP. THANK YOU.] This is a subsequent offense. Section 2(5)(v.1) – Failed to communicate directly with excavator within 2 hours of renotification. This is a new construction area. This is a subsequent offense. Recommendation: The penalties are applied. PUC compliance education has been recently completed. Verizon is in violation of : -Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. * Insufficient Ticket 20260621413-003 was submitted by EMPOWER CONSTRUCTION on 3/10/2026 with a	

Case Number	Stakeholders	Summary	Violations & Recommendation
		response due by 3/10/2026. RNO Remarks [ATTN VERIZON YOU STILL HAVE NOT RESPONDED TO THIS RENOTIFICATION. PLEASE MARK OR CLEAR LINES ASAP.] Verizon did not respond “Field marked” until 3/11/2026 at 10:29pm. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Verizon did not respond by marking their lines to renotify tickets 20260621413 -000. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Verizon did not respond by marking their lines to renotify ticket 20260621413 -001. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Verizon did not respond by marking their lines to renotify ticket 20260621413 -002. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Verizon did not respond by marking their lines to renotify ticket 20260621413 -003. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Verizon did not respond by marking their lines to renotify ticket 20260621413 -004 This is a subsequent offense. Verizon did not respond by marking their lines to renotify tickets 20260621413 -000, 20260621413 -001, 20260621413 -002, 20260621413 -003, or 20260621413 -004, and Empower Construction once again asked Verizon to come mark their lines for the 5th time. This is a subsequent offense. Recommendation: The penalties are applied. PUC compliance education has been recently completed. PECO is in violation of: Ticket 20260621413-000 was submitted by EMPOWER CONSTRUCTION on 3/03/2026 with a response due by 3/08/2026. Legal dig date is 3/09/2026. PECO did respond “Field marked” on 3/06/2026, then they scheduled a date to mark out on 3/10/2026. This was not in agreement with the excavator and insufficient ticket 20260621413-002 requests that PECO return to complete their mark out. PECO completed the markout on this same day. This is a subsequent offense. -Section 2(5)(iii.1) – Facility owner failed to propose a mutually agreeable scheduling by which the excavator, facility owner or designer may locate the facilities. PECO responded to ticket 20252511942 that, they attended the meeting and reached an agreement. This agreement has not been provided. Responses for Complex project ticket 20252511942. The ticket was not responded to until on 9/17/2026, PECO scheduled to have the markout completed by 9/17/2025, but then on 9/17/2025 PECO responded with “Clear” no facilities.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Ticket was due by 9/16/2025. The excavator saw evidence of gas and electric lines which were not marked. This is a third time offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. * Insufficient Ticket 20260621413-003 was submitted by EMPOWER CONSTRUCTION on 3/10/2026 with a response due by 3/10/2026.RNO Remarks: [ATTENTION PECO AN EXELON COMPANY YOU RESPONDED 003-FIELD MARKED 3/9/2026 3:36:15 PM. THE CALLER STATES THE UNDERGROUND ELECTRIC AND GAS MARKINGS ARE INCOMPLETE. ATTENTION VERIZON PENNSYLVANIA LLC YOU RESPONDED 001-CLEAR. NO FACILITIES OR FACIL NOT INVOLVED 3/3/2026 10:58:56 AM. THE CALLER STATES THERE ARE UTILITY BOXES WITH UNDERGROUND LINES AT THE SITE. PLEASE RESPOND ASAP TO MARK THE UNDERGROUND LINES SO THE CREW ON SITE CAN CONTINUE WORK IN THIS AREA. THIS IS THE 2ND RENOTIFICATION. PLEASE CONTACT GEORGE DAYWALT AT HIS CELL LISTED ABOVE WITH ANY QUESTIONS THANK YOU.] Although PECO responded “field marked on 3/06/2026 to ticket 20260621413. They were asked to come out and mark their lines. This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PECO responded “field marked” on 3/06/2026, but on 3/09/2026 ticket 20260621413-002 was submitted with RNO remarks; ATTN PECO GAS ELEC AND AQUA YOUR MARKINGS AT THE SITE ARE INCOMPLETE.PLEASE VERIFY INVOLVEMENT GO TO THE SITE TO MARK LINES AND UPDATE YOURRESPONSE ASAP. This is a subsequent offense. -Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike or damaging a facility owner’s line during excavation or demolition work activities or if a project owner believes a violation of this act has been committed in association with excavation or demolition. PECO, the project owner, was sent an AVR request letter on 3/09/2026. No AVR has been received, no contact has been made. This is a third time offense. Section 6.1(8) - Project Owner failed to comply with all requests for information by the commission relating to the commission's enforcement authority under this act within 30 days of receipt of written req. Recommendation: The penalties are applied. PUC compliance education has been recently completed.	
62951	Facility Owner: Zayo Contractor/Excavator: Flyway Excavating Project Owner: City of Lancaster Pa Designer: JACOBS ENGINEERING	<u>On 3/9/2026 9:00:00 AM at S DUKE ST, LANCASTER CITY, LANCASTER</u> The incident occurred on 3/9/2026, at 9:00 AM, on S Duke St, in Lancaster City, Lancaster County. A communication line owned by Zayo was damaged. An emergency ticket was entered for the damage.	Zayo: \$1,750.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(5)(v.2) 1st Offense \$250.00 Section 2(10) 1st Offense

Case Number	Stakeholders	Summary	Violations & Recommendation
	Other: VERIZON PENNSYLVANIA LLC	Zayo is the facility owner. An Alleged Violation Report (AVR) was not filed as of 04/06/2026 and an AVR request was sent the same day. An AVR was not submitted, and no contact was made by Zayo on this case. Flyway Excavating is the excavator. Their AVR states, “Our operator was digging in an area that had been PA 1-called with utilities marked out on S. Duke St in Lancaster. While digging, the operator caught a conduit with wires inside of it that was not field marked. An emergency one-call was placed to determine what utility owned the line in question. Both the regular one call and emergency one call were not responded to by Zayo who is believed to be the utility owner.” City Of Lancaster is the project owner. Their AVR states, “Flyway Excavating is working for the City as a prime contractor for a construction project on South Duke Street. Flyway placed a Pa 1 Call on 02/25/26 (Serial Number--[20260561730]-[000]) for a routine utility mark out ahead of excavation. On 03/09/2026 Flyway hit a Zayo orange conduit and ripped it out of the ground with a track hoe excavator. The contractor placed an emergency damage Pa 1 Call (Serial Number--[20260681168]-[000]). A utility mark out representative showed up around 11:00-11:30am and mentioned that "the line that is hit was shown on a map and wasn't sure why it wasn't marked out". The person mentioned that they were still trying to get ahold of someone from Zayo and that they would stop back to let us know next steps. There was never any further communication with this mark out person or a Zayo representative regarding this damaged utility.” Verizon entered an AVR that states, “we were not affected, another telecom was, we did however arrive after the dig time .” A preliminary design ticket was entered by Jacobs Engineering for this project. No additional design tickets were found by PA One Call Systems for this project. Ticket 20260561730 was the routine ticket for this excavation. The response due date was 2/27/2026 and Zayo responded “Field Marked” on 3/13/2026 at 1:48 PM. Ticket #20260681168 was the emergency ticket entered for this damage that specifically listed Zayo as the facility. Zayo responded “clear”. Violations: Facility owner- Zayo: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket 20260561730 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	\$1,000.00 City of Lancaster Pa: \$500.00 Section 6.1(3) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement. Project Owner - City Of Lancaster: Section 6.1(3) – Released a project to bid or construction before final design was complete. PUC online Compliance Training is required for the designer(s) who worked on this project, or their replacement(s).	
63275	Facility Owner: Lumen Facility Owner: Pennsylvania American Water (PAWC) Facility Owner: Verizon Facility Owner: Zayo Bandwidth Contractor/Excavator: JD ECKMAN INC	On 3/9/2026 10:00:00 AM at SEPTA Bridge, <u>MULTIPLE, MONTGOMERY</u> This non damage incident occurred on March 9th, 2026, at 10am for the SEPTA Bridge, across multiple townships within Montgomery County. Alleged: Facility Owners failed to attend or respond clear to a complex meeting. Alleged Violation Reports (AVR): Excavator: J.D. Eckman, Inc's AVR states, “Utility owners with facilities in the area did not show for Complex Project Meeting.” Complex Ticket 20260571776: Crown Castle responded Insufficient and did not attend the meeting. Please note that Crown Castle is now owned by Zayo. Lumen, PAWC, and Verizon did not respond to the ticket or attend the meeting. Zayo responded will attend meeting, but the sign in sheet does not show Zayo as attending. Recommended violations, penalties, and education: Facility Owner: Lumen Section 2(5)(viii) – Failed to participate in preconstruction meetings for a complex project or as described in Section 5(3). 20260571776 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner: PAWC Section 2(5)(viii) – Failed to participate in preconstruction meetings for a complex project or as described in Section 5(3). 20260571776 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	Lumen: \$500.00 Section 2(5)(viii) 1st Offense \$500.00 Pennsylvania American Water (PAWC): \$500.00 Section 2(5)(viii) 1st Offense \$500.00 Verizon: \$1,000.00 Section 2(5)(viii) 2nd Offense \$1,000.00 Zayo Bandwidth: \$500.00 Section 2(5)(viii) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Facility Owner: Verizon Section 2(5)(viii) – Failed to participate in preconstruction meetings for a complex project or as described in Section 5(3). 20260571776 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner: Zayo Section 2(5)(viii) – Failed to participate in preconstruction meetings for a complex project or as described in Section 5(3). 20260571776 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
63037	Facility Owner: Peoples Gas Contractor/Excavator: Pittsburgh Water Project Owner: Pittsburgh Water (Placeholder)	<u>On 3/9/2026 7:32:00 PM at 3318 RIGEL ST, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on March 9th, 2026, at approximately 7:30 PM, at 3318 Rigel Street, located in Pittsburgh City, Allegheny County, Pennsylvania. A gas line owned by Peoples Gas was damaged. 911 was called. Peoples Gas, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “On 3/5/2026, PITTSBURGH WATER AND SEWER AUTHORITY was digging on an emergency one call ticket to repair a water line when they struck an accurately marked PNG plastic ML. PNG crews were called and repairs were made.” Photos were submitted. Pittsburgh Water, the excavator and project owner, submitted an AVR. Their AVR states, “PWSA digging and hit a mismarked gas main. 911 and Peoples Gas responded and made repairs.” Photos were submitted. The submitted photos show the damaged gas line. The damaged gas line is unsupported in the submitted photos and is laying off to the side, within the hole. The damage line extends out from where the gas line was marked using yellow paint and then is parallel to the paint, as the gas line mark out shifts. The damage occurred within the tolerance zone. Violations: Pittsburgh Water - - Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	Pittsburgh Water: \$500.00 Section 5(4) 1st Offense \$500.00
63099	Facility Owner: UGI UTILITIES INC Contractor/Excavator: LINDE CORPORATION Project Owner: UGI UTILITIES INC	<u>On 3/10/2026 11:00:00 AM at 935 CENTER ST, EASTON CITY, NORTHAMPTON</u> The incident occurred on Tuesday, March 10, 2026, at 935 Center Street, in Easton City Northampton County. A gas line owned by UGI Utilities was damaged.	UGI UTILITIES INC: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		The contractor, Linde Corporation, reported a facility owner issue as marked incorrectly. Linde Corporation stated in their Alleged Violation Report (AVR), "Crew was excavating for install of new UGI gas main and struck an unmarked 1" gas service." UGI, the facility and project owner, reported a facility owner issue as missing or incorrect facility line maps or records. UGI stated in their AVR, "Linde crew struck a gas service when digging their trench to install new gas main. Gas service was incorrectly plotted on UGI records and mapping. This gas service was not marked. Incorrect records on UGI mapping and records. All main and gas services were marked except this gas service that was damaged. Incorrect record." Violation: UGI Utilities is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalties applied	
63013	Facility Owner: Pittsburgh Water Contractor/Excavator: Carlisle Excavating Project Owner: FRANJO CONSTRUCTION	<u>On 3/11/2026 11:30:00 AM at MCCANDLESS AVE, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 3/11/2026, at 11:30 AM, on McCandless Ave, in Pittsburgh City, Allegheny County. A water line owned by Pittsburgh Water & Sewer was damaged. Pittsburgh Water & Sewer is the facility owner. Their Alleged Violation Report (AVR) states, "Carlisle Excavating was working at the Intersection of McCandless Avenue and Butler street. Their objective was to eliminate a private 4 inch service. As they were digging they claim that a giant rock crushed a repair coupling and that caused the leak. After further investigation, it appears contractor was careless digging and damaged PWSA 12" coupling water main. The line was marked correctly. PWSA responded, shut down main to make repairs." Carlisle Excavating is the excavator. An AVR was not filed as of 04/08/2026. An AVR was submitted on 4/13/2026 that states, "Carlisle Excavating was working on McCandless Ave on a project for Franjo Construction. We have had multiple 1 calls, as well as calling in to re-mark under ground lines. As this project has been going on for months. The current one call was for McCandless Avenue for multiple holes regarding sewer and water taps and terminations. On the 11th of March 2026 we were performing an excavation to prep for a water termination of a 4" service line to a building. The main line was marked previously for the 1 call, the service line was never marked for us. Even after calling for a remark. Perhaps PWSA thought it was already terminated. As it turns out this line was previously hit by M O Heron. Apparently, while installing a new gas, Main, the 4" service line was ripped out previously. When we excavated down in the vicinity, a coupling moved, or shifted at the T which was not blocked with Concrete (a PWSA requirement) It was the actual	

Case Number	Stakeholders	Summary	Violations & Recommendation
		coupling from their previous repair that failed when it was exposed. We dug with caution and care. We even had a VAC truck on site to do this work after going through the road Concrete and sub-base with the excavator. We did not hit or break the water line. It was not hit or ruptured or broken. It was the coupling that caused the leak. It is an unfortunate circumstance that the line was hit and repaired six months ago and the previous repair had failed when we exposed it. If this T had been replaced or repaired in the way that PWSA requires on their drawings nothing would have moved. We notified the water company immediately. I'm not sure what all this is for to be honest, when the water company came on site and realized we were digging to terminate this 4 inch lateral. They told us to just go ahead and do the repair under their direction. We cut out the old T and installed a stub piece of line making their 8 inch line a straight connection. We did all this at our own expense on labor and material. As this had to be done per our contract with Franjo. PWSA shut the water down for us eventually, as well as returned to turn the water back on after they looked at the repair. I did not fill out an AVR directly reported to this incident because we fixed this under the water companies direction and no one said this was even getting turned in for a hit, as it was contract work. I do apologize that there was a delay, when I got the letter in the mail I reached out. I will include all the photographs I have regarding this. On the sidenote PWSA has sent me a bill regarding this incident. After the fact we already made the repair. The office may be the ones doing that versus everyone in the field, so I will also include a photo of that as well. I cannot get any photos to attach to this AVR I will send them to damageprevention@pa.gov and attach the case number. Please reach out if there are any questions thank you, David 724-747-4676" Franjo Construction is the project owner. An AVR was not filed as of 04/08/2026. Images provided show a vac truck being used to locate the water lines. No documentation or images were provided that show the damage was caused by excavation, or failure to provide support and mechanical protection for known facility owner's lines at the construction work site during the excavation or demolition work. Violations: None.	
63018	Facility Owner: Pencore Services/Blue Ridge Communication Contractor/Excavator: All Season Tree LLC Project Owner: Homeowner	<u>On 3/11/2026 1:00:00 PM at 200 Conway Dr, LITITZ BORO, LANCASTER</u> The incident occurred on 3/11/2026, at 1:00 PM, on 200 Conway Dr, in Lititz Boro, Lancaster County. A communication line owned by Pencor Services Blue Ridge Communication was damaged. The facility was not notified by the excavator of the damage. Pencor Services Blue Ridge Communication is the facility owner. Their Alleged Violation Report (AVR)	All Season Tree LLC: \$3,250.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(6)(i) 1st Offense \$250.00 Section 5(7) 1st Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		states, "No One Call was submitted, during tree stump removal by All Season Tree the Pencor Services/Blue Ridge Comm buried fiber optic service drop in 3/4 duct was cut and customer was out of service. Customer and property location of damage are the same, 200 Conway Dr, Lititz. Two foot section of duct with fiber was missing, this should have been noticed by excavator and reported at time of damage." All Season Tree LLC is the excavator. An AVR was not filed as of 04/08/2026 and an AVR request was sent the same day. No AVR was submitted by the excavator. Brian Bednar is the project owner (homeowner). An AVR was not filed as of 04/08/2026 and an AVR request was sent the same day. Brian contacted the PUC and provided the following information, "My name is Brian Bednar and I recieved a letter from you yesterday concerning an incident that happened at our home last month. We hired All Season Tree service to come out and remove two of our silver maples in the front yard. This project included stump grinding which apparently nicked our fiber optic internet wire. Blue ridge cable company was notified by me to come out and see why or wifi was not working. The technician found the problem and contacted his supervisor who also then showed up and took pictures and assisted with the repair. I spoke with Blue ridge customer service this morning to ask if they sent those pictures when they notified your department about the damage that All Season created. I am expecting either them or the owner of All Season to provide whatever you need since this story is the only thing I have to help you with. I am ignorant of the Act 127 of 2024 and would expect All Season to be knowledgeable since it is their job to know such things. I hope this helps in some small way." PA One Call states the excavator has not been a member since 2020. PA Act 127 of 2024 defines "Excavation work" - the use of powered equipment or explosives in the movement of earth, rock or other material... Images submitted show the area where the stump was removed. All dirt in the area is disturbed through use of powered equipment and is where the damage occurred to the communication line. Violations: Excavator - All Season Tree Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. Section 5(7) – Failed to immediately report to the facility owner any break or leak in its lines, or any dent, gouge, groove, or other damage to such lines or to their coating or cathodic protection.	Section 5(16) 1st Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
63054	Facility Owner: PITTSBURGH WATER Contractor/Excavator: WILSON EXCAVATING - A LINDY GROUP COMPANY Project Owner: PEOPLES NATURAL GAS COMPANY LLC	<u>On 3/12/2026 8:30:00 AM at CROSS ST, MILLVALE BORO, ALLEGHENY</u> The incident occurred on Thursday, March 2, 2026, on Cross Street, in Millvale Borough, Allegheny County. A water line owned by Pittsburgh Water was damaged. Wilson Excavating reported a facility owner issue as, failed to locate point of connection to facility lines (service or abandoned lines). Wilson Excavating stated in their Alleged Violation Report (AVR), “Wilson Excavating was performing work for PNG at 2 Cross Street. While digging, an unmarked PWSA water service was struck with an excavator. Facility owner was notified and repairs were made.” Pittsburgh Water, the facility owner, reported a facility owner issue as, missing or incorrect facility line maps or records. Pittsburgh Water stated in their AVR, Wilson Excavating And Utility Construction digging and hit a mismarked 2" water main. Lack of records and drill sheets in Millvale Borough; records and drill sheets are not up to date and could not get an accurate location of main on this street. Locate lines are very difficult in this area. Pittsburgh Water responded and made repairs. Peoples Natural Gas Company (PNG), the project owner reported a facility owner issue as marked incorrectly. PNG stated in their AVR, “On 3/13/2026, Wilson Excavating was working for PNG at 932 Cross Street when a mismarked PWSA water main was struck. Mainline was approximately 5 feet off from the marks. Facility owner was notified.” Violation: Pittsburgh Water is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalty applied	PITTSBURGH WATER: \$500.00 Section 2(5)(i) 1st Offense \$500.00
63049	Facility Owner: Verizon, PA LLC Contractor/Excavator: Pittsburgh Water Project Owner: Pittsburgh Water - Placeholder Other: Comcast Other: PACT STANWIX PLANT	<u>On 3/12/2026 11:15:00 AM at 1ST AVE, PITTSBURGH CITY, ALLEGHENY</u> Pact Stanwix violation is reduced from \$1000 to a warning of \$0. ***** The incident occurred on 3/12/2026, at 11:15 AM, on 1St Ave, in Pittsburgh City, Allegheny County. A communication line owned by Verizon was damaged. Verizon is the facility owner. No Alleged Violation Report (AVR) was submitted as of 4/13/2026 and an AVR request was sent the same day. An AVR was submitted that states, “On 03/12/2026, Pittsburgh Water,	Verizon, PA LLC: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Comcast: \$2,500.00 Section 2(5)(vii) Subsequent \$2,500.00 PACT STANWIX PLANT: \$0.00 Section 2(5)(vii) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		allegedly hit a utility owned by Verizon, PA LLC at 1ST AVE, PITTSBURGH CITY, ALLEGHENY.” Pittsburgh Water is the excavator, and project owner. Their AVR states, “PWSA digging to repair an emergency water main break. Emergency 1 call was placed. Pwsa hit a mismarked Verizon line. The Verizon line was marked parallel with the sidewalk, but it made a hard right turn running towards the other sidewalk. Dispatch and Verizon were notified. PWSA completed the water main break and Verizon made repairs.” Ticket #20260710810 was the emergency ticket entered for Pittsburgh Water to repair a water main break. The response due date was 3/12/2026 at 10:52 AM. COMCAST responded “Clear” at 3:46 PM, and PACT STANWIX PLANT responded “Clear” on 3/13/2026 at 8:32 AM. Damage is reported at 11:15 AM on 3/12/2026. Verizon responded “Field Marked” prior to the damage occurring. Images submitted show the site, excavation, marks, and damage. The images support the statements in the AVRs. Violations: Facility – Verizon: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - Comcast Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - PACT STANWIX PLANT Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63282	Facility Owner: UGI UTILITIES INC Contractor/Excavator: NEW ENTERPRISE STONE AND LIME COMPANY Project Owner: PENNDOT	On 3/12/2026 10:28:00 PM at Rt 405, 1000' N of Sports Zone Drive, POINT TWP, NORTHUMBERLAND The incident occurred on Thursday, March 12, 2026, on RT 405, near Sports Zone Dr, Point Twp, Northumberland County. A gas line owned by UGI Utilities was damaged. PENNDOT, the project owner, reported a facility owner issue as marked incorrectly. PENNDOT stated in their Alleged Violation Report (AVR), A contractor was excavating for proposed drainage facilities when their equipment struck an underground gas line. Other 1-call marks were visible, but none within 30 feet of the	UGI UTILITIES INC: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		location where the line was struck. Emergency services and the gas utility were notified, and repairs made within the same shift. The contractor, New Enterprise Stone and Lime Company, reported a facility owner issue as marked incorrectly. New Enterprise Stone and Lime Company stated in their AVR, Crew was excavating for drainage pipe for PDOT on the NB right shoulder of SR405 in Northumberland Co. when they struck an unmarked UGI gas line. The locate marks indicated the UGI gas line terminated 29' prior to where the crew struck the line. UGI reported a facility owner issue as marked incorrectly. UGI stated in their AVR, while excavating for new drainage, a contractor struck and damaged an incorrectly marked gas main. Locator had used electronic signal that terminated at a T.S. Locator had used information that was determined to be incorrect. Violation: UGI Utilities is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalties applied	
63864	Facility Owner: PECO Contractor/Excavator: Haggerty's Landscape and Designs LLC	<u>On 3/13/2026 1:00:00 PM at 123 Ridley Dr, NETHER PROVIDENCE TWP, DELAWARE</u> The incident occurred on March 13th, 2026, at approximately 1:00 PM, at 123 Ridley Drive, located in Nether Providence Township, Delaware County, Pennsylvania. A gas line owned by PECO was damaged. 911 was not called. PECO, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “On 3/13/2026, did not have a julie and was digging with an excavator when they struck and damaged the Exelon gas main.” Their AVR reports 911 were not called. PECO verified the damage was caused by Haggerty’s Landscape and Design. Photos were submitted. Haggerty's Landscape and Designs LLC is the excavator. An AVR has not been filed as of 06/03/2026. An AVR request letter was sent 05/04/2026. Unable to obtain the project owner's information without their AVR. Pa One Call reported that Haggerty's Landscape and Designs LLC have not placed a ticket since 2019. The submitted photos show the damaged utility line. No utility mark outs are seen in the submitted photos. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: - To submit a locate request to identify the location and type of facility owner lines at each work site by	Haggerty's Landscape and Designs LLC: \$3,500.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(8) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$1,000.00 Section 5(17) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		notifying the facility owner through the One Call System. Notification shall be not less than three nor more than ten business days in advance of beginning excavation or demolition work. No work shall begin earlier than the lawful start date which shall be on or after the third business day after notification. The lawful start date shall exclude the date upon which notification was received by the One Call System and notification received on a Saturday, Sunday or holiday, which shall be processed on the following business day. - To immediately notify 911 and the facility owner if the damage results in the escape of any flammable, toxic or corrosive gas or liquid. The excavator shall take reasonable measures, based on its knowledge, training, resources, experience and understanding of the situation, to protect themselves and those in immediate danger, the general public, the property and the environment until the facility owner or emergency responders have arrived and completed their assessment and shall remain on the work site to convey any pertinent information to responders that may help them to safely mitigate the situation. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of the receipt of the request. Violations: Haggerty's Landscape and Designs LLC- - Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. - Section 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid which endangers life, health, or property. - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
63270	Facility Owner: Columbia Gas Contractor/Excavator: SNYDER ENVIRONMENTAL SERVICES	<u>On 3/17/2026 7:50:00 AM at S ROSINA AVE, SOMERSET BORO. SOMERSET</u> The incident occurred on 3/17/2026, at 7:50 AM, on S Rosina Ave, in Somerset Boro, Somerset County.	Columbia Gas: \$500.00 Section 2(5)(i) 1st Offense \$500.00 Comcast: \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Project Owner: SOMERSET BORO Designer: EADS GROUP Other: Comcast	A gas line owned by Columbia Gas was damaged. An emergency ticket was entered for the damage. Columbia Gas is the facility owner. Their Alleged Violation Report (AVR) states, “SES was digging and struck an unlocated gas line. Columbia Gas did not mark the facility.” Snyder Environmental Services is the excavator. Their AVR states, “Gas was unmarked. Line was struck and 911 was notified. Then Columbia Gas and 811 were notified.” Somerset Boro is the project owner. Their AVR states, “Contractor hit a 2" unmarked gas line”. The Eads Group Inc is the designer. Their AVR states, “Gas was unmarked. Line was struck and 911 was notified. Then Columbia Gas and 811 were notified.” Images submitted support the statements on all AVRs that the line was unmarked. Columbia Gas marked the line after the damage occurred, which is seen in IMAGE 13 and 14. Ticket #20260060850 New – Excavation – Routine required a “Clear” or “Field Marked” response by 1/8/2026. Comcast did not enter a response. Columbia Gas responded “Conflict” on 1/8/2026 and “Field Marked” on 1/25/2026. Multiple tickets were entered by Snyder Environmental Services for the same timeframe and location. No Complex Project meeting was found. This case is related to the following cases by tickets: 061273 and 062014 Violations: Facility – Columbia Gas: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - Comcast: Section 2(5)(v) – Failed to respond to a routine One Call ticket. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	Section 2(5)(v) Subsequent \$2,000.00
63131	Facility Owner: PECO AN EXELON COMPANY Contractor/Excavator: KBC CONSTRUCTION	<u>On 3/17/2026 11:05:00 AM at MAIN ST, LANSDALE BORO, MONTGOMERY</u> The incident occurred on Tuesday, March 17, 2026, on Main Street, in Lansdale Borough, Montgomery County.	PECO AN EXELON COMPANY: \$1,500.00 Section 2(5)(i) 3rd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	LLC Project Owner: LANSDALE BOROUGH	A gas line owned by PECO An Exelon Company was damaged. KBC Construction LLC reported a facility owner issue as marked incorrectly. KBC Construction stated in their Alleged Violation Report (AVR), “We damaged an unmarked 1" plastic gas line.” PECO reported facility owner issue as missing or incorrect facility line maps or records. PECO stated in their AVR, “Contractor was excavating to repair a sanitary sewer main when they struck an unmarked 1/2" plastic gas service using a standard excavator. The locator failed to use the facility records provided to locate the service” Lansdale Borough, the project owner, stated in their AVR, “unmarked gas service hit” Violation: PECO is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalties applied	
63868	Facility Owner: PECO Contractor/Excavator: Verizon Project Owner: VERIZON (Placeholder)	On 3/18/2026 11:00:00 AM at <u>WAVERLY RD, LOWER MERION TWP, MONTGOMERY</u> PECO accepts. **** The incident occurred on March 18th, 2026, at approximately 11:00 AM, on Waverly Road, located in Lower Merion Township, Montgomery County, Pennsylvania. A gas line owned by PECO was damaged. 911 was not called. PECO, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “On 03-18-2026 Verizon, was installing a new pole when they struck a gas service using an auger.” Photos were submitted. Verizon was the excavator and project owner. An AVR has not been filed as of 06/02/2026. An AVR request letter was sent on 04/22/2026. PECO reported in their AVR that the damaged gas line was not marked and that the line was marked incorrectly. In the submitted photos, no utility markings can be seen. Routine ticket 20260692495 had a response due date of 03/12/2026. - PECO initially responded to this ticket on 03/13/2026. They entered additional responses on 03/18/2026. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each facility owner: - To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall	PECO: \$2,250.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(5)(v) 1st Offense \$250.00 Verizon: \$2,000.00 Section 5(16) 2nd Offense \$1,500.00 Section 5(17) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques. - To respond to all notices through the One Call System, provided the request is made in the time frame set forth under this act. The response shall be made not later than the end of the second business day following receipt of the notification by the One Call System, excluding the business day upon which the notification is received, or not later than the day prior to the lawful start date of excavation if the excavator specifies a later date. Violations: PECO- - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. - Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Routine ticket 20260692495. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Verizon- - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
63182	Facility Owner: PITTSBURGH WATER Contractor/Excavator: WILSON EXCAVATING - A LINDY GROUP COMPANY Project Owner: Peoples Gas Company	<u>On 3/18/2026 11:00:00 AM at CROSS ST, MILLVALE BORO, ALLEGHENY</u> Incident occurred on March 18th, 2026, at 11am along Cross Street, Millvale Boro, Allegheny County. Alleged: A water line was damaged. Case is related to 63054. Alleged Violation Reports (AVR): Facility Owner: Pittsburgh Water's AVR states, "Wilson Lindy Excavating digging and hit mismarked water service line. PWSA responded and made repairs. Millvale has very old infrastructure and PWSA doesn't have good maps or records of this borough" Excavator: Wilson Excavating's AVR states, "Wilson Excavating was working at the intersection of Hansen St & Seavey St for PNG when a mismarked PWSA mainline was struck with an excavator. Facility owner was notified."	PITTSBURGH WATER: \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Project Owner: Peoples Gas Company's AVR states, "On 3/18/2026, Wilson Excavating was working at the intersection of Hansen St & Seavey St for PNG when a mismarked PWSA mainline was struck with an excavator. Facility owner was notified." Alleged conclusion: Images show that the line was not marked within the tolerance zone. Recommended violations, penalties, and education: Facility Owner: Pittsburgh Water Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260582643 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
63242	Facility Owner: PECO Contractor/Excavator: ANRICH,INC. Project Owner: PENNSYLVANIA AMERICAN WATER Other: Norristown Municipal Authority Other: VERIZON	<u>On 3/19/2026 8:30:00 AM at 504 CHERRY ST AND another incident on 524 CHERRY ST, NORRISTOWN BORO, MONTGOMERY</u> Both incidents occurred on Thursday, March 19, 2026, One at 524 Cherry Street, and another at 504 Cherry St., in Norristown Borough, Montgomery County. A gas line owned by PECO was damaged. Also, there was an exposed unmarked line that was listed as an unknown facility owner. PENNSYLVANIA AMERICAN WATER stated in their Alleged Violation Report (AVR) that "While excavating the trench for new water main installation on PAWC Cherry Street project, Anrich identified a steel gas service which was assumed to be the active lateral. A second plastic gas service was uncovered and it was determined that the service was damaged during the additional excavation following the identification of the steel gas service. The location of the hit was outside of the PA One call 18 inch tolerance zone from the utility mark. Anrich contacted 911 to report the hit service. Anrich contacted PA One call to renew as a hit." Project is >\$400,000. And the length of the project is 600'. Reports and pictures were provided. Pictures provided by Pa American show the gas line at 524 Cherry St. ANRICH INC submitted 2 AVR's for 2 separate incidents. ANRICH INC stated in AVR2026MAR230016 that on 3/19/2026, "located gas service that was on the mark. moved over and hit service." They list project at <\$400,000., but PA American Water is the project owner, and the project is listed as >\$400,000. Project length is listed at 740'. This AVR lists this incident at 504 Cherry St, for an unknown facility type line which was exposed. *Emergency ticket 20260683896 was submitted by Anrich Inc on 3/09/2026 for an unknown exposed line. Anrich Inc also submitted AVR2026APR270030, which stated that on 3/19/2026 ," Working in front of 504	ANRICH,INC.: \$750.00 Section 5(4) 1st Offense \$500.00 Section 5(3) 1st Offense \$250.00 Norristown Municipal Authority: \$250.00 Section 2(5)(v) 1st Offense \$250.00 VERIZON: \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Cherry St Norristown We were using a Vac Truck unit to help to locate services in sidewalk. located a gas service line on the mark. We moved over close to 3 feet and hit a live gas service. 911 was notified. *Emergency ticket 20260780705 was submitted by Anrich Inc on 3/19/2026 at 8:42 for damage to a gas line using a trackhoe. PECO AN EXELON COMPANY stated in their AVR that “Contractor used an excavator 3 foot in front of the gas meter and was using mechanical equipment within the tolerance zone of buried facility.” Reports were provided. See attachments named “C1” and “C2”, to see that the excavation was right in line with the gas meter and within 18” of the markout. VIOLATIONS ANRICH,INC. is in violation of: Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Within the tolerance zone, the excavator shall employ prudent techniques, which may include hand-dug test holes, vacuum excavation or similar devices to ascertain the precise position of such facilities. Section 5(3) – Excavator failed to hold a preconstruction meeting prior to beginning a complex project. Recommendation: The penalties are applied. PUC compliance education is required for the excavators working onsite of this excavation or their replacements. Note that the PUC required education for excavators has been due since 1/08/2024. VERIZON is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260622111 was submitted by Anrich Inc on 3/03/2026 at 12:58 for new excavation to install water mains and service lines. The ticket response was due by 3/05/2026. Verizon had no response until 3/06/2026. Recommendation: The penalty is applied. PUC compliance education has been recently completed. Norristown Municipal Authority is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260622111 was submitted by Anrich Inc on 3/03/2026 at 12:58 for new excavation to install water mains and service lines. Norristown Municipal Authority did not respond “Field marked” until 3/06/2026. Recommendation: The penalty is applied.	
63342	Facility Owner: PENN STATE UNIVERSITY Contractor/Excavator: Glenn O Hawbaker Inc. Other: Barton Malow	<u>On 3/23/2026 6:30:00 AM at PENN STATE ANIMAL DIAGNOSTIC LAB, COLLEGE TWP, CENTRE</u> The incident occurred on 3/23/2026, at 6:30 AM, at Penn State Animal Diagnostic Lab, in College Twp, Centre County. An electric line owned by Penn State University was damaged.	Glenn O Hawbaker Inc.: \$250.00 Section 5(6)(i) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Penn State University is the facility owner and project owner. Their Alleged Violation Report (AVR) states, "At 6:30am on Monday March 23rd, Glenn O. Hawbaker (GOH) dug through a section of conduits at the PSU Animal Diagnostic Lab (ADL) while excavating subgrade for new paving. GOH contacted Barton Malow Builders (BMB) who then contacted PSU. PSU medium voltage crew, PSU locators, Doug Barefoot, and Mark Henry met onsite to assess the damage. Two conduits were damaged, and one was completely cut off. The conduit that was completely cutoff was the annunciator wire going to the only backup generator to the ADL. The other damaged conduit contained 1/0 power wires that feed the batteries and other ancillary systems of the generator itself. These power feeds are still live as of Monday morning, although we cannot confirm if the wire was damaged. PSU does not want to de-energize the wires yet, as this feed is actively keeping batteries charged at the generator. The annunciator panel for the generator is offline. PSU attempted to start the generator via the Automatic Transfer Switch (ATS) inside the building. The generator failed to start after working the ATS, which means that ADL currently does not have a backup power source. It was confirmed that a 1-call was submitted under ticket 20260640184 and completed prior to starting work and the PSU locators had identified the conduits. BMB is still investigating the root cause for GOH striking the conduits. The repair work to the conduit and wiring is being evaluated by an outside contractor. Repairs will require a scheduled shutdown of the generator. Communications wiring will need pulled out from the annunciator panel all the way to the generator. Conduit will need repaired, then new communications wires will need pulled and terminated at both the generator and the annunciator panel. Regarding the power conduit that was damaged, during this planned shutdown the contractor will inspect the wire for any signs of damage. If all insulation is intact, the conduit can be repaired with a split-conduit in-situ. If the wire itself is damaged, it will need pulled back to the nearest pull box and new cabling ran in a repaired conduit." Glenn O Hawbaker Inc is the excavator. Their AVR states, "Asphalt was removed causing the markout to be lost. Line was then struck while undercutting subgrade." Barton Malow lists themselves as the Construction Manager (Controller) and submitted an AVR that states, "Glenn O Hawbaker was cutting approximately 8" of subgrade in preparation for a repaving effort. They had previously placed a 1-call and all utility marks were laid out on the existing asphalt. After the asphalt was peeled up to cut their subgrade, they failed to have the utilities remarked. During the excavation of subgrade, they struck a telecommunications line." Images submitted show the site, marks, and damaged line. The line was marked in red prior to excavation. No	

Case Number	Stakeholders	Summary	Violations & Recommendation
		renotify, update, or new routine ticket were found for this excavation after the marks were removed with the asphalt. Violations: Excavator - Glenn O Hawbaker: Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
63440	Facility Owner: UGI Utilities Contractor/Excavator: STAFURSKY PAVING Project Owner: Clarks Green Borough Designer: COLWELL NAEGELE ASSOCIATES INC	<u>On 3/23/2026 7:56:00 AM at 110 YALE BLVD, CLARKS GREEN BORO, LACKAWANNA</u> Incident occurred on March 23rd, 2026, at 7:56am on 110 Yale Boulevard, Clarks Green Boro, Lackawanna County. Incident: A gas line was damaged. Emergency services were notified. No final design was placed. Alleged Violation Reports (AVR): Facility Owner - UGI's AVR states, “Excavator struck and damaged unmarked gas facility.” AVR notes 911 was called. AVR submission date: 3/30/26 Was the AVR submitted after 30 business days? No Excavator - Starfursky Paving's AVR states, “Upon arriving to work site on, 3/23/2026 after 1call was cleared to located all utilities, operator proceeded to dig for installation of storm pipe. While digging operator encounter unmarked gas service for house #110 Yale Blvd, and ripped out said service. there were no marks identifying this service and with further inspection other marks were unclear so, Stafursky Paving requested a more thorough markout to clarify all lines associated with job. Locates were very unclear and uncertain, some marks were crossed out and even painted out in black paint.” AVR submission date: 3/27/26 Was the AVR submitted after 30 days? No. Designer - Colwell Naegele Associates Inc's AVR states, “Our office was contacted by Stafursky Paving Co., that they encountered an un-marked gas service lateral that served 110 Yale Blvd. while excavating for the installation of a stormwater pipe. The service lateral was ripped through while excavating due to no pavement markings for this service. Once this incident occurred, Stafursky contacted the appropriate parties to make them aware of the issue. Our office went to the site to document the incident, as we arrived on site UGI was working with the contractor to resolve the issue and locate/mark the un-marked lateral. The line that got hit was unmarked, and UGI did not provide our office with documentation to indicate its presence. Please know that our office completed a PA One Call Ticket for Design, which is No. 20252604526. Stafursky's Paving PA One	UGI Utilities: \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Clarks Green Borough: \$500.00 Section 6.1(3) 1st Offense \$500.00 Section 6.1(7) 1st Offense \$0.00 COLWELL NAEGELE ASSOCIATES INC: \$500.00 Section 4(2) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Call Ticket for construction is Ticket No. 20260651798.” AVR submission date: 4/28/26 Was the AVR submitted after 30 business days after being aware of incident? No Alleged conclusion: Gas line was not marked with yellow paint within the tolerance zone. No final design ticket was placed and the project owner, Clarks Green Borough, did not submit an AVR within 30 days of the damage emergency ticket, 20260820601. Recommended violations, penalties, and education: Facility Owner - UGI Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Project Owner - Clarks Green Borough Section 6.1(3) – Released a project to bid or construction before final design was complete. 20252604526 Section 6.1(7) – Project Owner failed to submit an Alleged Violation Report within 30 Days of a line strike. 20260820601 -PUC compliance education is required for the person responsible for submitting AVR or their replacement. -PUC compliance education is required. Designer - Colwell Naegele Associates Inc. - Section 4(2) – Designer failed to request the line and facility information prescribed by section 2(4) from the One Call System not less than ten nor more than ninety business days before final design is to be completed. 20252604526 -PUC compliance education is required for the designer(s) who worked on this project or their replacement(s).	
63382	Facility Owner: Peoples Natural Gas Contractor/Excavator: Mele & Mele & Sons Project Owner: Pittsburgh Water Other: JOHNSON MIRMIRAN AND THOMPSON Other: Proscap	<u>On 3/24/2026 8:45:00 AM at 5463 MAYNARD ST, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 3/24/2026, at 8:45 AM, on 5463 Maynard St, in Pittsburgh City, Allegheny County. A gas line owned by Peoples Natural Gas was damaged. Peoples Natural Gas is the facility owner. Their Alleged Violation Report (AVR) states, “ProScape doing road restoration for Mele and Mele following water line installation for Pittsburgh Water struck and damaged a Peoples Gas service line with no locate request. There are markings from other tickets on this project and the line was still damaged with visible paint within the tolerance zone of the excavation.”. Proscap is listed as the excavator and an AVR was not submitted as of 5/6/2026. An AVR was requested the same day. No AVR was submitted by Proscap, and no contact was made by them after an AVR request letter	Mele & Mele & Sons: \$500.00 Section 5(4) 1st Offense \$500.00 Proscap: \$500.00 Section 5(17) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		was sent which requested additional information and documentation on the incident. Mele And Mele And Son was originally listed as the project owner as they sub-contracted excavation work to the excavator. Their AVR states, "The Sub-contractor hit MARKED gas service at 8:45am on Maynard Ave while excavating for concrete road base at 10" depth. -911 was called at 8:45am by contractor. -Fire dept arrived at approx 8:50am -Fire dept cleared scene and left @ 8:55am. -Peoples gas showed up @ 10:30a -People's gas service crew showed up on site @ 1:30PM -Gas line was repaired by service crew @ 2:00pm. -Sub-contractor resumed concrete road base and roadblock replacement." Mele and Mele was questioned about the contact information for Proscape and stated, "Mele is handling all one calls for our subcontractors on this project." Once informed that the excavator needed their own ticket Mele and Mele stated, "After some internal investigation. I found out that Mele was doing the excavation and Proscape was replacing the Belgian Block on the street. I also found out that the people gas line was only 10" below finish grade of the roadway and encompassed in the Belgian Block's base, that needed replaced. Thank you for pointing out section 5(23). I was unaware of it and will pass the information along here at Mele." Pittsburgh Water is the project owner. Their AVR states, "The Sub-contractor hit MARKED gas service at 8:45am on Maynard Ave while excavating for concrete road base at 10" depth. -911 was called at 8:45am by contractor. -Fire dept arrived at approx 8:50am -Fire dept cleared scene and left @ 8:55am. -Peoples gas showed up @ 10:30a -People's gas service crew showed up on site @ 1:30PM -Gas line was repaired by service crew @ 2:00pm. -Sub-contractor resumed concrete road base and roadblock replacement." Johnson Mirmiran And Thompson is the designer. Their AVR states, "The Sub-contractor hit MARKED gas service at 8:45am on Maynard Ave while excavating for concrete road base at 10" depth. -911 was called at 8:45am by contractor. -Fire dept arrived at approx 8:50am -Fire dept cleared scene and left @ 8:55am. -Peoples gas showed up @ 10:30a -People's gas service crew showed up on site @ 1:30PM -Gas line was repaired by service crew @ 2:00pm. -Sub-contractor resumed concrete road base and roadblock replacement. PNG provided records do not show location of service lines. Service line approximate location was shown on the drawings as per the survey delineation provided to JMT." This case is related to the following cases by tickets: 056640, 056926, 056929, 057058, 059523, 060197, 060339 Violations: Excavator - Mele and Mele:	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. Proscape: Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within thirty days of the receipt of the request. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
63381	Facility Owner: COLUMBIA GAS OF PA_ South Contractor/Excavator: LEES PLUMBING AND EXCAVATING INC Project Owner: PENNSYLVANIA AMERICAN WATER	<u>On 3/24/2026 9:28:00 AM at 337 CONNELLSVILLE ST, UNIONTOWN CITY, FAYETTE</u> The incident occurred on Tuesday, March 24, 2025, at 349 Connellsville Street (damaged at the intersection), in Uniontown City, Fayette County. A gas line owned by Columbia Gas was damaged. Lees Plumbing and Excavating Inc reported a facility owner issue as marked incorrectly. Lees Plumbing stated in their Alleged Violation Report (AVR), “We were working on a water main break. We were breaking up the concrete road to start our excavation when we damaged a gas line with our hammer hoe from the excavator.” PA American Water Company (PAWC) reported facility owner issue as marked incorrectly. PAWC stated in their AVR, “PAWC had a valve leaking and put a emergency ticket in gas line was struck with hammer. 8:30 am American Water crew arrived on scene. American Water employee started to plan the shutdown to complete the job knowing it was going to be a good bit of valves to get the water off. 8:58 am American Water employee called me to help assist with shutdown. I arrived around 9:15am or so to assist. 10:40 am - 10:45 am we arrived back on the job site after shutting valves down and thats when Lee's Plumbing (our contractor) started to hammer the road to start the job. I told American Water employee I would check the hydrant on my way out to see if the water was fully off, at that time he called me and stated that the gas line was hit. 10:50 am I called a American Water employee to call in a emergency ticket for hit gas line and during that time Lee's Plumbing Employee was calling 911. Roughly around 11:12 am the fire department arrived and roughly around 11:20 am Columbia showed up. The gas main was only 11.5" deep under the pavement. While I was there i seen that the contractor stayed below the yellow marks knowing that the gas was there. In the photos you can see that the "newer fresh" marks are off a bit from the "old marks". Columbia put a clamp on the damaged main and back filled the hole.” Columbia Gas reported an excavator Issue as failed to use prudent techniques in the tolerance zone. Columbia Gas stated in their AVR, “Lees Plumbing working for Pa	LEES PLUMBING AND EXCAVATING INC: \$500.00 Section 5(3) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		American Water proceeded to operate a hoe ram directly above an accurately marked-out 6-inch steel gas main. Despite the clear and accurate markings indicating the exact location of the underground facility, the operator positioned the hoe ram bit directly over the marked main and made contact with it. This action resulted in the bit striking the steel gas main itself, causing damage significant enough for natural gas to begin escaping from the line.” The photos provided from (view attachments): *Lees Plumbing photos show a damaged shallow gas line. *PAWC-Photos show Photo 2 and 3 with a hit-kit and old faded yellow gas marks that looks mismarked by 1.5 feet. Cannot see if it indicated the size of the gas line. Photo 4 shows the shallowness of the gas line. Photo 5 shows the repaired gas line, with the old faded marks to the left, and fresh yellow gas marks aligned with the repaired gas line. *Columbia Gas pic1 shows the damage with fresh yellow marks, pic2 shows the damage, and pic3 shows the repaired gas line and shallowness. Violations: *Lees Plumbing and Excavating Inc is in violations: 5(3) – Excavator failed request a remark. Recommendation: Penalty applied and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
63633	Facility Owner: PECO Contractor/Excavator: TRI COUNTY WATER SERVICES Project Owner: PA AMERICA WATER Other: COATESVILLE CITY Other: COMCAST Other: PENNSYLVANIA AMERICAN WATER/WASTE WATER - spacesaver	<u>On 3/24/2026 10:00:00 AM at 141 ROSEMONT AVE, COATESVILLE CITY, CHESTER</u> The incident occurred on 3/24/2026 at 141 ROSEMONT AVE in COATESVILLE CITY in Chester Co. A 1” plastic service gas line was damaged. Root Cause: Lines were not marked within 18” horizontally of the outside wall of the line. PECO AN EXELON COMPANY stated in their Alleged Violation Report (AVR) that, “Contractor TRI COUNTY WATER SERVICES was using an excavator and hit an Exelon 1" plastic gas service.” Damage report with pictures was provided. Damage Report summary stated that “ On 3/24/26 USIC was notified of a gas service that was damaged at 141 Rosemont Ave in Coatesville, Chester County, PA. The investigation determined that the contractor TRI COUNTY WATER SERVICES was using an excavator under ticket 20260793302 and hit a mismarked Exelon 1" plastic gas service”. TRI COUNTY WATER SERVICES stated in their AVR that, “Tri-County Water Services was contracted by Pennsylvania American Water to perform an emergency water service supply line repair for a line that was leaking underground. The property was located at 141 Rosemont Ave. Coatesville, PA 19320. The One Call responses and markings were reviewed prior to the dig start. After a few strokes with the mini excavator	PECO: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 PA AMERICA WATER: \$1,000.00 Section 2(5)(vii) 1st Offense \$1,000.00 COATESVILLE CITY: \$1,000.00 Section 2(5)(vii) 1st Offense \$1,000.00 COMCAST: \$2,500.00 Section 2(5)(vii) Subsequent \$2,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		working from the curb stop to the home it was determined that the technician had struck a gas service line. The service line had crossed over and across the water service line, which was not reflected in the markings. The markings reflected that the gas service was to the left of the water service line. Pictures are attached of before the dig start. 911 were called as well as the PECO emergency line. Fire, police and PECO were dispatched to the site and the leaking gas service line was repaired and service restored. Also, Water service line was completed and the ground put back in place, rake and seeded. PENNSYLVANIA AMERICAN WATER stated in their AVR that, “ Tri-County was replacing a service line and hit a missed marked gas line.” *Emergency ticket 20260793302 was submitted by TriCounty Water Services on 3/20/2026 at 15:19. PA American Water responded “field marked on 3/20/2026, and PA American Water/Waste Water did not respond “clear – no facilities or facilities not involved until 3/23/2026”. PECO scheduled mark but did not “field mark” until 3/23/2026. There is no information that the Facility owner proposed a mutually agreeable scheduling by which the excavator, facility owner or designer may locate the facilities. Comcast did not respond until 3/25/2026, when they responded “clear” On 5/04/2026 DPI Maki asked if PECO had a mutual agreement with TriCo Water to make out late. An email was received from TriCo Water confirming that PECO representative did call, and they verbally agreed to have the locate completed by 3/23/2026. Coatesville City had no response until on 3/24/2026 they responded “Clear”. VIOLATIONS PECO AN EXELON COMPANY is in violation of: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. PUC compliance education has been recently completed. PENNSYLVANIA AMERICAN WATER/WASTE WATER is in violation of: Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260793302 was submitted by TriCounty Water Services on 3/20/2026 at 15:19. PA American Water/Waste Water did not respond “clear – no facilities or facilities not involved until 3/23/2026”. Recommendation: The penalty is applied. PUC compliance education has been recently completed. COATESVILLE CITY Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260793302 was submitted by	

Case Number	Stakeholders	Summary	Violations & Recommendation
		TriCounty Water Services on 3/20/2026 at 15:19. Coatesville City had no response until on 3/24/2026 they responded "Clear". Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). COMCAST is in violation of: Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Recommendation: The penalty is applied. PUC compliance education has been recently completed. Emergency ticket 20260793302 was submitted by TriCounty Water Services on 3/20/2026 at 15:19. Comcast did not respond until 3/25/2026, when they responded "clear"	
63551	Facility Owner: Philadelphia Gas Works (PGW) Contractor/Excavator: Danella Companies Inc Project Owner: Placeholder - Philadelphia Gas Works (PGW) Designer: Placeholder - Philadelphia Gas Works (PGW)	<u>On 3/25/2026 10:00:00 AM at N 12TH ST, PHILADELPHIA CITY, PHILADELPHIA</u> The incident occurred on 3/25/2026, at 10:00 AM, on N 12Th St, in Philadelphia City, Philadelphia County. A gas line owned by Philadelphia Gas Works was damaged. Philadelphia Gas Works is the facility owner, project owner, and designer. Their Alleged Violation Report (AVR) states, "While contractor Danella was digging to install 6" plastic main, they hit a 1 1/4" plastic gas service line. The service was marked at the located that was listed in PGW records, but the information was inaccurate. The service was 5 feet off from marks. We apologize for not submitting the AVR sooner." Danella Construction is the excavator. Their AVR states, "on 3/25/26 at approximately 11:30 am, after hand digging within the tolerance zone at 6519 N. 12th ST. The crew was excavating and came in contact with an unmarked 2" plastic gas service 4' off the closest mark." Images provided show the site, excavation, marks, and damaged gas line. Yellow marks are seen over 3 feet away from the damaged line, and there are no marks that indicate the line that was damaged. Violations: Facility Owner - Philadelphia Gas Works: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	Philadelphia Gas Works (PGW): \$500.00 Section 2(5)(i) 1st Offense \$500.00
63685	Facility Owner: City of Pittsburgh - Pittsburgh Department of Mobility and Infrastructure Contractor/Excavator: M. O'Herron Company Project Owner: Peoples Natural Gas	<u>On 3/25/2026 11:00:00 AM at CENTRE AVE, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 3/25/2026, at 11:00 AM, on Centre Ave, in Pittsburgh City, Allegheny County. The facility owner "Pittsburgh City" reports an electric line was damaged. An emergency ticket was entered for the damage by the excavator.	City of Pittsburgh - Pittsburgh Department of Mobility and Infrastructure: \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Designer: Peoples Natural Gas - Placeholder	City of Pittsburgh is the facility owner. Their Alleged Violation Report (AVR) states, “Contractor damaged City signal conduit and cables causing damage to signal hardware at two locations. Centre/Aiken and Centre/Graham. The. Project owner is claiming City did not mark a location in the middle of the roadway between the intersections. City clearly marked underground facilities within each signalized intersection.” No documents or images were provided. M Oherron Company is the excavator. Their AVR states, “Digging for new steel gas main install in road on Centre Ave damaged unmarked electric line crossing to street light pole across from 5430 Centre ave. Electric marked in sidewalks on both sides of street and down center of road but no crossings marked in that area. Allegheny City electric contractor came to repair City of Pittsburgh owned electric line.” Peoples Natural Gas is the project owner and designer. Their AVR states, “M O'Herron working Peoples Gas struck and damaged an unmarked electric wire. It was determined after the fact that it was a street light line owned by Allegheny City Electric.” Images submitted show markings on both sides of the street. The damage occurred in the roadway and there are no marks to indicate the line that was damaged. Violations: Facility Owner - City of Pittsburgh: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63526	Facility Owner: York Water Company Contractor/Excavator: AWK Consulting Engineers Project Owner: York Water - Place holder Designer: CS DAVIDSON INC Other: Verizon North	<u>On 3/25/2026 2:35:00 PM at W MARKET ST, YORK CITY, YORK</u> 9-11-26 update CS Davidson to designer and York Water to the Project Owner. ***** The incident occurred on 3/25/2026, at 2:35 PM, on W Market St, in York City, York County. A water line owned by York Water Company was damaged. An emergency ticket was entered for the damage. York Water Company is the facility owner. Their Alleged Violation Report (AVR) does not have any detailed information in the Summary section. AWK Consulting Engineers is the excavator. Their AVR states, “On March 25th, AWK, who is a sub-consultant for the West Market Street Bridge replacement in The City of York, was on site to complete geological boring testing to obtain data for the design of the proposed abutments and other key features of the replacement. Prior to the borings taking place, AWK completed a PA One Call on 3/19/2026, and markings in the field were	York Water Company: \$500.00 Section 2(5)(i) 1st Offense \$500.00 AWK Consulting Engineers: \$500.00 Section 5(4) 1st Offense \$500.00 Verizon North: \$500.00 Section 2(5)(v.2) 2nd Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		completed by the local utility companies that owned and operated facilities in the area. The York Water Company marked out its water line on 3/23/2026, which was located in the middle of the roadway running parallel with West Market Street. The first boring was completed with no conflicts, but at the second location, a water main was struck about 23-25 feet below the surface. The location of the boring was approximately 20 feet away from where the water main was marked out in the street. AWK notified The York Water Company, who relayed that they were sending a crew out to the site to shut off the water line. AWK also notified the CSD's Project Manager, Daryl Jurkiewicz, at 2:47 PM via email that the line had been impacted. When Daryl arrived on site and discussed with York Water, it was stated that they believe that the water main that was impacted had been installed in 1942 and was "missed" when the markings were completed following the PA One Call." CS Davidson Inc is the designer and project owner. Their AVR states, "The City of York owns the West Market Street Bridge, located between N. Newberry Street and N. Pershing Avenue. On the City's behalf, the York County Economic Alliance has executed a design contract for the replacement of this bridge with C.S. Davidson, Inc. On March 25th, 2026, AWK Consulting Engineers, who is a geo-technical consultant for C.S. Davidson, Inc., was on site to complete soil borings to obtain data for the design of the proposed abutments and other key features of the replacement bridge. On October 12, 2023, C.S. Davidson completed a Design One Call for the project (Serial Number 20232850219), requesting utilities to mark lines in the field to avoid design conflicts. York Water Company failed to identify the impacted water line in response to the Design One Call. In addition, on November 6, 2023, C.S. Davidson initiated design coordination with York Water Company. Again, the only water line identified by York Water Company was the 12" water line which is attached to the existing bridge. The water line attached to the superstructure and identified by York Water Company is also identified in C.S. Davidson's utility tracking spreadsheet for the Market St. Bridge project. Additionally, on March 19, 2026, prior to the borings taking place, AWK completed a PA One Call (Serial Number 20260784201). AWK clearly indicated the type of excavation to be drilling at a depth of 50 feet and appropriately identified the areas for drilling to include the street, sidewalk, and public property. The markings in the field were completed by the local utility companies that owned and operated facilities in the area, including York Water Company. On March 23, 2026, the York Water Company marked out its water line. The marked water line was located in the middle of the roadway, running parallel with West Market Street, and is the water line attached to the underside of the existing West Market Street Bridge. Prior to York Water Company marking its water line on March 23, 2026, the Soil Boring drill locations were marked with spray paint and an "SB" indicator. On March 25, 2026, AWK	

Case Number	Stakeholders	Summary	Violations & Recommendation
		completed its first soil boring with no conflicts or line strikes. However, at the second location (identified as Soil Boring 5), a water main was struck about 23-25 feet below the sidewalk surface and about 5-6 feet below the streambed. The location of Soil Boring 5 was approximately 20 feet away from where York Water Company marked out its water main in the street. No markings were made in the vicinity of Soil Boring 5. AWK notified York Water Company after the line strike, who relayed that they were sending a crew out to the site to shut off the water line. AWK also notified the CSD's Project Manager, Daryl Jurkiewicz, at 2:47 PM via email that the line had been impacted. When Daryl Jurkiewicz arrived on site and discussed with York Water crew, it was stated that they believe that the water main that was impacted had been installed in 1942 and was "missed" when the markings were completed following the PA One Call on March 23, 2026. York Water Company crew shut the water main off and capped it on both sides of the bridge. Representatives of the City Public Works Department responded to the utility strike and provided traffic control." Images submitted show the site, excavation, and marks. There are no blue water or green sewer marks in the area where damage occurred. There are red and orange marks within the excavation area and there is no indication that prudent techniques were used in the tolerance zone. Section 5(4) of PA Act 127 of 2025 states, "Within the tolerance zone the excavator shall employ prudent techniques, which may include hand-dug test holes, vacuum excavation or similar devices to ascertain the precise position of such facilities. If insufficient information to safely excavate is available pursuant to section 2(5), the excavator shall employ like prudent techniques which shall be paid for by the project owner pursuant to clause (15)." Ticket#20260784201 – Verizon North did not respond by the response due date of 3/23/2026. Violations: Facility – York Water Company: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Excavator - AWK Consulting Engineers: Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. Facility (other) – Verizon North: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63431	Facility Owner: PEOPLES NATURAL GAS COMPANY LLC Contractor/Excavator: ALEX E PARIS CONTRACTING COMPANY Project Owner: PENNSYLVANIA AMERICAN WATER	<u>On 3/26/2026 8:30:00 AM at 131 SUMMERFIELD DR, MUNHALL BORO, ALLEGHENY</u> The incident occurred on Thursday, March 26, 2026, at 131 Summerfield Drive, in Munhall Borough, Allegheny Country. A gas line owned by Peoples Natural Gas Company (PNG) was damaged. Alex E. Paris Contracting Company, working for PA American Water Company (PAWC), reported an excavator issue as failed to use prudent techniques in the tolerance zone. Alex E. Paris Contracting stated in their Alleged Violation Report (AVR), "Excavator was digging for DIP water main installation. Located and exposed 1" gas service (131 Summerfield). While continuing to dig, the operator backed up and grounded the bucket of the excavator damaging the service line. Checked for leak, no smell or sound of gas being released. Facility owner responded and repaired the line." PNG reported an excavator issue as failed to use prudent techniques in the tolerance zone. PNG stated in their AVR, "on 3/26/26 Alex E Paris Contracting working at 131 Summerfield Dr, homestead struck a PNG main to curb service line. The plastic line was deformed but not leaking. PNG crews were called to the site, and repairs were made. Alex E Paris Contracting failed to maintain clearance." PAWC, reported an excavator issue as failed to use prudent techniques in the tolerance zone. PAWC stated in their AVR, "Paris crew while laying water main did Level A SUE and spotted the Peoples Gas service line. During excavation the operator moved the machine and dragged his bucket across the service. There wasn't any smell/sound of gas, Peoples arrived and fixed the line." Violation: Alex E. Paris Contracting Company is in violation of section: 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Recommendation: Penalty applied	ALEX E PARIS CONTRACTING COMPANY: \$500.00 Section 5(4) 1st Offense \$500.00
64005	Facility Owner: Aqua Contractor/Excavator: DANELLA CONSTRUCTION Project Owner: PECO Designer: ENTRUST/EN ENGINEERING Other: COMCAST Other: EAST BRADFORD TOWNSHIP Other: West Chester Borough	<u>On 3/26/2026 10:45:00 AM at N BRADFORD AVE, WEST CHESTER BORO, CHESTER</u> East Bradford violation is reduced from \$1000 to \$0 as a warning violation. ***** The incident occurred on 3/26/2026 at N BRADFORD AVE in WEST CHESTER BORO in CHESTER Co. A 4" cast iron water main owned by Aqua was damaged. DANELLA stated in their Alleged Violation Report (AVR) that, "On 3/26/26 a Danella crew working on the PECO system when the crew came in contact with a 6-inch water main that was 5'5" from the marks.	Aqua: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 COMCAST: \$1,000.00 Section 2(5)(v) Subsequent \$1,000.00 EAST BRADFORD TOWNSHIP: \$0.00 Section 2(5)(vii) 1st Offense \$0.00 West Chester Borough:

Case Number	Stakeholders	Summary	Violations & Recommendation
		Directional drilling was used for this project. Pictures were provided. This project is to INSTALL GAS MAIN AND SERVICE/S.and is expected to be completed in 6mo. " PECO AN EXELON COMPANY stated in their AVR that, "On March 25, 2026, Danella working for PECO was performing missile boring operations to install a new gas service when they struck an unmarked 4-inch cast iron water main, resulting in damage to a foreign utility. The crew immediately stopped work, secured the area, and all notifications were made. No project information was provided. Job photo sketch was provided. On 5/05/2026 DPI Maki sent an email asking PECO for the size and scope of this project. Aqua stated in their AVR that, "Excavator hit mismarked water main on W Chestnut St." Pictures were provided. *Case 62192 is connected by tickets VIOLATIONS Aqua is in violation of: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. This is a subsequent violation. Recommendation: The penalty is applied. PUC compliance education has been recently completed. COMCAST is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260780409 was submitted by DANELLA CONSTRUCTION on 3/19/2026 with a response due by 3/23/2026. Comcast did not respond "Clear", until 3/25/2026. This is a subsequent violation. Recommendation: The penalty is applied. PUC compliance education has been recently completed. West Chester Borough is in violation of: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260780410 was submitted by DANELLA CONSTRUCTION on 3/19/2026 with a response due by 3/23/2026. WEST CHESTER BOROUGH never responded. Comcast did not respond "Clear", until 3/25/2026. Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). EAST BRADFORD TOWNSHIP is in violation of: Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency ticket 20260851802 was submitted by DANELLA CONSTRUCTION on 3/26/2026 at 11:17. EAST BRADFORD TOWNSHIP did not respond "Clear" until 3/26/2026 at 12:30.	\$250.00 Section 2(5)(v) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
63610	Facility Owner: PECO Contractor/Excavator: UTILITY LINE SERVICES Project Owner: Aqua America Designer: BRANDYWINE CAD DESIGN INC	<u>On 3/26/2026 11:20:00 AM at EAGLE FARM RD, LOWER MERION TWP, MONTGOMERY</u> The incident occurred on 3/26/2026, at 11:20 AM, on Eagle Farm Rd, in Lower Merion Twp, Montgomery County. A gas line owned by PECO was damaged. An emergency ticket was entered for the damage. PECO is the facility owner. An Alleged Violation Report (AVR) was not filed as of 05/29/2026 and PECO was contacted the same day for information. An AVR was submitted on 6/2/2026 that states, "On 03/26/2026 UTILITY LINE SERVICES was installing a water main under locate ticket 20260690151 when they struck a 1 1/4" steel service unmarked gas stub. This stub was not on the PECO prints, and this was why the line was struck." Utility Line Services is the excavator. An AVR was filed that states, "While the crew was trenching in the area of 733 Eagle Farm Road an unmarked 3/4 inch steel gas line was damaged. All proper notifications were made." Aqua Pennsylvania is the project owner. Their AVR states, "Aqua Contractor Utility Line Services, while the crew was trenching in the area of 733 Eagle Farm Road an unmarked 3/4 inch steel gas line was damaged. All proper notifications were made." BRANDYWINE CAD DESIGN INC is the designer. An AVR was not filed as of 05/29/2026. Ticket # 20260851989 New – Damage – Emergency was entered at 11:40 AM on 3/26/2026 by Utility Line Services when they encountered an unmarked gas line. PECO and Everstream responded "Clear" at 3:16 PM as their only response. All other facilities responded by the response due date/time, and PECO is the only facility on the ticket with gas lines. Ticket #20260611010 New – Excavation– Complex Project was for this excavation. PECO said will attend meeting but did not sign in on the sign in sheet. PA One Call was in attendance. Ticket #20260611010 New – Excavation– Complex Project Violations: Facility Owner – PECO: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Section 2(5)(viii) – Failed to participate in preconstruction meetings for a complex project or as described in Section 5(3). Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification.	PECO: \$4,500.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(10) 1st Offense \$1,000.00 Section 2(5)(viii) 1st Offense \$500.00 Section 2(5)(vii) 1st Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement.	
63416	Facility Owner: Peoples Gas Company Contractor/Excavator: Five Point Supply Contractor/Excavator: WILSON EXCAVATING - A LINDY GROUP COMPANY Project Owner: GROVE CITY BOROUGH Designer: GFT INC Other: Verizon	<u>On 3/26/2026 2:30:00 PM at East Main Street, GROVE CITY BORO, MERCER</u> GFT Accepts *** Peoples violation and penalty removed. **** Incident occurred on March 26th, 2026, at 2:30pm along East Main Street, Grove City Boro, Mercer County. Incident: A gas line was damaged. Alleged Violation Reports (AVR) Facility Owner - Peoples Gas Company's AVR states, “On 3/26/2026, Five Point Supply was saw cutting in front of 308 E Main Street without a one call when they struck an unmarked PNG SL (main to curb). PNG crews were called and repairs were made.” AVR submission date: 3/27/26 Was the AVR submitted after 30 business days? No. PA1call noted: Five Point Supply has placed One Call notifications in the past. Project Owner - Grove City Borough's AVR states, “Subcontractor Wilson Excavating - A Lindy Group hired Five Point Supply as a subcontractor. They were working at 308 E. Main Street they struck an unmarked PNG gas service line. 911 was called and People's Gas was notified.” AVR submission date: 3/31/26 Was the AVR submitted after 30 days? No. Designer - GFT INC's AVR states, “A subcontractor for Wilson Excavating was saw cutting the road and cut through an unmarked gas line” AVR submission date: 3/30/26 Was the AVR submitted after 30 business days after being aware of incident? No. Other Excavator- Wilson Excavating's AVR states, "Subcontractor, Five Point Supply, was working at 308 E Main St without a valid or active one call in place. While working Five Point struck an unmarked PNG gas service. 911 was called. Facility owner was notified."	Peoples Gas Company: \$0.00 Five Point Supply: \$1,500.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$500.00 GROVE CITY BOROUGH: \$500.00 Section 6.1(3) 1st Offense \$500.00 GFT INC: \$1,000.00 Section 4(2) 2nd Offense \$1,000.00 Verizon: \$1,000.00 Section 2(5)(v) 2nd Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Alleged conclusion: Five Point Supply did not place a PA1call and damage a gas line. No AVR was submitted by Five Point Supply within 30 days. No final design ticket was placed for the project. Verizon failed to respond to ticket 20260611133. 5 Points Supply submitted an AVR on 6/3/26 stating, "Subcontractor Five Point Supply, was working at 308 E Main Street without a valid or one call in place. While working Five Point struck and Unmarked PNG gas service. 911 was called. Facility owner was notified." Recommended violations, penalties, and education: Facility Owner: Peoples Gas Company Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260761321. Excavator: Five Point Supply Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or other violation. Reduced for filing an AVR after request from \$1,000 to \$500. -PUC compliance education is required for the excavators working onsite of this excavation or their replacements. -PUC compliance education is required for the person responsible for submitting AVR or their replacement. Project Owner: Grove City Borough Section 6.1(3) – Released a project to bid or construction before final design was complete. 20252030829 -PUC compliance education is required. Designer: GFT Inc. Section 4(2) – Designer failed to request the line and facility information prescribed by section 2(4) from the One Call System not less than ten nor more than ninety business days before final design is to be completed. 20252030829 -PUC compliance education is required for the designer(s) who worked on this project or their replacement(s). Facility Owner: Verizon Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260611133. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
63420	Facility Owner: Pennsylvania American Water (PAWC) Contractor/Excavator: Golden Triangle Construction Project Owner:	<u>On 3/27/2026 12:50:00 PM at SR 2040, PLEASANT HILLS BORO, ALLEGHENY</u> The incident occurred on 3/27/2026, at 12:50 PM, on Sr 2040, in Pleasant Hills Boro, Allegheny County. A water line owned by Pennsylvania American Water was damaged.	Pennsylvania American Water (PAWC): \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Pennsylvania Department of Transportation (PennDOT) Designer: PennDOT - Placeholder	Pennsylvania American Water is the facility owner. Their Alleged Violation Report (AVR) states, “Golden Triangle crew digging during road and drainage construction hit and damaged an unmarked water service. The locator marked a service for 125 Curry Hollow but didn't realize there was another service.” Golden Triangle Construction is the excavator. Their AVR states, “Prior to the start of drainage install, GTC brought hydrovac on site to located all marked utilities crossing or near drainage trench. GTC was excavating for drainage install along curry hollow road at approximately 12:50PM the unmarked line was struck with excavator bucket. The line was 4.5' below the roadway surface. PA American was called at 12:51PM and they arrived on site a 2PM and said they could not fix it and an additional crew would be sent out to repair. GTC remained on site until line was repaired. The line was not marked. The nearest mark was approximately 14' away at at a different service line.” Penndot is the project owner. Their AVR states, “Prior to the start of drainage install, GTC brought hydrovac on site to locate all marked utilities crossing or near drainage trench. GTC was excavating for drainage install along curry hollow road at approximately 12:50PM the unmarked line was struck with excavator bucket. The line was 4.5' below the roadway surface. PA American was called at 12:51PM and they arrived on site a 2PM and said they could not fix it and an additional crew would be sent out to repair. GTC remained on site until line was repaired. The line was not marked. The nearest mark was approximately 14' away at a different service line.” Images provided support the statements in all AVRs that the damaged line was not within the tolerance zone of any marks. Violations: Facility - Pennsylvania American Water (PAWC): Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63475	Facility Owner: Verizon Contractor/Excavator: City Of Lancaster Water Placeholder Project Owner: LANCASTER CITY OF WATER	<u>On 3/27/2026 6:30:00 PM at CROOKED OAK DR, MANHEIM TWP, LANCASTER</u> Incident occurred on March 27th, 2026, at 6:30pm along Crooked Oak Drive, Manheim Township, Lancaster County. Incident: A telecom line was damaged, and Verizon failed to respond to emergency tickets. Alleged Violation Reports (AVR): Excavator & Project Owner - City of Lancaster's AVR states, “repairing a broken, leaking water valve. While digging we struck a tel-com pipe and wire causing	Verizon: \$3,500.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(5)(vii) 1st Offense \$1,000.00 Section 2(5)(vii) 1st Offense \$1,000.00 Section 2(10) 1st Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		damage. No tel-com (Verizon) responded. After strike did another one call and again no response.” Was the AVR submitted after 30 days? No Alleged conclusion: An unmarked Verizon telecom line was damaged, Verizon failed to respond to two emergency tickets, and failed to submit an AVR within 30 business days following the emergency damage ticket. Recommended violations, penalties, and education: Facility Owner: Verizon Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260863675 Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260863675 Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260864261 Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. 20260864261	
63457	Facility Owner: Kenic Oil and Gas Contractor/Excavator: Mekis Construction Corporation Project Owner: Pennsylvania Department of Transportation (PennDOT)	<u>On 3/30/2026 9:14:00 AM at US HWY 422, SUMMIT TWP, BUTLER</u> Kenic contacted Damage Prevention Section and provided additional information. 2(5)(v.1) This violation is being reduced from \$500 to a warning of \$0. 2(5)(v.2) This violation is being reduced from \$250 to a warning of \$0. ***** The incident involves non-responses to routine and renotify tickets and occurred on 3/30/2026 on Us Hwy 422, in Summit Twp, Butler County. KENIC GAS AND OIL COMPANY submitted an AVR after the case was submitted that states, "AVR-CASE #63457 I AM RESPONDING TO THE EMAIL NOTICE THAT KENIC GAS AND OIL DID NOT RESPOND TO PA1CALL TICKETS #20260842205-000,20260842205-001,20260842205-002 I DID RESPOND TO THIS TICKET ON APRIL 6,2026 THE DUE DATE TO RESPOND WAS 03/17/2026 AND 03/20/2026 I APOLOGIZE FOR NOT RESPONDING BY THE DUE DATE. MY LIASON, WHO CHECKS INWITH, TOLD ME LAST TIME WE SPOKE, THAT I HAD 100% RESPONSE TO ALL THE TICKETS." Mekis Construction Corporation is the excavator. Their AVR states, “1 Call was placed on 3/28/2026 through online system. All responses came back "clear" except Kenic Oil and Gas to which there was no response. At 7:14AM on day of legal start date (3/30/2026), a renotification was issued through the online system	Kenic Oil and Gas: \$500.00 Section 2(5)(v.1) 1st Offense \$500.00 Section 2(5)(v.1) 1st Offense \$0.00 Section 2(5)(v.2) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		allowing 2 hours for contact. At current time, there has been no contact made and no response through the system.” 4 design tickets were included by PA One Call Systems for this project during their Initial Research of the AVR: 20240784138, 20240784137, 20221093658, 20221093657 Ticket #20260842205 had a response due date of 3/17/2026. A renotify was entered on 3/20/2026 at 7:14AM and again at 11:03. Kenic Oil and Gas responded “Clear” on 4/6/2026. No other response was entered by Kenic Oil and Gas. Act 127 of 2024 states: SECTION 2. It shall be the duty of each facility owner: (5)(v)To respond to all notices through the One Call System, provided the request is made in the time frame set forth under this act. The response shall be made not later than the end of the second business day following receipt of the notification by the One Call System, excluding the business day upon which the notification is received, or not later than the day prior to the lawful start date of excavation if the excavator specifies a later date or, in the case of an emergency, to respond through the One Call System as soon as practicable following receipt of notification of the emergency by the One Call System. (v.1) To, if a facility owner failed to respond to an original, proper, nonemergency locate request from the One Call System or to a renotification under section 5(20), communicate directly to the excavator within two hours after renotification of the information about its facility location and, if necessary and possible, go to the proposed work site to mark, stake or locate its underground lines or to verify to the excavator that the facility owner's underground lines are not within the area of the proposed work site. (v,2)To timely enter a final response to all locate requests. Violations: Facility - Kenic Oil and Gas: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket #20260842205-000 Section 2(5)(v.1) – Failed to communicate directly with excavator within 2 hours of renotification. Ticket #20260842205-001 Section 2(5)(v.1) – Failed to communicate directly with excavator within 2 hours of renotification. Ticket #20260842205-002 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63567	Facility Owner: UGI UTILITIES INC Contractor/Excavator: Skrip Excavating and	<u>On 3/31/2026 10:17:00 AM at 8611 CASCADE RD, UPPER MACUNGIE TWP, LEHIGH</u> The incident occurred on Tuesday, March 31, 2026, at 10:17am, at	Skrip Excavating and Paving LLC: \$1,500.00 Section 5(2.1) 1st Offense \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	Paving LLC Project Owner: Homeowner Other: ROBINSON PLUMBING	8611 Cascade Road, in Upper Macungie Township, Lehigh County. A gas line owned by UGI Utilities was damaged. UGI reported an excavator issue as failed to provide One Call System with exact information to identify the work site, and failed to use prudent techniques in the tolerance zone. UGI stated in their Alleged Violation Report (AVR), "Robison Plumbing has a Pa One Call Ticket for this work site. They hired Skrip Paving to dig their trench. Skrip Paving did not have a PA One Call Ticket for this work site. When Skrip was digging they struck a correctly marked gas service facility creating a damage and a leak. Skrip was piggybacking off of Robison Plumbing PA One Call Ticket." On Tuesday, 5/26/2026, letters and emails were sent requesting AVR's from Skrip Excavating and Paving LLC, Robinson Plumbing; the project manager, and the Homeowner. Robinson Plumbing, Inc submitted their AVR on Tuesday, 6/2/2026, reporting an excavator issue as failed to request the location and type of facility owner thru the One Call System 3-10 business days in advance of beginning the work. Robinson Plumbing stated in their AVR, "We hired Skrip Paving to dig for a sewer line repair, Skrip paving failed to call in a PA One Call. While digging Skrip Paving hit a gas line. The serial number 20260753385 was called in by Robinson Plumbing for estimating purposes only." Skrip Excavating and Paving, LLC submitted their AVR on Thursday, 6/4/2026, reporting an excavator issue as failed to protect and preserve the markings after beginning excavation, or contact the One Call System to request the facilities be marked again. Skrip Excavating and Paving stated in their AVR, "Skrip Paving & Excavating was hired by Robinson Plumbing to excavate for work on a sewer line. Upon arrival the site was marked with flags showing all utilities. Upon excavation the gas line was struck, due to UGI flag being moved or painted lines being disturbed. 911 was called as well as UGI. Unaware that we could not use the PA One Call done by Robinson Plumbing, a One Call was made under Skrip Paving, serial #20260902557." UGI provided photos of the damage line. PA One Call compliance commented, contractor Skrip Paving has placed One Call notifications with PA One Call in the past. Robinson Plumbing placed an excavation insufficient ticket, 20260753385 on 3/16/2026, for sewer line repair, with lawful start dates 3/19/2026 – 3/31/2026. UGI reported that the damage occurred at 10:17am. Skrip Excavating and Paving placed an excavation emergency ticket after the damage, 20260902557, at 11:55am, with type of work as digging for sewer line replacement.	Section 5(22) 1st Offense \$500.00 Section 5(16) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, definition: "Emergency" means a sudden or unforeseen occurrence involving a clear and immediate danger to life, property and the environment, including, but not limited to, serious breaks or defects in a facility owner's lines. The Underground Utility Line Protection Law (UULPL) aka PA One Call Law, ACT 127, Responsibilities Of The Excavator, Section 5(16) states: To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. The report of an alleged violation shall be in a form and manner as required by the commission. Violations: Scrip Excavating and Paving, LLC is in violation of sections: 5(2.1) – Excavator failed to submit a location request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. 5(22) – Excavator provided a misrepresentation of an emergency excavation 20260902557 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalties applied. For section 5(16) zero penalty but keep the violation. PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
63531	Facility Owner: LEBANON CITY OF Contractor/Excavator: JMF Underground INC. Project Owner: UGI Utilities	On 4/1/2026 11:50:00 AM at MARY ST, LEBANON CITY, LEBANON Incident occurred on April 1st, 2026, at 11:50am along Mary Street, Lebanon City, Lebanon County. Incident: An emergency ticket was placed for a non-emergency. Alleged Violation Reports (AVR): Facility Owner - City of Lebanon's AVR states, "Inappropriate use of emergency one call to avoid 3 days wait. Installation of a gas service is not an emergency" Excavator - JMF Underground's AVR states, "JMF was dispatched to 15 E Maple street to run new gas service to this residence, there electric source of heat had failed and needed to get a gas service ran to their house to hook up their new heating source. This was during winter months where it was cold outside and heat was very important to have." Project Owner - UGI's AVR states, "JMF working for UGI to install a gas service. This property previously had electric heat, which failed, the homeowner needed emergency service to connect their new heating system.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		This was a no heat situation, so the emergency was justified." Alleged conclusion: Emergency ticket 20260912769, "Location Information WE WILL BE INSTALLNG NEW GAS SERVICE TO 15 E MAPLE STREET COMING OFF OF MARY STREET GOING THROUGHT THE REAR OF YARD TO HOUSE 15 E MAPLE ST." UGI's email claims this was a regulatory requirement for a no heat situation after the customer's electric heat failed. No violation.	
64488	Facility Owner: SERVICE ELECTRIC CABLE TV INC Contractor/Excavator: Core Structures Inc	<u>On 4/1/2026 12:00:00 PM at 6270 Martin Dr, Zionsville, UPPER MILFORD TWP, LEHIGH</u> The incident occurred on Wednesday, April 1, 2026, at 6270 Martin Drive, in Upper Milford Township, Lehigh County. A communication line owned by Service Electric Cable Tv Inc. No tickets associated with this case. Service Electric Cable Tv reported an excavator issue as failed to request the location and type of facility owner thru the One Call System 3-10 business days in advance of beginning the work. Service Electric Cable Tv stated in their Alleged Violation Report (AVR), "On 4/1/2026, Core Structures Inc was digging without a PA One Call and damaged a Service Electric Cable TV distribution coax cable. Location was at 6270 Martin Dr, Zionsville, PA." Thursday, 6/4/2026 a letter and email were sent requesting an AVR from the contractor, Core Structures Inc. Core Structures submitted their AVR on 6/9/2026, reporting an excavator issue as failed to request the location and type of facility owner thru the One Call System 3-10 business days in advance of beginning the work. Core Structures stated in their AVR, "Was told by the owner that the new pole building that we were constructing was put in a location to avoid all underground utilities. The digging to strip topsoil and create a building pad was done prior by someone else that the owner hired. I do not know whom that was. I was under the assumption that either the owner or his excavator had done a one call to locate the building prior to us being there. I was wrong, and I hit an underground cable line in the last set of holes that I dug with a skidsteer and auger attachment. We ended up moving the building back even further than the customer had already moved it to avoid the undergrounds when we discovered that he was mistaken. So the new building was moved back 3' away from the original location and away from the cable line." Violations: Core Structures Inc is in violation of sections:	Core Structures Inc: \$1,000.00 Section 5(2.1) 1st Offense \$1,000.00 Section 5(16) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		5(2.1) – Excavator failed to submit a location request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalties applied. For section 5(16) zero penalty but keep the violation. PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
63989	Facility Owner: PECO AN EXELON COMPANY Contractor/Excavator: J F KIELY CONSTRUCTION Project Owner: PECO AN EXELON COMPANY	<u>On 4/1/2026 3:00:00 PM at CHURCH RD, CHELTENHAM TWP, MONTGOMERY</u> PECO violation and penalty have been removed. ***** The incident occurred on Wednesday, April 1, 2026, at 353 Church Road, in Cheltenham Township, Montgomery County. A gas line owned by PECO an Exelon Company was damaged. PECO, the project and facility owner, reported an excavator issue as failing to use prudent techniques in the tolerance zone. PECO stated in their Alleged Violation Report (AVR) and attached investigated report, "on 4/1/26, at 353 Church Rd, J F Kiely Construction was using a backhoe to excavate for new gas main and services, when they severed a half inch plastic gas service that was not marked. Facility not marked due to Locator error marked inaccurately." J F Kiely Construction reported a facility owner issue as marked incorrectly. J F Kiely Construction stated in their AVR, "unmarked gas service was hit at 353 Church Road." Violation: PECO an Exelon Company is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalty applied	PECO AN EXELON COMPANY: \$0.00
63740	Facility Owner: ALTOONA WATER AUTHORITY WATER DIVISION Contractor/Excavator: BLAIR EXCAVATING COMPANY INC Project Owner: DelGrosso Foods Inc Designer: KELLER ENGINEERS Other: THE ORR GROUP, INC	<u>On 4/6/2026 12:00:00 PM at 198 KRISTEL LN, ANTIS TWP, BLAIR</u> The incident occurred on Monday, April 6, 2026, at 198 Kristal Lane, in Antis Township, Blair County. A water line owned by Altoona Water Authority Water Division was damaged. Altoona Water Authority Water Division reported an excavator issue as failed to exercise due care and take all reasonable steps necessary to avoid interference with the water line. Altoona Water stated in their Alleged Violation Report (AVR), "on April 06, 2026 a contractor, Blair Excavating, contacted Altoona Water Authority on call foreman, Eric Fleck, for the location 198 Kristel Ln, Tyrone PA (Delgross's sauce plant). The call was made due to contractor hitting an A.W.A A Eight inch water main."	BLAIR EXCAVATING COMPANY INC: \$500.00 Section 5(6)(ii) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Blair Excavating, Inc. reported an excavator issue as failed to exercise due care and take all reasonable steps necessary to avoid interference with the water line. Blair Excavating stated in their AVR, "The waterline was marked. The waterline was hit by accident by an experienced employee that took reasonable steps to avoid any damage. There was a large rock that was less than 12 inches away from an 8 inch ductile waterline. The excavator bucket slipped on the rock and hit the waterline. The damage was approximately a 1 inch hole in the waterline. Delgrosso Foods work was not interrupted due to the waterline damage. Our downtime was due to waiting until the end of Delgrosso Foods workday." The Orr Group, Inc was the general contractor, stated in their AVR, "Waterline was clearly marked with paint. Our Subcontractor, Blair Excavating Company, hit the water line. There was large rock that was less than 12 inches from an 8 inch ductile waterline. The excavator bucket slipped on the rock and hit the waterline. The damage was an approximate one (1) inch hole in the waterline. Delgrosso Foods work was not interrupted due to the waterline damage." KELLER ENGINEERS, and representing the project owner, DelGrosso Foods, Inc stated in their AVR, "Blair Excavating, acting as subcontractor to JC Orr, bumped and damaged an Altoona Water Authority main while installing a new gravity sewer line from the DelGrosso factory to a proposed pretreatment facility. The water main was marked and excavated, but a slip of the excavator bucket caused contact with the active pipe. AWA was alerted to the damage and arrived to make the repair. Operations at the factory were partially impacted for the day while repairs were made. Work on the sewer resumed the following day." Violation: Blair Excavating, Inc. is in violation of section: 5(6)(ii) – Excavator failed to provide support and mechanical protection for known facility owner's lines at the construction work site. Recommendation: Penalty applied and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
63704	Facility Owner: National Fuel Gas Contractor/Excavator: Sallot Concrete Inc	On 4/7/2026 11:00:00 AM at 8279 MOREHOUSE RD, GREENE TWP, ERIE Incident occurred on April 7th, 2026, at 11am on 8279 Morehouse Road, Greene Township, Erie County . Incident: Excavator began working prior to legal start date. Alleged Violation Reports (AVR): Facility Owner - National Fuel Gas' AVR states, "Excavator working prior to lawful start date. Field personnel advised the excavator of the PA One Call Law	

Case Number	Stakeholders	Summary	Violations & Recommendation
		of waiting the required 3 days. Excavator told National Fuel personnel that he didn't care about legal dig dates.” AVR submission date: 4/7/26 20260930023 - Lawful Start Dates--[08-Apr-26] thru [17-Apr-26] Response Due Date--[07-Apr-26] Scheduled Excavation Date--[08-Apr-26] Dig Time--[0800] Duration--[2 DAYS] Method of Excavation--[POWER EQUIP] Equip Type--[MINI EXCAVATOR] Alleged conclusion: Ticket had a lawful start date of 4/8/26. AVR was completed on 4/6/26 and the images are date stamped 4/7/26. Pictures show tread marks from machinery but no active digging. Excavator claims hand tools only in their emails. Googlestreet view shows a compacted dirt area was dug up.	
64102	Facility Owner: PECO Project Owner: Whitemarsh Township Designer: GILMORE ASSOCIATES Other: Ash Associates Other: N ABBONIZIO CONTRACTORS INC Other: VERIZON Other: Whitemarsh Township Authority	On 4/9/2026 9:43:00 AM at 4112 HAIN DR, <u>WHITEMARSH TWP, MONTGOMERY</u> PECO disagreed but accepted the section 2.5.i violation and the 2.5.ix violation with the penalty. Violation section 2(5)(v) is withdrawn for not responding to ticket 20260860232000, since PECO responded to the ticket, but did not mark out completely and were called out to remark. Ticket 20260860232001 had a response due by April 8 and PECO did not respond to this ticket until 4/09/2026. And the excavator again asked PECO to come mark their lines correctly and completely in Ticket 20260860232002. On 7/31/2026 and email was received from PECO accepting the violations for 2(5)(v) for 20260860232-001 and the second 2(5)(i). ***** The incident occurred on 4/09/2026 at 4112 Hain Dr. In WHITEMARSH TWP in MONTGOMERY Co. A gas service line owned by PECO was damaged. N ABBONIZIO CONTRACTORS INC stated in their Alleged Violation Report (AVR) that, “While excavating for new storm sewer in front of 4112 Hain Drive, we again were given two separate markings for a gas service at this address. The actual gas service was found 3 feet away from the closest mark at the curb line and 8 feet away from the second gas mark.” Project is listed at >\$400,000. With a length of 2,000. Sq ft. They added that, “This is one of many instances on Hain Drive on this project where PECO left multiple marks for single services at each address because they were unsure of their actual location”. Pictures were provided. Whitemarsh Township, the project owner, is represented by Gilmore and Associates. See email named “Gilmore is representing Whitemarsh Twp”. GILMORE AND ASSOCIATES INC, the designer, stated in their AVR that, “While excavating for new storm sewer in front of 4112 Hain Drive, we again were given two separate markings for a gas service at this	PECO: \$6,000.00 Section 2(5)(i) Subsequent \$2,000.00 Section 2(5)(ix) 1st Offense \$1,000.00 Section 2(5)(v) Subsequent \$1,000.00 Section 2(5)(i) Subsequent \$2,000.00 Whitemarsh Township: \$500.00 Section 6.1(3) 1st Offense \$500.00 GILMORE ASSOCIATES: \$1,000.00 Section 4(2) 1st Offense \$500.00 Section 4(4.1) 1st Offense \$500.00 VERIZON: \$8,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00 Whitemarsh Township Authority: \$750.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		address. The actual gas service was found 3 feet away from the closest mark at the curb line and 8 feet away from the second gas mark. ON 5/04/2026 DPI Maki sent an email asking if the designer was provided the information about the unlocatable gas service lines. An email was received from Gilmore and Associates stating that they submitted AVR's for PECO. Multiple AVR's were provided. All of the AVR's have different dates, times and do not show that they are a Representing agent for PECO. DPI recommended reaching out to PAOne call to update the information and sent snippets of how to fill out the AVR form. PECO was sent an AVR request letter on 4/24/2026. Peco stated in their AVR that, "On 4/8/2026, N Abbonizio Contractors Inc damaged a gas service using a track hoe." 911 was not notified. Grid Hawk investigation report was provided. In the investigation report it states that the gas line was severed in half before test holing was done. After reviewing the pictures in the report, DPI Maki found that the address and the area in the pictures did not match. On 6/11/2026, DPI Maki sent an email asking if PECO had any other pictures to provide and showed a snippet of the discrepancy found with the pictures in the report. On 6/18/2026 PECO responded that, "It's the house to the left of where you took is where the damage was. The damage photos show the house on each side of the damage. The other mark out photos seem to around the neighborhood." Please see email with picture named "house on left" ***Investigations related by ticket numbers: 63892 and 63984. VIOLATIONS PECO is in violation of: -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. RNO remark: [ATTN PECO CALLER STATES THAT MULTIPLE ADDRESSES HAVE TWO TO THREE SETS OF MARKINGS PER ADDRESS BUT ONLY ONE OF THE MARKINGS IS IN LINE WITH THEACTUAL SERVICE. CALLER IS REQUESTING YOU REPORT TO THE SITE ASAP TO VERIFY THE MARKINGS.] This is a subsequent offense. -Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. The excavator submitted another renotify ticket asking PECO to help locate the gas lines. [ATTN PECO AN EXELON COMPANY, YOU RESPONDED AS FIELD MARKED, BUT THE CALLER STATES THAT WHEN THE LOCATOR ARRIVED TO THE SITE YESTERDAY, THEY SAID THAT THEY COULD NOT MARK THE LINES AND THAT THE CONTRACTOR WOULD HAVE TO REACH OUT TO PECO DIRECTLY. THE LINES AT THIS SITE STILL NEED VERIFIED. THERE ARE UNMARKED AND	Section 2(5)(v) 1st Offense \$250.00 Section 2(5)(v) 1st Offense \$250.00 Section 2(5)(v) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		INCORRECTLY MARKED LINES AT THE SITE. PLEASE REVERIFY AND REMARK AS SOON AS POSSIBLE. THANK YOU.] This is a subsequent offense. -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260860232-000 was submitted by N ABBONIZIO CONTRACTORS INC on 3/27/2026 with a response due by 3/31/2026. PECO responded “field Marked” on 4/08/2026and again on 4-09-2026. This is a subsequent offense. -Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260860232-001 was submitted by N ABBONIZIO CONTRACTORS INC on 4/08/2026 with a response due by 4/08/2026 RNO remark: [ATTN PECO CALLER STATES THAT MULTIPLE ADDRESSES HAVE TWO TO THREE SETS OF MARKINGS PER ADDRESS BUT ONLY ONE OF THE MARKINGS IS IN LINE WITH THEACTUAL SERVICE. CALLER IS REQUESTING YOU REPORT TO THE SITE ASAP TO VERIFY THE MARKINGS.] PECO responded “field Marked” on 4/08/2026and again on 4-09-2026.This is a subsequent offense. Ticket 20260860232-002 was submitted by N ABBONIZIO CONTRACTORS INC on 4/09/2026 with a response due by 4/09/2026. RNO Remarks--[ATTN PECO AN EXELON COMPANY, YOU RESPONDED AS FIELD MARKED, BUT THE CALLER STATES THAT WHEN THE LOCATOR ARRIVED TO THE SITE YESTERDAY, THEY SAID THAT THEY COULD NOT MARK THE LINES AND THAT THE CONTRACTOR WOULD HAVE TO REACH OUT TO PECO DIRECTLY. THE LINES AT THIS SITE STILL NEED VERIFIED. THERE ARE UNMARKED AND INCORRECTLY MARKED LINES AT THE SITE. PLEASE REVERIFY AND REMARK AS SOON AS POSSIBLE. THANK YOU.]. Incident occurred on 4/09/2026. PECO responded on 4/09/2026. -Section 2(5)(ix) – Facility owner failed to respond promptly to the site of an excavation where its underground line was damaged. Emergency ticket 20260992298-000 was submitted on 4/09/2026 at 11:30 by N ABBONIZIO CONTRACTORS INC. RNO Remarks : [THE LINE WAS 3-5FT OFF OF MARK. CALLER IS UNSURE IF THE LINE WAS DAMAGED OR NOT.FACILITY TYPE: NATURAL GAS-PECO EXCAVATION EQUIPMENT: EXCAVATOR HAZARDOUS RELEASE: YES CALLER HAS NOTIFIED 911.] Emergency renotify ticket20260992298-001 was submitted by N ABBONIZIO CONTRACTORS INC. on 4/09/2026 at 16:01. Emergency ticket 20260992298-002 was submitted by N ABBONIZIO CONTRACTORS INC. on 4/13/2026. RNO Remarks-- [SPECIAL ATTN TO PECO CALLER NEEDS A REPRESENTATIVE FROM PECO TO GO TO THE SITE ASAP TO VERIFY IF THIS IS AN ACTIVE LINE THAT HAS BEEN EXPOSED. PLEASE CONTACT ED AT 6102758540 WITH ANY QUESTIONS. THE LINE WAS EXPOSED 3-5FT OFF	

Case Number	Stakeholders	Summary	Violations & Recommendation
		THE MARKINGS. THIS IS THE 2ND RENOTIFICATION. CALLER STATES YOU ARE HOLDING THEIR WORK SCHEDULE. THANK YOU] Recommendation: The penalties are applied. PUC compliance education has been recently completed. GILMORE ASSOCIATES are in violation of: -Section 4(2) – Designer failed to request the line and facility information prescribed by section 2(4) from the One Call System not less than ten nor more than ninety business days before final design is to be completed. No Final Design ticket was submitted. -Section 4(4.1) - Failed to depict lines or facilities with the appropriate quality levels based on the complexity of the design and construction activities obtained through the SUE process in the planning and design phases in accordance with the American Society of Civil Engineers (ASCE) most recently published standard CI/ASCE 38. Recommendation: The penalties are applied. PUC compliance education is required for the designer(s) who worked on this project or their replacement(s). Whitemarsh Township is in violation of: -Section 6.1(3) – Released a project to bid or construction before final design was complete. Recommendation: The penalty is applied. PUC project owner compliance education is required for the person responsible for submitting AVR or their replacement. White March Township Authority -Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260141852 was submitted by N ABBONIZIO CONTRACTORS INC on 1/14/2026 with a response due by 1/16/2026. Whitemarsh Township Authority responded “field marked” late, on 1/20/2026 -Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. Ticket 20260860232-000 was submitted by N ABBONIZIO CONTRACTORS INC on 3/27/2026 with a response due by 3/31/2026. Whitemarsh Township Authority did not respond until 4/07/2026. -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260651136 was submitted by N ABBONIZIO CONTRACTORS INC on 3/06/2026 with a response due by 3/10/2026Whitemarsh Township Authority did not respond “Field Marked” until 3/13/2026. Recommendation: The penalties are applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). *White March Township Authority was required to take the PUC required education by 7/14/2025. This has not been completed as of 6/11/2026. Verizon is in violation of: -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260141852 was submitted by N ABBONIZIO CONTRACTORS INC on 1/14/2026 with	

Case Number	Stakeholders	Summary	Violations & Recommendation
		a response due by 1/16/2026. Verizon never responded. This is a subsequent offense. -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260490347 was submitted by N ABBONIZIO CONTRACTORS INC on 2/18/2026 with a response due by 2/20/2026. Verizon never responded. This is a subsequent offense. -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260651136 was submitted by N ABBONIZIO CONTRACTORS INC on 3/06/2026 with a response due by 3/10/2026. Verizon never responded. This is a subsequent offense. -Section 2(5)(v) – Failed to respond to a routine One Call ticket. Ticket 20260860232 was submitted by N ABBONIZIO CONTRACTORS INC on 3/27/2026 with a response due by 3/31/2026. Verizon never responded. This is a subsequent offense. Recommendation: The penalties are applied. PUC compliance education has been recently completed.	
64126	Facility Owner: Peoples Natural Gas Contractor/Excavator: Mele & Mele & Sons Project Owner: Pittsburgh Water Other: JOHNSON MIRMIRAN AND THOMPSON	<u>On 4/20/2026 2:40:00 PM at ELLA ST, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 4/20/2026, at approximately 2:40 PM, on Ella St, in Pittsburgh City, Allegheny County. A gas line owned by Peoples Natural Gas was damaged. The facility was notified / not notified of the damage. Peoples Natural Gas is the facility owner. Their Alleged Violation Report (AVR) states, “ Mele and Mele and Sons working for Pittsburgh Water struck and damaged s Peoples Gas service line at 220 Ella St.” Mele And Mele And Son is the excavator. Their AVR states, “Laborer hand digging to find gas service line and hit line with shovel (small leak). 2:45pm Superintendent (Shane) of Mele called People's Gas Co. (did not call 911 due to small leak and Peoples Gas Co. close by). 2:50pm People's Gas Co. showed up 3:30pm People's Gas Co repaired line on off site.” No images or documents were submitted by Mele. Pittsburgh Water & Sewer is the project owner. Their AVR states the same as Mele and Mele’s AVR. Johnson Mirmiran And Thompson is the designer. Their AVR states the same thing as Mele and Mele’s AVR and adds the following, “PNG provided records do not show location of service lines. Service line approximate location was shown on the drawings as per the survey delineation provided to JMT. Gas curb box shown on plans as per survey”. Images submitted show the site, excavation, marks, and damaged line. Mechanical excavation occurred within the tolerance zone of yellow marks, and the damaged line. 911 was not contacted upon escape of flammable gas. Violations: Excavator - Mele And Mele And Son:	Mele & Mele & Sons: \$2,000.00 Section 5(4) 1st Offense \$500.00 Section 5(8) 2nd Offense \$1,500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Section 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid which endangers life, health, or property. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
64290	Facility Owner: Peoples Natural Gas Contractor/Excavator: A. Folino Construction, Inc. Project Owner: Pittsburgh Water	<u>On 4/22/2026 9:20:00 AM at 2921 NORWOOD AVE, PITTSBURGH CITY, ALLEGHENY</u> The incident occurred on 4/22/2026, at approximately 9:20 AM, on 2921 Norwood Ave, in Pittsburgh City, Allegheny County. A gas line owned by Peoples Natural Gas was damaged. An emergency ticket was entered for the damage by the excavator 1.5 hours after the damage. Peoples Natural Gas is the facility owner. Their Alleged Violation Report (AVR) states, “On 4/22/2026, A FOLINO CONSTRUCTION INC was digging on a insufficient one call for restoration of roadway at 2921 Norwood Ave when they struck a PNG SL (main to curb) in front of 2911 Norwood Ave. Folino was digging outside the scope of their one call ticket.” A Folino Construction is the excavator. Their AVR states, “A. Folino Construction was digging in front of 2921 Norwood Ave to prep to pour new road base when we hit a gas service line. 911 was called and a damage ticket was made through 811. Peoples Gas responded and claimed the line as theirs. Peoples Gas had a crew come out and make the repairs.”. Pittsburgh Water is the project owner. Their AVR states, “A. Folino Construction was digging in front of 2921 Norwood Ave to prep to pour new road base when we hit a gas service line. 911 was called and a damage ticket was made through 811. Peoples Gas responded and claimed the line as theirs. Peoples Gas had a crew come out and make the repairs.” Damage occurred at 9:20AM on 4/22/2026, as reported by the excavator. An emergency ticket was then entered by the excavator at 10:47, and an insufficient excavation ticket was entered at 10:52AM. The excavator was working without a ticket when the damage occurred. Images show the site, excavation, mechanized equipment, and damaged line. Violations: Excavator - A Folino Constructio: Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area.	A. Folino Construction, Inc.: \$2,250.00 Section 5(2.1) 3rd Offense \$2,000.00 Section 5(6)(i) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
64254	Facility Owner: PEOPLES NATURAL GAS COMPANY LLC Contractor/Excavator: NIANDO CONSTRUCTION INC Project Owner: ROBINSON TOWNSHIP MA Designer: NIRA CONSULTING ENGINEERS INC Other: Verizon PA LLC	On 4/22/2026 11:45:00 AM at <u>WEST HARBISON ROAD, ROBINSON TWP, ALLEGHENY</u> The incident occurred on Wednesday, April 22, 2026, near 5063 West Harbison Road, in Robinson Township, Allegheny County. A gas line owned by Peoples Natural Gas Company (PNG) was damaged. PNG reported issues of the facility owner as marked incorrectly, and the of the excavator as failed to immediately notify 911 and the facility owner if damage results in the escape of any flammable, toxic, or corrosive gas or liquid. PNG stated in their Alleged Violation Report (AVR), “Niando Construction working for Robinson Water struck and damaged an unmarked Peoples Gas line near 5063 W Harbison.” Niando Construction, Inc reported a facility owner issue as marked incorrectly. Niando Construction stated in their AVR, "hit an unmarked main gas line at the intersection of West Harbison Road and Windover Drive. The gas company admitted that their line was not marked." The project owner, Robinson Township Municipal Authority stated in their AVR, “Niando Construction struck an unmarked Main Gas Line at the intersection of West Harbison Road and Windover Drive.” Nira Consulting Engineers stated in their AVR, “Niando Construction struck an unmarked Peoples Gas main at the intersection of West Harbison Road and Windover Drive in Robinson Township, Allegheny County, PA.” Routine ticket, 20260894513, placed on 3/30/2026. No response from Verizon PA LLC, response due date was 4/1/2026, they responded late on 4/9/26 as field marked. Violations: *Peoples Natural Gas Company is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260894513 Recommendation: Penalty applied *Niando Construction, Inc is in violation of section: 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid. Recommendation: Penalty applied and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements. *Verizon PA LLC is in violation of section: 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20260894513	PEOPLES NATURAL GAS COMPANY LLC: \$2,000.00 Section 2(5)(i) Subsequent \$2,000.00 NIANDO CONSTRUCTION INC: \$1,000.00 Section 5(8) 1st Offense \$1,000.00 Verizon PA LLC: \$1,000.00 Section 2(5)(v) Subsequent \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
64266	Facility Owner: PECO AN EXELON COMPANY Contractor/Excavator: BRUBACHER EXCAVATING INC Project Owner: AQUA PENNSYLVANIA INC Designer: GFT INFRASTRUCTURE, INC.	Recommendation: Penalty applied <u>On 4/23/2026 8:00:00 AM at VALLEY VIEW LN, TREDYFFRIN TWP, CHESTER</u> The incident occurred on Thursday, April 23, 2026, on Valley View Lane, in Tredyffrin Township, Chester County. Two gas lines were damaged. Damage One: Damage Emergency ticket, 20261130655, placed at 8:25, 2-inch steel gas line was damaged. Remarks-attention PECO energy the caller states the crew on site hit a 2in dia steel gas line which was not marked. there is no gas blowing. please respond asap and contact Casey Ogg at his with any questions. Facility type: natural gas-PECO energy. Excavation equipment: excavator. Hazardous release: no. PECO responded as Clear No Facilities Brubacher Excavating, Inc. reported a facility owner issue as marked incorrectly. Brubacher Excavating stated in their Alleged Violation Report (AVR), While excavating the trench for new water main installation on Knox Rd project, the crew encountered an unmarked gas line. A 2" diameter steel conduit was found at 3'- 6" deep. The excavation was in the street at the intersection of Knox Rd and Valley View Ln. The work was being performed for Aqua PA. Original Ticket #20260684522 and the damage ticket #20261130655. PECO an Exelon Company reported a facility owner issue as missing or incorrect facility line maps or records. PECO stated in their AVR, "On 4/23/26, BRUBACHER EXCAVATING INC was using an excavator to install a water main when they struck an unmarked PECO 2" steel gas main. On 4/23/26, USIC was notified of a hit gas line on Valley View Ln in Tredyffrin Township, Chester County, PA. The investigation determined that the contractor BRUBACHER EXCAVATING INC was using an excavator to install a water main under ticket# 20260684522 when they hit an unmarked Exelon 3/4" steel gas service. Andrew with PECO and Paula with USIC both agree this line is abandoned." AQUA reported a facility owner issue as marked incorrectly. Aqua stated in their AVR, Aqua Contractor Brubacher Excavating, while excavating the trench for new water main installation on Knox Rd project, the crew encountered an unmarked gas line. A 2" diameter steel conduit was found at 3' 6" deep. The excavation was in the street at the intersection of Knox Rd and Valley View Ln. Gannett Fleming, Inc. reported a facility owner issue as marked incorrectly. Gannett Fleming stated in their AVR, Aqua Contractor Brubacher Excavating crew, while excavating the trench for new water main installation on Knox Rd project, encountered an	PECO AN EXELON COMPANY: \$0.00 Section 2(5)(i) 2nd Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		unmarked gas line. A 2" diameter steel conduit was found at 3' 6" deep. The excavation was in the street at the intersection of Knox Rd and Valley View Ln. GFT as a designer was not involved with construction phase of this project. GFT was not involved in the bidding of this project, and therefore does not know if any modifications were made to the bid documents/final design package provided by Aqua to the Contractor. GFT was not on site and had no knowledge of the incident until it received an email notification by PA One Call Compliance Coordinator on Saturday May 9th, 2026. GFT is submitting this AVR in compliance with its requirements under Act 50, and based on information provided to GFT by Aqua. Damage Two: Damage Emergency ticket, 20261130844 placed at 8:50am, 1-inch steel gas line was damaged. Remarks-attention PECO energy the caller states the crew on site hit a 1in dia steel gas line which was not marked. There is no gas blowing. please respond asap and contact Casey at his cell with any questions. Facility type: natural gas-PECO energy. Excavation equipment: excavator. Hazardous release: no PECO responded as Clear No Facilities. Brubacher Excavating, Inc. reported a facility owner issue as marked incorrectly. Brubacher Excavating stated in their AVR, While excavating the trench for new water main installation on Knox Rd project, the crew encountered an unmarked gas service. A 1" diameter steel conduit was found at 2' - " deep. The excavation was in the street at 610 Valley View Ln. The work was being performed for Aqua PA. Original Ticket #20260684522 and the damage ticket #20261130844. PECO stated in their AVR, "PECO was not aware of this damage. Submitting Alleged Violation Report per request from PUC." AQUA reported a facility owner issue as marked incorrectly. Aqua stated in their AVR, Aqua Contractor Brubacher Excavating, while excavating the trench for new water main installation on Knox Rd project, the crew encountered an unmarked gas service. A 1" diameter steel conduit was found at 2' deep. The excavation was in the street at 610 Valley View Ln. Gannett Fleming, Inc. reported a facility owner issue as marked incorrectly. Gannett Fleming stated in their AVR, Aqua Contractor Brubacher Excavating crew, while excavating the trench for new water main installation on Knox Rd project, encountered an unmarked gas service. A 1" diameter steel conduit was found at 2' deep. The excavation was in the street at 610 Valley View Ln. GFT as a designer was not involved with construction phase of this project. GFT was not involved in the bidding of this project, and therefore	

Case Number	Stakeholders	Summary	Violations & Recommendation
		does not know if any modifications were made to the bid documents/final design package provided by Aqua to the Contractor. GFT was not on site and had no knowledge of the incident until it received an email notification by PA One Call Compliance Coordinator on Saturday May 9, 2026. GFT is submitting this AVR in compliance with its requirements under Act 50, and based on information provided to GFT by Aqua. Violation: PECO an Exelon Company is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260684522 Recommendation: Zero penalty but keep the violation. PECO responded as Clear No Facilities to both. Line was abandoned.	
64386	Facility Owner: Home Owner Contractor/Excavator: Leinbach Excavating Project Owner: BRECKNOCK BUILDERS Other: PENNSYLVANIA AMERICAN WATER	<u>On 4/23/2026 10:30:00 AM at 2257 LINCOLN AVE, SPRING TWP, BERKS</u> The incident occurred on 4/23/2026, at 9:55 AM, on 2257 Lincoln Ave, in Spring Twp, Berks County. A water line owned by Jed Holzmacher was damaged. No routine ticket was found for this excavation, but an Emergency ticket was entered for the damage. A routine ticket was entered after the damage by the project owner. Jed Holzmacher is the homeowner whose line was damaged when the excavator was doing work for him. An Alleged Violation Report (AVR) was not filed as of 04/30/2026 and an AVR request was sent the same day. Leinbach Excavating is the excavator that entered the damage ticket that states, “CALLER STATES THEY HIT A WTR LINE AND HE IS CURRENTLY ONSITE”. An AVR was not filed as of 04/30/2026 and an AVR request was sent the same day. No AVR was submitted. BRECKNOCK BUILDERS submitted an AVR on May 12th that states, “Digging in a new waterline from the street to the house, were digging down on both sides of the shutoff sleeve. The excavator hit the existing waterline with the corner of his bucket, causing the shutoff to break loose. PA American Water was immediately notified; they were out within half an hour and soon had a new shutoff installed we had done a PA ONE call earlier at this project (20251672925)”. No images or documents were provided with the AVR. Brecknock was contacted and provided more information in a timely fashion. Only Leinbach was excavating for this incident, and Brecknock was the project owner. PENNSYLVANIA AMERICAN WATER submitted an AVR that states, “This was a private Customer service that was damaged. Owned by the customer on private property. No PAWC involvement. No one was called in for initial work.” No images were submitted.	Leinbach Excavating: \$750.00 Section 5(6)(i) 1st Offense \$250.00 Section 5(2.1) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Leinbach was excavating at the site during the incident. Brecknock is the project owner, as they employ Leinbach as a 1099 contractor. No tickets were entered prior to the damage occurring. A demolition ticket was entered on 06/16/2025 for a week duration by Brecknock. Leinbach entered a damage/emergency ticket on 04/23/2026 for the water damage, and Brecknock entered a routine at 1:50PM after the damage. The incident that occurred was to install new service as indicated on the routine ticket. Violations: Excavator - Leinbach Excavating: Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. This violation is reduced from \$1000 to \$500 as a first time offense. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
64352	Facility Owner: UGI Contractor/Excavator: Rogele, Inc. Project Owner: Capital Region Water Other: Herbert Rowland & Grubic Inc (HRG) Other: PPL	<u>On 4/27/2026 9:30:00 AM at DERRY ST, HARRISBURG CITY, DAUPHIN</u> PPL provided additional information. PPL penalty on 2(5)(i) violation on is removed. UGI stated that the repaired line was not due to damage from the incident. The case is moved to a non-damage case. ***** The incident occurred on 4/27/2026, at approximately 9:30 AM, on Derry St, in Harrisburg City, Dauphin County. A gas line owned by UGI was damaged. A ticket was entered to report a mis-marked gas line, and to determine if the line was still live. The line was then determined to be live by UGI. UGI is the facility owner. An Alleged Violation Report (AVR) was not filed as of 06/12/2026 and an AVR request was sent the same day. UGI was on scene for this incident, as indicated in the images provided. No AVR was submitted within 30 business days, which was on was 6/9/2026. Rogele Inc is the excavator. Their AVR states, “There were two gas services marked by UGI in the area of house #1511 Derry Street. While digging by hand within the tolerance zone of the first mark, we uncovered a line that appeared to be covered in a gray conduit. Rogele did not damage or strike the line. We could not tell who the owner of the line was or if the line was live, so I contacted PA One Call. I told the operator that we uncovered a line and would like the facility owners to return to the site to determine what it was and if it was still live. The serial number from that call is 20261171655. If the line was no longer live, we would	UGI: \$2,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Section 2(10) 1st Offense \$1,000.00 Capital Region Water: \$500.00 Section 2(5)(i) 1st Offense \$500.00 PPL: \$0.00 Section 2(5)(i) Subsequent \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		like for it to be removed from our trench. UGI came to the site and determined it was their service line. UGI thought the service was abandoned. UGI tested the service line and found that it was still live. UGI then made a repair to the service line. There was no service found at the second UGI mark. Rogele did not damage or strike the UGI service line. Rogele is submitting this AVR as required because the project owner submitted an AVR.” Capital Region Water is the project owner. Their AVR states, “The Contractor Rogele Inc unearthed a 1" gas service line. There were no markings where this line was located. They called for UGI to respond to the project site to confirm if it was an old service. UGI Field Rep arrived at 11:05am, checked records and believed the service to be an old service. A second UGI field rep arrived and they believed it was ok to cut the service line out of the way. At 11:20am UGI field rep cut the 1" service line and determined it was still active. They called for a supervisor/inspector to the site. At 11:30am supervisor/inspector Nathan Dobb arrived. He advised the markings were off approx. 10' and also the UGI computer records were not accurate. At 12:17pm UGI completed the repair. The Contractor down time hours were 11:00am to 12:20pm. If more”. Herbert Rowland And Grubic Inc is the designer. Their AVR states, “The Contractor (Rogele Inc) unearthed a UGI 1" gas service line. There were no markings where this line was located. They called for UGI to respond to the project site to confirm if it was an old service. UGI Field Rep arrived at 11:05am, checked records and believed the service to be an old service. A second UGI field rep arrived and they believed it was ok to cut the service line out of the way. At 11:20am UGI field rep cut the 1" service line and determined it was still active. They called for a supervisor/inspector to the site. At 11:30am supervisor/inspector Nathan Dobb arrived. He advised the markings were off approx. 10' and also the UGI computer records were not accurate. At 12:17pm UGI completed the repair. The Contractor down time hours were 11:00am to 12:20pm.” Ticket # 20261103545 was the New – Excavation – Routine ticket for this excavation and was entered on 4/20/26 at 2:19 PM. The response due date was 4/26/2026. Capital Region Water, and PPL responded “Field Marked” on 4/27/2026. The lines were not marked within the time limits required under 2(5)(i) of Act 127 of 2024. Section 2(5)(i) of Act 127 states, “After receipt of a timely request from an excavator or operator who identifies the work site of excavation or demolition work he intends to perform and not later than the business day prior to the lawful start date of excavation: To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall	

Case Number	Stakeholders	Summary	Violations & Recommendation
		of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines.” Images submitted show the site, excavation, marks, and gas line. The images support the statements in the AVRs that the marks were not within the tolerance zone of the line. As there was an emergency ticket to notify the utilities of a mismarked line, and there was a release of hazardous gas when UGI cut the underground utility line, an AVR was required to be submitted by UGI. Violations: Facility – UGI: Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). PUC online Compliance Training is required for the person responsible for submitting AVRs, or their replacement. Facility (other) -Capital Region Water Section 2(5)(i) – Failed to TIMELY locate underground lines within 18 inches horizontally of the outside wall of line. Ticket # 20261103545 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) – PPL Section 2(5)(i) – Failed to TIMELY locate underground lines within 18 inches horizontally of the outside wall of line. Ticket # 20261103545 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
64761	Facility Owner: PENNSYLVANIA AMERICAN WATER Contractor/Excavator: G & B CONSTRUCTION GROUP INC Project Owner: Yardley Borough Designer: REMINGTON VERNICK ENGINEERS	<u>On 5/5/2026 9:15:00 AM at 154 N Main Street, YARDLEY BORO, BUCKS</u> The incident occurred on Tuesday, May 5, 2026, at 154 N. Main Street, in Yardley Borough, Bucks County. A water line owned by PA American Water Company (PAWC) was damaged. G&B Construction reported a facility owner issue as marked incorrectly. G&B Construction stated in their Alleged Violation Report (AVR), "G&B Construction was digging in the roadway to install stormwater pipe	PENNSYLVANIA AMERICAN WATER: \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		and inlets. An unmarked water line was struck and damaged." PAWC reported a facility owner issue as missing or incorrect facility line maps or records. PAWC stated in their AVR, "Received an emergency 1 call alert (pa20261251196) at 9:38am 05-05-2026. About a struck water service that was unmarked. PAWC arrived on scene and seen that a unmarked Water valve was struck. Water was gushing out of the valve head. According to our records (maps, gis, mapcall, and old files) this is an abandoned 4inch cast iron main. The cast iron main used to run down main street between Cold Springs and McKinley. while looping thru Cold Springs around to Jervue coming back across main street and running along the edge of the road way same side of the roadway as the 12inch ductial iron pipe that runs all the way to Dolington and Taylorsville. PAWC employees went around turning all the valves between Taylorsville and Dolington all the way to Wayfaring Lane. by 2:30 we were able to finally relieve the pressure to a manageable level for Caddick to cut out the old valve and section of pipe that was being fed. we were able to verify that the 4inch cast iron valve was only being feed from Jervue or the 6inch cast iron main on the opposite side of the road. Caddick capped the pipe around 5:30 pm. PAWC turned back on the rest of the shut valves verifying that there was no longer a leak or any issues and the repair was good." In the submitted photos with active water release from the damaged line, no blue mark outs are seen. PAWC water also noted in there AVR that when they arrived on scene and they saw an unmarked water valve was struck. Yardley Borough, the project owner and Remington Vernick Engineers both reported a facility owner issue as marked incorrectly. They stated in their AVR's, "On the morning of 5/5/2026 at approximately 9:15am, the contractor (G&B Construction) struck a water valve at 154 N Main Street, while excavating to install new stormwater piping. The valve was said to be unmarked, and G&B had performed multiple test pits throughout the roadway as called out within the plans. PA American Water was informed after the strike and were on site all day but were unable to isolate and shut down the line. The Design used SUE levels D and C, above ground survey and utility drawings to locate the utility on the project plans, the plans also noted SUE level A, test pits, in case of unknown utilities locations." Violation: PA American Water Company is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalty applied	
64842	Facility Owner: NATIONAL FUEL GAS Contractor/Excavator: F	<u>On 5/5/2026 10:10:00 AM at 35 VAN WOERT ST,</u> SYKESVILLE BORO, JEFFERSON The Non-Damage violation occurred on Tuesday, May 5, 2026, at 35 Van Woert Street, in Sykesville Borough, Jefferson County.	F M SMEAL ENTERPRISES: \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	M SMEAL ENTERPRISES	National Fuel Gas (NFG) reported a non-damage violation, an excavator issue as began excavation work before the lawful start day that was on the ticket, 20261241110. NFG stated in their Alleged Violation Report (AVR), Excavator had a ticket with a lawful start date of May 7th, on May 5th an NFG employee arrived onsite to perform the mark out and discovered the excavator was already working. Digging had taken place in direct conflict with NFG facilities. The excavator refused to stop working and became very confrontational and continued working after NFG left the site. NFG provided photos. Routine ticket, 20261241110, placed on 5/4/2026, with response due date of 5/6/2026, and lawful start dates of 5/7/2026 - 5/18/2026. On Wednesday, 5/13/2026 a letter and email were sent requesting an AVR from F. M. Smeal Enterprises. They submitted their AVR on 6/4/2026. F. M. Smeal Enterprises reported an excavator issue as began excavation work before the lawful start day that was on the ticket, 20261241110. F. M. Smeal Enterprises stated in their AVR, Scrapped off grass, dumped shale for a new driveway. No damage occurred. Violation: F. M. Smeal Enterprises is in violation of section: 5(2.1) - Began excavation work before the lawful start day (on ticket). 20261241110 Recommendation: Penalty applied and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	Section 5(2.1) 1st Offense \$1,000.00

Full Session

Case Number	Stakeholders	Summary	Violations & Recommendation
62139	Facility Owner: WESTMORELAND CO MUNI AUTH Contractor/Excavator: MORGAN EXCAVATING LP Project Owner: WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY Designer: BANKSON ENGINEERS INC Other: Peoples Natural Gas Company Other: WASHINGTON TOWNSHIP of WESTMORELAND CO	<u>On 1/19/2026 2:15:00 PM at KING ARTHUR DR, WASHINGTON TWP, WESTMORELAND</u> On Tuesday, September 15, 2026, at the All Virtual DPC meeting, disputing parties and voted as: Morgan Excavating LP- Remove violation, Washington Twp. Municipal Authority- NO SHOW, Accept the DPI's recommendations and \$250 to 2(5)(v) ticket 20260060717 for NO SHOW. Peoples Natural Gas- Accept the DPI's recommendations ***** Washington Township's penalty was reduced to a warning. This is their first time ever before the DPC. and they have agreed to education. ***** Dispute- Morgan Excavating LP (email Friday, 6/19/26) stated, "Morgan Excavating LP would like to reject the DPI Report and present our case before the DPC." *****	MORGAN EXCAVATING LP: \$0.00 WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY: \$1,000.00 Section 2(5)(v) 1st Offense \$500.00 Section 2(5)(v) 1st Offense \$250.00 Section 2(5)(v) 1st Offense \$250.00 Peoples Natural Gas Company: \$1,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Dispute- WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY is disputing and they stated, To the best of my knowledge, I have responded to the one call system in a timely manner. I am fully aware and prepared to attend the online training, but I would like to appeal the penalty fees to have this reviewed, reduced and possibly waived as this is my first offensive. ***** Dispute- PNG is disputing and stated, Violation 2(5)(vii) is respectfully disputed, as the ticket in question was not related to damaged gas facilities as stated on the ticket by the caller, Kyra Morton. The caller specifically indicated that the damage involved a water line, and a review of our records confirms that we have no gas facilities located on this section of Kung Arthur Dr., but we received the notification due to the buffer zone. Peoples Natural Gas' dispatch center did respond to the request within an appropriate timeframe being notes and acknowledging this damage was not gas related; however, a Karl response was not entered. While we acknowledge this administrative oversight, it did not impact public safety or delay response to gas-related emergency notifications, as no such gas facilities were present or affected. For this above reasons and highlighted attached one call ticket, Peoples Natural Gas respectfully asks for violation 2(5)(vii) be waived. ***** The incident occurred on Monday, January 19, 2026, on King Arthur Drive, in Washington Township, Westmoreland County. A water line owned by Westmoreland County Municipal Authority (MAWC) was damaged. Morgan Excavating reported a facility owner issue as marked incorrectly. Morgan Excavating stated in their Alleged Violation Report (AVR), "Hit a 6" Water Main while digging out for a catch basin. Marks were 2.5 feet off." MAWC reported an excavation issue as failed to protect and preserve the markings or request another remark. MAWC stated in their AVR, "Excavator Morgan Excavating was working for Project Owner Municipal Authority of Washington Township to install new storm sewer facilities. Morgan placed POCS damage ticket 20260191383 stating that they struck a Municipal Authority of Westmoreland County (MAWC) water facility. MAWC responded and observed that that blue flags that were placed to locate the water main were no longer visible, possibly obliterated during the construction process. Morgan excavated the MAWC main, MAWC placed a repair clamp on its damaged main. MAWC feels its original marks were accurate, and the excavator should have used prudent techniques to locate the MAWC water main"	Section 2(5)(vii) 1st Offense \$1,000.00 WASHINGTON TOWNSHIP of WESTMORELAND CO: \$0.00 Section 2(5)(vii) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Washington Township Municipal Authority, the project owner, stated in their AVR, "Morgan Excavating hit a 6" Water Main while digging out for a catch basin." Bankson Engineers, the designer stated in their AVR, "Contractor hit a 6" watermain while digging out for a catch basin. Marks were 2.5 feet off." MAWC provided photos showing blue locate markings over the snow and there are some blue flags (Westmoreland MA pic1, pic7, pic8); the photos do not show the size of facility. MAWC did not indicate the size of the water line; therefore, Morgan Excavating could not establish a tolerance zone. Morgan Excavating provided photos of the damaged water line with the hit-kit, and up to the hit-kit and damage there are no visible blue locate marks; tickets were called in for remarks. Morgan Excavating first photo appears that a blue flag is missing (Morgan Excavating- Hit Water Main Pictures) 20260191383- Damage Emergency ticket placed on 1/19/2026. Late Response on 1/20/26 from- Washington Twp of Westmoreland Co and PNG 20260060717- Routine ticket placed on 1/6/2026. Washington Twp MA responded Scheduled Mark did not finalize response with Field Mark or Clear No Facilities. 20253421070- Routine ticket placed on 12/8/2025. Washington Twp MA responded Scheduled Mark did not finalize response with Field Mark or Clear No Facilities. 20253171230- Routine ticket placed on 11/13/2025. Washington Twp MA responded Scheduled Mark did not finalize response with Field Mark or Clear No Facilities. Violations: *Morgan Excavating is in violation of section: 5(3) – Excavator failed to preserve mark-outs Recommendation: Zero penalty but keep violation with PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements. *Washington Township of Westmoreland County is in violation of section: 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260191383 Recommendation: PUC Online Compliance Training is required for the Individual(s) responsible to respond to locate for this ticket, or their replacement(s). *Peoples Natural Gas is in violation of section:	

Case Number	Stakeholders	Summary	Violations & Recommendation
		2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. 20260191383 Recommendation: Penalty applied *Washington Township Municipal Authority is in violation of sections: Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20260060717 Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20253421070 Section 2(5)(v) – Failed to respond to a routine One Call ticket within the required amount of time. 20253171230 Recommendation: Penalties applied and PUC Online Compliance Training is required for the Individual(s) responsible to respond to locates for these tickets, or their replacement(s).	
66205	Facility Owner: LOWER PAXTON TOWNSHIP AUTHORITY Contractor/Excavator: Everhart and Hoover Powerline Construction Inc Project Owner: PPL ELECTRIC UTILITIES CORPORATION	On 2/2/2026 7:00:00 AM at Multiple locations on TYLER DR, LOWER PAXTON TWP, DAUPHIN On 9/15/ 2026 the Damage Prevention Committee (DPC) voted to remove the violation to Everhart and Hoover. Everhart and Hoover are disputing violation section (11.2). They accept violation section 5(16) with the \$1000. penalty reduced to a warning and violation section 5(7) with the penalty of \$1000. reduced to a warning, but for the record respectfully disagree with the findings. They did not want to discuss either of these 2 violations. Everhart and Hoover accept and will complete the recommended PUC compliance education for its excavation personnel regardless of how the counts are resolved. They added that "We appreciate your guidance on the treatment of service laterals and will apply it going forward." ***** The 2 incidents occurred on about 2/02/2026 on TYLER DR in LOWER PAXTON TWP in Dauphin Co. A new 18" HDPE storm pipe was damaged in two places and a private lateral service at 6059 was also damaged. Everhart and Hoover were hired to install PPL electric 3PH Main on Tyler Dr. Tickets include the area from Burgandy Rd to Springlake Rd. This area includes the address ranges of 5881 through 6059 Tyler Dr. 6059 is the site of the damage of the private lateral service. LOWER PAXTON TOWNSHIP AUTHORITY stated in their Alleged Violation Report (AVR) that "I am submitting an AVR because our new 18" HDPE storm pipe, installed in 2023, was damaged during a project performed by PPLs sub Everhart and Hoover this past winter 2026. The Authority's pipe was damaged in two locations on Tyler Dr in Lower Paxton Township. One area of damage Everhart and Hoover is claiming responsibility, the other area they are not. They also hit a private sanitary sewer service lateral at 6059 Tyler Dr and did not contact the Authority for an inspection to repair properly. I spoke with Eva Maki to confirm an	Everhart and Hoover Powerline Construction Inc: \$0.00 Section 5(16) 1st Offense \$0.00 Section 5(7) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		AVR should be submitted. Unsure of date when damaged. Notes from meeting with Everhart and Hoover: Melissa Smith is disputing that the damage between station 0+37 and 0+49 was an installation issue. The storm sewer installation was inspected at the time of installation with no defects noted, however, the storm sewer was not televised after the backfill was placed and compacted. Melissa stated her opinion that the proximity and depth of the water service strike suggest the storm sewer damage occurred at the same time and was caused by the boring head impacting the pipe. Damage to other utilities: Sanitary Sewer: The service lateral at 6059 Tyler Dr was damaged. LPTA was not contacted for an inspection of the repair or notified that it had happened. Everhart and Hoover repaired the lateral with schedule 40 pipe, which is not permitted per the Authority's standard specifications. Sewer laterals are private and not marked by LPTA. Water: The water service at 5929 Tyler Dr was damaged as noted above. Contractor indicated that it was mismarked in the field. Veolia repaired this service. Verizon: Contractor indicated that Verizon FiOS lines had also been hit as they were mismarked in the field. See also attachment named "Tom Novy response to minutes" where they state that they hit the rod that goes down to the water pipe on Tyler Dr. No specific address was mentioned in this email. An email was received on 7/02/2026 stating that "As I was walking the site with Tom Novy of Everhart and Hoover pointing out sinkholes in the street and other damage to the curbs and sidewalks, he informed me that they hit the lateral pipe to 6059 Tyler Drive and repaired it. LPTA was not informed of the hit, so we were not onsite for the repair." Everhart and Hoover were sent an AVR request letter asking about the damage to storm pipe. Everhart and Hoover submitted an AVR with a violation date of 2/02/2026. They stated in their AVR that, "We were excavating and boring a 6 inch smooth wall conduit from PPL Pole 26851S35704 to PPL Pole 27116S35856 along entire length of Tyler Drive Paxtonia. We also installed 3 manholes along Tyler Drive. We were working for PPL under Work Order # 13057508. Work began in November of 2025. Everhart and Hoover added that "Lower Paxton Authority did not respond to complex ticket. Did not respond to any one calls." An email was received from Everhart and Hoover on 7/02/2026 that stated that "The township did not show up for the complex meeting. They also didn't locate the sewer laterals. We did are best locating the laterals. Talking to homeowners if they know where there lines are. The township will not locate the laterals. So after doing all we could to find the laterals. We started the bore. We did hit the one lateral at 6059 Tyler Dr.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Since the township considered where we it the line it is the homeowners responsible. The township didn't locate the laterals. The sewer lateral we hit with the drill.I had the vac truck exposed the line . I talked to the home owners and they were ok with them for use to do the repair. We did the repair with schedule 40 pipe . PPL was sent an AVR request letter on 6/29/2026 asking about the damaged storm pipe. Due to the statute of limitations, this case was completed without waiting on the AVR from PPL for this incident. PPL did fil out AVR's for the other incidents that occurred on this project. PPL send in an AVR stating that “Everhart and Hoover was boring to replace primary when they struck a sewer line owned by Lower Paxton Sewer Authority. PPL Electric Utilities was not made aware of this sewer line damage until the receipt of this AVR Request.” *Complex Project ticket 20252920156 was submitted by EVERHART AND HOOVER on 10/19/2025 with a response due by 10/22/2025. The work site is listed to be on Tyler Drive in Lower Paxton Township. This is expecte3d to be a 6 mo project. Lower Paxton Township Authority responded to this ticket that they were “Clear. No facilities or facilities not involved.” *Ticket 20252973430 was submitted by EVERHART AND HOOVER on 10/24/2025 with a response due by 11/02/2025. The site is marked in white. LPTA responded “Filed Marked” on 10/27/2025. *Ticket 20253081349 was submitted by EVERHART AND HOOVER on 11/04/2025 with a response due by 11/06/2025. Lower Paxton Authority responded Scheduled mark on 11/06/2025 and field marked on 11/11/2025. **AVR's for the telecom cable are included in this case. VIOLATIONS Everhart and Hoover are in violation of: Section 5(11.2) – When using trenchless technology, Excavator failed to utilize at a minimum, the best practices published by the Common Ground Alliance. Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or damaging a facility owner’s line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. AVR that was not filed within 30 days when the service lateral was damaged at 6059 Tyler Dr. ACT 50 reads: To submit a report of alleged violation to the commission through the One Call System not more than 30 days after striking or damaging a facility owner’s line during excavation or demolition or if the excavator believes a violation of this act had been committed in association with excavation or demolition	

Case Number	Stakeholders	Summary	Violations & Recommendation
		work. The report of alleged violation shall be in a form and manner as required by the commission. How much damage occurred cannot be verified, but in the meeting minutes from 6-22-26 Evenhart and Hoover took responsibility for the damage caused by the boring machine at Station 1+20. They will replace this section of pipe. See attachment named "Meeting minutes from 6-22-26 onsite meeting Tyler Dr." An AVR should have been submitted for this damage within 30 days of its occurrence. Meeting minutes (see attachment named " Meeting Minutes from 6-22-26 onsite meeting Tyler Dr") stating that. "As I was walking the site with Tom Novy of Everhart and Hoover pointing out sinkholes in the street and other damage to the curbs and sidewalks, he informed me that they hit the lateral pipe to 6059 Tyler Drive and repaired it. LPTA was not informed of the hit, so we were not onsite for the repair." CGA 22.0 glossary of Terms and Definitions describes the Facility Owner / Operator: Any utility, municipality, authority, political subdivision, or other person or entity who owns, operates, or controls the operation of an underground facility. Section 5(7) – Failed to immediately report to the facility owner any break or leak in its lines, or any dent, gouge, groove, or other damage to such lines or to their coating or cathodic protection. Emergency ticket 20260282566 was submitted on 1/28/2026 stating that Everhart and Hoover damaged a mismarked fiber service. An AVR2026JAN290008 was filed for this incident. Recommendation: The penalties are applied. PUC compliance education is required for the excavators working onsite of this excavation or their replacements.	
62695	Facility Owner: UGI UTILITIES INC Contractor/Excavator: J MEDINA CONSTRUCTION LLC Project Owner: Property Owner	On 2/6/2026 4:00:00 PM at 252 N WASHINGTON ST, WILKES BARRE CITY, LUZERNE On Tuesday, September 15, 2026, at the All Virtual DPC meeting, disputing was J. Medina Construction and it was voted to Accept the DPI's recommendations ***** Disputing- J. Medina Construction LLC- "We believe there are significant facts and evidence that warrant further review, including the existence of a valid Pennsylvania One Call ticket, the presence of utility markings at the work site, and the involvement of an underground gas service line that was not marked and was later determined to serve an adjacent property." ***** The incident occurred on Friday, February 6, 2026, at 252 N. Washington Street, in Wilkes Barre, Luzerne County. A gas line owned by UGI Utilities was damaged. UGI reported an excavator issue as failed to provide accurate location information of the work site, failed to notify 911 and the facility owner of damage and gas leak, and failed to renotify the One Call System of any unmarked or incorrectly marked facility. UGI stated in their Alleged Violation Report (AVR), "Excavator struck and damaged an unmarked gas facility while	J MEDINA CONSTRUCTION LLC: \$2,500.00 Section 5(2.2) 1st Offense \$250.00 Section 5(7) 1st Offense \$1,000.00 Section 5(8) 1st Offense \$1,000.00 Section 5(20) 1st Offense \$250.00 Section 5(16) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		digging outside the scope of the ticket. Ticket stated work would be done in private front of address 254 N Washington St. Damage occurred at rear property 252 N Washington St. Excavator left after damaging gas facility, excavator did not notify UGI or 911. UGI received a phone call from the property owner of 252 N. Washington St. for a gas odor complaint. Upon investigation by UGI it was determined the facility had been struck by an unknown excavator. The only information we have for the potential excavator is the ticket that was called in for the front address (254 N. Washington St.). That ticket number has been attached to this AVR.” “Service was not marked due to area in question not being in scope of ticket.” UGI provided pictures of locate marks in front of 254 N. Washington Street, and the damaged gas line at the rear of the house. Routine ticket, 20260271016, placed on 1/27/2026, duration of 3 days, Work Site--[254 N WASHINGTON ST], Type of Work--INSTL NEW WTR LINE, Pvt Prop--[X], Other--[] Private Front--[X] Rear--[] Left--[] Right--[] J. Medina Construction did not place a new ticket indicating that excavation will take place at the rear of the house. After the incident they placed a routine, 20260722038 and a damage emergency, 20260722049, ticket. On Monday, 4/20/2026 a letter and an email were sent to J. Medina Construction LLC requesting an AVR. Their AVR was submitted on 4/30/2026 with pictures. J. Medina Construction reported an excavator issue as failed to use the color white to mark a proposed excavation work site when exact work site information cannot be provided. J. Medina Construction stated in their AVR, (see attachments- J Medina Construction summary add info, and J Medina Construction-Response_Full_Photos). “J. Medina Construction LLC respectfully submits this Alleged Violation Report in response to the request from the Pennsylvania Public Utility Commission regarding an incident involving a gas line operated by UGI Utilities Inc.” “Prior to commencing excavation work, J. Medina Construction LLC fully complied with Pennsylvania One Call (811) requirements and obtained Ticket #20260271016 (see attached confirmation). The work location was clearly identified as 254 N Washington St, Wilkes-Barre, PA, and the site was marked accordingly.” “Utility markings were present at the job site and identified a gas line corresponding to the work location. J. Medina Construction relied on these markings in good faith.” “The project involved the installation of a new sewer line. During excavation within the marked work area, an	

Case Number	Stakeholders	Summary	Violations & Recommendation
		additional underground gas line was encountered that had not been marked or identified prior to excavation.” “This unmarked gas line was not the same line that had been previously marked. It was later determined that this line was supplying natural gas service to the adjacent property located at 252 N Washington St, and not the property associated with the permitted excavation.” “Additionally, this gas line was observed to cross beneath a fence line and extend into the neighboring property. This routing was not marked, not disclosed, and not reasonably identifiable prior to excavation.” “Due to the absence of markings for this specific line and lack of prior knowledge of its existence, the gas line was inadvertently struck.” “Upon occurrence, work was immediately stopped and safety measures were taken, including shutting off the gas flow to mitigate any potential hazard. No injuries occurred.” “J. Medina Construction LLC did not contact 911; however, the resident promptly notified UGI Utilities Inc., who responded to the site and completed the necessary repairs.” Responses to Requested Information: 1. Photos/Documents: Supporting documentation includes: *Pennsylvania One Call ticket confirmation (Ticket #20260271016) *Photographs taken after repair by UGI Utilities Inc. *Photographs of the site and fence line showing property separation and utility routing context Photo Explanation: *The excavation photos were taken after the incident during and following repair activities by UGI Utilities Inc. These images are provided to demonstrate site conditions, excavation depth, soil conditions, and the presence of multiple underground utilities. *No visible markings indicating the presence of the affected gas line are observed in the work area. *Additional photos show the fence line separating the properties. The gas line that was struck was later identified as crossing beneath this fence and supplying service to the adjacent property (252 N Washington St). This routing was not marked and not reasonably identifiable prior to excavation. 2. Was the line marked within the tolerance zone? No. The gas line that was struck was not marked within the work area. A different gas line corresponding to the job location had been marked. 3. Was the facility owner notified? Was 911 notified? The facility owner was notified by the resident. 911 was not contacted. 4. Did the facility owner respond to repair the line? Yes. UGI Utilities Inc. responded and completed repairs. 5. Was a complex project ticket placed? No.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		6. What was the total length of the project? [Insert if available or write "N/A"] 7. What was the total cost of the project? \$3,500. 8. Why wasn't exact location information provided on the One Call ticket? The work location was accurately provided as 254 N Washington St. The gas line that was struck was not associated with this service location and was not disclosed or reflected in the markings provided. 9. Did J. Medina Construction call 911 immediately after the incident? If not, who did? No. The resident contacted the utility provider. 10. Did J. Medina Construction contact UGI Utilities after the incident? No. UGI Utilities Inc. was contacted immediately by the resident and responded. 11. Why was no damage ticket placed through PA One Call? At the time of the incident, there was a lack of awareness regarding the requirement to submit a damage ticket. 12. Why was the Alleged Violation Report not submitted within 30 days? The delay was due to lack of knowledge of the reporting requirement and administrative oversight. Corrective measures have since been implemented to ensure full compliance moving forward. 13. Summary of what led to the incident: J. Medina Construction LLC initiated excavation after obtaining a valid 811 ticket and relying on the markings provided. During excavation, an unmarked gas line—separate from the marked utility and serving an adjacent property—was encountered and inadvertently struck due to lack of prior identification. 14. Additional Information: J. Medina Construction LLC acted in good faith, followed all required pre-excavation procedures, and relied on the markings provided. The incident resulted from the presence of an unmarked underground facility whose routing—crossing property boundaries and a fence line—was not disclosed or reasonably identifiable prior to excavation. Violations: *J. Medina Construction LLC is in violation of sections: 5(2.2) – Excavator failed to provide exact information to identify the worksite. 20260271016 5(7) – Failed to immediately report to the facility owner any break or leak in its lines, or any dent, gouge, groove, or other damage to such lines or to their coating or cathodic protection. 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid. 5(20) – Excavator failed to renotify One Call of an unmarked or incorrectly marked facility upon arrival at a	

Case Number	Stakeholders	Summary	Violations & Recommendation
		work site. (The routine ticket was placed to locate in front of the house. The contractor provided photos of excavation located in the rear of the house, facility owners did not get notified for a remark to locate in the rear.) 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line. Recommendation: Penalties applied, but for section 5(16) zero penalty but keep the violation, and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	
62612	Facility Owner: Breezeline Contractor/Excavator: WILSON EXCAVATING - A LINDY GROUP COMPANY Project Owner: Peoples Gas Company Designer: EADS GROUP Other: MARIANNA WEST BETH JOINT SEWAGE AUTH Other: WEST BETHLEHEM TOWNSHIP	<u>On 2/13/2026 1:01:00 PM at BEALLSVILLE RD, WEST BETHLEHEM TWP, WASHINGTON</u> On 9/15/2026 the DPC voted to: Motion by Haupt to: Marianna West Beth Joint Sewage Authority- 2(5)(v.2)- accept the DPI's recommendation and add additional \$250 penalty for not attending the DPC meeting Not in attendance West Bethlehem Township- 2(5)(v.2)- accept the DPI's recommendation and add additional \$250 penalty for not attending the DPC meeting Not in attendance ***** MARIANNA WEST BETH JOINT SEWAGE AUTH and WEST BETHLEHEM TOWNSHIP are disputing ***** Incident occurred on February 13th, 2026, at 1:01pm along Beallsville Road, West Bethlehem Township, Washington County. An unmarked Breezeline telecom line was damaged by Wilson Excavating. Excavator - Wilson Excavating's Alleged Violation Report (AVR) states, "Wilson Excavating was performing work for Peoples Gas at 2235 Beallsville Road when an unmarked Breezeline cable service was struck with an excavator. Facility owner notified." Project Owner - Peoples Gas Company's AVR states, "Wilson Excavating was performing work for Peoples Gas at 2235 Beallsville Road when an unmarked Breezeline cable service was struck with an excavator. Facility owner notified." Facility Owner - Breezeline was mailed and emailed a request for an AVR on 4/6/26. Breezeline responded that per their management they are not involved. Please see AVR request follow up document that show the PUC is still requesting an AVR.	Breezeline: \$2,000.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(10) 1st Offense \$1,000.00 Section 2(11) 1st Offense \$500.00 MARIANNA WEST BETH JOINT SEWAGE AUTH: \$500.00 Section 2(5)(v.2) 1st Offense \$500.00 WEST BETHLEHEM TOWNSHIP: \$500.00 Section 2(5)(v.2) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Designer The EADS Group's AVR states, "The EADS Group received the first notification of the alleged utility strike on April 7th, 2026 when a Notice of Pending AVR report was sent to Susan Daugherty. No other notification was sent to the EADS Group that an alleged utility strike occurred. No EADS employees were on site to witness the alleged utility strike. During the preliminary & final design Breezeline/Atlantic Broadband (HEL) noted on the POCS responses 001-CLEAR. NO FACILITIES OR FACILITIES NOT INVOLVED BASED ON TICKET INFORMATION. Prelim and final design tickets are included in the AVR. SUE level D was completed for the project based on the field markings and design maps received from utility owners. The contractor was not paid to use soft digging technologies. Breezeline noted that their facilities were clear from the project area so telecom drops were not identified during the design phase." Google Streetview shows addresses within ticket 20260291079 have underground lines running to them. Breezeline's website shows that some of these addresses are current customers. Breezeline responded clear no facilities to ticket 20260291079. Breezeline responded by email, but no AVR has been filed. Ticket 20260291080 had a "no response" from Marianna West Bethlehem Joint Sewage Authority along with a "no response" followed up by a late clear response on 2/5/26 by West Bethlehem Township. Recommended violations, penalties, and education: Breezeline Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260291080 Section 2(10) – Facility owner failed to submit an Alleged Violation Report through the One Call System within 30 business days after receipt of notice that the facility owner’s lines have been damaged by excavation or demolition work or if the facility owner believes a violation of this act has been committed in association with excavation or demolition work. Section 2(11) – Facility Owner failed to comply with all requests for information by the Commission relation to the Commission’s enforcement authority under this act within thirty days of the receipt of the request. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). -PUC compliance education is required for the person responsible for submitting AVR or their replacement. Marianna West Bethlehem Joint Sewage Authority Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260291080. -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Original \$250 plus \$250 for not attending for a total of \$500.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		West Bethlehem Township Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260291080 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Original \$250 plus \$250 for not attending for a total of \$500.	
62822	Facility Owner: COMCAST Contractor/Excavator: CARP EXCAVATING Project Owner: Property Owner Other: PECO	On 2/16/2026 11:00:00 AM at 725 W CURRY DR, WHITPAIN TWP, MONTGOMERY On 09/15/2026, The Damage Prevention Committee (DPC) voted to keep Carp Excavating's violations and penalties. An additional \$250 penalty was added to violation 5(16) for Carp Excavating not attending the DPC meeting. Carp Excavating was not in attendance at the 09/15/2026 DPC meeting. ***** Carp Excavating is disputing. Peco's penalty amount reduced. They submitted additional documentation with date and timestamps to show they had responded timely to the tickets. The responses were not reflected in the Karl system due to a technology issue. ***** The incident occurred on February 16th, 2026, at approximately 11:00 AM, at 725 West Curry Drive, located in Whitpain Township, Montgomery County, Pennsylvania. A cable TV line owned by Comcast was damaged. Comcast, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “Dug before due date. Summation on Liability: This damage occurred at 725 W Curry Dr, Blue Bell, Pa and this damaged cable line was due to Carp Excavating digging on an invalid ticket.” Photos were submitted. Carp Excavating is the excavator. An AVR request letter was sent on 04/03/2025. An AVR was not filed until 05/20/2026. Their AVR states, "There was a cable line marked out behind the curb we had to dig up to for a new construction home tie in. There was also a transformer we had to install so excavation was needed for that. The cable line was marked in the wrong location. I understand that the location is not always correct, but the person who marked everything out was most certainly not experienced due to the fact of how far off the mark out was and marking out a transformer as live when we did not even install it yet as a picture of it sitting on a pallet. The original cable line was a direct bury and was pulled apart when we dug it up because it was above the freeze line and was frozen into the piece of dirt we pulled up. We then called the utility company to come repair it after we exposed all of the other lines around it. During backfill shortly after the repair a clump of frozen dirt rolled down into the hole and once again	CARP EXCAVATING: \$1,750.00 Section 1.1 1st Offense \$1,000.00 Section 5(16) 1st Offense \$750.00 PECO: \$500.00 Section 2(5)(vii) 1st Offense \$250.00 Section 2(5)(vii) 1st Offense \$250.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		comprised the same utility line that was just repaired. We then called the utility company again to come out and fix it but was not able to make it out that day. We left everything exposed so that he could make his repair." The property owner is the project owner. An AVR has not been filed as of 05/08/2026. Routine ticket 20260430532 had a lawful start date of 02/18/2026 (2 days after the damage occurred). The scheduled excavation date listed on the ticket was 02/18/2026. The excavation was started prior to the lawful start date. The damage occurred prior to Comcast being able to mark their lines for this ticket. (Comcast responded to this ticket prior to the response due date, but after the damage occurred.) The same line was damaged a second time on 02/18/2026. The emergency ticket for the damage stated, "A Comcast Cable line was damaged yesterday and was repaired. However, when backfilling, a rock came out of the bucket and broke the repair again."" Emergency ticket 20260471116 had a response due date of 02/16/2026. - Peco did not respond to this ticket. Emergency ticket 20260493287 had a response due date of 02/19/2026. - Peco did not respond to this ticket. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: - The lawful start date shall be three business days through ten business days following notification to the One Call System. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. - To comply with all requests for information by the commission relating to the commission's enforcement authority under this act within thirty days of the receipt of the request. Violations: Carp Excavating- - Section 1.1 – Excavator did not begin within legal timeframe. - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been	

Case Number	Stakeholders	Summary	Violations & Recommendation
		committed in association with excavation or demolition work. Recommendation: The penalty is reduced by 50% from \$1,000 to \$500 since the AVR was filed, but over 2 months after the incident. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s). PECO- - Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency Ticket 20260471116. Penalty amount reduced from \$1,000 to \$250.00. - Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification. Emergency Ticket 20260493287. Penalty amount reduced from \$1,000 to \$250.00. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
62540	Facility Owner: Pennsylvania American Water (PAWC) Contractor/Excavator: David J Woodhouse Project Owner: REDEVELOPMENT AUTHORITY OF THE COUNTY OF WASHINGTON Designer: REMINGTON AND VERNICK ENGINEERS INC Other: Columbia Gas	On 2/17/2026 2:30:00 PM at 543 W PIKE ST, CANONSBURG BORO, WASHINGTON On 9/15/2026 the Damage Prevention Committee voted on Columbia Gas' violation, 2(5)(v.2) remove violation and penalty ***** Columbia Gas disputing - their original dispute was that the "Conflict" response was a response that allowed no further doubt or dispute. On 7/9/2026 Columbia states the "Conflict" response, "was intended to clearly communicate to the excavator that the ticket remained under review and that further evaluation was required before a final determination could be provided." ***** The incident occurred on 2/17/2026, at 2:30 PM, on 543 W Pike St, in Canonsburg Boro, Washington County. A water line owned by Pennsylvania American Water was damaged. Pennsylvania American Water is the facility owner. An Alleged Violation Report (AVR) was not filed as of 03/23/2026 and an AVR request was sent the same day. An AVR was submitted that states, "Customer owned service line was struck during demolition activities for 543 W Pike St in Canonsburg PA." David J Woodhouse is the excavator. An AVR was not filed as of 03/23/2026 and an AVR request was sent the same day. An AVR was submitted that states, "In process of a building demo at 543 west pike st, canonsburg pa and hit a water line inside the building, water company never shut it off or located the curb box. immediately called pa american water and noftified them that the water was running and had not been shut off and they came out and shut it off after calling in their crew to dig up and terminate line. No damage was done."	David J Woodhouse: \$250.00 Section 5(6)(i) 1st Offense \$250.00 Columbia Gas: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Redevelopment Authority Of The County Of Washington is the project owner. Their AVR states, “Contractor for the Redevelopment Authority was working on a demolition at 543 West Pike Street Canonsburg, PA and hit an active waterline within the confinement of the building pad. Pennsylvania American Water and Verizon responded when the contractor hit the water line. Pennsylvania American Water failed to turn the water off at the curb box, our contractor believes they were unable to locate and access the curb box/valve prior to demolition.” Remington And Vernick Engineers Inc is the designer. An AVR was not filed as of 03/23/2026 and an AVR request was sent the same day. An AVR was submitted that states, “Contractor called and notified RVE of a water line rupture while removing concrete floor of previously demolished building structure located at 543 W Pike St in Canonsburg, PA. Contractor notified PA American as soon as the water line was encountered. PA American Water arrived on location dug down to access curb box that had been buried below the asphalt at the front of the property. Once curb box was exposed, it was corroded and inoperable to the point that the water company could not turn the water line off at this location. A secondary crew was dispatched to dig down upstream from the curb box, cut and cap the water line.” PA American Water submitted an AVR that states, “Customer owned service line was struck during demolition activities for 543 W Pike St in Canonsburg PA.” Ticket #20253081572 had a response due date of 11/17/2025. Columbia Gas responded “Conflict” on 11/14/2025 and “Clear” on 12/8/2025. Images submitted show the site, and that a water line was damaged during excavation as there is water actively spraying from the excavation site. PA American Water states in their AVR that this was a customer owned line. The excavator did not plan the excavation or demolition work to avoid damage to or minimize interference with facilities. Violations: Excavator - David J Woodhouse: Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. Facility - Columbia Gas: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket #20253081572	

Case Number	Stakeholders	Summary	Violations & Recommendation
		PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63008	Facility Owner: Columbia Gas Inc Contractor/Excavator: NEISWONGER CONSTRUCTION Project Owner: REDEVELOPMENT AUTHORITY OF THE COUNTY OF WASHINGTON Designer: LENNON SMITH SOULERET ENGINEERING INC Other: 79/70 Associates LLC Other: SOUTH STRABANE TOWNSHIP OF	<u>On 2/27/2026 9:35:00 AM at 301 OAK SPRING RD, SOUTH STRABANE TWP, WASHINGTON</u> Neiswonger Construction was a NO SHOW for the 9/15/2026 meeting. The Damage Prevention Committee (DPC) voted to Keep the violation and penalty as recommended and add a \$250. additional penalty for not attending the DPC meeting. Neiswonger Construction is disputing. *** On 9/15/2026 the Damage Prevention Committee (DPC) voted to Remove the violation and penalty. South Strabane Twp disagreed. ***** The incident occurred on 2/27/2026 at 301 OAK SPRING RD in SOUTH STRABANE TWP in Washington County. A gas distribution line owned by Columbia Gas was damaged. COLUMBIA GAS OF PA INC stated in their Alleged Violation Report (AVR) that, “ On Friday, February 27th, Neiswonger Construction was working a demolition project completing drainage work and struck a previously marked Columbia Gas 2" plastic mainline. Neiswonger provided a one call number that was from August 2025 for "demolition" and had not been updated since with their new scope of work. Columbia Gas and 911 were notified and responded. Plant crew made repairs to the facility and Columbia Gas locators remarked the remaining portion of the 2" gas main.” They added that, “ the Original locate was completed in August of 2025 for the demolition ticket. Since that time, demolition had started and drainage work as well that resulted in surface changes that eliminated existing marks.” 911 was notified. Neiswonger Construction was sent an AVR request letter on 3/23/2026. NEISWONGER CONSTRUCTION stated in their AVR that “While excavating for new storm line. A gas line was hit which was not located where one call showed it to be. 911 was notified. Project is >\$400,000. On 3/24/2026 DPI Maki sent an email to Neiswonger Construction asking how the marks were maintained and if there were any pictures with the mark out. No response has been received as of 5/19/2026. See attachment named “DPI asks Neiswonger Construction about marks.” REDEVELOPMENT AUTHORITY OF THE COUNTY OF WASHINGTON (RACW) was sent an AVR request letter on 3/23/2026. REDEVELOPMENT AUTHORITY OF THE COUNTY OF WASHINGTON stated in their AVR that, “Gas line strike at 301 Oak Spring Road, Washington PA 15301- Washington Mall Demolition Project”.	NEISWONGER CONSTRUCTION: \$2,000.00 Section 5(2.1) 1st Offense \$1,250.00 Section 5(3) 1st Offense \$250.00 Section 5(17) 1st Offense \$500.00 SOUTH STRABANE TOWNSHIP OF: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		LENNON SMITH SOULERET ENGINEERING INC (LSSE) stated in their AVR that “line strike while excavating a new storm sewer line”. A letter was provided with more details about the project including the bids for the project that were opened on May 16, 2025. Final Design ticket 20250973568 was given. This ticket states that the ticket is for structure demolition. On 6/09/2026 DPI Maki asked about 79/70 who was named in the AVR from LSSE. On 6/10/2026 LSSE sent an email explaining that, "79/70 Associates is the property owner re-developing the property. The Redevelopment Authority of Washington County is the holder of the Contract with the contractor to complete the demolition contract through blight mitigation founding". The letter also states that Construction Drawings and requests to mark the location of existing utilities were transmitted to Pennsylvania One Call respondents, via cover letter dated February 25, 2025. A utility coordination meeting was held on site on March 4th, 2025. There were no other design tickets or a complex project ticket submitted for this. LSSE states that level “C” and level ”D” Sue was utilized for this >\$400,000. Project. On 6/01/2026 DPI Maki sent an email to LSSE asking about any more tickets that may have been submitted for the complex project meeting or design. On 6/05/2026, DPI Maki returned a call to John from LSSE who stated that the project is still under demolition, primarily because 2 tenants have not moved out yet. John also confirmed that the construction has not yet started on this project. *Columbia Gas did not respond” filed marked” until 8/14/2025. West Penn Power did not respond “clear” until 8/25/2025. This information is noted, but no violations are cited for this due to the time limitation to process cases and because of the size and scope of the project. VIOLATIONS NEISWONGER CONSTRUCTION is in violation of: Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(3) – Excavator failed to hold a preconstruction meeting prior to beginning a complex project. Section 5(17) – Excavator failed to comply with all requests for information from PUC staff within 30 days of the receipt of the request. On 3/24/2026 DPI Maki sent an email to Neiswonger Construction asking how the marks were maintained and if there were any pictures with the mark out. No response has been received as of 5/19/2026. See attachment named “ DPI asks Neiswonger Construction about marks.” Recommendation: The penalties are applied. PUC compliance education is required for the excavators working onsite of this excavation or their replacements. SOUTH STRABANE TOWNSHIP OF Section 2(5)(vii) – Failed to respond to an emergency notification as soon as practicable following notification.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		*Emergency ticket 20260581239 was submitted by COLUMBIA GAS OF PA INC on 2/27/2026 at 10:16 to repair a gas line. SOUTH STRABANE TOWNSHIP did not respond "clear" until 3/04/2026. Recommendation: The penalty is applied. PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s).	
62954	Facility Owner: Columbia Gas Contractor/Excavator: Mortimer Excavating Inc. Project Owner: Monaca Borough Other: WIDMER ENGINEERING	On 3/10/2026 3:00:00 PM at INDIANA AVE, MONACA BORO, BEAVER On 08/11/2026, The Damage Prevention Committee (DPC) voted to keep Columbia Gas' violation and remove the penalty. ***** Columbia Gas is disputing. ***** The incident occurred on March 10th, 2026, at approximately 3:00 PM, on Indiana Avenue, located in Monaca Borough, Beaver County, Pennsylvania. A gas line owned by Columbia Gas was damaged. 911 was called. Columbia Gas, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, "Mortimer Excavating working to install to water main on Indiana Ave in Monaca struck and damaged and unmarked and unmapped 1.25" idled stub. They notified (911/Columbia Gas) when the damage occurred. Columbia Gas responded immediately to make the area safe and complete repairs. An onsite root cause investigation was conducted to determine why the gas main was not marked. This damage was deemed as inaccurate records due to the fact of having no records of the stub coming off mainline or it being on the map. It was capped for repair a marker ball placed at the end of the stub and an order placed for a crew to come back and abandoned the stub properly at the main." Photos were submitted. Mortimer Excavating Inc., the excavator, submitted an AVR. Their AVR states, "on March 10, 2026 while excavating down about 2'6" we caught a steal gas line. There were no markings for any gas service. When Columbia gas came out they put a cap on the end and told us line was idle. There is video but unable to load as to large even compressed. Can not edit anything out." Photos were submitted. Monaca Borough, the project owner, submitted an AVR. Their AVR states, "An unmarked gas service line was struck at 1129 Indiana Avenue and was repaired by Columbia Gas." Widmer Engineering, the designer, submitted an AVR. Their AVR states, "An unmarked gas line was struck during trenching for the replacement of a potable water main. This strike led to EMS being alerted and repairs being made to the gas line. All known utilities were	Columbia Gas: \$0.00 Section 2(5)(i) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		displayed on the construction plans based on information provided by the utility owners from Design and Construction PA One Calls. The gas line was struck around 1129 Indiana Ave.” Photos were submitted. The submitted photos show the gas line was not marked. The closest yellow mark out can be seen on the opposite side of the street, several feet away. Columbia Gas reported in their AVR the gas main was not marked due to inaccurate records and having no records of the stub coming off mainline or it being on the map. The designer reported in their AVR that all known utilities were displayed on the construction plans based on information provided by the utility owners. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each facility owner: - To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques. Facility owners shall make reasonable efforts during the excavation phase to locate or notify excavators of the existence of any known lines and abandoned lines. Violations: Columbia Gas- - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63289	Facility Owner: Peoples Natural Gas Company Contractor/Excavator: Kukurin Contracting, Inc. Project Owner: TARENTUM BOROUGH Other: GIBSON THOMAS ENGINEERING CO INC	<u>On 3/16/2026 7:00:00 AM at 7TH AVENUE, TARENTUM BORO, ALLEGHENY</u> On 9/15/2026 The Damage Prevention Committee voted to remove both violations. Peoples disagreed. Peoples provided the communication with the excavator. Violation 2.1.2 violation is withdrawn. This was not an agreeable schedule for Kukurin. The project was delayed because Peoples did not mark out until 3/17/2026. Kukurin provided notes from the Complex Project meeting that all of the facility owners including Peoples agreed to the usual ticket placement and mark out within 3 days. ***** The incident occurred on 3/16/2026 on 7th Ave, in TARENTUM BORO in Allegheny County. A gas line owned by Peoples Natural Gas was not marked by the required time. *No Damage KUKURIN CONTRACTING INC stated in their Alleged Violation Report (AVR) that they are	Peoples Natural Gas Company: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		representing TARENTUM BORO (project owner) and GIBSON-THOMAS (Designer) They also stated that, “This AVR is being filed against Peoples Natural Gas Co. for not meeting the required deadline of 7am, March 16, for marking their lines”. Kukurin also made comments stating that “This AVR is being filed against Peoples Natural Gas Co. for not meeting the required deadline of 7am, March 16, for marking their lines. Kukurin submitted dig ticket 2026-069-0359 (total length = 190 lf) on March 10. We were legal to dig starting at 7am on March 16. On March 13 at 4:25pm, Peoples emailed Kukurin (attached to this AVR) stating they would be complete with markings ON March 16. On March 16 at 2am, via the POCS's email (attached to this AVR), Peoples stated their lines would be marked by 4:21pm on March 17. On March 18 at 6pm, via the POCS's email (attached to this AVR) Peoples stated their lines were marked. Due to Peoples' multiple late responses, their lines were not ready for us until 7am on March 19, 3 days after they should have been. The Complex Project Meeting's sign-in sheet and minutes are attached to this AVR. The minutes show all parties agreed to the standard 3-business day turnaround time for locating their utilities. KUKURIN CONTRACTING INC submitted another AVR stating that “This AVR is being filed against Peoples Natural Gas Co. for not marking their lines by March 17 like the March 16 POCS email said they would be”. This AVR is being filed against Peoples Natural Gas Co. for not marking their lines by March 17 like the March 16 POCS email said they would be. Kukurin submitted dig ticket 2026-069-0359 (total length = 190 lf) on March 10. We were legal to dig starting at 7am on March 16. On March 13 at 4:25pm, Peoples emailed Kukurin (attached to this AVR) stating they would be complete with markings ON March 16. On March 16 at 2am, via the POCS's email (attached to this AVR), Peoples stated their lines would be marked by 4:21pm on March 17. On March 18 at 6pm, via the POCS's email (attached to this AVR) Peoples stated their lines were marked. Due to Peoples' multiple late responses, their lines were not ready for us until 7am on March 19, 3 days after they should have been. The Complex Project Meeting's sign-in sheet and minutes are attached to this AVR. The minutes show all parties agreed to the standard 3-business day turnaround time for locating their utilities. Documents were provided. Peoples Natural Gas Company (PNG) was sent an AVR request letter on 3/30/2026. PNG stated in their AVR that “Peoples Natural Gas recieved a one call ticket notification 20260690359 on 3/10/2026. The ticket was placed by KUKURIN CONTRACTING INC for storm sewer separation along e 7th ave in tarentum boro. Peoples responded ongoing schedule date and time on 3/13/2026 and again on 3/17/2026 due to a trouble locate. The PNG locator called the onsite contact each time an ongoing response was placed. PNG responded field marked on 3/18/2026. PNG locator also recieved word from the contractor that	

Case Number	Stakeholders	Summary	Violations & Recommendation
		excavation wasnt starting until 3/23. The contractor placed an update ticket on 3/23 stating work not started no additional marks needed. Work has still not started on this project as of 4/1/2026.” Please note that PNG violation date is incorrect, and the same as the submission date, but the AVR information is for this incident. Pictures were provided. Complex Project Ticket 20260613738 was submitted by Kukurin Contracting Inc on 3/02/2026 at 15:07 with a response due by 3/08/2026. Peoples Gas responded on 3/09/2026 that they attended the meeting and reached an agreement. No notes were provided on this ticket. Complex Project Meeting notes which were provided stated that All the parties in attendance will mark out within 3 business days and that multiple ticket submission is planned for the same day. This is specified to include the entire area of the project. Complex Project meeting sign-in sheet attendees: Kukurin, Ancog, Verizon, Peoples Gas, Gibson-Thomas. USIC representing West Penn Power and Windstream did not attend the meeting. Winstream (and West Penn Power) were represented by USIC. Notes were entered timely and an agreement reached. VIOLATIONS Peoples Gas is in violation of: Section 2(5)(iii.1) – Facility owner failed to propose a mutually agreeable scheduling by which the excavator, facility owner or designer may locate the facilities. Ticket 20260690359 was submitted by Kukurin Contracting Inc on 3/10/2026 with a response due by 3/15/2026. Peoples Gas responded “Scheduled mark on 3/13/2026 and on 3/17/2026, then on 3/18/2026 Peoples Gas responded “field marked’. There was no mutual agreement for this late mark out. Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. This is a subsequent offense. Peoples did not mark their lines by the due date. Section 2(5)(i.2) – Failed to document Communications between a Facility Owner and Excavator to ensure the excavator is aware of a facility owner’s inability to locate it’s facilities. This is a third-time offense. There are no notes on the Complex project ticket 20260613738. There are not any notes nor agreements with PNG noted in the Complex Project meeting notes. Recommendation: The penalty is applied. PUC compliance education has been recently completed.	
63308	Facility Owner: National Fuel Gas Distribution Contractor/Excavator: C AND R DIRECTIONAL BORING LLC Project Owner: Johnsonburg Municipal Authority Other: JONES TOWNSHIP	<u>On 3/18/2026 4:00:00 PM at ROSE ST, JOHNSONBURG BORO, ELK</u> On 9/15/2026 the Damage Prevention Committee voted on Jones Township Municipal Authority's 2(5)(v.2) penalty to reduce it to a warning of \$0. ***** JONES TOWNSHIP MUNICIPAL AUTHORITY is disputing. **** The incident occurred on 3/18/2026, at 4:00 PM, on Rose St, in Johnsonburg Boro, Elk County.	National Fuel Gas Distribution: \$0.00 C AND R DIRECTIONAL BORING LLC: \$1,000.00 Section 5(16) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	MUNICIPAL AUTHORITY	A gas line owned by National Fuel Gas was damaged. An emergency ticket was entered for the damage. National Fuel Gas is the facility owner. Their Alleged Violation Report (AVR) states, "Excavator struck properly marked natural gas distribution service line at 136 Mary St." C And R Directional Boring is the excavator. An AVR was not filed as of 05/06/2026 and an AVR request was sent the same day. An AVR was submitted 61 days after the incident that states, "Gas service was interrupted on Rose st in Johnsonburg. was a 3/4 gas service. Line was on the marks. case number 63308". Johnsonburg Muni Auth is the project owner. An AVR was not filed as of 05/06/2026. Ticket #20260683292 New – Excavation – Routine had a response due date of 3/11/2026. Jones Township responded "Clear" on 3/12/2026 as their only response. National Fuel Gas responded "Conflict" on 3/11/2026 and "Field Marked" on 3/13/2026. Images submitted support the statement in both AVRs that the line which was damaged was marked within 18". Violations: Facility - National Fuel Gas Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Excavator – C And R Directional Boring Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. This violation is being reduced by 50% from \$1000 to \$500. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. C&R is delinquent on DPC ordered education from 2022 for case 18380 Facility(other) – Jones Township: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	Section 5(4) 1st Offense \$500.00 JONES TOWNSHIP MUNICIPAL AUTHORITY: \$0.00 Section 2(5)(v.2) 2nd Offense \$0.00
63304	Facility Owner: Peoples Natural Gas Contractor/Excavator: B	On 3/23/2026 11:40:00 AM at 1455 N NEGLEY AVE, PITTSBURGH CITY, ALLEGHENY On 9/15/2026 the Damage Prevention Committee voted on B K G	B K G INDUSTRIES: \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
	K G INDUSTRIES Project Owner: Pittsburgh Water	Industries' violation, 5(2) remove violation and penalty, 5(6)(i) remove violation and penalty ***** B K G Industries disputing ***** The incident occurred on 3/23/2026, at 11:40 AM, on 1455 N Negley Ave, in Pittsburgh City, Allegheny County. A gas line owned by Peoples Natural Gas was damaged. No tickets were found for this excavator, time frame, and location. The excavator has placed PA One Call tickets in the past. Peoples Natural Gas is the facility owner. Their Alleged Violation Report (AVR) states, “BKG Industries working for Pittsburgh Water struck and damaged a customer side gas service line. BKG Industries was working without a locate request.” B K G Industries is the excavator. Their AVR states, “On 03/23/26 around 11:40am BKG operator struck a 1"nat gas line, that was approximately buried 16" below grade.” Pittsburgh Water is the project owner. Their AVR states, “While digging for new access road to the pump station, subcontractor BKG excavator struck 3/4" gas line. 911 was contacted. People's gas arrived shortly after the notification. People's gas then cut & capped the line. In addition to this, People's Gas shut off the valve at the curb. This was private side hit. Peoples gas claims that they own all private sides and are responsible for repairs.” Images submitted show the site, excavation, and damage. There are no tickets for this excavator, time frame, and location. Act 127 of 2024 requires a PA One Call ticket to be submitted prior to excavation: SECTION 5. It shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: (2.1)To submit a locate request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. Notification shall be not less than three nor more than ten business days in advance of beginning excavation or demolition work. No work shall begin earlier than the lawful start date which shall be on or after the third business day after notification. The lawful start date shall exclude the date upon which notification was received by the One Call System and notification received on a Saturday, Sunday or holiday, which shall be processed on the following business day. In the case of a complex project, notification shall not be less than ten business days in advance of the beginning of excavation or demolition work.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		*** (6)To inform each operator employed by the excavator at the work site of such work of the information obtained by the excavator pursuant to clauses (2.1) through (5), and the excavator and operator shall: (i) Plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner's facilities in the construction area. Excavation or demolition work which requires temporary or permanent interruption of a facility owner's service shall be coordinated with the affected facility owner in all cases. Violations: Excavator – B K G Industries Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. Section 5(6)(i) – Excavator failed to plan the excavation or demolition work to avoid damage to or minimize interference with a facility owner’s facilities in the construction area. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements.	
63307	Facility Owner: COLUMBIA GAS OF PA INC_Central Contractor/Excavator: WILSON EXCAVATING - A LINDY GROUP COMPANY Project Owner: PENNSYLVANIA AMERICAN WATER	<u>On 3/23/2026 1:15:00 PM at FREELAND ST., PITTSBURGH CITY, ALLEGHENY</u> Columbia Gas would like to withdraw our dispute and accept violation 2(5)(i) for Freeland St. ***** Disputing is Columbia Gas of PA stating, "At the time of the locate, our locator followed established procedures and utilized all available resources to perform a good faith and compliant locate in accordance with CGA Best Practices. This included reviewing our mapping system as well as conducting a physical locate using appropriate locating equipment to tone out the main. Our mapping system at that time depicted the gas main traveling straight through the intersection of Freeland Street and Haberman Avenue and did not reflect the presence of two 90 degree bends. Consistent with the mapping records, the locator’s signal tracing also indicated a straight alignment of the facility. As a result, the marks placed in the field were based on both the available records and the physical locate evidence. Based on this information, the locator reasonably relied on all available and verifiable resources at the time to complete the locate. Since the incident, our records have been reviewed and updated to accurately reflect the configuration of the gas main, including the two 90 degree bends at the intersection of Freeland Street and Haberman Avenue. This corrective action ensures improved accuracy moving forward. Please see attached. Given that the locator exercised due diligence, relied on available records, and performed a physical locate in alignment with industry best practices, we respectfully request reconsideration of the alleged violation." *****	COLUMBIA GAS OF PA INC_Central: \$500.00 Section 2(5)(i) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		The incident occurred on Monday, March 23, 2026, on Freeland Street, in Pittsburgh City, Allegheny County. A gas line owned by Columbia Gas was damaged. Wilson Excavating-A Lindy Group Company reported a facility owner issue as marked incorrectly. Wilson Excavating stated in their Alleged Violation Report (AVR), "Wilson Excavating was working at Haberman Ave & Freeland St for PAWC. While excavating, a mismarked Columbia Gas mainline was struck. 911 was called. Facility owner was notified." PA American Water Company (PAWC), the project owner, reported a facility owner issue as marked incorrectly. PAWC stated in their AVR, Wilson crew while excavating to install water hit and damage a Columbia Gas main that was mis-marked by more than 10'. Columbia Gas reported a facility owner issue as Missing or incorrect facility line maps or records. Columbia Gas stated in their AVR, "On March 23rd, 2026, WILSON EXCAVATING AND UTILITY CONSTRUCTION LLC was working on a water project on Freeland St when they hit an unmarked 4" Columbia Gas main. Columbia records indicated the gas line crossed the road in a straight line, however the line had two 90-degree elbows that were unmapped. 911 and Columbia Gas were notified and responded. Plant and service crews made all necessary repairs and safety checks, and the locator remarked the area." Violation: Columbia Gas is in violation of section: 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. Recommendation: Penalties applied	
63546	Facility Owner: PENCOR SERVICES BLUE RIDGE COMMUNICATION Contractor/Excavator: Pocono Township Project Owner: Pocono Township (Placeholder)	<u>On 3/24/2026 11:30:00 AM at 571 tara hills dr, stroudsburg, POCONO TWP, MONROE</u> On 09/15/2026, The Damage Prevention Committee (DPC) voted for Pocono Township: 5(2.1)- Keep the violation, remove the penalty. 5(16)- Keep violation (warning). ***** Pocono Township is disputing. ***** The incident occurred on March 24th, 2026, at approximately 11:30 AM, at 571 Tara Hills Drive, located in Pocono Township, Monroe County, Pennsylvania. A cable line owned by Pencor Services Blue Ridge Communication was damaged. The was no PA One Call ticket for this project.	Pocono Township: \$0.00 Section 5(2.1) 1st Offense \$0.00 Section 5(16) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Pencor Services Blue Ridge Communication, the facility owner, submitted an Alleged Violation Report (AVR). Their AVR states, “Pocono Township was digging to install a fence gate and hit Blue Ridge facilities. The township did not submit a PA one call.” Photos were submitted. Pocono Township is the excavator and project owner. An AVR request letter was sent 05/04/2026. They submitted an AVR on 05/05/2025. Their AVR did not include a summary of the incident. Photos were submitted. In the submitted photos, no utility mark outs are seen. In the submitted photo [2 (7).jpg] there is a visible telecom vault, indicating there are underground utilities in the immediate area. Submitted photo [IMG_2442.jpeg] shows the damaged utility line. Pa One Call reported Pocono Twp has placed one calls in the past. Pocono Township did not plan the excavation work to avoid damage or minimize interference with a facility’s owner’s facilities in the construction area. A Pa One Call ticket was not requested for this project. There is a telecom vault in the immediate area, which is an indication of underground utilities within the immediate area. Requesting a Pa One Call ticket in advance of the project (as required by law), to have all underground utilities marked out would significantly reduce the risk of damaging an underground utility. Act 127 of 2024, also known as the Underground Utility Line Protection Law states it shall be the duty of each excavator who intends to perform excavation or demolition work within this Commonwealth: - To submit a locate request to identify the location and type of facility owner lines at each work site by notifying the facility owner through the One Call System. Notification shall be not less than three nor more than ten business days in advance of beginning excavation or demolition work. No work shall begin earlier than the lawful start date which shall be on or after the third business day after notification. The lawful start date shall exclude the date upon which notification was received by the One Call System and notification received on a Saturday, Sunday or holiday, which shall be processed on the following business day. - To submit a report of an alleged violation to the commission through the One Call System not more than thirty days after striking or damaging a facility owner's line during excavation or demolition or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. Violations: Pocono Township –	

Case Number	Stakeholders	Summary	Violations & Recommendation
		- Section 5(2.1) – Excavator failed to submit a location request to One Call within the correct timeframe. - Section 5(16) – Excavator Failed to submit an Alleged Violation Report within 30 days of striking a line or if the excavator believes a violation of this act has been committed in association with excavation or demolition work. (This violation is reduced to a warning.) Recommendation: The penalty is applied. PUC online Compliance Training is required for the individual(s) responsible, or their replacement(s).	
63487	Facility Owner: Peoples Gas Company Contractor/Excavator: Independent Enterprises Inc Project Owner: Pittsburgh Department of Mobility and Infrastructure Designer: GAI CONSULTANTS INC	On 3/30/2026 8:03:00 AM at GASS AVE, <u>PITTSBURGH CITY, ALLEGHENY</u> On 9/15/2026 the DPC voted to: Motion by Kiger to: Independent Enterprises 5(3)- Accept the DPI’s recommendations. Add additional \$250 penalty for not attending the DPC meeting. 5(4)- Accept the DPI’s recommendations. Not in attendance ***** Incident occurred on March 30th, 2026, at 8:03 am along Gass Avenue, Pittsburgh City, Allegheny County. Incident: A gas line was damaged. Case is related to 057007, 057069, 057305, 057764, 057768, 057941, 058568, and 061494. Alleged Violation Reports (AVR): Facility Owner - Peoples Gas Company's AVR states, “On 3/30/2026, Independent Enterprises was working to install water water mains and services for PWSA when they struck a PNG SL tap tee on top of ML. Independent was working on a one call ticket from 6/24/2025 and marks were extremely faded. No updates were called in for remarks. Excavator issue for failing to maintain marks.” AVR submission date: 3/31/26 Was the AVR submitted after 30 business days? No Excavator - Independent Enterprises' AVR states, “Gas line was struck. Gas line was UNMARKED. Closest mark was 21 FT away. Line was at a depth of 12 INCHES, at the bottom of the road base.” Was the AVR submitted after 30 days? No Project Owner - PWSA's AVR states, “Gas line was struck. Gas line was UNMARKED. Closest mark was 21 FT away. Line was at a depth of 12 INCHES, at the bottom of the road base.” AVR submission date: 4/1/26 Was the AVR submitted after 30 days? No Designer - GAI Consultant's AVR states, “Gas line was struck. Gas line was UNMARKED. Closest mark was 21 FT away. Line was at a depth of 12 INCHES, at the bottom of the road base.”	Independent Enterprises Inc: \$1,750.00 Section 5(3) 2nd Offense \$1,250.00 Section 5(4) 1st Offense \$500.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		AVR submission date: 5//26/26 Was the AVR submitted after 30 business days after being aware of incident? No Alleged conclusion: Images show mark outs for the gas to the right of the tree stump. Please note the fire hydrant was relocated in front of the tree stump. Last ticket was called in on 6/24/25 and damage occurred on 3/30/26. No lateral mark outs are visible in the damage photos. Emergency ticket noted that 911 was notified. Images from the gas company have the incorrect date stamp setting on the camera, and this can be proven by the vegetation that was removed after October of 2024, (please see Google Streetview file October 2024 Buses.png.) Recommended violations, penalties, and education: Excavator: Independent Enterprises Section 5(3) – Excavator failed to preserve mark-outs or request a remark. 20251750635. Add \$250 on to original \$1,000 for a total of \$1,250. Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. 20251750635 -PUC compliance education is required for the excavators working onsite of this excavation or their replacements.	
63518	Facility Owner: Peoples Natural Gas Contractor/Excavator: CONTINENTAL CONSTRUCTION Project Owner: The Municipal Authority of the Borough of Portage Other: EADS GROUP Other: Portage Area Sewer Authority	<u>On 3/30/2026 3:00:00 PM at SONMAN AVE, PORTAGE TWP, CAMBRIA</u> On 9/15/2026 the Damage Prevention Committee voted on Continental Construction's violations, 5(8) no changes, 5(4) Remove the violation and penalty. ***** Continental Construction disputing Portage Area Sewer Authority violation reduced from \$250 to a warning. ***** The incident occurred on 3/30/2026, at 3:00 PM, on Sonman Ave, in Portage Boro, Cambria County. A gas line owned by Peoples Natural Gas was damaged. 911 was not notified when damage occurred. Peoples Natural Gas is the facility owner. Their Alleged Violation Report (AVR) states, “CONTINENTAL CONSTRUCTION was digging when they struck a marked service for 1112 Sonman Ave, contractor kept digging and covered up the damage with dirt. Contractor did not call 911. PNG crews repaired the line. This is the second service they hit that was marked correctly.” Continental Construction is the excavator. Their AVR states, “Incident Summary: On March 30, 2026, while performing excavation activities at 1111 Sonman Avenue, our crew struck a gas service branch. Although a PA One Call ticket was active and valid, the facility owner (Peoples Gas) failed to provide accurate markings or follow the standards set forth in PA Act 287. Key Arguments for Defense: Failure of the 18" Tolerance Zone: The markings provided by the facility owner were	CONTINENTAL CONSTRUCTION: \$1,000.00 Section 5(8) 1st Offense \$1,000.00 Portage Area Sewer Authority: \$0.00 Section 2(5)(v.2) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		inaccurate. Upon physical verification after the strike, the actual location of the gas service branch was found to be outside the mandated 18-inch tolerance zone from the marks provided across the road. Incomplete Marking of the Work Site: The facility owner failed to mark the service line where it crossed the driveway. The excavator relied on the absence of marks on the driveway as an indication that the area was clear, per standard industry practice and PA One Call protocols. Discriminatory/Inconsistent Marking Practices: The representative from Peoples Gas explicitly stated that they do not mark improved driveways as a "courtesy to the homeowner." Statutory Violation: PA Act 287 does not grant facility owners the discretion to omit markings based on surface type or "courtesy." The law requires the identification of underground lines regardless of whether the surface is grass, gravel, concrete, or asphalt. Inconsistency: Peoples Gas demonstrated that they are capable of marking improved surfaces, as other driveways within the same project scope were clearly marked. The failure to mark this specific driveway was a direct cause of the line strike. Safety Risk and Negligence: The decision to prioritize the aesthetic of a driveway over the safety of the excavation crew and the public is a gross misinterpretation of safety regulations. By omitting these marks, Peoples Gas created a hazardous environment that could have resulted in a catastrophic event.” Portage Borough is the project owner. Their AVR states, “Continental Construction was digging when they struck a marked 1" Plastic service for 1112 Sonman Ave.” EADS Group is the designer. Their AVR states, “CCI crew was installing water main along Sonman Avenue and struck a gas service line that crossed the trench excavation. The gas service line was plastic inserted in existing steel gas service line less than 12 inches below grade. The service line served one structure, 1112 Sonman Ave. The utility owner, Peoples Natural Gas, was notified and repaired the service line. The road service markings and the location of the service tap and gas main were not directly in line with each other. The gas service line and main was not marked on the driveway where the service tap was located. The incident was observed and pictured by the project inspector.” Ticket # 20260720027 and Ticket # 20260720028 had a response due date of 3/17/2026. Portage Area Sewer Authority Images submitted show the site, pre-excavation marks, damaged line, post-excavation marks, and equipment. The line that was damaged is within the tolerance zone of the yellow marks. There is no indication that the excavator attempted to locate the line prior to beginning mechanized excavation. This case is related to case 062853 by tickets.	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Violations: Excavator - Continental Construction: Section 5(4) – Excavator failed to exercise due care and employ prudent excavation techniques. Section 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid which endangers life, health, or property. PUC online Compliance Training is required for the excavator(s) working onsite at this excavation, or their replacements. Facility(other) - Portage Area Sewer Authority: Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. Ticket # 20260720027 and Ticket # 20260720028 PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
63666	Facility Owner: Astound powered by RCN Facility Owner: PPL Electric Facility Owner: Service Electric Cable TV Inc. Facility Owner: Verizon Placeholder Contractor/Excavator: PLUG UTILITIES Project Owner: Verizon Designer: Placeholder Verizon	On 4/1/2026 7:00:00 AM at <u>TIMBERKNOLL DR, LOWER MACUNGIE TWP, LEHIGH</u> On 9/15/2026 the DPC voted to: Motion by Ditty to: Service Electric Cable TV 2(5)(i)- remove the violation and penalty. 2(5)(i)- remove the violation and penalty. 2(5)(i)- remove the violation and penalty. 2(5)(i)- remove the violation and penalty. ***** SECTV Inc. is disputing and provided mark out photos from May 2026 on ticket violations from March 2026. *** PPL Accepts 2.5.i violations and penalties. Violations for 2(5)(v.2) were removed after reviewing documentation. *** This non-damage incident occurred between 3/5/26 - 6/3/26 along Timberknoll Drive & Rolling Meadow Drive, Lower Macungie Township, Lehigh County. Incident: Tickets were not marked out within 18 inches & were not given final responses. Alleged Violation Reports (AVR): Excavator - Plug Utilities AVR states, “This complaint is being filed regarding ongoing utility locate issues with USIC in Lower Macungie Township, Lehigh County, PA, specifically in the Kuhnsville area where we are performing a complex construction project. A coordination meeting was held and an agreement was reached on March 23, establishing a legal project start date of Wednesday, April 1. Locate requests were properly submitted beginning March 24 to ensure compliance and adequate time for marking. However, upon arrival of our crews on site, utility markings have consistently been incomplete—particularly those assigned to USIC, who performs locating services for	Astound powered by RCN: \$2,000.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(5)(i) 1st Offense \$500.00 Section 2(5)(i) 1st Offense \$500.00 PPL Electric: \$4,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Section 2(5)(i) 2nd Offense \$1,000.00 Service Electric Cable TV Inc.: \$0.00 Verizon: \$15,000.00 Section 4(2) 2nd Offense \$1,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		PPL Electric Utilities, Service Electric Cable TV Inc., and Astound Broadband powered by RCN. Despite repeated submissions and adherence to timelines, USIC has provided inconsistent explanations for the lack of completed markings, resulting in significant inefficiencies, delays, and loss of resources. Our crews are being pressured to meet project deadlines and face potential penalties, while being unable to proceed safely due to missing or incomplete locates. Additionally, a USIC representative, Mr. Taylor Pagan, has repeatedly responded to tickets with “CONFLICT – LINES NEARBY – DIRECT CONTACT TO FOLLOW BY FACILITY OWNER,” yet no markings have been placed on site and no follow-up communication has occurred. Further concerns include unprofessional and unreliable conduct, including citing personal issues such as vehicle breakdowns as reasons for non-performance. In one instance, Mr. Taylor claimed that two tickets were due on Sunday, April 6, despite the tickets being submitted on March 26 with a legal start date of Monday, April 6. He then unilaterally stated he would reschedule the tickets to April 14, which appears to be inconsistent with PA One Call (PA811) requirements and has caused additional delays to the project. These ongoing failures have also had a direct financial impact on our operations. Due to incomplete and missing locates, we have incurred substantial losses including wasted crew hours, unnecessary travel time to and from the job site, repeated mobilization and preparation efforts, fuel costs, and hotel accommodations. These avoidable expenses continue to accumulate as a direct result of USIC’s inability to perform required services in a timely and reliable manner. Additionally, this is not an isolated issue; prior complaints have been filed regarding similar concerns, yet no meaningful resolution or corrective action has been achieved. This pattern of behavior demonstrates a lack of accountability, consistency, and adherence to established procedures. USIC’s failure to properly complete locates is directly impacting project timelines, increasing costs, and creating unnecessary risk. We respectfully request that the PUC investigate this matter, ensure compliance with PA811 regulations, and require USIC to fulfill its obligations in a timely and professional manner. Additionally, we request that appropriate action be taken regarding the conduct of the assigned locator, including requiring improved performance, accountability, or reassignment if necessary.” Additional Plug Utilities' AVR states, "This complaint is being filed regarding ongoing utility locate issues with USIC in Lower Macungie Township, Lehigh County, PA, specifically in the Kuhnsville area where we are performing a complex construction project. A coordination meeting was held and an agreement was reached on March 23, establishing a legal project start date of Wednesday, April 1. Locate requests were properly submitted beginning March 24 to ensure compliance and adequate time for marking. However, upon arrival of our crews on site, utility markings have	Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00 Section 2(5)(v) Subsequent \$2,000.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		consistently been incomplete—particularly those assigned to USIC, who performs locating services for PPL Electric Utilities, Service Electric Cable TV Inc., and Astound Broadband powered by RCN. Despite repeated submissions and adherence to timelines, USIC has provided inconsistent explanations for the lack of completed markings, resulting in significant inefficiencies, delays, and loss of resources. Our crews are being pressured to meet project deadlines and face potential penalties, while being unable to proceed safely due to missing or incomplete locates. Additionally, a USIC representative, Mr. Taylor, has repeatedly responded to tickets with “CONFLICT – LINES NEARBY – DIRECT CONTACT TO FOLLOW BY FACILITY OWNER,” yet no markings have been placed on site and no follow-up communication has occurred. Further concerns include unprofessional and unreliable conduct, including citing personal issues such as vehicle breakdowns as reasons for non-performance. In one instance, Mr. Taylor claimed that two tickets were due on Sunday, April 6, despite the tickets being submitted on March 26 with a legal start date of Monday, April 6. He then unilaterally stated he would reschedule the tickets to April 14, which appears to be inconsistent with PA One Call (PA811) requirements and has caused additional delays to the project. These ongoing failures have also had a direct financial impact on our operations. Due to incomplete and missing locates, we have incurred substantial losses including wasted crew hours, unnecessary travel time to and from the job site, repeated mobilization and preparation efforts, fuel costs, and hotel accommodations. These avoidable expenses continue to accumulate as a direct result of USIC’s inability to perform required services in a timely and reliable manner. Additionally, this is not an isolated issue; prior complaints have been filed regarding similar concerns, yet no meaningful resolution or corrective action has been achieved. This pattern of behavior demonstrates a lack of accountability, consistency, and adherence to established procedures. USIC’s failure to properly complete locates is directly impacting project timelines, increasing costs, and creating unnecessary risk. We respectfully request that the PUC investigate this matter, ensure compliance with PA811 regulations, and require USIC to fulfill its obligations in a timely and professional manner. Additionally, we request that appropriate action be taken regarding the conduct of the assigned locator, including requiring improved performance, accountability, or reassignment if necessary.” Alleged conclusion: Tickets Responses 20260831901 Verizon - No Response 4/1/26 12:01am Astound, Service Electric, and PPL Electric - Conflict 3/31/26 6:33am	

Case Number	Stakeholders	Summary	Violations & Recommendation
		20260832007 Verizon - No Response 4/2/26 12:01am Astound, Service Electric, and PPL Electric - Conflict 3/31/26 6:42am 20260832103 Verizon - No Response 4/1/26 12:01am Astound, Service Electric, and PPL Electric - Conflict 3/31/26 6:46am 20260843652-00 & 20260843652-01 Verizon - No Response 4/3/26 12:02am Astound, Service Electric, and PPL Electric - Scheduled Mark on 4/2/26 by 4/6/26 Astound, Service Electric, and PPL Electric - No Response 4/21/26 1:01pm Astound, Service Electric, and PPL Electric - Conflict 4/22/26 1:53pm PPL Electric - Conflict 5/7/26 4:38pm PPL Electric - Conflict 6/3/26 5:16pm 20260852105-00 & 20260852105-01 Verizon - No Response 4/6/26 12:00am Astound, Service Electric, and PPL Electric - Scheduled Mark on 4/3/26 by 4/14/26 Astound, Service Electric, and PPL Electric - No Response 4/21/26 1:01pm Astound, Service Electric, and PPL Electric - Conflict 4/22/26 1:54pm PPL - Conflict 5/7/26 PPL - Conflict 6/3/26 20260861227-00 & 20260861227-01 Verizon - No Response 4/6/26 12:01am Astound, Service Electric, and PPL Electric - Scheduled Mark on 4/3/26 by 4/14/26 Astound, Service Electric, and PPL Electric - No Response 4/21/26 1:01pm Astound, Service Electric, and PPL Electric - Conflict 4/22/26 1:55pm PPL - Conflict 5/7/26 PPL - Conflict 6/3/26 20260892524 Astound, Service Electric, and PPL Electric - Scheduled Mark on 4/6/26 by 4/8/26 Astound, Service Electric, and PPL Electric - Conflict 4/22/26 1:59pm 20260892450-00 & 20260892450-01 Verizon - No Response 4/7/26 12:00am Astound, Service Electric, and PPL Electric - Scheduled Mark on 4/6/26 by 4/8/26 Astound, Service Electric, and PPL Electric - No Response 4/21/26 1:01pm Astound, Service Electric, and PPL Electric - Conflict 4/22/26 1:57pm PPL - Conflict 5/7/26 PPL - Conflict 6/3/26	

Case Number	Stakeholders	Summary	Violations & Recommendation
		No design tickets were placed by Verizon for this project. Images show where the locator stated they would not mark tickets over the weekend and was unsure when the locates could be completed. Google streetview shows that lines going through the neighborhood are underground via pad mounts and lack of utility poles. PA Act 127 of 2024 Section 2(5)(i): (5) After receipt of a timely request from an excavator or operator who identifies the work site of excavation or demolition work he intends to perform and not later than the business day prior to the lawful start date of excavation: (i) To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines. This shall be done to the extent such information is available in the facility owner's records or by use of standard locating techniques other than excavation. Standard locating techniques shall include, at the utility owner's discretion, the option to choose available technologies suitable to each type of line or facility being located at the work site, topography or soil conditions or to assist the facility owner in locating its lines or facilities, based on accepted engineering and operational practices. Facility owners shall make reasonable efforts during the excavation phase to locate or notify excavators of the existence of any known lines and abandoned lines. Images show that lines were not marked within 18 inches by their lawful dig dates. PDF files from the contracted locator shows mark outs were completed after 5/5/26. Recommended violations, penalties, and education: Facility Owner: Service Electric Cablevision Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260843652-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260852105-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260861227-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260892450-00 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner: Astound powered by RCN	

Case Number	Stakeholders	Summary	Violations & Recommendation
		Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260843652-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260852105-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260861227-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260892450-00 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner: PPL Electric Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260843652-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260852105-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260861227-00 Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. 20260892450-00 Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260843652-01 Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260852105-01 Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260861227-01 Section 2(5)(v.2) – Failed to timely enter a final response to all locate requests. 20260892450-01 -PUC compliance education is required for the individual(s) responsible to perform the locate for this ticket or their replacement(s). Facility Owner, Project Owner, and Designer: Verizon Section 4(2) – Designer failed to request the line and facility information prescribed by section 2(4) from the One Call System not less than ten nor more than ninety business days before final design is to be completed. Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260831901 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260832007 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260832103 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260843652 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260852105 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260861227 Section 2(5)(v) – Failed to respond to a routine One Call ticket. 20260892450	

Case Number	Stakeholders	Summary	Violations & Recommendation
		-PUC compliance education is required for the designer(s) who worked on this project or their replacement(s).	
63881	Facility Owner: UGI Contractor/Excavator: R L E ENTERPRISES Other: KINGSTON MUNICIPALITY Other: Pennsylvania American Water (PAWC)	<u>On 4/8/2026 3:00:00 PM at CHARLES AVE, KINGSTON BORO, LUZERNE</u> On 9/15/2026 the Damage Prevention Committee voted: 2(5)(i)-UGI - remove violation and penalty 2(5)(i)-PA American Water - remove violation and penalty ***** PAWC is disputing. *** UGI is disputing. ***** The incident occurred on 4/8/2026, at 3:00 PM, on 548 Charles Ave, in Kingston Boro, Luzerne County. A gas line owned by UGI was damaged. An emergency ticket was entered for the damage. UGI is the facility owner. Their Alleged Violation Report (AVR) states, "Excavator struck and damaged an incorrectly marked gas facility that was imbedded in the macadam. UGI spotted the facility at the tap and the facility was offset and UGI did not have documentation of that offset on it's records. No violation occurred had to put one because there is no option for no violation." R L E Enterprises is the excavator. Their AVR states, "While pot holing to locate a gas service, our crew struck a 3/4" gas service with a jack hammer while removing the pave. the gas service was struck 6" below the top of the pave and the gas service was 4' 8" from the mark." Pennsylvania American Water is the project owner and designer. Their AVR states, "Contractor damaged a 1/2" Plastic gas service for #548 Charles Ave, Kingston at 2:38 PM on 4/8/26 while Jackhammering for the vac truck. The Gas Service was 8" deep. 911 and UGI were contacted immediately. UGI came out and made the repairs." Images submitted support the statement in all AVRs that the line which was damaged was not within the tolerance zone of any gas/yellow marks. Additionally, other facility owners did not locate their lines within the required amount of time allowed under Act 127 of 2024. Ticket #20260781816 New – Excavation – Routine was entered on 3/19/26 at 11:35 AM. The response due date for the facility owners to notify the excavator whether they have marked the requested area was 3/23/2026. KINGSTON MUNICIPALITY did not respond. PENNSYLVANIA AMERICAN WATER responded "SCHEDULED DATE & TIME LINES WILL BE MARKED BY: 30 Jun 2026 2359" and then "Field Marked" on 4/4/2026. UGI UTL responded	UGI: \$0.00 KINGSTON MUNICIPALITY: \$500.00 Section 2(5)(i) 1st Offense \$500.00 Pennsylvania American Water (PAWC): \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		“SCHEDULED DATE & TIME LINES WILL BE MARKED BY:23 Apr 2026 1046” and then “Field Marked” on 4/10/2026. Act 127 of 2024 – Section 2(5)(i) - After receipt of a timely request from an excavator or operator who identifies the work site of excavation or demolition work he intends to perform and not later than the business day prior to the lawful start date of excavation: To mark, stake, locate or otherwise provide the position of the facility owner's underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques, which may include hand-dug test holes, to determine the precise position of the underground facility owner's lines. Violations: Facility - UGI Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - KINGSTON MUNICIPALITY - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s). Facility (other) - PENNSYLVANIA AMERICAN WATER - Section 2(5)(i) – Failed to locate underground lines within 18 inches horizontally of the outside wall of line. PUC online Compliance Training is required for the individual(s) responsible to perform the locate for this ticket, or their replacement(s).	
64679	Facility Owner: PECO AN EXELON COMPANY Contractor/Excavator: UTILITY LINE SERVICES Project Owner: PECO AN EXELON COMPANY Designer: ENTRUST SOLUTIONS	<u>On 5/4/2026 9:00:00 AM at 245 ARDEN RD, UPPER MERION TWP, MONTGOMERY</u> On Tuesday, September 15, 2026, at the All Virtual DPC meeting, disputing was Utility Line Services the section 5(8) and it was voted to Remove penalty but keep violation. ***** ULS is disputing 5(8) by stating they were told to not call 911 by PECO. *** The incident occurred on Monday, May 4, 2026, at 245 Arden Road, in Upper Merion Township, Montgomery County. A gas line owned by PECO An Exelon Company was damaged. PECO reported an excavator issue as failed to use prudent techniques in the tolerance zone. PECO stated in their Alleged Violation Report (AVR), On 5/4/26 at 245	UTILITY LINE SERVICES: \$500.00 Section 5(6)(ii) 1st Offense \$500.00 Section 5(8) 1st Offense \$0.00

Case Number	Stakeholders	Summary	Violations & Recommendation
		Arden Rd, UTILITY LINE SERVICES was using a track hoe to install new gas main and services and severed a correctly marked within tolerance a .75-inch plastic gas service to property. Damage was due to contractor using mechanical equipment within the tolerance zone of a mark facility. Utility Line Services reported a facility owner issue as failure to locate point of connection to facility lines. Utility Line Services stated in their AVR, "While the crew was exposing the prior gas service in the area of 245 Arden Road, a piece of asphalt from the street fell back into the excavation. The operator attempted to retrieve the asphalt with the bucket of the excavator. The tooth of the bucket extended slightly deeper than intended making contact with the 1-inch gas service, causing a break in the service and a release of gas; however, the excess flow valve immediately activated and stopped the gas flow." Photos were provided showing the damage within the tolerance zone. Damage emergency ticket, 20261240886, was placed on 5/4/2026, at 9:01am, with remarks: Caller states it is a 1in Gas Line. Small Escape. Caller States PECO is onsite and told them Not To Contact 911. Facility Type: Natural Gas-Peco. Excavation Equipment: Excavator. Hazardous Release: Yes. Caller Advised to notify 911. Violations: Utility Line Services is in violation of section: 5(6)(ii) – Excavator failed to provide support and mechanical protection for known facility owner’s lines at the construction work site. 5(8) – Excavator failed to immediately notify 911 and the facility owner when damage resulted in the escape of any flammable, toxic or corrosive gas or liquid. Recommendation: Penalties applied and PUC Online Compliance Training is required for the Excavator(s) working onsite at this excavation, or their replacements.	