

JAMES A. SCHNEIDER
SOLICITOR FOR DORRANCE TOWNSHIP
439 WEST BROAD STREET
HAZLETON, PA 18201-6106
TEL: 570-454-2489
FAX: 570-454-1132

January 29, 2010

RECEIVED
2010 FEB -2 AM 9:16
PA P.U.C.
SECRETARY'S BUREAU

James J. McNulty, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
P.O. Box 3265, 400 North Street
Harrisburg, PA 17105-3265


Re: Benjamin Ostrowski, Jr.
vs. PPL Electric Utilities Corporation
Docket No. C-2009-2118321

Dear Mr. McNulty:

Enclosed is a copy of my letter to you of January 4, 2010 and a copy of my letter to you of December 15, 2009, complete with enclosures.

Neither Ben Ostrowski, Jr. nor I have heard from you since December 15, 2009. Will you be so kind as to tell me the next step in the process regarding the Complaint which was filed.

Very truly yours,



JAMES A. SCHNEIDER

JAS/jv

Enclosure

cc: Andrew H. Ralston, Jr., Esquire
Mr. Benjamin Ostrowski, Jr.
Dorrance Township Supervisors
Administrative Law Judge Ember S. Jandebaur
State Representative Karen Boback

JAMES A. SCHNEIDER
SOLICITOR FOR DORRANCE TOWNSHIP
439 WEST BROAD STREET
HAZLETON, PA 18201-6106
TEL: 570-454-2489
FAX: 570-454-1132

January 4, 2010

RECEIVED
2010 FEB -2 AM 9:16
PA.P.U.C.
SECRETARY'S BUREAU

James J. McNulty, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
P.O. Box 3265, 400 North Street
Harrisburg, PA 17105-3265


Re: Benjamin Ostrowski, Jr.
v. PPL Electric Utilities Corporation
Docket No. C-2009-2118321

Dear Mr. McNulty:

Enclosed is a copy of my letter to you of December 15, 2009, complete with enclosures.

I have not heard from you since my letter of December 15, 2009. Will you be so kind as to tell me the next step in the process regarding the Complaint which was filed.

Very truly yours,



JAMES A. SCHNEIDER

JAS/jv

Enclosure

cc: Andrew H. Ralston, Jr., Esquire
Mr. Benjamin Ostrowski, Jr.
Dorrance Township Supervisors
Administrative Law Judge Ember S. Jandebaur

JAMES A. SCHNEIDER
SOLICITOR FOR DORRANCE TOWNSHIP
439 WEST BROAD STREET
HAZLETON, PA 18201-6106
TEL: 570-454-2489
FAX: 570-454-1132

December 15, 2009

James J. McNulty, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
P.O. Box 3265, 400 North Street
Harrisburg, PA 17105-3265

RECEIVED
2010 FEB -2 AM 9:17
PA.P.U.C.
SECRETARY'S BUREAU

Re: Benjamin Ostrowski, Jr.
v. PPL Electric Utilities Corporation
Docket No. C-2009-2118321

Dear Mr. McNulty:

I received a copy of the Certification Of Satisfaction Of Complaint prepared by Attorney Andrew H. Ralston, Jr.

Enclosed are copies of three documents:

- (1) The Certification Of Satisfaction Of Complaint;
- (2) My letter of December 11, 2009
- (3) A copy of the letter from Timothy R. Figura to Benjamin Ostrowski, Jr., the Complainant dated December 2, 2009.

To the extent that the Certification Of Satisfaction Of Complaint is not in accordance with the letter from Mr. Figura, my client objects to the Certification Of Satisfaction.

RECEIVED
2010 FEB -2 AM 9:17
PA.P.U.C.
SECRETARY'S BUREAU

James J. McNulty, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building


Page 2

December 15, 2009

Re: Benjamin Ostrowski, Jr.
vs. PPL Electric Utilities Corporation
Docket No. C-2009-2118321

Also, I would like to have a copy of the letter incorporated into the Certification Of Satisfaction.

Very truly yours,



JAMES A. SCHNEIDER

JAS/jv

Enclosure

cc: Andrew H. Ralston, Jr., Esquire
Mr. Benjamin Ostrowski, Jr.
Dorrance Township Supervisors
Administrative Law Judge Ember S. Jandebaur

BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION

BENJAMIN OSTROWSKI, JR.,

Complainants,

vs.

PPL ELECTRIC UTILITIES CORPORATION,

Respondent.

COMPLAINT DOCKET
NO. C-2009-2118321

RECEIVED
2010 FEB -2 AM 9:17
PA. P.U.C.
SECRETARY'S BUREAU

CERTIFICATION OF SATISFACTION OF COMPLAINT

1. Complainant is Benjamin Ostrowski, Jr. (hereinafter "Complainant").
2. Respondent is PPL Electric Utilities Corporation (hereafter "PPL").
3. This Certificate of Satisfaction of Complaint is submitted pursuant to 52 Pa. Code §5.24(b).

4. PPL hereby certifies that the parties to the above-referenced formal Complaint, now pending before the Pennsylvania Public Utility Commission, have mutually and voluntarily agreed on the following terms as full satisfaction of all outstanding legal and factual disputes in this proceeding, and Complaint has acknowledged satisfaction to PPL:

- (a) PPL transferred 124 residential customers along Blue Ridge Trail, including Complainant, from the St. Johns 30-03 12kV line to the Blytheburn 86-01 12kV circuit on August 5, 2009;

(b) This was done by removing one span of single phase primary wire at pole 49093N33735 on Blue Ridge Trail to create an electrical separation between the circuits;

(c) PPL is currently reinforcing the lines in the Blue Ridge Trail to maintain this configuration and does not intend to permanently transfer these 124 customers back to the St. Johns 30-03 line;

(d) PPL maintains the right to temporarily interconnect the Blytheburn 86-01 and St. Johns 30-03 lines in the event of required system maintenance and/or in response to other emergency situations such as storms or power outages. Once such maintenance work or emergency would be resolved, Complainant's service would be returned solely to the Blytheburn 86-01 circuit;

(e) PPL considers this a permanent solution. However, if PPL deems that all possible causes of flicker have been removed from the St. Johns 30-03 line (i.e. the quarry operating on Small Mountain Road moves or goes out of business or is provided with their own circuit, or provides there own circuit), PPL reserves the right to re-evaluate the customer distribution on these lines so as to provide the most economical and reliable service; and

(f) Complainant agrees to withdraw its Complaint with prejudice.

5. Respondent, PPL, hereby notifies Complainant of the filing of the Certificate of Satisfaction, and that if Complainant objects or disagrees with the terms of the Certificate of Satisfaction, Complainant must notify the Commission in writing of his objection and/or disagreement within ten (10) days of the date that the Certificate of


Satisfaction was signed and served, or the terms of the Certificate of Satisfaction will become final and binding.

WHEREFORE, PPL Electric Utilities Corporation respectfully requests that the docket be marked closed in this matter.

Respectfully submitted,

PPL Electric Utilities Corporation

BY:


ANDREW H. RALSTON, JR., ESQUIRE
Gross McGinley, LLP
33 South 7th Street; PO Box 4060
Allentown, PA 18105-4060

Dated: December 9, 2009
At Allentown, Pennsylvania

RECEIVED
2010 FEB - 2 AM 9:17
P.A.P.U.C.
SECRETARY'S BUREAU

BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION

BENJAMIN OSTROWSKI, JR.,

Complainants,

vs.

PPL ELECTRIC UTILITIES CORPORATION,

Respondent.

COMPLAINT DOCKET
NO. C-2009-2118321

RECEIVED
2010 FEB -2 AM 9:47
P.A.P.U.C.
SECRETARY'S BUREAU


CERTIFICATE OF SERVICE

I hereby certify that I have this date served a true copy of the foregoing document upon the participants, listed below, in accordance with the requirements of § 1.54 (relating to service by a participant):

James A. Schneider, Esquire
439 West Broad Street
Hazleton, PA 18201-6106

Attorney for Complainant

Dated this 9th day of December, 2009.


ANDREW H. RALSTON, JR., ESQUIRE

JAMES A. SCHNEIDER
SOLICITOR FOR DORRANCE TOWNSHIP
439 WEST BROAD STREET
HAZLETON, PA 18201-6106
TEL: 570-454-2489
FAX: 570-454-1132

December 11, 2009

Andrew H. Ralston, Jr., Esquire
33 South Seventh Street
P.O. Box 4060
Allentown, PA 18105-4060
FAX: 610-820-6006

Re: Benjamin Ostrowski, Jr.
vs.
PPL Electric Utilities Corp.
C-2009-2118321

RECEIVED
2010 FEB -2 AM 9:17
PA.P.U.C.
SECRETARY'S BUREAU

Dear Attorney Ralston:


I received your letter and the Certification Of Satisfaction Of Complaint.

I have no problem with paragraphs 1, 2, 3, 4b, 4d, 4e, 4f and 5.

I object to paragraph 4c and specifically the words "does not intend to transfer these 124 customers back to the St. Johns 30-03 line".

I would prefer "and does not intend to transfer these 124 customers back to the St. Johns line 30-03 line unless temporarily as set forth in subparagraph (d) below or in the event that the quarry operating on Small Mountain Road moves or goes out of business as set forth in sub-paragraph (e) below".

Very truly yours,


JAMES A. SCHNEIDER

JAS/jv

cc: Dorrance Township Supervisors

PPL Electric Utilities
Two North Ninth Street
Allentown, PA 18101-1179
Tel. 610.774.5151
www.pplweb.com

December 2, 2009

Benjamin Ostrowski
7197 Blue Ridge Trail
Mountain Top, PA 18707

RECEIVED
2010 FEB -2 AM 9:17
P.A.P.U.C.
SECRETARY'S BUREAU

Dear Mr. Ostrowski:

On August 5, 2009, PPL Electric Utilities permanently transferred 124 residential customers along Blue Ridge Trail, including your residence, to the Blytheburn 86-01 12kV circuit due to an issue with flickering lights on the St. Johns 30-03 12kV line. This was done by removing one span of single phase primary wire at pole 49093N33735 on Blue Ridge Trail to create an electrical separation between the circuits. PPL Electric Utilities is currently reinforcing the lines in the area of Blue Ridge Trail to maintain this permanent configuration and does not intend to permanently transfer these 124 customers back to the St. Johns 30-03 line.

PPL Electric Utilities must still maintain the right to temporarily interconnect the Blytheburn 86-01 and St. Johns 30-03 lines in the event of required system maintenance and/or in response to other emergency situations such as storms or power outages. Once such maintenance work or emergency would be resolved, your service would again return solely to the Blytheburn 86-01 circuit.

At this time PPL Electric Utilities considers this a permanent solution. However, in the future, if PPL Electric Utilities deems that all possible causes of flicker have been removed from the St. Johns 30-03 line (i.e. quarry operation on Small Mountain Road moves or goes out of business, quarry operation on Small Mountain Road is provided with or provides their own circuit, etc) PPL Electric Utilities reserves the right to re-evaluate the customer distribution on these lines so as to provide the most economical and reliable service.

Sincerely,



Timothy R. Figura
Reliability Supervisor – Central Operating Area