



Before the
Pennsylvania Public Utility Commission

**SCHOENECK #1 & #2
138/69 kV TAP LINE**

**Exhibits and Appendices in
Support of the
Letter of Notification**

Application Docket No. _____

Submitted by: PPL Electric Utilities Corp.

SUMMARY

This filing is submitted by PPL Electric Utilities Corporation (PPL Electric) pursuant to the Pennsylvania Public Utility Commission's (PUC) regulations at 52 Pa. Code §§ 57.71 through 57.77 for PUC approval to site and construct the Schoeneck #1 and #2 138/69 kV Transmission Tap Line. The proposed project is located in Lower Macungie Township, Lehigh County.

The proposed tap line will provide the source of electrical supply to the new Schoeneck 69 – 12 kV Substation. The substation and associated 12 kV distribution facilities are required to meet the increasing demand for electricity and improve the reliability of service in the southwestern section of Lehigh County.

The estimated cost to design and construct the proposed 138/69 kV tap line is \$412,400. Due to difficulties in finding a suitable site for the substation, the required in-service date for this project will not be met. Project construction will begin as soon as possible after Commission approval to minimize the potential exposure of an unplanned interruption of electrical service.

This document, which describes the need for the project and discusses the engineering and siting analysis for the proposed construction, consists of the following exhibits and appendices:

- Exhibit "A" - Necessity Statement
- Exhibit "B" - Engineering Description
- Exhibit "C" - Environmental Assessment

- Appendix A - PPL Design Criteria and Safety Practices
- Appendix B - PPL Electric Magnetic Field Management Program
- Appendix C - List of Property Owners Within the Proposed Right-of-Way
- Appendix D - List of Involved Governmental Agencies, Municipalities and Other Public Entities

PPL ELECTRIC UTILITIES SERVICE TERRITORY




EXHIBIT A

EXHIBIT "A"
SCHOENECK #1 & #2 138/69 kV TAP LINE
NECESSITY STATEMENT

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	INTRODUCTION.....	1
B.	EXISTING SYSTEM.....	2
C.	DEFINITION OF THE PROBLEM.....	2
D.	PROPOSED SOLUTION.....	2
E.	FUNCTIONAL ALTERNATIVES.....	3

LIST OF FIGURES

FIGURE 1	FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING FACILITIES.....	4
FIGURE 2	FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED FACILITIES.....	5
FIGURE 3	FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING DISTRIBUTION FACILITIES.....	6
FIGURE 4	FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED DISTRIBUTION FACILITIES.....	7
MAP 1	PPL ELECTRIC TRANSMISSION FACILITY MAP	EXHIBIT "A" MAP POCKET

EXHIBIT "A"
SCHOENECK #1 & #2 138/69 kV TAP LINE
NECESSITY STATEMENT

A. INTRODUCTION

PPL Electric is requesting PUC approval to install a double-circuit 138/69 kV transmission tap line. The proposed Schoeneck #1 & #2 138/69 kV Tap Line will extend approximately 1700 feet from the Victaulic 138/69 kV Tap to the new PPL Electric-owned Schoeneck 69 - 12 kV Substation. The proposed tap line will be designed and constructed to operate as a double-circuit 138 kV line although initially, it will operate as a single-circuit 69 kV tap line until future load increases make it appropriate for the installation of the second circuit and the system to be operated at 138 kV. The proposed facilities are required to serve the projected load increases in the area due to residential growth as well as increased demand at Lower Macungie Industrial Park.

The estimated cost to design and construct the proposed tap line is approximately \$412,400. The required in-service date for this project is May 2010. The required in-service date is defined as the date the proposed facility needs to be placed in service to prevent overloading existing facilities that could potentially damage equipment and result in interruption of service to customers. Due to difficulties in finding a suitable site for the substation, the required in-service date for this project will not be met. Project construction will begin as soon as possible after Commission approval to minimize the potential exposure of an unplanned interruption of electrical service.

A PPL Electric system map showing existing transmission facilities with a design voltage of 35 kV or greater is included in the Exhibit "A" map pocket. This filing addresses only the existing and proposed 138/69 kV system in the Lower Macungie area.


Schoeneck #1 & #2 138/69 kV Tap Line. PPL Electric will own, operate and maintain the new Schoeneck 69 – 12 kV Substation and the Schoeneck 138/69 kV Tap Line. The new Schoeneck 69 - 12 kV Substation will relieve the loading on the Trexlertown 69 - 12 kV Substation and the Macungie 27-4 12 kV Line. Transfer of a portion of the existing load to the new Schoeneck Substation and Tap Line will also improve the reliability and operating flexibility in the area.

The total estimated cost of this project is approximately \$2.7 million, which includes \$2.0 million for the new substation, \$0.4 million for the transmission, and \$0.3 million for distribution work.

E. FUNCTIONAL ALTERNATIVE

An alternative to building the new substation and transmission line would be to increase the transformer capacity at PPL Electric's existing Trexlertown Substation, and build two new lines and terminals; one at Trexlertown Substation and one at Macungie Substation. At an estimated cost of \$3.0 million, this alternative is more expensive to implement. PPL Electric rejected this alternative because the preferred alternative described in Section D above, provides sufficient additional capacity at a lower cost. The preferred alternative also offers additional reliability benefits, and increases operational flexibility.


**Functional One-Line Diagram
Of Existing Facilities**



Note: Only select sectionalizing shown

FIGURE 1


**Functional One-Line Diagram
Of Proposed Facilities**



Note: Only select sectionalizing shown

FIGURE 2


Functional One-Line Diagram Of Existing Distribution Facilities



Note: Only select sectionalizing shown

FIGURE 3

Functional One-Line Diagram Of Proposed Distribution Facilities




Note: Only select sectionalizing shown

FIGURE 4

SUBSTATION LISTING

1	WEST WILLIAMSPORT	151	CRACKERSPORT	301	CENTER CITY
2	FAIRFIELD	152	SCHNECKSVILLE	302	NEW KINGSTOWN
3	MONTGOMERY	153	HEMLOCK	303	REAMSTOWN
4	VARDEN	154	MT. ALLEN	304	DUPONT
5	HONESDALE	155	PRINCE	305	HUMBOLDT
6	JERSEY SHORE	156	WAKEFIELD	306	CEDAR AVE
7	LOGANTON	157	COOPERSBURG	307	INDIAN ORCHARD
8	VALMONT	158	WERTZVILLE	308	NOTTINGHAM
9	RIVER	159	WEST CARLISLE	309	NORTH COOLBAUGH
10	LIMESTONE	160	BENVENUE	310	LETOUR
11	NORTHUMBERLAND	161	HEGINS	311	EAST MOUNTAIN
12	REED	162	LEOLA	312	JERMYN
13	WRIGHT	163	YATESVILLE	313	BLOOMSBURG
14	ST. JOHNS	164	CENTRAL ALLENTOWN	314	MIFFLINTOWN
15	FREELAND	165	DBERLIN	315	RIDGE ROAD
16	GILBERT	166	STRASBURG	316	SUSQUEHANNA
17	* GILBERT	167	ATELEN	317	T-O SW. YD.
18	* GILBERT	168	BROOKSIDE	318	KIMBLES
19	CHERRY HILL	169	WILLIAMSTOWN	319	CHRISTMANS
20	SUSQUEHANNA 230KV	170	C. PETERSBURG	320	OTTER CREEK
21	TAMANEND	171	WERNERSVILLE	321	STEELE CITY
22	WHITE HILL	172	N. BETHLEHEM	322	MCGOVERNVILLE
23	PALMERTON	173	W. ALLENTOWN	323	ROBESONIA
24	HAMILTON	174	FLEMINGTON	324	ELROY
25	HUNTER	175	MECKESVILLE	325	BUSHKILL
26	FAIRVIEW	176	DOANVILLE	326	WALLENPAUPACK
27	* CANADA	177	MILLERSVILLE	327	ELK MOUNTAIN
28	MONTOUR PUMP	178	SHILLINGTON	328	JACK FROST
29	MT. CARMEL	179	DUKE	329	HARWOOD 230/69KV
30	SPORTING HILL	180	MCCALLISTERVILLE	330	HARWOOD 69/12KV
31	MAHANDY CITY	181	WOLFENDLAND	331	NAZARETH
32	GREENWOOD	182	MARLIN	332	ALBURTIS
33	MDWY	183	WEST BERWICK	333	FRACKVILLE
34	ALAMOUNT	184	KEYSER AVENUE	334	* ALBURTIS
35	HAMLIN	185	MICKEYS	335	ELMSPORT
36	ASHFIELD	186	EAST ALLENTOWN	336	ALLENWOOD
37	SOUTH SLATINGTON	187	PINE RIDGE	337	* ALLENWOOD
38	SOUTH MIDDLEBURG	188	DALMATIAT	338	* ALLENWOOD
39	WALKER	189	PENNSBURG	339	GRATZ
40	FRILEY	190	NORTH COLUMBIA	340	HICKERSVILLE
41	MDRGANTOWN	191	HUGHESVILLE	341	BLOOMING GROVE
42	EGYPT	192	TRAIL ALLENTOWN	342	MONROE
43	CRESSINA	193	WEISSPORT	343	LACKAWANNA ##
44	SOUTH WHITEHALL	194	HONEYBROOK	344	STANTON
45	EAST TOWHICKEN	195	WDCSW	345	JACKSON
46	BEAR GAP	196	ROSSMOYNE	346	EAST PALMERTON
47	SALISBURY	197	NORTH HAMPTON	347	SIEGFRIED
48	SOUTH MILTON	198	WOODRICH	348	HOSSENSACK 230/69KV
49	HELDENBERG	199	FAXON	349	HOSSENSACK 500KV
50	LYKENS	200	ELIZABETHTOWN	350	CONESTOGA
51	UPPER HANDOVER	201	ENOLA	351	MANOR
52	RICHLAND	202	TERRE HILL	352	CLINTON
53	MARACA	203	BUCK	353	EXCHANGE
54	ROCKVILLE	204	BETHEL	354	MILTON
55	THOMPSONTOWN	205	RICHFIELD	355	DAUPHIN
56	PAXTON	206	SCRANTON	356	QUARRY SUB.
57	DEALICO	207	TWIN LAKES	357	STEELTON
58	EAST ELIZABETHTOWN	208	HARTLAND	358	JUNIATA 500/230KV
59	WARWICK	209	HALEIGH	359	JUNIATA 230/69KV
60	EARL	210	TAFTON	360	CUMBERLAND
61	HEMPFIELD	211	BEAR CREEK	361	DUNEGAL
62	EAST LANCASTER	212	DRYSDALE	362	JENKINS 230/69KV
63	KINZER	213	EAST TEXAS	363	JENKINS CTG
64	MT. NEBO	214	CANDENSIS	364	WILKES-BARRE
65	MT. POCONO	215	LINDEN	365	BUXMONT
66	PENNS	216	MT. JOY	366	SOUTH AKRON 230/138/69KV
67	PAULSBORO	217	WEST BLOOMSBURG	367	SOUTH AKRON 69/12KV
68	DILLERVILLE	218	MINSI TRAIL	368	SOUTH MANHEIM 69/12KV
69	GIRARD MANOR	219	LAKE NADMI	369	SOUTH MANHEIM 230/69KV
70	KENMAR	220	LANARK	370	ENGLESIDE
71	GDWEN CITY	221	MONTOURSVILLE	371	COLUMBIA
72	* GDWEN CITY	222	PORT CARBON	372	DANVILLE
73	* GDWEN CITY	223	BLTYHEBURN	373	SUNBURY
74	ELLIOT HEIGHTS	224	MILFORD	374	LUMMEL'S WHARF
75	RDHRESTDWN	225	TREHILLERS	375	LYCOMING
76	MACUNGIE	226	ROSEVILLE	376	LOCK HAVEN CTG
77	EAST HAZLETON	227	RUTHERFORD	377	HUMMELSTOWN 69/12KV
78	EAST CARBONDALE	228	HARTLAND	378	WEST SHORE
79	EVNONG	229	COLUMBIA	379	MONTAGE
80	MINDOHA	230	POINT NEW HOLLAND	380	SOUTH FARMERSVILLE
81	OLD FORGE	231	WEST NEW HOLLAND	381	WESCOSVILLE
82	FOUNTAIN SPRINGS	232	LAKEVILLE	382	FISHBACH
83	SULLIVAN TRAIL	233	NORTH MANHEIM	383	BERKS
84	* SULLIVAN TRAIL	234	HATFIELD	384	MENTOUR
85	* SULLIVAN TRAIL	235	HERSHEY	385	SUBURBAN YARD
86	* SULLIVAN TRAIL	236	S. HERSHEY	386	* SULLIVAN TRAIL
87	* SULLIVAN TRAIL	237	S. WILLIAMSPORT	387	* SULLIVAN TRAIL
88	* SULLIVAN TRAIL	238	FDGELSVILLE	388	* SULLIVAN TRAIL
89	* SULLIVAN TRAIL	239	WINDSOR	389	* SULLIVAN TRAIL
90	* SULLIVAN TRAIL	240	W. WILLOW	390	* SULLIVAN TRAIL
91	* SULLIVAN TRAIL	241	WESTGATE	391	* SULLIVAN TRAIL
92	* SULLIVAN TRAIL	242	EDELA	392	* SULLIVAN TRAIL
93	* SULLIVAN TRAIL	243	SUMMEYDALE	393	* SULLIVAN TRAIL
94	* SULLIVAN TRAIL	244	BORNEVILLE	394	* SULLIVAN TRAIL
95	* SULLIVAN TRAIL	245	BOHEMIA	395	* SULLIVAN TRAIL
96	* SULLIVAN TRAIL	246	WHITE HAVEN	396	* SULLIVAN TRAIL
97	* SULLIVAN TRAIL	247	LAURELTON	397	* SULLIVAN TRAIL
98	* SULLIVAN TRAIL	248	LINGLESTOWN	398	* SULLIVAN TRAIL
99	* SULLIVAN TRAIL	249	POCONO FARMS	399	* SULLIVAN TRAIL
100	* SULLIVAN TRAIL	250	HICKORY RUN		
101	* SULLIVAN TRAIL	251	BLOOMING GLEN		
102	* SULLIVAN TRAIL	252	SHERMANSDALE		
103	* SULLIVAN TRAIL	253	* HARRY'S CREEK		
104	* SULLIVAN TRAIL	254	SPANGLER MILLS		
105	* SULLIVAN TRAIL	255	DANVILLE		
106	* SULLIVAN TRAIL	256	WELAND		
107	* SULLIVAN TRAIL	257	CARBON		
108	* SULLIVAN TRAIL	258	SELLERSVILLE		
109	* SULLIVAN TRAIL	259	MECHANICSBURG		
110	* SULLIVAN TRAIL	260	CARLISLE		
111	* SULLIVAN TRAIL	261	CEDAR		
112	* SULLIVAN TRAIL	262	ARRDHEAD		
113	* SULLIVAN TRAIL	263	NEUPORT		
114	* SULLIVAN TRAIL	264	HALIFAX		
115	* SULLIVAN TRAIL	265	MILLERSBURG		
116	* SULLIVAN TRAIL	266	MUNCY		
117	* SULLIVAN TRAIL	267	HAUTO		
118	* SULLIVAN TRAIL	268	BERWICK		
119	* SULLIVAN TRAIL	269	SHEMANDDAH		
120	* SULLIVAN TRAIL	270	LINE GROVE		
121	* SULLIVAN TRAIL	271	STROUDSBURG		
122	* SULLIVAN TRAIL	272	FREEMANSBURG		
123	* SULLIVAN TRAIL	273	ALLENTOWN		
124	* SULLIVAN TRAIL	274	BINGEN		
125	* SULLIVAN TRAIL	275	RHEIMS		
126	* SULLIVAN TRAIL	276	CLEVELAND		
127	* SULLIVAN TRAIL	277	LITTLE GAP		
128	* SULLIVAN TRAIL	278	DRIVILLA		
129	* SULLIVAN TRAIL	279	TUSCARORA		
130	* SULLIVAN TRAIL	280	BARTONSVILLE		
131	* SULLIVAN TRAIL	281	ALTON PARK		
132	* SULLIVAN TRAIL	282	SALEM		
133	* SULLIVAN TRAIL	283	NORTH BRIDGEPORT		
134	* SULLIVAN TRAIL	284	HAMPDEN		
135	* SULLIVAN TRAIL	285	CAMELBACK		
136	* SULLIVAN TRAIL	286	SILVER SPRING		
137	* SULLIVAN TRAIL	287	BRACKNOCK		
138	* SULLIVAN TRAIL	288	BENTON		
139	* SULLIVAN TRAIL	289	MCMICHAELS		
140	* SULLIVAN TRAIL	290	HUGHESVILLE		
141	* SULLIVAN TRAIL	291	NEWVILLE		
142	* SULLIVAN TRAIL	292	POINTE NORTH		
143	* SULLIVAN TRAIL	293	MARIETTA		
144	* SULLIVAN TRAIL	294			
145	* SULLIVAN TRAIL	295			
146	* SULLIVAN TRAIL	296			
147	* SULLIVAN TRAIL	297			
148	* SULLIVAN TRAIL	298			
149	* SULLIVAN TRAIL	299			
150	* SULLIVAN TRAIL	300			



INTERCONNECTIONS

PS PUBLIC SERVICE ELECTRIC AND GAS CO. OF N.J.
 ME METROPOLITAN EDISON CO. (FIRST ENERGY)
 PHILADELPHIA ELECTRIC CO. (PECO ENERGY)
 BC BALTIMORE GAS AND ELECTRIC CO.
 SH SAFE HARBOR WATER POWER CORPORATION
 UP THE UNITED GAS IMPROVEMENT CO. - LUZERNE ELECTRIC DIVISION
 JN PENNSYLVANIA ELECTRIC CO. (FIRST ENERGY)
 JC JERSEY CENTRAL POWER AND LIGHT CO. (FIRST ENERGY)

- COMBUSTION TURBINE
- HYDRO ELECTRIC
- COMBINATION
- FIRM SALES
- SUBSTATION / SWITCHING STATION
- STEAM ELECTRIC
- NON-UTILITY GENERATION
- INDEPENDENT POWER PRODUCERS

- 500KV OPERATION
- 230KV OPERATION
- 138KV OPERATION
- 69KV OPERATION

* - SUBSTATIONS THAT HAVE BEEN RETIRED.
 ## - SITE OF THE EXISTING 230KV SUBSTATION AND PROPOSED 500KV SUBSTATION

ACCT- 805201	ELECTRICAL SYSTEM MAP		
SCALE- NONE	SCHOENECK 138/69KV TAP LINE		
BY- CDW	APPROVED	DATE	PPL ELECTRIC UTILITIES
	G. HAKUN III	7/1/785	
PPL DRAWING NO.	SHEET NO.	REV.	
D191830	1	53	

52	2/20/09	0012375	ADDED FIRST QUALITY NONWOVENS 138/69KV TAP LINE	RRC	NHU
51	2/17/09	389358	ADDED BELTZVILLE 138KV TAP LINE.	RRC	NHU
50	2/21/09	389346	ADDED JESSUP 138/69KV TAP LINE	RRC	NHU
53	2/25/09	389349	SCHOENECK 138/69KV TAP LINE	RRC	KEK
ND.	DATE	ACCT.		BY	REVIEWED




EXHIBIT B

EXHIBIT "B"
SCHOENECK #1 & #2 138/69 kV TAP LINE
ENGINEERING DESCRIPTION

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	DESCRIPTION OF PROPOSED LINE DESIGN.....	1
B.	MAGNETIC FIELD MANAGEMENT.....	3
C.	RIGHT-OF-WAY STATUS.....	3

LIST OF TABLES

TABLE 1	DESIGN MINIMUM CONDUCTOR CLEARANCES.....	2
TABLE 2	CONDUCTOR THERMAL RATING.....	2

LIST OF FIGURES

FIGURE 1	PROPOSED 138/69 kV TANGENT STRUCTURE.....	4
FIGURE 2	PROPOSED 138/69 kV ANGLE STRUCTURE.....	5

MAP

AERIAL EXHIBIT

EXHIBIT "B" MAP POCKET

EXHIBIT “B”
SCHOENECK #1 & #2 138/69 kV TAP LINE
ENGINEERING DESCRIPTION

A. DESCRIPTION OF PROPOSED LINE DESIGN

PPL Electric proposes to construct a new approximately 1,700 foot long, double-circuit 138/69 kV Tap from the existing Victaulic 138/69 kV Tap to the new Schoeneck 69 – 12 kV Substation. The proposed tap line will be designed and constructed to operate as a double-circuit 138 kV line although initially, it will operate as a single-circuit 69 kV tap line until future load increases make it appropriate for the installation of the second circuit and the system to be operated at 138 kV. The proposed line will be located in Lower Macungie Township, Lehigh County. Refer to the aerial location map in the Exhibit “B” map pocket.

The proposed line will consist of approximately five single-shaft steel poles. The poles will average approximately 90 feet tall. The tap pole will be guyed and the angle structures will be installed on concrete foundations. Tangent structures will be direct-embedded. The proposed structures are shown in Figures 1 and 2 at the end of Exhibit “B”. Initially, three power conductors (single circuit) and one overhead ground wire will be installed. The conductors will be 556.5 kcmil 24/7 stranding ACSR. A 3/8-inch diameter high strength steel overhead ground wire will be installed for lightning protection.

The proposed line will be designed to, and generally exceed, National Electrical Safety Code standards. Design specifications and safety rules practiced by PPL Electric are included in Appendix A. The minimum conductor to ground clearance for the proposed line will be 32 feet which occurs at a maximum conductor temperature of 125°C. The designed minimum conductor clearances and conductor thermal ratings are as follow:

TABLE 1
DESIGN MINIMUM CONDUCTOR CLEARANCES
FOR 556.5 KCMIL 24/7 STRANDING ACSR*
SCHOENECK #1 & #2 138/69 kV TAP LINE

<u>Condition</u>	Transmission Double-Circuit Design <u>Clearance-to-Rail</u>	Transmission Double-Circuit Design <u>Clearance-to-Ground</u>
Normal load average weather (16°C ambient temperature)	47.5 feet	40.2 feet
Predicted extreme thermal load (125°C conductor temperature)	45.0 feet	33.6 feet
Predicted extreme weather conditions (1 inch ice, 4 lb. Wind, -18°C)	46.0 feet	39.0 feet

*Clearances based on a maximum tension of 9,900 pounds and a ruling span of 700 feet.

CONDUCTOR THERMAL RATING
556.5 KCMIL 24/7 STRANDING ACSR
125°C MAXIMUM CONDUCTOR TEMPERATURE

<u>Condition</u>	Ambient <u>Temperature °C</u>	Wind Speed <u>Knots</u>	Ampacity <u>Amps</u>
Summer Normal	35	0	799
Winter Normal	10	0	922
Summer Emergency	35	1-1/2	1045
Winter Emergency	10	1-1/2	1178

B. MAGNETIC FIELD MANAGEMENT

PPL Electric's Magnetic Field Management Program is summarized in Appendix B and applied to reconstruction and new line projects. In order to lower magnetic field exposures, the program generally prescribes the use of line design that provides 5 feet higher ground clearances and reverse phasing new double-circuit lines where it is feasible to do so at low or no cost. The implementation of additional modifications will be considered, provided those modifications can be made at low or no cost.

For this project, reverse phasing cannot be utilized to reduce magnetic field levels because initially, only one circuit is being installed. PPL Electric will evaluate reverse phasing when the second circuit is added in the future. However, some reduction of the magnetic field will be achieved through the use of taller poles.

C. RIGHT-OF-WAY STATUS

Right-of-way for the proposed tap is required from three property owners. To date, agreements have been secured from two property owners. PPL Electric continues to negotiate with the remaining property owner and anticipates reaching an agreement in the near future. The Aerial Exhibit at the end of Exhibit "C" shows existing property lines and current ownership along the right-of-way. Appendix "C" identifies the property owners within the proposed right-of-way.

FIGURE 1
PROPOSED 138/69 kV TANGENT STRUCTURE




Average Height – 90 Feet

Length of Top Arms – 7 Feet

Length of Lower Arm – 11 Feet

FIGURE 2
PROPOSED 138/69 kV ANGLE STRUCTURE



Average Height – 90 Feet

Length of Top Arms – 7 Feet

Length of Lower Arm – 11 Feet

PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT WRITTEN AUTHORIZATION FROM PPL ELECTRIC UTILITIES.



PROPERTY OWNERS

- 1. HEADLANDS REALTY CORP.
- 2. ALEX G. TAMERLER
- 3. NORFOLK SOUTHERN RAILWAY COMPANY
- 4. ALTHEA M. WALBERT
- 5. PPL ELECTRIC CORP.



ACCT- 10012611	SCHOENECK #1 & #2 138/69KV TAP	
SCALE- 1"=300'	AERIAL EXHIBIT	
BY- RWM		
REVIEWED	LOWER MACUNGIE TWP.	LEHIGH CO., PA.
	APPROVED	DATE
	<i>Kenneth B. Kuhns</i>	9/18/09
PPL DRAWING NO.	SHEET NO.	REV.
	EXHIBIT	1 0

REFERENCE TITLE	NUMBER	NO.	DATE	ACCT.	REVISION	BY	REVIEWED	APPROVED



PPL ELECTRIC UTILITIES FORM EU (001)

EXHIBIT C

EXHIBIT "C"
SCHOENECK #1 & #2 138/69 kV TAP LINE
ENVIRONMENTAL ASSESSMENT

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	INTRODUCTION.....	1
B.	LAND USE.....	1
C.	CULTURAL RESOURCES.....	2
D.	NATURAL FEATURES.....	2
E.	THREATENED AND ENDANGERED SPECIES.....	3

EXHIBIT "C"
SCHOENECK #1 & #2 138/69 kV TAP LINE
ENVIRONMENTAL ASSESSMENT

A. INTRODUCTION

PPL Electric is requesting PUC approval to site and construct a double-circuit 138/69 kV transmission tap line. The proposed line is approximately 1,700 feet long and involves the installation of approximately five single-shaft steel poles. The tap line will be designed for ultimate double-circuit 138 kV operation although initially, only one circuit will be installed and it will be operated at 69 kV.

The proposed project was reviewed with representatives of Lower Macungie Township and Lehigh County, and neither the Township nor the County has any objection. A list of involved governmental agencies, municipalities and other public entities is presented in Appendix C.

B. LAND USE

The proposed tap line is located along Quarry Road just north of Alburdis Borough. A new, partially occupied distribution center is found on the east side of Quarry Road. Across the road from the distribution center is a myTableware.com authorized retailer. A Victaulic facility is to the south of myTableware.com. The Lower Macungie Township Community Park is located approximately 500 feet northeast of the northern terminus of the proposed tap. Due to the industrial development in the area, visual impacts to the park will be minimal.

No communication towers, pipelines or other utilities will be affected by the proposed project. A nearby railroad is easily spanned by the proposed line and will not be impacted. Queen City Airport is approximately 6.4 miles from the project area. PPL Electric will file the appropriate documentation with both the Federal Aviation Administration and the PennDOT Bureau of Aviation to ensure the proposed tap line will not be a hazard to the airport's flight operations.

C. CULTURAL RESOURCES

This project was reviewed with the Pennsylvania Historical and Museum Commission (PHMC). PHMC has determined that, based upon their survey files which include both archaeological sites and standing structures, there are no National Register eligible or listed historic or archaeological properties in the area of this proposed project and therefore, no further archaeological investigations are required (File No. ER 2009-1026-077-A).

D. NATURAL FEATURES

The proposed tap line will not affect any unique geological, scenic, or natural areas. No National Natural Landmarks, parks, or recreational facilities are located near the project area. Tree clearing will be minimal and PPL Electric will apply its "Specification for Initial Clearing and Control of Vegetation On or Adjacent to Electric Line Right-of-Way Through Use of Herbicides, Mechanical and Hand Clearing Techniques" to mitigate any impacts. The proposed tap line will not cross any wetlands or other aquatic resources. As required, PPL Electric will acquire and adhere to the terms and conditions of any required soil erosion and sedimentation control plans as appropriate.

E. THREATENED AND ENDANGERED SPECIES

PPL Electric has coordinated with different state and federal agencies to obtain information regarding endangered and threatened plant and animal habitat in close proximity to the project area. Both the Pennsylvania Fish and Boat Commission and the U. S. Fish and Wildlife Service note the potential presence of the bog turtle (*Glyptemys muhlenbergii*, state endangered, federally listed threatened) in the area of the proposed project. PPL Electric retained the services of recognized wetland and bog turtle experts to investigate further.

A review of the substation site and the transmission line route note the absence of wetlands in or near the project area. Because the bog turtle inhabits wetlands with specific characteristics, a lack of wetlands indicates that no bog turtles exist in the project area. PPL Electric will file the proper reports to clear this conflict with both agencies prior to the start of construction.

Appendices

LIST OF APPENDICES

APPENDIX A – PPL Electric Design Criteria and Safety Practices

APPENDIX B – Magnetic Field Management at PPL Electric

APPENDIX C – List of Property Owners Within the Proposed Right-of-Way

**APPENDIX D – List of Involved Governmental Agencies, Municipalities, and Other
Public Entities**

APPENDIX A

PPL DESIGN CRITERIA AND SAFETY PRACTICES

The National Electrical Safety Code (NESC) is a set of rules to safeguard people during the installation, operation, and maintenance of electric power lines. The NESC contains the basic provisions considered necessary for the safety of employees and the public. Although it is not intended as a design specification, its provisions establish minimum design requirements. PPL Electric Utilities Corp. (PPL) has developed design specifications and safety rules which meet or surpass all requirements specified by the NESC.

Engineering Design Criteria and Parameters

The NESC includes loading requirements and clearances for the design, construction, and operation of power lines. The "loads" on conductors and supporting structures are the mechanical forces that develop from the weight of the conductors, the weight of ice on the conductors, plus wind pressure on the conductors and supporting structures. Loading requirements are the loads on the conductors and structures that are anticipated assuming certain ice and wind conditions. Loading requirements always contain "safety factors" to allow for unknown or unanticipated contingencies. The clearances and loading requirements contained in the NESC were developed to ensure public safety and welfare.

PPL transmission line design standards meet or surpass the NESC standards. For example, the relative order of grades of construction for conductors and supporting structures is B, C, and N; Grade B being the highest. According to the NESC standards, construction Grades B, C, or N may be used for transmission lines (except at crossings of railroad tracks and limited access highways where Grade B construction is specified). However, PPL designs all of its transmission lines for Grade B construction. The use of Grade B design and construction specifies enhancements such as larger-minimum crossarm dimensions, larger-minimum conductor size, and increased safety factors.

Another example is the design parameters utilized to account for ice and wind loadings on the overhead ground wire (OHGW) and power conductors. The NESC standard ice and wind design magnitudes for the PPL territory are 0.5 inch thickness of radial ice combined with four pounds per square foot horizontal wind pressure (equivalent to 40-mile per hour wind velocity). The conductor sags and tensions used in line designs are the result of various ice and wind combinations, depending on the elevation at the line location and line design voltage. The conductor sags and tensions used in the design of all PPL transmission lines are at least 0.5-inch ice combined with eight pounds wind pressure (equivalent to 57 miles per hour wind velocity). This means that PPL lines are designed to operate safely and reliably during inclement weather even more severe than assumed by the NESC. In addition, PPL transmission lines are designed with more clearance to the ground than required by the NESC. The tables below compare PPL and NESC ground clearances for lines of various voltages.

138 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Design</u>
Roads, streets, alleys	21 Ft.	30 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	21 Ft.	30 Ft.
Spaces accessible to pedestrians only	17 Ft.	30 Ft.
Railroad tracks	31 Ft.	35 Ft.

230 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Design</u>
Roads, streets, alleys	23 Ft.	32 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	23 Ft.	32 Ft.
Spaces accessible to pedestrians only	19 Ft.	32 Ft.
Railroad tracks	31 Ft.	36 Ft.

500 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Design</u>
Roads, streets, alleys	28 Ft.	53 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	28 Ft.	53 Ft.
Spaces accessible to pedestrians only	24 Ft.	53 Ft.
Railroad tracks	38 Ft.	53 Ft.

A relay protection system is used to protect the public safety and welfare as well as equipment and the transmission system. Relay protection is installed for all transmission lines to automatically de-energize the line in the unlikely event that the line or supporting structure fails and the line contacts the ground.

Periodic Maintenance Program on All Transmission Lines

To ensure continued public safety and integrity of service, a periodic maintenance and inspection program is implemented for every transmission line. The program is administered through the use of helicopter patrols, with supplemental foot and structure

climbing patrols. A number of helicopter patrols are performed on all lines annually. The two-man helicopter crew flies parallel, to the left, and above the line so that the observer can look for signs of line damage or deterioration and observe clearances between vegetation and conductors. The observations are included in a report that is forwarded to the appropriate department for corrective action.

Foot and structure climbing patrol programs for a transmission line begin approximately three to five years after the line is energized, unless a helicopter patrol reports a need for earlier action. The frequency of foot patrols varies from once every year to once every several years depending on line type and age.

An assigned foot patroller checks right-of-way conditions, including access roads, bridges, pole washouts, tower footers, vegetation height and clearance to conductors, pole and tower deterioration and, with the use of binoculars, insulators, and condition of hardware. Identified problems are included in a report that is forwarded to the appropriate department for corrective action.

A scheduled line outage is required to perform an overhead patrol because of "hands-on" inspection of hardware. Overhead patrols are conducted on a schedule determined by line age, operating record, and observed general condition. The necessary repairs are also done during the inspection outage.

Personnel Safety Rules

The following are a few of the PPL safety rules that demonstrate the Company's concern for employee safety:

- Work procedures have been developed to allow work to be performed on energized facilities in a safe manner. When lines or apparatus are removed from service to be worked on, the Energy Control Process system is applied. This system provides that a red tag must be physically placed on the control handle of the de-energized equipment. The red tag may be removed only after proper authorization to energize the equipment. Various other tags are used for limited operations and informational purposes.

Employees will not apply or remove a tag or change the status of tagged equipment unless authorized.

- Temporary safety grounds are used on de-energized facilities for employee safety during maintenance, construction, or reconstruction work. Safety grounds are wires connecting the de-energized facility to an electrical ground. If the facility should be energized, the safety grounds will divert the current directly to ground and reduce the likelihood of personal injury. The conductor size and attachment clamps of temporary safety grounds must be capable of conducting anticipated fault currents. Rubber gloves, rubber sleeves, and additional rubber protective equipment are used as required when applying or removing temporary safety grounds to or from the lines or apparatus to be grounded. An approved nonconductive working stick of sufficient length to allow workers to maintain the following required minimum clearances is used to test that the line has been de-energized and to apply temporary safety grounds:

<u>Voltage-kV</u>	<u>Minimum Clearance</u>
138	3'-7"
230	5'-3"
500	11'-3"

Before applying grounds, a test is done to confirm that the line is de-energized. The voltage test device is checked before and after use to assure reliability. When ground pins are used to establish proper ground points, they are driven to a depth of not less than four feet as near vertical as possible.

- Poles or structures are inspected and examined for structural integrity before climbing. If there is any reason to believe that a pole is unsafe, it is stabilized before work is performed. Appropriate safety gear in the form of body belts, safety straps, hard hats, gloves, etc., is worn by linemen during line work activity.



**MAGNETIC
FIELD
MANAGEMENT**
**PPL Electric Utilities
Corporation**

APPENDIX B

DECEMBER 2004

TABLE OF CONTENTS

INTRODUCTION 1

DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM..... 6

VARIABLES THAT AFFECT MAGNETIC FIELDS 6

 Effect of Phase Current on Magnetic Fields 6

 Effect of Conductor Configuration on Magnetic Fields 7

 Effect of Distance from the Magnetic Field Source 7

SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM..... 8

MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES 9

 Overhead Lines 9

 New or Rebuilt Transmission Lines 9

 Reconductoring or Adding Additional Circuits to Existing Transmission Lines 14

 Distribution Lines 14

 Underground Transmission Lines 15

CHARTS 16

INTRODUCTION

At PPL Electric Utilities Corp. (PPL EU), magnetic field management means investigating and implementing methods at low or no cost to reduce magnetic fields in new or rebuilt transmission and distribution lines. This document explains PPL EU's Magnetic Field Management Program, which is part of PPL EU's larger Electric and Magnetic Fields (EMF) policy.

PPL EU's View

Some people are worried that electric and magnetic fields are harming their health. Others think the scientific research does not show a problem at all, and still others believe there's just too much scientific uncertainty to draw any conclusions.

Here's what we do know now. Various panels of scientists that have reviewed the EMF research generally have drawn two main conclusions. First, the large body of evidence does not demonstrate that EMF are harmful. Second, additional research is recommended to explore questions raised in some studies.

Given these conclusions, PPL EU is taking a reasoned approach in responding to the EMF issue. PPL EU's approach to the EMF issue consists of five elements:

- Providing EMF information to customers and employees
- Providing magnetic field measurements
- Establishing and implementing a magnetic field management program to reduce magnetic fields in new or rebuilt facilities when it can be done at no, or low, cost
- Integrating EMF in the public involvement process that PPL EU undertakes in the siting of transmission lines
- Have supported additional research

EMF Are All Around Us

Electric and magnetic fields occur in nature and in all living things. The earth, for instance, has a magnetic field, which makes the needle on a compass point north.

Electric fields and magnetic fields of a different type also surround every wire that carries electricity. In everyday life, these EMF arise from several basic sources, including power lines, electrical appliances, home and building wiring, other utility lines and cables, and currents flowing on water pipes. Though they often occur together, EMF are made up of two separate components:

Electric Fields

Electric fields are produced by the voltage—or electrical pressure—on a wire. The higher the voltage, the higher the electric field. As long as a wire is energized—has voltage present—an electric field is present (see Figure 1). In other words, an appliance, or an electric power line, doesn't actually have to be turned on to create an electric field. It just has to be plugged in. Electric fields diminish with distance and can be blocked or partially shielded by objects such as trees and houses.

Magnetic Fields

Magnetic fields are created by the current or flow of electricity through a wire. Generally speaking, the higher the current, the higher the magnetic field. Because they only occur when current is flowing, magnetic fields are present only when the power is turned on (see Figure 1). Magnetic fields also diminish with distance, but—unlike electric fields—are not blocked by common objects. In recent years, public and scientific interest has turned toward the magnetic field component of EMF because of some scientific studies regarding these fields.

Figure 1




Figure 2









Magnetic field strengths decrease with distance Magnetic fields are measured in milligauss		Source: "EMF in Your Environment", U.S. Environmental Protection Agency 1992		
		At 6 inches	At 1 foot	At 2 feet
Clothes dryer		2 to 10	* to 3	*
Microwave oven		100 to 300	1 to 200	1 to 30
Toaster		5 to 20	* to 7	*
Power drill		100 to 200	20 to 40	3 to 6
Can opener		500 to 1500	40 to 300	3 to 30
Mixer		30 to 600	5 to 100	* to 10
Hair dryer		1 to 700	* to 70	* to 10
Color television		Data not available	* to 20	* to 8

FIGURE 2 * The magnetic field measurement at this distance from the operating appliance could not be distinguished from background measurements taken before the appliance had been turned on.

Measuring Magnetic Fields

Magnetic fields usually are measured in a unit called a milligauss. Magnetic field levels found in the living areas of homes typically range from less than 1 milligauss to about 4 milligauss according to the U.S. Environmental Protection Agency. They can be higher in some cases. The levels next to appliances can exceed 1,000 milligauss (1 gauss). Figures 2 and 3 show how the strength of the field falls off as you move away from the source, just as the heat of a campfire grows weaker as you walk away from it. For overhead power lines, the strength of the magnetic fields is dependent upon a number of factors that will be explained later. Those factors produce a magnetic field that drops off rapidly as you move away from the power line.

Figure 3

Sample Magnetic Field Levels in Milligauss				
Type of Overhead Power Line	Distance from the line			
	Under the line	50 ft.	100 ft.	200 ft.
220 kV and 500 kV	5-400	5-250	1-75	0.5-20
69 kV and 138 kV	3-80	0.5-2.5	0.1-10	0.1-3
12 kV and below	0.4-20	0.1-1	-	-

The magnetic field values provided in this table represent a general range of values associated with the types of overhead power lines listed and are provided for illustration. There will be circumstances in which there will be magnetic field levels above or below the range of values provided due to variations in such factors as height of the wires, current flow and so on.

DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

One element of our response to EMF concerns expressed by some of our customers is PPL EU's Magnetic Field Management Program. The program was initiated in March 1991 because PPL EU believes it makes good sense, as a matter of policy, to respond to the concerns expressed by some of our customers and to reduce magnetic fields in new and rebuilt facilities where it can be done with either no-cost or low-cost design changes.

This document updates the original program which has been revised several times since 1991. These guidelines were developed by PPL EU's EMF Working Group.

VARIABLES THAT AFFECT MAGNETIC FIELDS

Magnetic fields from transmission and distribution lines are a function of a number of design variables. The following parameters affect the magnetic field levels produced by transmission and distribution lines:

- Current
- Height of conductors above ground
- Configuration of conductors
- Distance from the line

EFFECT OF PHASE CURRENT ON MAGNETIC FIELDS

At power frequencies (i.e., 60 hertz), the magnetic field level is a function of the current or flow of electricity through a wire. Keeping all other parameters the same, the magnetic field is proportional to the current. Hence, if the current increases by 25 percent, the resulting magnetic field level will increase by 25 percent.

The overall load current on any line varies with the demand for power. It's usually highest during daytime hours and lowest at night. There also are weekly, monthly, seasonal and yearly variations.

The difference in the currents between each phase in a multiphase line also can affect the magnetic field. This difference is called phase unbalance. For a constant load, a statistical analysis of this phase unbalance can be made to determine its effect on the magnetic field. Close to the line, there is very little effect. However, the phase unbalance slows the rate at which the magnetic field decreases with distance from the line.

EFFECT OF CONDUCTOR CONFIGURATION ON MAGNETIC FIELDS

In the transmission and distribution of power, utilities like PPL EU presently use both three-phase and single-phase lines. Each phase on a three-phase power line has either a single conductor or a bundle of two or more conductors. In a three-phase system, the ground-level magnetic field is a result of the fields produced by the currents in each of the phases. Placing the three phases as close together as possible (compaction) creates some field cancellation, and the ground-level magnetic field is reduced. However, appropriate phase separation is required for the reliable operation of the line. In addition, the arrangement of the phases can create some; field cancellation and reduction of the ground-level magnetic field.

EFFECT OF DISTANCE FROM THE MAGNETIC FIELD SOURCE

Magnetic field strength diminishes with the vertical and lateral distances from the magnetic field source. Increasing the height of the conductors above ground is useful for magnetic field reduction at ground level, but may result in increased structure costs and increased aesthetic impact of the structures. Another possible method of increasing the distance to the magnetic field source is to increase the right-of-way requirements. By keeping buildings off increased rights of way, thereby requiring the public to live and work further away from lines, exposure to magnetic fields produced by the lines can be reduced. Increases in right of way are not always practical and may increase costs significantly, however.

SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

Under its Magnetic Field Management Program, PPL EU has changed the way it builds and rebuilds some of its transmission and distribution lines. These design changes reduce magnetic field levels (assuming balanced circuit loadings and phase currents) by up to 69 percent in most of the company's new transmission lines. These guidelines now are being applied to new and reconstructed transmission facilities, based on this program.

The distribution component of the program focuses on 12 kV lines, the company's standard distribution voltage. It concentrates on the three-phase, primary 12 kV lines, since these are the most heavily loaded facilities and often are located in densely populated areas. The guidelines in this program are being applied to these three-phase, primary 12 kV lines.

A maximum 3-5 percent change in estimated cost was used as the limit for the guidelines since this value is consistent with low cost, is within estimating accuracy and is likely to have little impact on overall line costs.

The magnetic field calculations used in this document for the design of PPL EU's overall magnetic field management plan assume balanced load conditions among the phases and a fixed level of current, not necessarily representative of specific transmission or distribution lines. These levels were calculated using the Electric Power Research Institute's ENVIRO computer program. Under actual operating conditions, the magnetic field levels that result may vary due to such things as actual load per circuit, overall current on each phase conductor and the electrical configuration and operation of each line.

MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES

The guidelines for magnetic field management are noted below, with discussion points for each.

OVERHEAD LINES

NEW OR REBUILT TRANSMISSION LINES

- 1. Balance transmission circuit loads and phase currents as much as possible.**
 - PPL EU should continue to make every effort to balance loadings between the two circuits of a double circuit line when planning new or rebuilt facilities to maximize the effects of reverse phasing.
 - PPL EU should continue the practice of balancing single-phase loads across the three phases of the distribution system. (Unbalanced phase currents on the distribution system are reflected through to the transmission system.)
 - Unbalanced phase currents result in higher magnetic fields that do not drop off as quickly with distance as do the fields resulting from balanced phase currents.
 - For a 5 percent phase current unbalance, the magnetic field 50 feet from the centerline of a single circuit 138 kV line could be more than twice the value than if the same line had balanced phase circuits.
 - Balanced phase currents on each three-phase distribution circuit also reduce magnetic fields from the distribution circuits themselves. In addition, they reduce magnetic fields on the transmission system from which the distribution system circuits are supplied and connected through substations.
 - Apart from magnetic field considerations, balanced phase currents on each three-phase distribution circuit also reduce line losses and improve the system voltage.

2. **Continue with the present practice of using long-span construction as the PPL EU 138/69 kV standard**
 - Structure designs for short-span and long-span construction are illustrated on Charts I and II, respectively.
 - Short-span design does not significantly reduce magnetic fields when compared to long-span design even though it is more compact than long-span design. Comparison of the magnetic field values from Chart III indicates essentially the same values. Therefore, short-span design should not be used solely to reduce magnetic fields.
 - PPL EU will continue to use long-span construction for 138/69 kV double-circuit lines and for single-circuit/future-double-circuit lines.
 - For single-circuit/future-double-circuit lines, PPL EU will continue to install two conductors on the top positions and one in the middle position as shown in Chart IV.
 - This arrangement minimizes magnetic fields as shown in Chart V by placing the three initial conductors higher on the structure, which increases the ground clearances, and by placing the conductors in a triangular configuration.
3. **Compact design structures are not a low-cost alternative and should be used for magnetic field reduction only in special applications.**

Chart VI illustrates the compact design structure.

 - The compact design increases the initial installation costs by 79 percent when compared to the long-span design but reduces the magnetic field from 9 mG to 3 mG (about 67 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.
4. **Reverse phase new or rebuilt double-circuit transmission lines for all voltage levels.**
 - Reverse phasing was adopted by PPL EU in March 1991 for double-circuit 138/69 kV transmission lines and in April 1992 for all other double circuit transmission lines. Reverse phasing is shown in Chart VII. Reverse phasing will reduce the magnetic fields when the current flow on both circuits is in the same

direction. Calculated values contained here are based on balanced and equal phase currents on both circuits.

- Reverse phasing reduces the magnetic field of a double circuit 138 kV single pole transmission line from 29 mG to 9 mG (about 69 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.
- Reverse phasing reduces the magnetic field of a double circuit 230 kV single pole transmission line from 49 mG to 16 mG (about 67 percent) at the edge of the 150-foot-wide right of way as shown on Chart VIII.
- Reverse phasing reduces the magnetic field of a double-circuit 500 kV single pole transmission line from 37 mG to 21 mG (about 43 percent) at the edge of the 200-foot-wide right of way as shown on Chart IX.
- When new or rebuilt double-circuit lines require tapping existing double-circuit lines, PPL EU will review the existing lines to determine if reverse phasing can be provided at low cost.
- Computer modeling is required to develop the optimum phasing and overall conductor arrangements for lines added to, or rebuilt in, multiple-line corridors.
 - Merely adding a reverse-phase double-circuit line to an existing transmission line corridor or reverse phasing a rebuilt line in the multiple-line corridor will not necessarily produce lower magnetic field levels at the edge of the corridor right of way.
 - The corridor must be computer modeled with all the lines, existing phase conductor locations and currents. Then, magnetic field calculations must be made varying the phase arrangements of the new or reconstructed line to determine the appropriate phasing arrangement.
 - Current flow direction on a line also must be considered. For example, a reverse-phased line should have the current flowing in the same direction on both circuits. If the current flow is in the opposite direction for one circuit, reverse phasing will not produce the lowest magnetic field and another phase arrangement that produces lower fields may need to be utilized.

5. Increase the minimum ground clearance for all new transmission lines.

138/69 kV Transmission Lines

- Increasing the minimum line design ground clearance from 25 feet to 30 feet may add up to about 5 percent to the installed cost of a new double-circuit single pole 138/69 kV line. For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. With long-span reverse-phase design, the magnetic field is reduced from 9 mG to 7 mG (about 22 percent) at the edge of a 100-foot-wide right of way as shown in Chart X.
 - In the actual design of transmission lines to include higher minimum ground clearances, there may be limited segments (such as highway crossings, severe slopes and transmission line crossing locations) where National Electrical Safety Code (NESC) minimum ground clearances may need to be used. The NESC minimum ground clearances are less than the increased ground clearance discussed previously.

230 kV Transmission Lines

- Increasing the minimum line design ground clearances from 27 feet to 32 feet may add up to about 5 percent to the cost of a single-circuit single-pole line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 30 mG to 28 mG (about 7 percent) at the edge of a 150-foot-wide right of way.
- Increasing clearances from 27 feet to 32 feet could theoretically add up to about 2.8 percent to the cost of a double-circuit single-pole line (current standard) and reduce the magnetic field of a reverse-phase line from 16 mG to 15 mG (about 6 percent) at the edge of a 150-foot-wide right of way. Chart XI is a summary of this data.
- Studies are required for each new 230 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such

studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced phase spacing (a "Delta" configuration on a single-circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

500 kV Transmission Lines

- Increasing ground clearances from 33 feet to 53 feet may add up to about 4.5 percent to the cost of a single-circuit "H-frame" line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 42 mG to 35 mG (about 17 percent) at the edge of a 200-foot-wide right of way.
- Increasing ground clearances from 33 feet to 53 feet could theoretically add up to 2.8 percent to the cost of a double-circuit "H-frame" line (current standard) and reduces the magnetic field of a reverse-phase line from 21 mG to 16 mG (about 24 percent) at the edge of a 200-foot-wide right of way. Chart XII is a summary of this data.
- Studies are required for each new 500 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced-phase spacing (a "Delta" configuration on a single circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

RECONDUCTORING OR ADDING ADDITIONAL CIRCUITS TO EXISTING TRANSMISSION LINES

When reconductoring or adding additional circuits to existing transmission lines, PPL EU will evaluate low-cost or no-cost options for magnetic field management on a case-by-case basis.

When reconductoring existing transmission lines or adding additional circuits, low-cost alternatives may not exist; however, the following steps will be taken:

- For a single-circuit line, the use of a Delta arrangement or other modifications on the existing structure, with reduced-phase spacing, will be evaluated.
- For double-circuit lines, application of reverse phasing may reduce the magnetic field under the line and within the right of way and will be evaluated.
- For single- and double-circuit lines, evaluate using higher conductor tensions that can increase the minimum line design ground clearance.

DISTRIBUTION LINES

At the 12 kV distribution level, new main three-phase lines will continue to be constructed with five feet of additional ground clearance.


- Main lines are the most heavily loaded sections of a distribution line and therefore have the highest magnetic fields associated with them.
- Increasing the ground clearance by five feet reduces the magnetic field under the line from 14 mG to 11 mG using the standard eight-foot crossarm design. These values are based on increasing pole heights from 45 feet to 50 feet and a typical operating current of 300 amps per phase.
- Chart XIII is a summary of this data. Increasing ground clearance by five feet could theoretically add about 5 percent to the cost of a typical distribution line.

UNDERGROUND TRANSMISSION LINES

Underground transmission lines are required due to environmental or land use factors or restrictions on available clearances, PPL EU will evaluate options for magnetic field management techniques on a case-by-case basis.


- The phase arrangement that produces the lowest field will be determined.
- The depth of burial of the line will be determined considering the cost of excavation and the location of other buried utilities in the area.
- The use of steel pipe ferromagnetic shielding that reduces magnetic fields will be evaluated.

Short-Span Construction



- **More compact design**
- **Should not be used solely to reduce magnetic fields**
- **Typical conductor data:**
 - 1 3/8" HS steel overhead ground wire - 7.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 10.0 feet sag
 - Average span - 400 feet

Long-Span Construction Remains PPL EU 138 kV Standard




- Lower cost alternative
- Reduces magnetic fields due to higher structures
- Typical conductor data:
 - 1 3/8" HS steel overhead ground wire - 17.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 23.0 feet sag
 - Average span - 600 feet

**138/69 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SHORT SPAN (CHART I)	30
SHORT SPAN (REVERSE PHASE)	8
LONG SPAN (CHART II)	29
LONG SPAN (REVERSE PHASE)	9
COMPACT (CHART VI)	14
COMPACT (REVERSE PHASE)	3

The edge of right of way is 50 feet from the line centerline.
 The 400 ampere phase current is balanced between phases.
 Calculations are based on a minimum ground clearance of 25 feet.
 LONG SPAN, SHORT SPAN and COMPACT are double-circuit lines.

Typical Single-Circuit Structure Designs




——— initial single circuit
- - - - future second circuit

**138/69 kV SINGLE CIRCUIT TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
TOP/MIDDLE/BOTTOM	20
VERTICAL	17
TOP/MIDDLE	12


The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 25 feet.

Compact Design Structure



- **Minimize magnetic fields due to compact design**
- **Not a low-cost alternative**
- **Typical conductor data:**
 - 1 3/8" HS steel overhead ground wire - 9.0 feet sag**
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 9.0 feet sag**
 - Average span - 300 feet**

Reverse Phasing of Double-Circuit Transmission Lines



From: → → → → To:

Reverse phasing also can be one of the following phase arrangements:

A	B		B	A		B	C		C	A		C	B
C	C	or	C	C	or	A	A	or	B	B	or	A	A
B	A		A	B		C	B		A	C		B	C

**230 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	49
DOUBLE CIRCUIT POLE (REVERSE-PHASE)	16

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 27 feet.

**500 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 1100 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	37
DOUBLE CIRCUIT POLE (REVERSE PHASE)	21

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 33 feet.

**INCREASED 138/69 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	25	12
SINGLE CIRCUIT TOP/MIDDLE	30	10
LONG SPAN	25	29
LONG SPAN	30	26
LONG SPAN (REVERSE PHASE)	25	9
LONG SPAN (REVERSE PHASE)	30	7

The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.

**INCREASED 230 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	27	30
SINGLE CIRCUIT TOP/MIDDLE	32	28
DOUBLE CIRCUIT POLE	27	49
DOUBLE CIRCUIT POLE	32	46
DOUBLE CIRCUIT POLE (REVERSE PHASE)	27	16
DOUBLE CIRCUIT POLE (REVERSE PHASE)	32	15

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.

**INCREASED 500 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 1,100 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT "H" STRUCTURE	33	42
SINGLE CIRCUIT "H" STRUCTURE	53	35
DOUBLE CIRCUIT POLE	33	37
DOUBLE CIRCUIT POLE	53	31
DOUBLE CIRCUIT POLE (REVERSE PHASE)	33	21
DOUBLE CIRCUIT POLE (REVERSE PHASE)	53	16

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.

**12 kV DISTRIBUTION LINES
CALCULATED MAGNETIC FIELDS AT 300 AMPERES**

TYPE CONSTRUCTION	POLE HEIGHT FEET	MAGNETIC FIELD IN MILLIGAUSS*	
		AT CENTERLINE	AT 30 FEET FROM CENTERLINE
STANDARD CROSSARM	45	14	7
STANDARD CROSSARM	50	11	6

* Field level under the line at mid-span based on 300 amps, balanced loading, one meter above ground level.

APPENDIX C

LIST OF PROPERTY OWNERS WITHIN THE PROPOSED RIGHT-OF-WAY

<u>Property Owner/Address</u>	<u>Parcel Number</u>
Headlands Realty Corporation C/O AMB Property Corporation Mr. Bo Farkas Vice President, Investments One Meadowlands Plaza Suite 100 East Rutherford, NJ 07073	1
Mr. Alexander G. Tamerler 5300 Crackersport Road Allentown, PA 18104	2
Ms. Althea M. Walbert P. O. Box 33 Alburtis, PA 18011	3

APPENDIX D

LIST OF INVOLVED GOVERNMENTAL AGENCIES, MUNICIPALITIES AND OTHER PUBLIC ENTITIES RECEIVING APPLICATIONS

1. Pennsylvania Historical and Museum Commission
Bureau for Historic Preservation
Commonwealth Keystone Building, Second Floor
400 North Street
Harrisburg, Pennsylvania 17120-0053
Attn: Mr. Douglas C. McLearn, Chief

2. Pennsylvania Department of Transportation
Commonwealth Keystone Building
400 North Street, 8th Floor
Harrisburg, Pennsylvania 17120
Attn: The Honorable Allen D. Biehler, P.E., Secretary

3. Department of Environmental Protection
P.O. Box 2063
Market Street State Office Building
Harrisburg, Pennsylvania 17105-2063
Attn: Office of Field Operations

4. Lehigh County
17 South 7th Street
Allentown, PA 18101
Attn: The Honorable Donald T. Cunningham, Jr., Executive

5. Lehigh Valley Planning Commission
961 Marcon Blvd., Suite 310
Allentown, PA 18103
Attn: Mr. Michael N. Kaiser, AICP, Executive Director

6. Lower Macungie Township
3450 Brookside Road
Macungie, PA 18062-1427
Attn: Mr. Bruce Fosselman, Manager

7. Lower Macungie Township Planning Commission
3450 Brookside Road
Macungie, PA 18062-1427
Attn: Mr. Maury Robert, Chair