



17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
717-731-1970 Main
717-731-1985 Fax
www.postschell.com

Christopher T. Wright

cwright@postschell.com
717-612-6013 Direct
717-731-1985 Fax
File #: 2507/140066

May 11, 2010

BY HAND

Rosemary Chiavetta
Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

RE: Letter of Notification Of PPL Electric Utilities Corporation, Filed Pursuant To 52 Pa. Code Chapter 57 Subchapter G, With Respect To The Schoeneck #1 and #2 138/69 kV Transmission Tap Line In Lower Macungie Township, Lehigh County, Pennsylvania - Docket No. A-2010-2161788

Dear Secretary Chiavetta:

This letter corrects two typographical errors in the above-referenced Letter of Notification filed by PPL Electric Utilities Corporation ("PPL Electric") on February 25, 2010. In preparation for a hearing on the related Zoning Petition, PPL Electric noticed two typographical errors on page 5. Specifically, in Paragraph 12 of the Letter of Notification, PPL Electric indicated that the Trexlertown 47-3 12 kV line is projected to exceed its normal planning guidelines in "2010," and that the peak load on the distribution line forecasted for the summer of "2010" is 10.1 MVA. Paragraph 12 should be corrected to reflect that the Trexlertown 47-3 12 kV line is projected to exceed its normal planning guidelines in "2012" and should read as follows:

12. Additionally, the Trexelertown 47-3 12 kV line is projected to exceed its normal planning guidelines in **2012**. The normal and emergency ratings of the 336 kcmil² aluminum conductor steel reinforced ("ACSR") of the Trexlertown 47-3 12 kV distribution line are 10 and 12 MVA, respectively. The line, however, reached a peak load 10 MVA during summer 2009, and the peak load on

² Thousand circular Mils.


May 11, 2010
Page 2

the distribution line forecasted for the summer of **2012** is 10.1
MVA.

With this correction, the Letter of Notification is true and correct in all other aspects.

As indicated on the certificate of service, copies are being provided to the persons listed on the certificate of service in the manner indicated. If there are any questions concerning this matter, please contact me at the address or telephone number provided above.

Respectfully Submitted,



Christopher T. Wright

CTW/skr

cc: Certificate of Service

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing has been served upon the following persons, in the manner indicated, in accordance with the requirements of § 1.54 (relating to service by a participant).

VIA FIRST CLASS MAIL

Pennsylvania Historical and Museum
Commission
Bureau for Historic Preservation
Commonwealth Keystone Building, Second
Floor
400 North Street
Harrisburg, PA 17120-0053
Attn: Mr. Douglas C. McLearn, Chief

Pennsylvania Department of Transportation
Commonwealth Keystone Building
400 North Street, 8th Floor
Harrisburg, PA 17120
Attn: The Honorable Allen D. Biehler, P.E.,
Secretary

Department of Environmental Protection
P.O. Box 2063
Market Street State Office Building
Harrisburg, PA 17105-2063
Attn: Office of Field Operations

Lehigh County
17 South 7th Street
Allentown, PA 18101
Attn: The Honorable Donald T.
Cunningham, Jr., Executive

Lehigh Valley Planning Commission
961 Marcon Blvd., Suite 310
Allentown, PA 18103
Attn: Mr. Michael N. Kaiser, AICP,
Executive Director

Lower Macungie Township
3450 Brookside Road
Macungie, PA 18062-1427
Attn: Mr. Bruce Fosselman, Manager


Lower Macungie Township Planning
Commission
3450 Brookside Road
Macungie, PA 18062-1427
Attn: Mr. Maury Robert, Chair

Headlands Realty Corporation
C/O AMB Property Corporation
Mr. Bo Farkas Vice President, Investments
One Meadowlands Plaza Suite 100
East Rutherford, NJ 07073

Mr. Alexander G. Tamerler
5300 Crackersport Road
Allentown, PA 18104

Ms. Althea M. Walbert
P. O. Box 33
Alburtis, PA 18011

Date: May 11, 2010



Christopher T Wright