



Rod Nevirauskas
Director of Rates & Regulations
800 West Hershey Park Drive
Hershey PA 17033

P (717) 531-3340
F (717) 531-3235

July 22, 2010

VIA FIRST CLASS MAIL
Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
P.O. Box 3265
Harrisburg, PA 17105-3265

Re: **Pennsylvania Public Utility Commission v. Pennsylvania American Water –
Docket No. R-2010-2166208**

Dear Secretary Chiavetta:

Enclosed for filing are an original and three copies of the Certificate of Service evidencing service upon the parties and their respective consultants, if any, of Pennsylvania American Water's Answer to the following Clarion Wastewater Interrogatories:

OCA-19-2

Respectfully submitted,


John Cox

Enclosures

cc: Per Certificate of Service

RECEIVED
2010 JUL 26 AM 9:48
PA.P.U.C.
SECRETARY'S BUREAU



PENNSYLVANIA
AMERICAN WATER

CERTIFICATE OF SERVICE


I hereby certify that a true and correct copy of the *foregoing has been served upon the following persons, in the manner indicated, in accordance with the requirements of § 1.54 (relating to service by a participant).

VIA *

Dianne E. Dusman, Esquire
Shaun A. Sparks, Esquire
Office of Consumer Advocate
555 Walnut Street
Forum Place, Fifth Floor
Harrisburg, PA 17101
ddusman@paoca.org
SSparks@paoca.org

Charles Daniel Shields, Esquire
chshields@state.pa.us
Carrie B. Wright, Esquire
carwright@state.pa.us
Office of Trial Staff
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
P.O. Box 3265
400 North Street, 2nd Floor West
Harrisburg, PA 17105-3265

Ralph Smith, Consultant OCA
Larkin & Associates
15728 Farmington Road
Livonia, MI 48154
rsmith@aol.com



John Cox
Pennsylvania American Water
800 West Hershey Park Drive
Hershey, Pennsylvania 17033
(717) 533-5000

RECEIVED
2010 JUL 26 AM 9:48
PA.P.U.C.
SECRETARY'S BUREAU

Date: July 22, 2010

Pennsylvania-American Water – Clarion Wastewater
Docket No. R-2010-2166208
Office of Consumer Advocate

OCA-19-2 On the drawings and sketches referred to in Q1 above, please provide the following information. If exact information is not available, provide estimated information and identify it as such.

- a. Size and type of pipe.
- b. Location pumping stations and force mains.
- c. Location of treatment plant.

A.

- a. Based on our most current mapping, the Clarion wastewater collection and conveyance system consists of the pipe size and type as shown on the attached chart. The Company owned portion of the system totals 201,448 feet, whereas the Clarion University owned portion totals 8,475 feet.
- b. Five lift stations plus force mains are located on the map provided in response to OCA 19-1.
- c. The location of the one treatment plant is identified on the map provided in response to OCA 19-1.

RECEIVED
2010 JUL 26 AM 9:48
PA, P.U.C.
SECRETARY'S BUREAU

Responsible Witness: David R. Kaufman

Pennsylvania American Water
Clarion, Pennsylvania
Total Length of Sewer Main (feet)

| Type | 4" | 6" | 8" | 10" | 12" | 15" | 16" | 18" | 20" | 24" | Unknown | Total | Total |
|------------------------------|--------------|---------------|----------------|---------------|---------------|--------------|--------------|--------------|-----------|--------------|---------------|----------------|----------------|
| University | | | | | | | | | | | | | 8,475 |
| Unknown | 0 | 0 | 1100 | 0 | 169 | 0 | 0 | 0 | 0 | 0 | 6,343 | 7,612 | |
| VCP | 0 | 0 | 356 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | 356 | |
| PVC | 0 | 0 | 507 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | 507 | |
| Forcemain | | | | | | | | | | | | | 11,643 |
| Unknown | 0 | 0 | 6420 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2,191 | 8,611 | |
| PVC | 1004 | 0 | 0 | 0 | 830 | 0 | 0 | 0 | 0 | 0 | | 1,834 | |
| DIP | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1198 | 0 | 0 | | 1,198 | |
| Gravity | | | | | | | | | | | | | 189,806 |
| Unknown | 583 | 11581 | 77636 | 8671 | 3711 | 296 | 188 | 703 | 0 | 762 | 4,375 | 108,506 | |
| VCP | 527 | 4002 | 25144 | 4077 | 4813 | 3449 | 826 | 1812 | 33 | 656 | | 45,339 | |
| PVC | 140 | 1128 | 13463 | 2034 | 9992 | 840 | 1315 | 1732 | 0 | 876 | | 31,520 | |
| Concrete | 0 | 898 | 405 | 526 | 0 | 0 | 0 | 0 | 0 | 0 | | 1,829 | |
| PE | 0 | 0 | 1053 | 0 | 1165 | 0 | 0 | 0 | 0 | 0 | | 2,218 | |
| DIP | 0 | 0 | 0 | 262 | 106 | 26 | 0 | 0 | 0 | 0 | | 394 | |
| Abandoned¹ | | | | | | | | | | | | | 0 |
| VCP | 0 | 215 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | 215 | |
| Total | 2,254 | 17,824 | 126,084 | 15,570 | 20,786 | 4,611 | 2,329 | 5,445 | 33 | 2,294 | 12,908 | 210,138 | 209,923 |

¹ Abandoned pipe not included in the Total Length of Gravity Mains

RECEIVED
 2010 JUL 26 AM 9:49
 PA.P.U.C.
 SECRETARY'S BUREAU