

MEMORANDUM

COMMONWEALTH OF PENNSYLVANIA
PA Public Utility Commission

DATE: January 24, 2011

SUBJECT: Neville Island Supply v.
Duquesne Light Company
Docket No. C-2009-2132987

TO: Commonwealth Reporting Company

FROM: ALJ John H. Corbett, Jr. *JAC/sro*
Office of Administrative Law Judge, Pittsburgh

At the request of Anne Thompson, please find enclosed Respondent's Exhibit 3 admitted during the hearing on December 21, 2010, for inclusion in the file for the above-captioned matter.

Thank you.

JHC:seo

Enclosure

RECEIVED
2011 JAN 28 PM12:06
PA PUC
SECRETARY'S BUREAU

[Duquesne Light](#) > [Customer Services](#) > [Connecting Service](#) > [Electric Service Installation Rules](#) >

Meter Transformer Poles

For 2,400 or 4,160 volt services, the Company will furnish, install, own, and maintain the transformer and metering pole, if required. These poles will be located on private property and are a part of the service line for which the Customer may be required to make a contribution in accordance with [Section 3.7](#) of these rules. For metering of 2,400 or 4,160 volt services, see [Section 8.10](#).

UNTRANSFORMED SERVICE - UNDERGROUND

Where untransformed service is supplied underground, the Company will furnish the metering equipment as described in [Section 8.9](#). The Customer shall furnish and install an enclosure approved by the Company to house the terminals of the service line and the metering transformers. The Customer shall also furnish and install the service-entrance conductors from the termination of the service line to the service equipment.

UNTRANSFORMED SERVICE - OVERHEAD

Where untransformed service is supplied overhead, see [Section 8.10](#) for the metering requirements. The Customer shall furnish and install all construction beyond the service point which is usually at the Company's metering terminals. Overhead conductors of sufficient length shall be provided by the Customer to permit the Company to connect them to the service point. The service point will be determined by service requirements and designated by the Division Office.

TRANSFORMED SERVICE INSTALLATIONS FROM SUBSTATIONS, VAULTS, OR PADS

Where transformed service is furnished from equipment in a substation, in a vault, or on a pad, the Company will furnish and install the main transformers, meters, and meter wiring. See [Section 8.8](#) for the metering requirements.

For all installations, except for residential developments where [Tariff Rule 13.2](#) applies, the Customer shall furnish and install the service-entrance conductors beginning at the secondary terminals of the Company's transformer or transformers. The Customer shall furnish and install the connectors for attaching the conductors to the transformer terminals. The service-entrance conductors at the secondary terminals of the transformer shall be of a flexible type, and the connectors shall be of the type specified by the Company.

The Customer shall furnish, install, maintain and own the physical structure; power, relay and control wiring; underground conduits and the protective grounding system necessary to support the installation of the Company's transformers and equipment. The Company will provide plans and instructions for the installation as follows:

SECRETARY'S BUREAU

2011 JAN 28 PM 12:06

Terms of All

EXHIBIT
Pittsburgh
3
12/21/10 AT

Copyright 2007

C-2009-2132987