



Before the  
Pennsylvania Public Utility Commission

**HOSENSACK - WESCOSVILLE 230 kV LINE  
REPLACEMENT**

**ATTACHMENTS IN SUPPORT OF THE  
LETTER OF NOTIFICATION**

Application Docket No. \_\_\_\_\_

Submitted by: PPL Electric Utilities Corp.

## SUMMARY

A Letter of Notification is being submitted by PPL Electric Utilities Corporation (“PPL Electric”) pursuant to the Pennsylvania Public Utility Commission’s (“Commission”) regulations at 52 Pa. Code §§ 57.71 through 57.77 for approval to reconstruct the single-circuit Hosensack – Wescosville #3 230 kV Transmission Line. This transmission line is being reconstructed as part of PPL Electric’s Vintage Conductor program, which was developed to address deteriorated facilities within PPL Electric’s system. The facilities in the Vintage Conductor Program were initially constructed between the mid-1920’s and the late 1930’s. The Vintage Conductor Program is further described in Attachment 1.

The Hosensack – Wescosville #3 230 kV Project described in this, the third filing for the Vintage Conductor Program, will rebuild approximately 8.7 miles of the single-circuit transmission line. The transmission line begins near PPL Electric’s Hosensack Substation located in Lower Milford Township, Lehigh County. The line continues north and terminates at PPL Electric’s Wescosville Substation, which is located in Upper Macungie Township, Lehigh County. The project will be contained on the existing PPL Electric right-of-way that traverses portions of Lower Milford Township, Upper Milford Township, Lower Macungie Township, and Upper Macungie Township in Lehigh County, Pennsylvania. The proposed reconstructed line will be designed and constructed for one 230 kV circuit.

The reconstruction of this transmission line will include the removal of the existing lattice towers and conductors, which will be replaced with new single shaft steel poles, conductors, insulators and overhead ground wire. No new rights-of-way will be required because the proposed line will be rebuilt within the existing PPL Electric right-of-way. Due to the deteriorated condition of the Hosensack – Wescosville #3 Transmission Line, PPL Electric is expeditiously moving forward with this project before failure of this line occurs.

The total estimated cost of the proposed transmission work is approximately \$15,670,000. This project has a scheduled construction start date of August 2012, in order to meet an in-service date of November 2013. PPL Electric is seeking approval at this time to take advantage of system operations that may allow for an earlier construction start date.

This document, which describes the need for the project and explains the engineering and siting analysis for the proposed construction, consists of the following:

Attachment "1"	Necessity Statement
Attachment "2"	Engineering Description
Attachment "3"	Siting Analysis and Environmental Assessment
Attachment "4"	PPL Electric Design Criteria and Safety Practices
Attachment "5"	PPL Electric Magnetic Field Management Program
Attachment "6"	List of Involved Governmental Agencies, Municipalities
Attachment "7"	List of Owners of Property within the Existing Right-of-Way

# PPL ELECTRIC UTILITIES SERVICE TERRITORY



# **Attachment**

**1**

**ATTACHMENT "1"**  
**HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT**  
**NECESSITY STATEMENT**

---

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>TOPIC</u></b>	<b><u>PAGE</u></b>
A.	INTRODUCTION.....	1
B.	OVERVIEW OF VINTAGE CONDUCTOR PROGRAM.....	1
C.	PROPOSED SOLUTION.....	5

**LIST OF TABLES**

TABLE 1	VINTAGE CONDUCTOR PROGRAM.....	4
TABLE 2	PPL ELECTRIC ANALYSIS OF REBUILD VS REHABILITATE.....	6

**ATTACHMENT "1"**  
**HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT**  
**NECESSITY STATEMENT**

---

**A. INTRODUCTION**

PPL Electric is requesting Commission approval to rebuild the eighty-three year-old Hosensack – Wescosville #3 230 kV Transmission Line. The proposed replacement involves a section of transmission line which begins near the Hosensack substation, located in Lower Milford Township, Lehigh County, and continues north to PPL Electric's Wescosville Substation located in Upper Macungie Township, Lehigh County, a distance of approximately 8.7 miles. A 1.06 mile section of this line was constructed in the 1960s, when PPL Electric constructed the existing Hosensack 230-69 kV Substation. A field review of this section found the towers and supporting components to be in good condition. Therefore, rebuilding this section is not necessary at this time. This project is part of PPL Electric's Vintage Conductor Program, which was developed to address deteriorated facilities in PPL Electric's transmission system. The proposed project will be designed to accommodate a single 230 kV circuit. As explained in detail below, reconstruction of the transmission line is required to maintain system reliability.

The estimated cost to design and replace the transmission line is \$15,670,000. Construction is scheduled to begin in the fall of 2012 in order to meet the in-service date of November 2013.

A PPL Electric system map showing the existing transmission facilities with design voltage of 35 kV or greater is included in the Attachment "1" map pocket. Although this Necessity Statement provides a broad discussion of the Vintage Conductor Program, this filing addresses only the Hosensack – Wescosville #3 Transmission Line, which is located in Lehigh County, Pennsylvania.

**B. OVERVIEW OF VINTAGE CONDUCTOR PROGRAM**

The PPL Electric transmission system includes multiple 230 kV line segments that are approximately 80 years old. These line segments were installed in the mid-1920's through the

1930's. Lines that operate at 230 kV are part of the bulk electric system. These lines serve as major pathways for the flow of large amounts of electrical power: (a) from one bulk substation or switchyard to other bulk stations within the electric utility's territory, or (b) between one electric utility and another. At the bulk substations, power is transformed to lower voltage levels for delivery to residential, commercial, or industrial customers. PPL Electric owns approximately 1,000 miles of transmission lines that operate at 230 kV. The Hosensack – Wescosville #3 Transmission Line connects PPL Electric's Hosensack 230-69 kV Substation to its Wescosville 500-230-138-69 kV Substation.

The Vintage Conductor Program began when, as a result of a review process, PPL Electric's Transmission Engineering group informed the Transmission Planning group of the deteriorated facilities existing on the 230 kV line located between the Bushkill 230 kV switchyard and Wallenpaupack hydroelectric plant. The Transmission Engineering group subsequently identified other 230 kV lines dating to the same construction era with similarly designed structures and conductors.<sup>1</sup> Conversations between the Planning and Engineering groups resulted in the identification of eleven line segments that contained aged and deteriorated facilities. The identified segments, totaling approximately 140 miles, were grouped into a program that PPL Electric named the Vintage Conductor Program. The process of identifying aged and deteriorated facilities is on-going. Three more line segments have been identified for further analysis.

In 1983, PPL Electric tested a portion of this "vintage conductor" – specifically those line segments located between the Wallenpaupack, Blooming Grove, Bushkill, and Siegfried electric stations. At the time of this testing, the steel core of the "795" conductor was showing deterioration, but the greatest concern to PPL Electric personnel was the deterioration occurring at the conductor splices.

Consequently, most splices in the line between the Wallenpaupack and Siegfried stations were replaced. The Transmission Engineering group determined that the line conductor was expected to last another 10 to 15 years. The 15 year time frame has been exceeded, and no follow up

---

<sup>1</sup> 795 thousand circular mils (kcmil), aluminum conductor steel reinforced (ACSR), 54.7 stranding, and variations of that stranding.

examination or similar major repair work has been performed on the other line segments. PPL Electric, however, continues to perform aerial inspections of these facilities every four years, on average. Specific maintenance tasks are identified from the inspections. PPL Electric prioritizes, schedules, and completes these tasks in a timely manner.

In early 2010, PPL Electric hired an outside engineering consultant, DiGioia Gray and Associates,<sup>2</sup> to perform an independent field investigation and assessment of the line segments.<sup>3</sup>

The engineering consultant reported on the degree of deterioration of the structural components, foundations, insulators, line hardware, shield wire, grounding, signage, paint, and galvanizing. The status of right-of-way encroachment and adjacent land features were also reported.

A short length of conductor (loop) and its insulator string used to connect two spans of conductors at tension towers was removed and examined (laboratory and visual) from four of the eleven line segments. Overhead line conductor was not examined or tested to determine its physical condition or its tensile strength. Tensile strength testing would have required a line outage in order to physically remove multiple samples from the span (i.e.; conductor located between two adjacent towers) at numerous locations along the identified line segments. Furthermore, an examination of the conductor would be an unnecessary initial step if the other tower-line components (i.e.; structures, foundations, etc) were found to be significantly deteriorated, as was expected from the findings in 1983. Sampling of overhead conductor will only be initiated if deteriorated tower-line components can be remedied by rehabilitation.

DiGioia Gray & Associates identified a statistically significant number of structures for each line segment. The identified structures, and associated foundations and line equipment, were then inspected in the field by DiGioia Gray & Associates. Results of the evaluations were summarized in line-specific assessment reports.

---

<sup>2</sup> DiGioia Gray & Associates of Monroeville, PA 15146

<sup>3</sup> Two of the line sections, specifically the Bushkill – Blooming Grove and Blooming Grove – Wallenpaupack line segments, were excluded from the field investigation performed by the engineering consultant because those segments are to be completely rebuilt as part of the proposed Susquehanna – Roseland 500 kV line project. A recent Commission decision approved the Susquehanna – Roseland project, and the associated rebuilding of these two line segments. Appeals from that decision are pending.

Based upon the issues that were identified in 1983, and the recent findings of the independent external engineering consultant, the identified line segments are now at an increased exposure to failing. This creates a safety concern for both the public and PPL Electric field personnel. Further, if this issue is left unresolved, the potential for degradation in grid reliability will exist, due to an increased risk to line equipment outages. PPL Electric determined that a program to systematically upgrade these line segments was required, and established the Vintage Conductor Program to perform the necessary upgrades.

The original nine segments included in the Vintage Conductor Program, which total approximately 90 miles, and the two projects that are included in the Susquehanna-Roseland 500 kV project are identified in Table 1. Review of PPL Electric's transmission system to determine whether additional segments need to be replaced is on-going.

**TABLE 1**  
**Vintage Conductor Program**

<b>Super Project No.</b>	<b>Project Name / Line Segment</b>	<b>Line Segment Miles</b>	<b>Original In-Service Date</b>
9056	Manor – Graceton	14.52	1937
9057	Otter Creek – Conastone	11.98	1933
9054	Martins Creek – Siegfried # 2	10.69	1926
9049	Hosensack – Wescosville # 3	9.76	1928
9053	Whitpain – Buxmont	7.72	1928
9050	Shawnee – Bushkill	2.20	1926
9051	Fox Hill – Shawnee	8.27	1926
9052	Martins Creek – Monroe	16.14	1926
9055	Hummelstown – Middletown Junction # 1	7.00	1954
N/A	Bushkill – Blooming Grove (note 1)	21.80	1926
N/A	Blooming Grove – Wallenpaupack (note 1)	29.40	1926

N/A – not applicable.

(note 1) – Line segments to be upgraded as part of the Susquehanna-Roseland 500 kV Line project.

### C. PROPOSED SOLUTION

The Hosensack - Wescosville #3 line is the only 230 kV source of electric power to the 230-69 kV transformer # 2 at Wescosville. Permanent removal of the Hosensack - Wescosville #3 line from service would weaken the 230 kV system in eastern Pennsylvania.

When this line is temporarily removed from service to perform line maintenance, during heavy load periods an unplanned outage of either the Wescosville 138-69 kV transformer # 1 or # 4 causes an overload on the remaining transformer. The Hosensack - Wescosville #3 line and the 230-69 kV transformer # 2 at Wescosville would normally relieve this overload condition. In addition, the 230-69 kV transformer # 2 is used to relieve an overload on the Wescosville 500-138 kV transformer # 3 during peak load periods under specific generation dispatches or abnormal sectionalizing.

Therefore, abandonment of the Hosensack - Wescosville #3 230 kV Transmission Line is not an option.

Technical solutions to resolving the deteriorated components inherent to the "Vintage Conductor" line segments would be to either:

- (a) rehabilitate the components (i.e.; structures, foundations, conductors, insulators, and line hardware), or,
- (b) completely rebuild those line segments.

PPL Electric prepared a cost analysis and determined that a complete rebuild of the Hosensack - Wescosville #3 Transmission Line was less expensive than rehabilitation. Specifically, the PPL Electric cost analysis, summarized in Table 2, concluded that rehabilitation costs would be 101 percent of the total rebuild cost for the Hosensack - Wescosville # 3 Transmission Line, making a total rebuild the more cost effective option.

**TABLE 2**  
**PPL Electric Cost Analysis of Rebuild vs. Rehabilitation**

Scope	Labor & Material Cost (x 1000)		Ratio of Costs; Rehabilitation to Rebuild
	Rebuild	Rehabilitation	Percent
Labor and materials related to structures, foundations, insulators, line hardware and paint.	\$10,054	\$10,340	103
Common elements (includes labor and materials related to conductor, design and engineering, project management, acquisition of additional right-of-way, permitting, siting, PUC certification, environmental, and general overhead costs).	\$12,668	\$12,668	100
<b>Total</b>	<b>\$22,722</b>	<b>\$23,008</b>	<b>101</b>

In addition, Burns & McDonnell (“B&McD”), a consulting engineering firm, prepared an independent cost evaluation on an individual line segment basis and compared rehabilitation of conductor, structures, foundations, and associated line equipment against a complete rebuild. The results of the B&McD evaluation for the Hosensack – Wescosville #3 line were consistent with the PPL Electric cost evaluation.

The independent external engineering consultant, DiGioia Gray & Associates, also stated the following with regard to the Hosensack – Wescosville #3 line:

Given that five of eight structures inspected with embedded steel foundations are in a severe state, we do not advise that this line be rehabilitated. Repairing the majority of structures for severe section loss at ground line is not economically feasible and would result in a reliability index significantly lower than a newly constructed transmission line.

In further support of the decision to completely rebuild rather than rehabilitate the Hosensack – Wescosville #3 230 kV Transmission Line, PPL Electric also considered the following additional issues that are more efficiently addressed by rebuilding:

- Bent or missing steel components on the existing towers require removal and/or replacement, or the installation of additional bracing, to correct the structural deficiency. Depending on the number of crews assigned to the project, that work would either be done one tower at a time, or multiple towers grouped together for the repair work. On the other hand, the rebuild option will require only the erection of a single mono-pole structure after a new concrete foundation has been poured and cured.
- All insulator sets at the top of each tower should be replaced due to their age, the condition of the insulating material within the insulator, and the heavy contamination with pollutants from long-term exposure.
- Line hardware and related attachment steel on each tower should be removed and replaced, due to wear on the material at the connecting points. Metal against metal degradation was observed during the field inspections.
- Splices in the conductor should be replaced, due to their age, outdated design, and early manufacturing processes that were used to make these devices in the 1920's and 1930's.
- Conductor should be replaced based on its age.
- Grounding at each structure or tower leg must be upgraded by adding counterpoise in order to meet current safety standards.
- The overhead shield wires require replacement due to age, condition, and possible repositioning in order to bring the tower-line structure up to current lightning standards. In its assessment reports, the independent external engineering consultant noted that some line segments do not have the appropriate shielding angle, which makes the tower-line more susceptible to lightning strikes.

Rebuilding the Line will result in addition benefits that are explained below. In addition, completely rebuilding the Hosensack – Wescosville # 3 line is less expensive for PPL Electric than attempting to rehabilitate the line.

Rebuilding the Hosensack – Wescosville # 3 Transmission Line will result in a new structure that is capable of supporting a single-circuit line that would meet current National Electrical Safety Code (“NESC”) standards with regard to mechanical loading, including improved ground clearances. New structures will have an expected life that will exceed that of reconditioned structures.

The new structures will enable PPL Electric to comply with its modern magnetic field policy, and will improve the magnetic field values within and at the edge of the right-of-way. The new single circuit line will be designed to use 795 kcmil ACSR conductor, which matches the existing 795 conductor. Because the sole purpose of this transmission line is to supply electric power to the 150 MVA 230/69 kV transformer # 2 at Wescosville, the minimum wire size of 795 ACSR that can be used on a 230 kV circuit was selected for this project. Using the smaller wire size instead of 1590 ACSR will result in cost savings on this project because of the reduced mechanical loading on the structures, foundations, and supporting hardware. The 795 kcmil ACSR conductor will provide an ampacity of 425 MVA summer normal.

Rehabilitation of the Hosensack – Wescosville # 3 Transmission Line will require longer construction periods to perform the numerous repairs on a tower by tower basis. Most of the structures on the Hosensack – Wescosville # 3 Transmission Line have four foundations, because of the use of steel lattice towers. Where major foundation repairs are required, the individual tower will require temporary structural support while each foundation is replaced. Two or more towers likely would be grouped together for foundation repair work. A period of weeks will need to pass as the old concrete is removed and new concrete is placed and cured prior to placing the mechanical load back onto the new foundations. Foundation replacement would impede the speed at which crews could move from one structure and its associated foundations to the next. The process of repairing the foundations would prolong the construction period significantly if PPL Electric had determined to rehabilitate the existing line.

PPL Electric's current practice in rebuilding or reconductoring of lines is to install optical ground wire ("OPGW") instead of steel ground wire. Non-conductive strands of optical fiber material are surrounded by one or more layers of steel and/or aluminum wire to create the OPGW. This design change is employed so that protective relay schemes do not depend on less reliable hard-wired telephone circuits, or on power line carrier equipment that uses the line conductors for the communication path. The OPGW provides a relaying and communication path with improved reliability.

The completion date for each specific Vintage Conductor Program will be coordinated with the timing of the overall Asset Optimization Strategy ("AOS") Program, which is scheduled to conclude by 2020. Due to the physical condition of the Hosensack - Wescosville line segment, its in-service date has been established as November 2013. The in-service date of November 2013 will enable PPL Electric to budget, acquire resources, and schedule the rebuild of the Hosensack - Wescosville #3 Line segment with PPL Electric's system operators among the other line segments in the Vintage Conductor Program that also require rebuilding.



# SUBSTATION LISTING

1	WEST WILLIAMSPORT	151	CRACKERSPORT	301	CENTER CITY
2	FAIRFIELD	152	SCHNECKSVILLE	302	NEW KINGSTOWN
3	MONTGOMERY	153	HEMLOCK	303	REAMSTOWN
4	VARDEN	154	MT ALLEN	304	DUPONT
5	HENSEDALE	155	PRINCE	305	HUMBOLDT
6	JERSEY SHORE	156	WAKEFIELD	306	CEDAR AVE.
7	LOGANTON	157	COOPERSBURG	307	INDIAN ORCHARD
8	VALMONT	158	WERTZVILLE	308	NOTTINGHAM
9	RIVER	159	WEST CARLSLE	309	NORTH COOLBAUGH
10	LIMESTONE	160	BENVENUE	310	LEFORT
11	NORTHUMBERLAND	161	HIGINS	311	EAST MOUNTAIN
12	REED	162	LEWIS	312	LEWIS
13	WRIGHT	163	YATESVILLE	313	BLOODSBURG
14	ST. JOHNS	164	CENTRAL ALLENTOWN	314	MIFFLINTOWN
15	FREELAND	165	DBERLIN	315	RIDGE ROAD
16	GILBERT	166	STRASBURG	316	SUSQUEHANNA
17	CHERRY HILL	167	ATGLEN	317	T-10 SW. YD.
18	SUSQUEHANNA 230KV	168	BROOKSIDE	318	KIMBLE
19	TAMANEND	169	WILLIAMSTOWN	319	CHRISTIANS
20	WHITE HILL	170	E. PETERSBURG	320	WILSON
21	PALMERTON	171	WERNERSVILLE	321	OTTIER CREEK
22	HAMILTON	172	N. BETHLEHEM	322	STEEL CITY
23	HUNTER	173	V. ALLENTOWN	323	MCGOWANVILLE
24	FAIRVIEW	174	FLEMINGTON	324	ROBESONIA
25	MONTOUR PUMP	175	MECKESVILLE	325	S.FOGELSVILLE
26	MT. CARMEL	176	DONERVILLE	326	ELROY
27	HELLY	177	MILLERSVILLE	327	BUSHKILL
28	SPORTING HILL	178	DUKE	328	WALLENPAUPACK
29	MAHANDY CITY	179	MCALISTERVILLE	329	ELK MOUNTAIN
30	GREENWOOD	180	NEWFOUNDLAND	330	JACK FROST
31	MOWRY	181	MARLIN	331	HARWOOD 230/69KV
32	ALTAQUANT	182	WEST BERWICK	332	HARWOOD CTG
33	FAHLEIN	183	W. SEZER AVENUE	333	HARWOOD 69/12KV
34	SOUTH SLATINGTON	184	MICKLEYS	334	HAZARETH
35	SOUTH MIDDLEBURG	185	EAST ALLENTOWN	335	ALBURETH
36	WALKER	186	PINE RIDGE	336	FRACKVILLE
37	FRAILEY	187	DALMATIA	337	ELIMSPORT
38	MORGANTOWN	188	PENNSBORO	338	ALLENWOOD
39	GYPT	189	NORTH COLUMBIA	339	GRATZ
40	CRESSONA	190	HUGHESVILLE	340	HOCKERSVILLE
41	SOUTH WHITEHALL	191	WEISSPORT	341	BLOOMING GROVE
42	BEAR GAP	192	HONEY BROOK	342	MONROE
43	SALISBURY	193	MOISCO	343	LACKAWANNA ##
44	SOUTH MILTON	194	ROSSMOYNE	344	STANTON
45	HEIDELBERG	195	BEAUCHAMPTON	345	JACKSON
46	LYKENS	196	WOOLRICH	346	EAST PALMERTON
47	UPPER HANOVER	197	FAXON	347	SIEGFRIED
48	RICHLAND	198	ELIZABETHTOWN	348	HOSENSACK 230/69KV
49	MACHADA	199	TERRE HILL	349	HOSENSACK 500KV
50	ROCKY LE	200	BUCK	350	CONE STGA
51	THOMPSONSTOWN	201	MT. BETHEL	351	HANDY
52	PAXTON	202	RICHFIELD	352	CLINTON
53	COCALICO	203	SCRANTON	353	EXCHANGE
54	EAST ELIZABETHTOWN	204	TWIN LAKES	354	MILTON
55	WARWICK	205	HARLEIGH	355	DAUPHIN
56	EARL	206	TAFTON	356	QUARRY SUB.
57	HEMPFIELD	207	BEAR CREEK	357	STEELTON
58	EAST LANCASTER	208	DRIVESBURG	358	JUNIATA 500/230KV
59	KINZER	209	HENTZBURG	359	JUNIATA 230/69KV
60	MT. NEBO	210	CANDENSIS	360	CUMBERLAND
61	POCONO	211	LINDEN	361	DONEGAL
62	PENNS	212	MT. JOY	362	JENKINS 230/69KV
63	GOULDSTON	213	WEST BLOOMSBURG	363	JENKINS CTG
64	DILLERSVILLE	214	MINI TRAIL	364	VILKES-BARRE
65	GIRARD MANOR	215	LAKE NAOMI	365	BUXMONT
66	KENMAR	216	LANARK	366	SOUTH AKRON 230/138/69KV
67	GOVEN CITY	217	MONTOURSVILLE	367	SOUTH AKRON 69/12KV
68	ELLIOT HEIGHTS	218	PORT CARBON	368	SOUTH MANHEIM 69/12KV
69	ROHRENSSTOWN	219	W. LYBURN	369	SOUTH MANHEIM 230/69KV
70	MACUNGIE	220	MILFORD	370	ENGLISIDE
71	EAST HAZLETON	221	TRECHLERS	371	DANVILLE
72	WAGNERS	222	ROSEVILLE	372	SUNBURY
73	EAST CARBONDALE	223	MACUNGIE	373	HUMMELS WHARF
74	MINDOKA	224	EAST HAZLETON	374	LYCOMING
75	OLD FORGE	225	WAGNERS	375	LOCK HAVEN CTG
76	FOUNTAIN SPRINGS	226	PARRISH	376	LOCK HAVEN 69/12KV
77	SULLIVAN TRAIL	227	WEST NEW HOLLAND	377	HUMMELSTOWN
78	SWATARA	228	POINT	378	WEST SHORE
79	HEPBURN	229	LINDOLN	379	MONTAGE
80	HEPBURN	230	MIDDLETON	380	SOUTH FARMERSVILLE
81	FRANCONIA	231	STATE HILL	381	VECOSVILLE
82	EMMAUS	232	MILLVILLE	382	FISHBACH
83	MORGAN	233	TINKER	383	BERKS
84	THROOP	234	LAKEVILLE	384	MONTOUR
85	CHAPMAN	235	NORTH MANHEIM	385	SUBURBAN YARD
86	SUBURBAN	236	HATFIELD	386	DELA
87	PROVIDENCE	237	LAKEVILLE	387	BOHEMIA
88	AVOCA	238	NORTH MANHEIM	388	WHITE HAVEN
89	CASS	239	HATFIELD	389	LAURELTON
90	CATASAUQA	240	FRANCONIA	390	LINGLETOWN
91	SUSQUEHANNA 500KV	241	EMMAUS	391	ELDRED
92	SETTERSVILLE	242	MORGAN	392	MILLWOOD
93	ROSEMONT	243	THROOP	393	TELFORD
94	QUAKERTOWN	244	CHAPMAN	394	TWIN VALLEY
95	LAVINTON	245	SUBURBAN	395	DEVONSHIRE
96	LITITZ	246	PROVIDENCE	396	JESSUP
97	RENOVO	247	AVOCA	397	BELTZVILLE
98	WALNUT	248	CASS	398	SCHOENECK
99	WATSON	249	CATASAUQA	399	400 HAWLEY
100	ALBERTSTOWN	250	SUSQUEHANNA 500KV	401	EFFORT MOUNTAIN
101	WEST LANCASTER	251	SETTERSVILLE	402	COPPERSTONE
102	MADISONVILLE	252	ROSEMONT	403	RED FRONT
103	NEFFSVILLE	253	QUAKERTOWN	404	APPENZELL
104	BEAVERTOWN	254	LAVINTON	405	BLUE MOUNTAIN
105	BELMONT	255	LITITZ	406	DAPPERS 69-12KV
106	LAKE HARMONY	256	RENOVO	407	MEISERSVILLE
107	GEORGETOWN	257	WALNUT		
108	SCOTT	258	WATSON		
109	N. HARRISBURG	259	ALBERTSTOWN		
110	MOUNT ROCK	260	WEST LANCASTER		
111	GREENLAND	261	MADISONVILLE		
112	LANDISVILLE	262	NEFFSVILLE		
113	GREEN PARK	263	BEAVERTOWN		
114	SELINSGRIVE	264	BELMONT		
115	SUMNER	265	LAKE HARMONY		
116	AUBURN	266	GEORGETOWN		
117	ROHRSBURG	267	SCOTT		
118	DERRY	268	N. HARRISBURG		
119	EAST GREENVILLE	269	MOUNT ROCK		
120	NEW DANASUS	270	GREENLAND		
121	NEW COLUMBIA	271	LANDISVILLE		
122	FARMERSVILLE	272	GREEN PARK		
123	GREENFIELD	273	SELINSGRIVE		
124	NORTH STRUDSBURG	274	SUMNER		
125	TANNERSVILLE	275	AUBURN		
126	ELIZABETHVILLE	276	ROHRSBURG		
127	WYOMISSING	277	DERRY		
128	EXETER	278	EAST GREENVILLE		
129		279	NEW DANASUS		
130		280	NEW COLUMBIA		
131		281	FARMERSVILLE		
132		282	GREENFIELD		
133		283	NORTH STRUDSBURG		
134		284	TANNERSVILLE		
135		285	ELIZABETHVILLE		
136		286	WYOMISSING		
137		287	EXETER		
138		288			
139		289			
140		290			
141		291			
142		292			
143		293			
144		294			
145		295			
146		296			
147		297			
148		298			
149		299			
150		300			

\* - SUBSTATIONS THAT HAVE BEEN RETIRED.  
 ## - SITE OF THE EXISTING 230KV SUBSTATION AND PROPOSED 500KV SUBSTATION

## INTERCONNECTIONS

PS PUBLIC SERVICE ELECTRIC AND GAS CO. OF N.J.  
 ME METROPOLITAN EDISON CO. (FIRST ENERGY)  
 PE PHILADELPHIA ELECTRIC CO. (PECO ENERGY)  
 SC BALTIMORE GAS AND ELECTRIC CO.  
 SH SAFE HARBOR WATER POWER CORPORATION  
 UP THE UNITED GAS IMPROVEMENT CO. - LUZERNE ELECTRIC DIVISION  
 PN PENNSYLVANIA ELECTRIC CO. (FIRST ENERGY)  
 JC JERSEY CENTRAL POWER AND LIGHT CO. (FIRST ENERGY)



**HOSENSACK - WESCOSVILLE #3 230KV LINE**

ACCT - 805201	ELECTRICAL SYSTEM MAP		
SCALE - NONE	HOSENSACK - WESCOSVILLE #3 230KV LINE		
BY - CDW	DATE	PPL ELECTRIC UTILITIES	
APPROVED	7/17/85	G. HAKUN III	
PPL DRAWING NO.	SHEET NO.	REV.	
D191830	1	86	

REFERENCE TITLE	NUMBER	REFERENCE TITLE	NUMBER	NO.	DATE	ACCT.	BY	REVIEWED	APPROVED
				84	4/11	169004	MG	RWM	DJG
				83	4/11	161723	MG	RWM	JBW
				86	4/15/11	10013847	MG	RWM	DLH
				85	4/13/11	169004	MG	RWM	DG

# **Attachment**

**2**

**ATTACHMENT "2"**  
**HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT**  
**ENGINEERING DESCRIPTION**

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>TOPIC</u></b>	<b><u>PAGE</u></b>
A.	DESCRIPTION OF PROPOSED LINE .....	1
B.	MAGNETIC FIELD MANAGEMENT .....	3
C.	RIGHT-OF-WAY STATUS .....	4

**LIST OF TABLES**

TABLE 1	DESIGN MINIMUM CONDUCTOR CLEARANCES .....	2
TABLE 2	CONDUCTOR THERMAL RATINGS .....	3

**LIST OF FIGURES**

FIGURE 1	PROPOSED 230 kV SINGLE CIRCUIT STRUCTURE .....	5
----------	--	---

**LIST OF MAPS**

AERIAL EXHIBITS

ATTACHMENT "2" MAP POCKETS

## ATTACHMENT "2"

### HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT ENGINEERING DESCRIPTION

---

#### **A. PROPOSED LINE DESIGN**

PPL Electric proposes to rebuild 8.7 miles of the Hosensack – Wescosville #3 230 kV Transmission Line. This transmission line begins near the Hosensack Substation located in Lower Milford Township, Lehigh County, and continues north to PPL Electric's Wescosville Substation located in Upper Macungie Township, Lehigh County. As previously discussed in Attachment "1," this project is part of PPL Electric's Vintage Conductor Program, which was developed to address aged, deteriorated transmission facilities.

This project involves the removal of the existing transmission line, including the steel lattice towers and conductors, all of which were built in the late 1920's. The existing single circuit 230 kV transmission line is supported by lattice towers with an average height of approximately 90 feet and average span of approximately 1100 feet. The proposed rebuilt transmission line will be designed to accommodate a single circuit 230 kV line. The proposed new transmission line will consist mostly of single-shaft steel poles equipped with upswept steel arms (Figure 1). Angle structures may consist of single, two- or three-pole structures depending on the severity of the angle.

All poles will be installed on concrete foundations. Additionally, some angle structures may be guyed. Altogether, this project requires the installation of approximately 42 structures with an average height of 120 feet. The average span length will be 1100 feet. It is PPL Electric's intention to place the new poles adjacent to the existing lattice towers along the centerline of the right-of-way. However, to reduce environmental impacts, the location of some poles may be shifted or adjusted, which could result in more structures.

The rebuilt transmission line will be designed to meet, and generally exceed, National Electrical Safety Code ("NESC") minimum standards. Additional design criteria and safety rules practiced

by PPL Electric are included in Attachment 4. Three power conductors and one optical ground wire (“OPGW”) will be installed. The power conductors will be 795 KCMIL<sup>1</sup> 30/19 stranding ACSR.<sup>2</sup> The OPGW will be 0.752-inch diameter OPGW with 48 single mode fibers. In addition, a second overhead shield wire will be installed which will consist of ½-inch extra high-strength steel.

The minimum conductor-to-ground clearance will be 32 feet for the rebuilt transmission line. This minimum clearance occurs at a maximum sag, which occurs at the maximum thermal conductor temperature of 125°C or maximum ice loading. Table 1 shows the designed minimum conductor clearances and Table 2 shows the conductor thermal ratings of the proposed transmission line.

**TABLE 1**  
**DESIGN MINIMUM CONDUCTOR CLEARANCES**  
**FOR 795 KCMIL 30/19 STRAND ACSR<sup>3</sup>**

<u>Condition</u>	<u>Single-circuit Design Clearance-to-Ground</u>
Normal load, average weather (16°C ambient temperature)	40 feet
Predicted extreme thermal load (125°C conductor temperature)	32 feet
Predicted extreme weather conditions, 0°F (1-inch ice, 4 lbs. wind, -18°C)	38 feet

<sup>1</sup> A circular mil is the cross-sectional areas of a wire one mil in diameter, where 1 KCMIL = 0.5067 mm<sup>2</sup>.

<sup>2</sup> Aluminum covered steel reinforced.

<sup>3</sup> Clearances based on a maximum tension of 16,880 pounds and a ruling span of 1,000 feet.

**TABLE 2**  
**CONDUCTOR THERMAL RATING**  
**795 KCMIL 30/19 ACSR**  
**125°C MAXIMUM CONDUCTOR TEMPERATURE**

<u>Condition</u>	Ambient Temperature <u>°C</u>	Wind Speed <u>Knots</u>	Ampacity <u>Amps</u>
Summer Normal	35	0	1058
Winter Normal	10	0	1220
Summer Emergency	35	1.5	1350
Winter Emergency	10	1.5	1521

**B. MAGNETIC FIELD MANAGEMENT**

PPL Electric’s Magnetic Field Management Program is summarized in Attachment 5 and will be applied to reconstruction and new line projects including this reconstruction of the Hosensack – Wescosville #3 230 kV Transmission Line. In order to reduce magnetic field exposures, the program generally prescribes a line design that provides 5 feet higher ground clearances than those required under the NESC, and reverse phasing of new double-circuit lines where it is feasible to do so at low or no cost. The implementation of additional modifications will be considered, provided those modifications can be made at low or no cost and will not interfere with the operation of the line.

Since the Hosensack – Wescosville #3 230 kV Transmission Line is being reconstructed for single circuit operation, reducing magnetic fields by reverse phasing is not possible. However, pursuant to PPL Electric’s Magnetic Field Management Program, some reduction in magnetic field levels will be attained through the use of structures that are higher than the existing lattice towers.

### **C. RIGHT-OF-WAY STATUS**

The entire length of the Hosensack – Wescosville #3 230 kV Transmission Line will be rebuilt within the existing 100-foot wide PPL Electric right-of-way, and, therefore, acquisition of additional rights-of-way is not anticipated. A list of all owners of property within the right-of-way is included as Attachment 7, and is also shown on the aerial photographs contained in Attachment “2” map pockets.

## PROPOSED 230 kV SINGLE CIRCUIT STEEL POLE



**FIGURE 1**  
**POLE STATISTICS**

Average Height – 120 feet

Arm Length (Top & Bottom) – 12 feet


Arm Length (Middle) – 17 feet

Overhead Groundwire Arm Length – 14.5

Conductor Spacing:

Overhead Groundwire to Top Phase – 20 feet

Phase to Phase – 13 feet



**Right of Way Property Owners**

1 - Penna Power & Light Co	26 - Michael & Robyn Koprzewicz	51 - Donna M Batz & Dale G Raudenbush
2 - Most Rever John O Barnes Sd Jo DD	27 - Renoberto Bigatei & Lysia M Busoltis	52 - Edward T & Ann L Zabocki
3 - Most Rever John O Barnes Sd Jo DD	28 - Robert D & Sandra A Boag	53 - Michael A & Donna M Heisch
4 - Most Rever John O Barnes Sd Jo DD	29 - John O Barnes Sd Jo DD	54 - John J & Dawn C Dorazio
5 - Most Rever John O Barnes Sd Jo DD	30 - James J & Collette F Larnoe	55 - Robert J & Maureen A Calder
6 - Most Rever John O Barnes Sd Jo DD	31 - Angelo M & Jacqueline Fernandez	56 - Robert J & Maureen A Calder
7 - Yastishok Andrew Residuary Trust	32 - Yastishok Andrew Residuary Trust	57 - Joannis M Giannaris
8 - Lower Macungie Twp	33 - Yastishok Andrew Residuary Trust	58 - Michael R & Maria J Bleiler
9 - Ronald K Walsh	34 - Yastishok Andrew Residuary Trust	59 - Bai Huy & Loan Phan
10 - Adrienne M & Thomas L Miao	35 - Yastishok Andrew Residuary Trust	60 - Lower Macungie Twp
11 - Edward A & Pamela A Korobok	36 - Francis J & Jean A Szabo	61 - Dale & Joan Snyder
12 - Edward A & Pamela A Korobok	37 - Yastishok Andrew Residuary Trust	62 - 2250 Broxton Road LP
13 - Scott J Zolozick	38 - Yastishok Andrew Residuary Trust	63 - Faith Evan Free Church
14 - Yastishok Andrew Residuary Trust	39 - Patrick J & Nicola A Slatten	64 - Brendan & Katherine O'Brien
15 - Todd E Bricker	40 - Albert F & Constance E Ernst	65 - Lower Macungie Twp
16 - Lower Macungie Twp	41 - Yastishok Andrew Residuary Trust	66 - Lower Macungie Twp
17 - Yastishok Andrew Residuary Trust	42 - Edward P & Lori A Staniewicz	67 - Lower Macungie Twp
18 - Yastishok Andrew Residuary Trust	43 - Keith E & Sandra L Eberwein	68 - Lower Macungie Twp
19 - Gretchen Paarl	44 - Spencer L Hogan	69 - Lower Macungie Twp
20 - Matthew A & Julie E Nusbaum	45 - Larry I & Andrea T Evans	70 - Liv Hope Orthodox Presb Church
21 - A G & V Parapopoulos	46 - Day Times Inc	71 - Lower Macungie Twp
22 - A G & V Parapopoulos	47 - Day Times Inc	72 - Lower Macungie Twp
23 - Yastishok Andrew Residuary Trust	48 - Marc H & Michele L Friedman	73 - Sauerkraut Lane LP
24 - Daniel & Roseann Gagliardi	49 - Gregory P & Candice Leigh Douglass	74 - David W & Lisa Helmer
25 - Barry W & Sandra L Kuder	50 - Bert H Jr & Sullien C Blanton	



- Legend**
- Right-of-Way
  - Hosensack - Wescosville Existing Line
  - Right of Way
  - Property Owners

**Property Owners - Map Extent 1**  
**Hosensack - Wescosville Transmission**  
**Upgrade Project**  
 Lehigh County, Pennsylvania



Map formatted for 11" x 17" (297x427) size sheet.  
 Ratio scale not valid for other page sizes.  
 NAD83 1988 StatePlane Pennsylvania South  
 Projection Lambert Conformal Conic  
 Linear Unit US Feet  
 Lehigh County Parcel Data 2008  
 2008 PAMAP Imagery - Lehigh County, Missouri  
 PPL provided custom data  
 GCS North American 1983



**Right of Way Property Owners**

75 - Macarling Road LP	122 - Loriam & Henry Long
76 - Macarling Road LP	123 - Wade H Bailey
77 - Central Of Pennsylvania, Inc	124 - Debra B. Burt & Mark J. Feiertag
78 - Budd W & Wendy M Kahler	125 - Charrn Mogk
79 - Randal S & Susan F Barriard	126 - Edward Jr & Sue Newett
80 - John A & Tonya M Capizzi	127 - Nancy L O'Brien
81 - Mark A & Katherine A Lichterwaler	128 - Todd R & Sallyann M Huddleston
82 - Ira Leinrich Construction Co Inc	129 - Rudolf R Jr George
83 - Pennsylvania Lines LLC	130 - Dale Heppick
84 - Chelissa Schwanerich LLC	131 - Donald R & Kathy M Hunt
85 - Chelissa Schwanerich LLC	132 - Ivon L & Doreen D Ecker
86 - Jason O Adams & Robert C Newman Jr	133 - Ivon L & Doreen D Ecker
87 - Scott D Davis	134 - Geoffrey C & Susan L Warnwright
88 - Michael Harried	135 - Jeffrey A & Malli M Burges
89 - Walter F & Donna A Yext	136 - Gerald W Wachter
90 - Kathon Enterprises Llc	137 - Ariene F Wachter
91 - Evelyn & Joseph Sadovitz	138 - Sarah M Garwood & Todd R Farmand
92 - Linda K Schrick	140 - Gerald W & Ariene F Wachter
93 - Robert & Jennifer A Selbert	142 - Adam R & Jennifer B Korneichel
94 - John Hirscheschitz	143 - County of Lehigh
95 - John Hirscheschitz	144 - County of Lehigh
96 - O'Donnell Family Trust	
97 - Buckeye Pipe Line Company LP	
98 - Todd M & Suzanne M Garloff	

**Legend**

- Right-of-Way
- Existing Line
- Right of Way
- Property Owners

**ppl**  
PPL Electric Utilities

## Property Owners - Map Extent 2 Hosensack - Wescosville Transmission Upgrade Project


Lehigh County, Pennsylvania

Scale: 1 inch = 500 feet  
 0 250 500 1,000 feet

Map formatted for 17" (22"x34") size sheet  
 Refer to other pages for other page sizes

NAD 1983 StatePlane Pennsylvania South  
 Projection: Lambert Conformal Conic  
 Linear Unit: US Feet

Lehigh County Parcel Data 2008  
 2008 PAMAP Imagery - Lehigh County Mosaic  
 PPL provided custom data  
 GCS: North American 1983



**Right of Way Property Owners**

145 - Berniss & Linda Moyer	159 - Phyllis L Kline
146 - County of Lehigh	159 - Richard C Lutz
148 - County of Lehigh	160 - Sherry Hoch
149 - Peir & Julie Emerich	161 - David M & Emilee A Lobach
150 - Christine Blaine & Matthew Emey	162 - Jeffrey A & Diane K Wenner
151 - Peir A & Julie A Emerich	163 - Susan & David Averill Bell
152 - Peir A & Julie A Emerich	164 - Keith B & Margie K Wenner
153 - Forrest H Jr & Tina N Dottery	165 - Jeffrey L & Deborah L Derstern
154 - Kathy Z Poole-Price	166 - Dean S Bruch
155 - John H Mitchell	167 - Jeffrey L & Deborah L Derstern
156 - Roy H Wiser	168 - Linda R Falzer et al
157 - Tracy L Dreher	169 - Linda R Falzer et al
	170 - Linda R Falzer et al

**Legend**

- Right-of-Way
- Existing Line
- Right of Way
- Property Owners

**Property Owners - Map Extent 3**  
**Hosensack - Wescosville Transmission Upgrade Project**  
 Lehigh County, Pennsylvania



Scale: 1 inch = 500 feet  
 Map formatted for 27" (220x347) size sheet  
 Ratio scale not valid for other page sizes  
 NAD83 1983 (Bucklin) Pennsylvania South  
 Projection Lambert Conformal Conic  
 Linear Unit US Feet  
 Lehigh County Parcel Data 2009  
 2008 PAMAP Imagery - Lehigh County Mosaic  
 PPL provided custom data  
 GCS North American 1983

G:\GIS\_Data\PPL\HOSENSACK\Projects\ROW\_PropertyOwners\PPL\_Hosensack ROW\_PropertyOwners\_Extent3\_new.mxd



# **Attachment**

**3**

**ATTACHMENT "3"**  
**HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT**  
**SITING ANALYSIS AND ENVIRONMENTAL ASSESSMENT**

---

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>TOPIC</u></b>	<b><u>PAGE</u></b>
A.	INTRODUCTION.....	1
B.	ALTERNATIVE ROUTE ANALYSIS.....	1
C.	LAND USE.....	4
D.	EXISTING LAND USE.....	4
E.	CULTURAL RESOURCES.....	7
F.	NATURAL FEATURES.....	10
G.	THREATENED AND ENDANGERED SPECIES.....	14

**LIST OF TABLES**

TABLE 1	PERCENT EXISTING LAND USE ALONG RIGHT OF WAY BY TOWNSHIP.....	5
TABLE 2	PERCENT LVPC AND MUNICIPAL ZONING ALONG RIGHT OF WAY BY TOWNSHIP.....	6
TABLE 3	POPULATION CHANGE BY TOWNSHIP.....	6
TABLE 4	SURFACE WATER CLASSIFICATION.....	12
TABLE 5	NATURAL AREA INVENTORY DATA.....	15
TABLE 6	PADCNR SPECIES OF CONCERN.....	16

## ATTACHMENT "3"

### HOSENSACK – WESCOSVILLE #3 230 kV TRANSMISSION LINE REPLACEMENT SITING ANALYSIS AND ENVIRONMENTAL ASSESSMENT

---

#### A. INTRODUCTION

PPL Electric plans to rebuild the vintage 1920's transmission structures and conductor system on the Hosensack-Wescosville #3 230 kV Line in order to prevent degradation in reliability, as well as eliminate potential safety concerns for the public due to deteriorated facilities. The project involves removing the vintage lattice tower structures along an 8.7-mile long corridor and replacing them with single-shaft steel poles. The project also involves upgrading the conductor system.

Although PPL Electric is seeking approval of the rebuild of the Hosensack-Wescosville #3 230 kV transmission line through this Letter of Notification, which does not require an analysis of alternative routes, PPL Electric deemed it prudent to conduct such a review. PPL Electric believes that the additional review is appropriate given the length of the line to be rebuilt and the varying geography the line crosses.

The existing Hosensack-Wescosville #3 230 kV right-of-way ("ROW") traverses high-density residential areas, commercial districts, and open farmlands. PPL Electric determined through a review of the surrounding landscape, as discussed in the following narrative, that any alternative route outside of the existing ROW would result in significantly greater impacts to both the social and natural environments, and increase project costs. Therefore, the existing Hosensack-Wescosville #3 230 kV ROW was selected as the best option for rebuilding the transmission line.

#### B. ALTERNATIVE ROUTE ANALYSIS

PPL Electric conducted a siting analysis to determine if a reasonable alternative route for the Hosensack-Wescosville #3 230 kV Transmission Line could be developed. Initial aspects of this

process involved review of a broad study area to identify existing land use, evaluation of potential new residential, commercial, or other developments, and recognition of the natural and cultural elements within the study area. During this phase, major constraints to a potential alternative route, such as the high-density development on the east side of the Pennsylvania Turnpike, were identified and used to define the study area. Evaluation of the study area also noted potential alignment options along existing transmission line and pipeline ROWs, highway corridors, and undeveloped areas, such as stream valleys and agricultural areas.

Information from a study area field review assessment, conducted in the fall of 2010, was added to a high-resolution aerial map to aid with the alternative route appraisal. This field study information was primarily the location of new residential developments that had been built since the imagery was captured, but areas of low density residential located within steeply sloped forested areas were also identified as potential constraints. These residential constraints were located primarily in the northern and central sections of the study area. Additional Geographic Information Systems (“GIS”) information, such as streams, wetlands, county and local parks, schools, and cultural resource features were also added to the map to further describe the existing landscape. These features help to define best opportunity and constraint areas for transmission line development. Many of the more environmentally sensitive areas were located within the southern section of the study area, near the Hosensack substation.

Potential routes identified during the field review were digitized on the map and assessed. Other routes that might be feasible based on review of the map were also generated. Most of the field and map reviews explored routes using other electric transmission line ROWs to provide connection from the Wescosville substation to the Hosensack substation. The impact associated with using these ROWs from an engineering perspective, and also from a social and natural environment perspective, would be significantly greater than using the existing ROW. Development of these alternative routes would require acquisition of new ROW easements from landowners, some of whom may not be receptive of the project. Assuming these easements were obtained, the ROW corridor would also need to be cleared of vegetation and new access roads would need to be created for the construction process and ongoing maintenance. In some cases,

additional costs would also be necessary to modify existing transmission line structures to accommodate the co-location of the proposed line. Other route options involved paralleling existing pipeline ROWs. These routes eventually became constrained by the high-density residential development areas and restricted to rebuilding within the existing pipeline ROWs which may not be feasible from an engineering perspective. These options would also involve the additional social, natural, and engineering impacts associated with the need to acquire and create a new 150-foot ROW adjacent to the existing pipeline ROWs, where land was available. Similarly, the option of paralleling Route 222 was reviewed. Route 222 is a major highway that traverses east to west through the northern section of the study area. This option also became constrained by residential development and would involve acquisition of ROW for the full length of the line, which would result in increased impacts to natural features.

Very few overland routes were identified due to the high-density development in the northern and central sections of the study area. These potential routes tended to be convoluted and indirect due to the need to avoid individual residential units. To circumvent some residential areas, undeveloped stream valleys were assessed in certain locations. These streams were typically associated with the Little Lehigh Creek watershed, which has a Pennsylvania Department of Environmental Protection (“PADEP”) designated use of High Quality-Cold Water Fishes. Use of these stream valleys would generate elevated environmental impacts and initiate a more intensive permitting process. Potential overland routes in the southern section, which has significantly less residential development, were constrained primarily by the existence of several large natural areas (i.e., Hosensack Marsh, Indian Creek Floodplain), preserved farmlands (conservation easement areas), and multiple cultural resources, primarily churches and cemeteries.

Ultimately while some potential alternatives were identified, none of these options were determined to be feasible due to the significant social, natural environment, and economic costs. All of the alternatives would require acquisition of substantial new ROW, require the permitting of new stream and wetland crossings, and be up to forty percent longer than the existing line.

Based on this evaluation of the alternative route options, PPL Electric concluded that the existing Hosensack-Wescosville #3 230 kV line ROW was the best option.

### **C. LAND USE**

The Hosensack-Wescosville #3 230 kV Line runs in a north to south direction through the southwestern section of Lehigh County. The northern terminus in Wescosville lies to the immediate northwest of the intersection of I-476 and US-222. The southern terminus lies just east of Kings Highway (State Route 2027) near the Hosensack Substation. Townships where project activities will occur include Upper Macungie Township, Lower Macungie Township, Upper Milford Township, and Lower Milford Township. Aside from highways, other linear features in the study area include transmission lines, pipelines, and railroad networks. PPL Electric anticipates no impact on these features. The Queen City Airport is located 3.2 miles east of the rebuilt line, and the Company does not anticipate any impacts there. (Figure 1).

### **D. EXISTING LAND USE**

As designated by the Lehigh Valley Planning Commission (“LVPC”), land use in the project study area consists of a mix of development types ranging from industrial to open space/natural features (LVPC 2010). Table 1, Existing Land Use Along ROW, provides a list of land use types and the percent identified within each township along the Hosensack-Wescosville #3 230 kV ROW. The northern half of the project study area is dominated by Urban Development in Upper Macungie and Lower Macungie townships with smaller Natural Feature areas (e.g. streams) that are crossed over by the transmission lines (Figure 2). The middle of the project study area includes small sections of industrial development. The southern section of the project study area is largely rural and/or agricultural in nature, with significant areas of undeveloped riparian habitat associated with the Hosensack Marsh complex (See Natural Features section). The southern portions of the project study area are dominated by Rural Development, Farmland Preservation, and Natural Features. According to the *Southwestern Lehigh County Area Parks,*

*Recreation, and Open Space Plan* (Task Force 2008), “Lower Milford Township is 67% Agriculture & Vacant, and Upper Milford Township is 47% Agriculture & Vacant.”

**Table 1: Percent Existing Land Use Along ROW by Township**

<b>Municipality</b>	<b>LVPC Land Use Classification</b>	<b>Percent Land Use Type Along ROW</b>
<b>Upper Macungie</b>	Urban Development	100%
<b>Lower Macungie</b>	Urban Development	85%
	Natural Features	15%
<b>Upper Milford</b>	Rural Development	39%
	Farmland Preservation	26%
	Urban Development	25%
	Natural Features	10%
<b>Lower Milford</b>	Natural Features	65%
	Farmland Preservation	35%

Comprehensive Land Use Plans and Zoning

In an effort to “promote growth in existing centers of population and adjacent to these centers appropriately where infrastructure exists... [and] the continuation of rural landscapes and compatible land uses in outlying areas, where infrastructure currently does not exist” (*Southwestern Lehigh County Area Parks, Recreation, and Open Space Plan* 2008), the townships that make up the project study area and the LVPC have developed zoning districts that define allowable uses within each district. These zoning districts reflect the historic nature of the southwestern portion of Lehigh County as an agricultural and open space hub mixed with areas of denser urban/suburban development and industrial centers (Figure 3). Table 2, Zoning Along ROW, indicates the types and percent of various zoning districts identified within each township along the Hosensack-Wescosville #3 230 kV ROW. Like the existing land use data, the northern sections of the project study area are more developed urban and suburban areas while the southern sections of the project study area remain primarily agricultural and rural in nature.

Population growth is expected to increase development pressure within portions of the project study area. Forecasts completed by the LVPC indicate that Upper and Lower Macungie Townships will both see significant population growth through 2030. Much of this population growth will likely come from continued suburban sprawl spreading out from Philadelphia. Townships and the County are trying to plan ahead to direct new development or redevelopment required to support this population growth around existing development centers in the northern half of the project study area. Table 3, Population Change, provides a summary of both previous years' US Census data and population forecasts for each township within the project study area.

**Table 2: Percent LVPC and Municipal Zoning Along ROW by Township**

Municipality	LVPC Zoning	Municipal Zoning	Percent Zoning District
Upper Macungie	Suburban Residential	Medium-Low Density Residential	100%
Lower Macungie	Suburban Residential	Suburban	72%
	Urban Residential	Urban	9%
	Retail Commercial	Commercial	8%
	Rural	Rural	8%
	Light Industrial	Industrial	3%
Upper Milford	Rural	Rural Agricultural	73%
	Urban Residential	Suburban Residential	19%
	Suburban Residential	Rural Suburban Residential	10%
	Heavy Industrial	Industrial	7%
Lower Milford	Rural	Agricultural Rural	100%

**Table 3: Population Change by Township**

Municipality	1900 Census	2000 Census	2010 Forecast	2020 Forecast	2030 Forecast	2000-2030 Change
Upper Macungie Twp	2,081	13,895	19,859	26,479	33,508	19,613
Lower Macungie Twp	2,920	19,220	28,020	33,424	42,193	22,973
Upper Milford Twp	2,712	6,889	7,504	7,804	7,974	1,085
Lower Milford Twp	1,233	3,617	4,094	4,852	5,907	2,290
<b>Total</b>	<b>8,946</b>	<b>43,621</b>	<b>59,477</b>	<b>72,559</b>	<b>89,582</b>	<b>45,961</b>

## Agricultural Areas

In general, the Lehigh Valley is home to many historic agricultural areas that support eastern Pennsylvania. These agricultural districts are clustered in the southern sections of the study area. For example, much of the southern third of the project study area located within Upper and Lower Milford townships is designated by the LVPC as Farmland Preservation land (Figure 4). The existing transmission line runs north to south along the western edge of one designated area that comprises over 5,761 acres. Two other agricultural designations are also found primarily in the southern portions of the project study area – Agricultural Easements and Agricultural Security Areas. Two agricultural easements, both owned by a single family, are found in Upper Milford Township. These total over 250 acres. In addition, four agricultural security areas, one in Lower Macungie Township and three in Lower Milford Township, are also located within the project study area. The Lower Macungie agricultural security area is approximately 133 acres. The three agricultural security areas found in Lower Milford Township total 219 acres. Of all these areas, only portions of the three agricultural security areas in Lower Milford Township overlap with the land area designated as Farmland Preservation by the Lehigh Valley Planning Commission. Thus, it is evident that agricultural land use plays a major role in the southern sections of the project study area.

## **E. CULTURAL RESOURCES**

### Archaeological Assessment

The project area for the proposed transmission line passes through three physiographic provinces. The southern portion is within the Gettysburg-Newark Lowland Section of the Piedmont Province. Review of the Pennsylvania Historical and Museum Commission (“PHMC”) Bureau for Historic Preservation (“BHP”) Cultural Resources Geographic Information System (“CRGIS”) reveals that only two archaeological sites are recorded in this province within one mile of the proposed transmission line, neither of which is directly on the line (Figure 5). The northern portion of the transmission line is within the Great Valley Section of the Ridge and Valley Province and the Reading Prong of the New England Province. This

portion of the line traverses an area of intensive prehistoric jasper quarrying and is within the central, or quarry, zone of the Hardyston Jasper Prehistoric District. The line passes between two major recorded jasper quarries, Vera Cruz and Macungie. Over 40 archaeological sites are recorded in the CRGIS within one mile of the northern portion of the proposed transmission line. One site, 36LH117, is located in the transmission line corridor and, if feasible, will be avoided when selecting tower/pole locations. The site is recorded as a prehistoric jasper quarry and workshop. The eligibility of the site is undetermined due to insufficient data. Two previous archaeological surveys encompassed portions of the transmission line corridor. Studies for the proposed Route 222 relocation included the northern 4,000 ft of the proposed transmission line (ER No. 1990-0282-077). The survey area of the I-78 relocation project crossed the transmission line (ER No. 1981-0267-077). Neither survey identified sites within the transmission line corridor.

Distance to water has been found to be the best predictor of prehistoric archaeological site location. Therefore, areas within 150 m (500 ft) of a stream, spring, or wetland are considered to have a high probability for prehistoric sites. In areas of the Gettysburg-Newark Lowland Section that are more distant from water, the transmission line corridor is considered to have a low probability for prehistoric sites. In the Great Valley and Reading Prong Sections, areas that are in close proximity to a known quarry, even if distant from water, are considered to have a high probability for sites such as jasper workshops. Because of the intensity of quarrying in these two provinces, areas distant from both water and lithic quarries are considered to have a medium probability for prehistoric sites.

Pre-nineteenth century historic sites are generally located near streams. Historic-period maps will be consulted to identify areas of high probability for later historic archaeological sites. Locations of extant above-ground historic resources also have a high probability for historic archaeological deposits.

A consultation with the PHMC was held on January 28<sup>th</sup>, 2011 and indicated that Phase I archaeological survey is required. A strategy for Phase I archaeological survey was developed.

Given the relatively small area of impacts for each pole, surveys will be conducted only in high probability areas. High probability areas would consist of locations near streams and in areas likely to contain sites related to prehistoric jasper quarrying in the region. Shovel tests will be excavated to either side of the existing towers. A shovel test involves digging a small series of test holes to examine the soil for any potential cultural remains that are not visible on the surface. Should artifacts be identified, additional shovel tests will be performed to identify provisional site boundaries and artifact densities. Should it be determined later that pole construction would be required in an untested area a supplemental field survey will be conducted. A report of the archaeological survey will be prepared for PHMC in accordance with current guidelines. Should potentially significant archaeological sites be identified, a Phase II survey will be conducted to determine their eligibility for the National Register. If National Register-eligible sites are present within the APE and cannot be avoided, measures will be taken to mitigate the adverse effects of transmission line construction.

#### Historic Architectural Assessment

A desktop survey of historic architectural resources within the Hosensack Project area was completed that consisted of accessing the PHMC's CRGIS system to review available information on previously-recorded historic architectural sites on and near the transmission line alignment.

There are NRHP-listed and eligible resources located in the project area. The National Register-Listed Dillingersville Union School and Church in Lower Milford Township is located less than a mile to the east of the proposed transmission line route. It is possible that the new transmission line will be visible from this previously-recorded historic resource. The National Register-eligible Philadelphia and Reading Railroad Historic District, which traverses several municipalities, crosses the proposed transmission line route in two locations: primary rail system in Lower Macungie Township and a secondary line in Upper Milford Township.<sup>1</sup> It is unlikely that the transmission line will have an adverse effect on these linear resources. However, the

---

<sup>1</sup> PHMC key number 155708.

portion of these railroad lines that the transmission line crosses may need to be assessed for contributing elements once the pole locations and designs have been solidified. In addition, five individual historic resources located within a mile of the proposed transmission line have been previously determined eligible for the National Register of Historic Places. This list includes the Mechling Homestead in Lower Milford Township,<sup>2</sup> and the Thomas Shuler, George & Unger Farmstead,<sup>3</sup> J. Bastian House,<sup>4</sup> J. B. Wieland Hotel,<sup>5</sup> and the Tank Farm Road Bridge in Lower Macungie Township.<sup>6</sup>

A review by PHMC indicated that although historic buildings/structures/districts/objects may be located in the project area, in its opinion, the activity described with this proposed construction should have no effect on such resources. Letter dated January 4<sup>th</sup>, 2011, ER# 10-2324-077-A.

## **F. NATURAL FEATURES**

The project area crosses several physiographic regions, geologic formations, soil associations, streams, and wetlands as it runs from north to south. These features are described in detail within the following sections. The Lehigh-Northampton Natural Areas Inventory (The Nature Conservancy 2005) further describes two areas of ecological importance within the project area – East Texas-Little Lehigh Creek and Swabia/Indian/Hosensack Watershed.

### Physiographic Regions and Bedrock Geology

The project area traverses from north to south across three physiographic sections, the wide lowlands of the Great Valley Section, the higher, abrupt prominence of the Reading Prong Section (also referred to as South Mountain), and the rolling low hills of the Gettysburg-Newark Lowland Section. Bedrock geology found within the project area consists of the Allentown Formation and Leithsville Formation associated with the Great Valley Section, and various

---

<sup>2</sup> PHMC key number 86508,

<sup>3</sup> PHMC key number 86520,

<sup>4</sup> PHMC key number 96778,

<sup>5</sup> PHMC key number 96807,

<sup>6</sup> PHMC key number 97723.

components of the felsic to mafic gneiss, Hornblende gneiss, and Hardyston Formation associated with the Reading Prong and Gettysburg-Newark Lowland Sections (Berg 1980) (Figure 6). These formations consist of a mix of gneiss, dolomite, and quartzite as primary rock types. Limestone, sandstone, and shale are also found in various formations as secondary rock types.

### Soils

According to the Soil Survey of Lehigh County (USDA 1963), four primary soil associations are found within the project area. These soil associations, from north to south, are as follows:

- Washington-Duffield Association: deep soils of valleys on limestone
- Chester-Brandywine Association: deep and moderately deep soils of South Mountain on granite, gneiss, and quartzite.
- Murrill Association: deep soils of the lower slopes of South Mountain.
- Fleetwood-Chester Very Stony Association: deep and moderately deep, stony soils of the ridges of South Mountain on quartzite and gneiss.

The Washington-Duffield Association comprises the northern half of the entire project area. The Chester-Brandywine Association is found in smaller bands throughout sections of the southern half of the project area. The Murrill Association runs in a narrow band in an east-west direction through the center of the project area. The Fleetwood-Chester Very Stony Association forms the smallest bands of soil associations within the southern half of the project area.

### Surface Water Resources

The Hosensack-Wescosville Line crosses over six creeks as it runs from Wescosville in the north to Hosensack in the south. Three of these streams are named streams, and three streams are unnamed tributaries of named streams. All six of these streams have been classified by the PADEP under Title 25 Chapter 93 as Cold Water Fisheries (PADEP (a) 2010). Four of the six streams are also classified as High Quality Waters by PADEP. According to PADEP's e-

MapPA website, two of these High Quality Waters are also Trout Stocked Fisheries (PADEP (b) 2010). Table 4, Surface Water Classification, provides a summary of all streams found within the project area and their classifications (Figure 7). Definitions for each of these classifications are located below.

**Table 4: Surface Water Classification**

STREAMS		
Name	Designated Use	Trout Stocked Fishery
Little Lehigh Creek	HQ-CWF	Y
Swabia Creek	HQ-CWF	Y
Unnamed Tributary to Lehigh Creek	HQ-CWF	N
Leibert Creek	HQ-CWF	N
Unnamed Tributary to Hosensack Creek	CWF, MF	N

- CWF - *Cold Water Fishes*—Maintenance or propagation, or both, of fish species including the family Salmonidae and additional flora and fauna which are indigenous to a cold water habitat.
- TSF - *Trout Stocked Fishes*—Maintenance of stocked trout from February 15 to July 31 and maintenance and propagation of fish species and additional flora and fauna which are indigenous to a warm water habitat.
- HQ - *High Quality Waters*—Designation indicates that surface waters have quality which exceeds the level necessary to support propagation of fish, shellfish, and wildlife and recreation in and on the water as determined by §93.4b(a).
- MF - *Migratory Fishes*—Passage, maintenance and propagation of anadromous and catadromous fishes and other fishes which move to or from flowing waters to complete their life cycle in other waters.

### Wetlands

Based on review of the U.S. Fish and Wildlife Service's ("USFWS") National Wetland Inventory ("NWI"), the Hosensack-Wescosville Line also crosses several wetland systems as it runs from north to south (USFWS 2010). The majority of these wetland systems are found within the southern half of the study area, and some are major components of designated natural areas (See Natural Area Inventory section). Most of these wetlands are palustrine forested wetlands associated with riparian areas of streams. Palustrine emergent and palustrine scrub-shrub wetland systems are found interspersed throughout these stream riparian zones, as well. Throughout the study area scattered palustrine unconsolidated bottom, or small ponds, can also be found. Some of these ponds may be man-made.

The NWI provides a general overview of the potential wetlands that may be located within an area. For federal and state permitting purposes, wetlands and waterways within the project study area will be required to be delineated according to regulatory standards, surveyed, and illustrated on development plans. Impacts to these natural features may require mitigation. PPL Electric will obtain and adhere to the terms and conditions of all required permits.

### Vegetation

Vegetative cover in the northern and central sections of the project area has been influenced by the dense residential and commercial development. Most of the natural vegetative cover has been removed or is dominated by maintained lawns. Old fields, upland forests, or narrow forested riparian corridors are infrequently noted within the project area. Primary field species include goldenrods (*Solidago* spp.), bush honeysuckles (*Lonicera* spp.), and multiflora rose (*Rosa multiflora*). Upland forested areas are composed primarily of hardwoods that include white ash (*Fraxinus Americana*), chestnut oak (*Quercus montana*), red oak (*Quercus rubra*), and pignut hickory (*Carya glabra*). The forested riparian corridors include silver maple (*Acer saccharinum*), black willow (*Salix nigra*), and American elm (*Ulmus americana*).

Vegetative cover in the southern portion of the project area is more expansive but has been influenced by agricultural development. Several sections of the ROW traverse fields of row

crops, which include corn, soybeans, and hay, or over the few dairy or horse farms noted in the area. Much of the natural vegetation is in the form of upland forests or old fields and contains the same species noted for the northern and central sections. The southern section, however, has more diversity in habitats (swamps, marshes, floodplain forests), as well as vegetative species associated with the Swabia/Indian Creek/Hosensack Watershed.

## **G. THREATENED AND ENDANGERED SPECIES**

### Natural Areas Inventory

The Nature Conservancy's Lehigh-Northampton Natural Areas Inventory identified two sites within the project area of special concern (Figure 7). The first site, East Texas-Little Lehigh Creek, is located near the middle of the project area along the Little Lehigh Creek in the town of East Texas. Located just west of the ROW, this site is associated with the riparian zone along Little Lehigh Creek and is of importance due to the presence of a spikerush species, a state listed threatened species of concern. Transmission line construction activities should be able to avoid this area, so no impact is expected.

The second site is the Swabia/Indian Creek/Hosensack Watershed. This site is found within the southern portion of the project area. The watershed is much larger than the East Texas-Little Lehigh Creek, and includes several connected habitat types, including marshes, streams, forested riparian areas, and scrub-shrub wetlands. The Nature Conservancy, when investigating this watershed specifically identified the Hosensack Substation and associated powerline right of way as potentially being beneficial to threatened and endangered species found within this portion of the project area. This is evidenced in the following passage from *A Natural Areas Inventory of Lehigh and Northampton Counties, Pennsylvania*:

“Another site within this watershed includes areas of marsh and shrub swamp. Part of the site has been disturbed by the construction of an electric power transfer station and associated powerline ROW. Some of the habitat created by these disturbances may be benefiting the rare species that occur

here. The site supports a fair to good example of an animal species of concern.”

**Table 5: Natural Area Inventory Data** (modified from the *Lehigh and Northampton Counties NAI*)

Site Name	Special Species /Community Type	Last Seen
East Texas –Little Lehigh Creek	Matted Spike-rush ( <i>Eleocharis intermedia</i> )	9/29/93
Swabia/Indian/ Hosensack Watershed (Formerly Hosensack Marsh, Indian Creek Floodplain, and Macungie Watershed)	Animal	6/5/97
	White-Trout Lily ( <i>Erythronium albidum</i> )	4/20/01
	Animal	1996
	Northern Appalachian Circumneutral Seep NC	6/26/97

### Pennsylvania Natural Diversity Inventory Review


A review of the Pennsylvania Natural Diversity Inventory (“PNDI”) database was conducted for the project area (PNDI Number 20969). The Pennsylvania Fish and Boat Commission (“PAFBC”) and Pennsylvania Game Commission (“PGC”) noted that no impacts to fish or mammal species are anticipated. The USFWS noted the potential presence of the federally threatened bog turtle (*Glyptemys muhlenbergii*). This species prefers to live in shallow, spring-fed bogs, swamps, marshy meadows, and pastures with soft, muddy bottoms, and slow-flowing waters. Only USFWS qualified bog turtle surveyors can conduct the Phase I habitat or Phase II presence/absence surveys required by USFWS.

The review further indicated the potential presence of six plant species of concern identified by the Pennsylvania Department of Conservation and Natural Resources (“PADCNR”). The PADCNR requires that a qualified botanist conduct the survey of the project area for these species. These species and their habitats are listed in Table 6, PADCNR Species of Concern. Species followed by an asterisk (\*) are currently unlisted in Pennsylvania and are not a target species for the required survey, but due to their ecological significance, PADCNR is

recommending that they be voluntarily added to the survey to avoid potential impacts. All conflicts will be resolved prior to the start of construction.


**Table 6: PADCNR Species of Concern**

<b>Species</b>	<b>Scientific Name</b>	<b>Status</b>	<b>Habitat</b>	<b>Flowering Season</b>
White milkweed	<i>Asclepias variegata</i>	Proposed PA Endangered	Dry woods	May - July
Matted spike rush	<i>Eleocharis intermedia</i>	PA Threatened	Marshes, wet meadows, stream banks of calcareous soils	Mid-late summer
Swamp dog hobble	<i>Leucothoe racemosa</i>	Proposed PA Threatened	Wet woods and thickets	Late May - Early June
Winged loosestrife	<i>Lythrum alatum</i>	Proposed PA Endangered	Swamps, wet meadows, marshy shorelines and ditches	June - Early September
White trout lily*	<i>Erythronium albidum</i>	Currently Unlisted	Moist Woods and rich slopes, especially on limestone	April - May
Tall tick trefoil*	<i>Desmodium canadense</i>	Currently Unlisted	Wooded roadside banks and open woods	June - August



**Legend**

-  Hosensack-Wescosville #3 230 kV Line
-  Gas/Pipelines
-  Transmission Lines
-  Railroad
-  Limited Access Highway
-  US & State Highways
-  Local or City Street
-  Municipalities
-  Counties



Key Map  
Not to Scale



NAD 1983 StatePlane Pennsylvania  
FIPS 3701  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot

Transmission Line Data from PowerMAP & PPL  
Street & Railroad Data from ESRI




1 inch = 5,000 feet



**Figure 1**  
**Linear Features**  
**Hosensack-Wescosville #3**  
**230 kV Line Rebuild**

Upper Macungie, Lower Macungie,  
Upper Milford, and Lower Milford Townships,  
Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\ PPL Hosensack Figure 01 - Linear Features.mxd




**Legend**

Hosensack-Wescosville #3 230 kV Line

**Land Use**

- FP-Farmland Preservation
- NF-Natural Features
- RD-Rural Development
- UD-Urban Development
- Municipalities
- Counties



Key Map  
Not to Scale



NAD 1983 StatePlane Pennsylvania  
FIPS 3701  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot

Land Use provided by Lehigh County




1 inch = 5,000 feet



**Figure 2  
Existing Land Use  
Hosensack-Wescosville #3  
230 kV Line Rebuild**

Upper Macungie, Lower Macungie,  
Upper Milford, and Lower Milford Townships,  
Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\PPL Hosensack Figure 02 - Existing Land Use.mxd




**Legend**

Hosensack-Wescosville #3 230 kV Line

**Zoning**

- Agricultural Preservation
- Environmental Protection
- Heavy Industrial
- Light Industrial
- Mixed Uses
- Office/Business
- Retail Commercial
- Rural
- Suburban Residential
- Urban Residential
- PA Municipalities
- Counties



Key Map  
Not to Scale



NAD 1983 State Plane Pennsylvania  
South FIPS 3702 Feet  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot

Zoning data provided by Lehigh County




1 inch = 5,000 feet




**Figure 3  
Zoning  
Hosensack-Wescosville #3  
230 kV Line Rebuild**

Upper Macungie, Lower Macungie,  
Upper Milford, and Lower Milford Townships,  
Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\PPL Hosensack Figure 03 - Zoning.mxd



- Legend**
- Hosensack-Wescosville #3 230 kV Line
  - Agricultural Conservation Easements
  - Agricultural Security Areas
  - Municipalities
  - Counties



Key Map  
Not to Scale


N  
  
 NAD 1983 StatePlane Pennsylvania FIPS 3701  
 Projection: Lambert Conformal Conic  
 Linear Unit: US Foot  
 Agricultural Easement & Security Area Data provided by Lehigh County

0 2,500 5,000 10,000 Feet  
 1 inch = 5,000 feet

**Figure 4**  
**Agricultural Resources**  
**Hosensack-Wescosville #3**  
**230 kV Line Rebuild**


Upper Macungie, Lower Macungie, Upper Milford, and Lower Milford Townships, Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\PPL Hosensack Figure 04 - Agricultural Resources.mxd



**Legend**

- Hosensack-Wescosville #3 230 kV Line
- Cemetery
- Listed Historic Structures
- Eligible Historic Structures
- Eligible Historic Districts
- School
- Church
- Historic Railroads
- Municipalities
- Counties




Key Map  
Not to Scale



NAD 1983 StatePlane Pennsylvania  
FIPS 3701  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot

Lehigh County-Historic Structures  
(eligible/listed),  
Historic Raillines (eligible),  
Historic Districts (eligible/listed)  
ESRI 93 Cemeteries




1 inch = 5,000 feet




**Figure 5**  
**Cultural Resources**  
**Hosensack-Wescosville #3**  
**230 kV Line Rebuild**


Upper Macungie, Lower Macungie,  
Upper Milford, and Lower Milford Townships,  
Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\ PPL Hosensack Figure 05 - Cultural Resources.mxd



**Legend**

- Hosensack-Wescosville #3 230 kV Line
- Physiographic Provinces
- Municipalities
- Counties



Key Map  
Not to Scale



NAD 1983 StatePlane Pennsylvania  
South FIPS 3702  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot  
PA Geological Survey



1 inch = 5,000 feet

Bedrock Geology Units in Area of Study	
Cal - Allentown Formation	Ob - Beekmantown Group
Cha - Hardyston Formation	Oe - Epler Formation
Clv - Leithsville Formation	Ojk - Jacksonburg Formation
gn - Felsic to mafic gneiss	Om - Martinsburg Formation
hg - Hornblende gneiss	Ori - Rickenbach Formation
Jd - Diabase	Trb - Brunswick Formation
md - Metadiabase	Trfq - Quartz fanglomerate


See text for details




**Figure 6**  
**Geology & Physiographic Provinces**  
**Hosensack-Wescosville #3**  
**230 kV Line Rebuild**


Upper Macungie, Lower Macungie,  
Upper Milford, and Lower Milford Townships,  
Lehigh County, Pennsylvania

Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\ PPL Hosensack Figure 06 - Geology & Physiographic Provinces.mxd



**Legend**

- Hosensack-Wescosville #3 230 kV Line
- Streams - Designated Use**
- CWF(COLD WATER FISHES)
- HQ-CWF(HIGH QUALITY-COLD WATER FISHES)
- HQ-TSF(HIGH QUALITY-TROUT STOCKING)
- TSF(TROUT STOCKING)
- Wetlands
- 100-year Floodplains (A and AE)
- TNC Natural Areas
- Municipalities
- Counties



Key Map  
Not to Scale



NAD 1983 State Plane Pennsylvania  
South FIPS 3702 Feet  
Projection: Lambert Conformal Conic  
Linear Unit: US Foot

Wetlands and Floodplains provided  
by Lehigh County.  
PASDA Chapter 93 Designated Use Streams



1 inch = 5,000 feet

<p><b>Figure 7</b> <b>Natural Features</b> <b>Hosensack-Wescosville #3</b> <b>230 kV Line Rebuild</b></p> <p>Upper Macungie, Lower Macungie, Upper Milford, and Lower Milford Townships, Lehigh County, Pennsylvania</p>	
Prepared By: PLJ	Checked By: BAB
Job: 19998520.00001	Map: \\GIS_Data\PPL\Hosensack\Projects\ PPL Hosensack Figure 07 - Natural Features.mxd

# **Attachment**

**4**

## ATTACHMENT 4

### PPL ELECTRIC DESIGN CRITERIA AND SAFETY PRACTICES

The National Electrical Safety Code (NESC) is a set of rules to safeguard people during the installation, operation, and maintenance of electric power lines. The NESC contains the basic provisions considered necessary for the safety of employees and the public. Although it is not intended as a design specification, its provisions establish minimum design requirements. PPL Electric Utilities Corp. (PPL Electric) has developed design specifications and safety rules which meet or surpass all provisions specified by the NESC.

#### Engineering Design Criteria and Parameters

The NESC includes loading requirements and clearances for the design, construction, and operation of power lines. The "loads" on conductors and supporting structures are the mechanical forces that develop from the weight of the conductors, the weight of ice on the conductors, plus wind pressure on the conductors and supporting structures. Loading requirements are the loads on the conductors and structures that are anticipated assuming certain ice and wind conditions. Loading requirements always contain "safety factors" to allow for unknown or unanticipated contingencies. The clearances and loading requirements contained in the NESC were developed to ensure public safety and welfare.

PPL Electric transmission line design standards meet or surpass the NESC standards. For example, the relative order of grades of construction for conductors and supporting structures is B, C, and N; Grade B being the highest. According to the NESC standards, construction Grades B, C, or N may be used for transmission lines (except at crossings of railroad tracks and limited access highways where Grade B construction is specified). However, PPL Electric designs all of its transmission lines for Grade B construction. The use of Grade B design and construction specifies such things as larger-minimum crossarm dimensions, larger-minimum conductor size, and increased safety factors.

Another example is the design parameters utilized to account for ice and wind loadings on the overhead ground wire (OHGW) and power conductors. The NESC standard ice and wind design magnitudes for the PPL Electric territory are 0.5 inch thickness of radial ice combined with four pounds per square foot horizontal wind pressure (equivalent to 40-mile per hour wind velocity). The conductor sags and tensions used in line designs are the result of various ice and wind combinations, depending on the elevation at the line location and line design voltage. The conductor sags and tensions used in the design of all PPL Electric transmission lines are at least 0.5-inch ice combined with eight pounds wind pressure (equivalent to 57 miles per hour wind velocity). This means that PPL Electric lines are designed to operate safely and reliably during inclement weather even more severe than assumed by the NESC. In addition, PPL Electric transmission lines are designed with more clearance to the ground than required by the NESC. The tables below compare PPL Electric and NESC ground clearances for lines of various voltages.

138 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	21 Ft.	30 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	21 Ft.	30 Ft.
Spaces accessible to pedestrians only	17 Ft.	30 Ft.
Railroad tracks	31 Ft.	35 Ft.

230 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	23 Ft.	32 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	23 Ft.	32 Ft.
Spaces accessible to pedestrians only	19 Ft.	32 Ft.
Railroad tracks	31 Ft.	36 Ft.

500 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	28 Ft.	53 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	28 Ft.	53 Ft.
Spaces accessible to pedestrians only	24 Ft.	53 Ft.
Railroad tracks	38 Ft.	53 Ft.

A relay protection system is used to protect the public safety and welfare as well as equipment and the transmission system. Relay protection is installed for all transmission lines to automatically de-energize the line in the unlikely event that the line or supporting structure fails and the line contacts the ground.

Periodic Maintenance Program on All Transmission Lines

To ensure continued public safety and integrity of service, a periodic maintenance and inspection program is implemented for every transmission line. The program is administered through the use of helicopter patrols, with supplemental foot and structure climbing patrols. A number of helicopter patrols are performed on all lines annually. The two-man helicopter crew flies parallel, to the left, and above the line so that the observer can look for signs of line damage or deterioration and observe clearances between vegetation and conductors. The observations are included in a report that is forwarded to the appropriate department for corrective action.

Foot and structure climbing patrol programs for a transmission line begin approximately three to five years after the line is energized, unless a helicopter patrol reports a need for earlier action. The frequency of foot patrols varies from once every year to once every several years depending on line type and age.

An assigned foot patroller checks right-of-way conditions, including access roads, bridges, pole washouts, tower footers, vegetation height and clearance to conductors, pole and tower deterioration and, with the use of binoculars, insulators, and condition of hardware. Identified problems are included in a report that is forwarded to the appropriate department for corrective action.

A scheduled line outage is required to perform an overhead patrol because of "hands-on" inspection of hardware. Overhead patrols are conducted on a schedule determined by line age, operating record, and observed general condition. The necessary repairs are also done during the inspection outage.

#### Personnel Safety Rules

The following are a few of the PPL Electric safety rules that demonstrate the Company's concern for employee safety:

- Work procedures have been developed to allow work to be performed on energized facilities in a safe manner. When lines or apparatus are removed from service to be worked on, the Energy Control Process system is applied. This system provides that a red tag must be physically placed on the control handle of the de-energized equipment. The red tag may be removed only after proper authorization to energize the equipment. Various other tags are used for limited

operations and informational purposes. Employees will not apply or remove a tag or change the status of tagged equipment unless authorized.

- Temporary safety grounds are used on de-energized facilities for employee safety during maintenance, construction, or reconstruction work. Safety grounds are wires connecting the de-energized facility to an electrical ground. If the facility should be energized, the safety grounds will divert the current directly to ground and reduce the likelihood of personal injury. The conductor size and attachment clamps of temporary safety grounds must be capable of conducting anticipated fault currents. Rubber gloves, rubber sleeves, and additional rubber protective equipment are used as required when applying or removing temporary safety grounds to or from the lines or apparatus to be grounded. An approved nonconductive working stick of sufficient length to allow workers to maintain the following required minimum clearances is used to test that the line has been de-energized and to apply temporary safety grounds:

<u>Voltage-kV</u>	<u>Minimum Clearance</u>
138	3'-7"
230	5'-3"
500	11'-3"

Before applying grounds, a test is done to confirm that the line is de-energized. The voltage test device is checked before and after use to assure reliability. When ground pins are used to establish proper ground points, they are driven to a depth of not less than four feet as near vertical as possible.

- Poles or structures are inspected and examined for structural integrity before climbing. If there is any reason to believe that a pole is unsafe, it is stabilized before work is performed. Appropriate safety gear in the form of body belts, safety straps, hard hats, gloves, etc., is worn by linemen during line work activity.

# **Attachment**

**5**



**MAGNETIC  
FIELD  
MANAGEMENT  
PPL Electric Utilities  
Corporation**

**Attachment 5**

**DECEMBER 2004**

## TABLE OF CONTENTS

INTRODUCTION .....	1
DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	6
VARIABLES THAT AFFECT MAGNETIC FIELDS .....	6
Effect of Phase Current on Magnetic Fields .....	6
Effect of Conductor Configuration on Magnetic Fields .....	7
Effect of Distance from the Magnetic Field Source .....	7
SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	8
MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES.....	9
Overhead Lines.....	9
New or Rebuilt Transmission Lines .....	9
Reconductoring or Adding Additional Circuits to Existing Transmission Lines .....	14
Distribution Lines .....	14
Underground Transmission Lines.....	15
CHARTS.....	16

## INTRODUCTION

At PPL Electric Utilities Corp. (PPL EU), magnetic field management means investigating and implementing methods at low or no cost to reduce magnetic fields in new or rebuilt transmission and distribution lines. This document explains PPL EU's Magnetic Field Management Program, which is part of PPL EU's larger Electric and Magnetic Fields (EMF) policy.

### **PPL EU's View**

Some people are worried that electric and magnetic fields are harming their health. Others think the scientific research does not show a problem at all, and still others believe there's just too much scientific uncertainty to draw any conclusions.

Here's what we do know now. Various panels of scientists that have reviewed the EMF research generally have drawn two main conclusions. First, the large body of evidence does not demonstrate that EMF are harmful. Second, additional research is recommended to explore questions raised in some studies.

Given these conclusions, PPL EU is taking a reasoned approach in responding to the EMF issue. PPL EU's approach to the EMF issue consists of five elements:

- Providing EMF information to customers and employees
- Providing magnetic field measurements
- Establishing and implementing a magnetic field management program to reduce magnetic fields in new or rebuilt facilities when it can be done at no, or low, cost
- Integrating EMF in the public involvement process that PPL EU undertakes in the siting of transmission lines
- Have supported additional research

## **EMF Are All Around Us**

Electric and magnetic fields occur in nature and in all living things. The earth, for instance, has a magnetic field, which makes the needle on a compass point north.

Electric fields and magnetic fields of a different type also surround every wire that carries electricity. In everyday life, these EMF arise from several basic sources, including power lines, electrical appliances, home and building wiring, other utility lines and cables, and currents flowing on water pipes. Though they often occur together, EMF are made up of two separate components:

### **Electric Fields**

Electric fields are produced by the voltage—or electrical pressure—on a wire. The higher the voltage, the higher the electric field. As long as a wire is energized—has voltage present—an electric field is present (see Figure 1). In other words, an appliance, or an electric power line, doesn't actually have to be turned on to create an electric field. It just has to be plugged in.

Electric fields diminish with distance and can be blocked or partially shielded by objects such as trees and houses.

### **Magnetic Fields**

Magnetic fields are created by the current or flow of electricity through a wire. Generally speaking, the higher the current, the higher the magnetic field. Because they only occur when current is flowing, magnetic fields are present only when the power is turned on (see Figure 1). Magnetic fields also diminish with distance, but—unlike electric fields—are not blocked by common objects. In recent years, public and scientific interest has turned toward the magnetic field component of EMF because of some scientific studies regarding these fields.

Figure 1




Figure 2


Magnetic field strengths decrease with distance		Source: "EMF In Your Environment", U.S. Environmental Protection Agency 1992		
Magnetic fields are measured in milligauss		At 6 inches	At 1 foot	At 2 feet
Clothes dryer		2 to 10	* to 3	*
Microwave oven		100 to 300	1 to 200	1 to 30
Toaster		5 to 20	* to 7	*
Power drill		100 to 200	20 to 40	3 to 6
Can opener		500 to 1500	40 to 300	3 to 30
Mixer		30 to 600	5 to 100	* to 10
Hair dryer		1 to 700	* to 70	* to 10
Color television		Data not available	* to 20	* to 8

FIGURE 2 \* The magnetic field measurement at this distance from the operating appliance could not be distinguished from background measurements taken before the appliance had been turned on.

### Measuring Magnetic Fields

Magnetic fields usually are measured in a unit called a milligauss. Magnetic field levels found in the living areas of homes typically range from less than 1 milligauss to about 4 milligauss according to the U.S. Environmental Protection Agency. They can be higher in some cases. The levels next to appliances can exceed 1,000 milligauss (1 gauss). Figures 2 and 3 show how the strength of the field falls off as you move away from the source, just as the heat of a campfire grows weaker as you walk away from it. For overhead power lines, the strength of the magnetic fields is dependent upon a number of factors that will be explained later. Those factors produce a magnetic field that drops off rapidly as you move away from the power line.

Figure 3

Sample Magnetic Field Levels in Milligauss				
Type of Overhead Power Line	Distance from the line			
	Under the line	50 ft.	100 ft.	200 ft.
220 kV and 500 kV	5-400	5-250	1-75	0.5-20
69 kV and 138 kV	3-80	0.5-2.5	0.1-10	0.1-3
12 kV and below	0.4-20	0.1-1	-	-

The magnetic field values provided in this table represent a general range of values associated with the types of overhead power lines listed and are provided for illustration. There will be circumstances in which there will be magnetic field levels above or below the range of values provided due to variations in such factors as height of the wires, current flow and so on.

## **DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM**

One element of our response to EMF concerns expressed by some of our customers is PPL EU's Magnetic Field Management Program. The program was initiated in March 1991 because PPL EU believes it makes good sense, as a matter of policy, to respond to the concerns expressed by some of our customers and to reduce magnetic fields in new and rebuilt facilities where it can be done with either no-cost or low-cost design changes.

This document updates the original program which has been revised several times since 1991. These guidelines were developed by PPL EU's EMF Working Group.

### **VARIABLES THAT AFFECT MAGNETIC FIELDS**

Magnetic fields from transmission and distribution lines are a function of a number of design variables. The following parameters affect the magnetic field levels produced by transmission and distribution lines:

- Current
- Height of conductors above ground
- Configuration of conductors
- Distance from the line

### **EFFECT OF PHASE CURRENT ON MAGNETIC FIELDS**

At power frequencies (i.e., 60 hertz), the magnetic field level is a function of the current or flow of electricity through a wire. Keeping all other parameters the same, the magnetic field is proportional to the current. Hence, if the current increases by 25 percent, the resulting magnetic field level will increase by 25 percent.

The overall load current on any line varies with the demand for power. It's usually highest during daytime hours and lowest at night. There also are weekly, monthly, seasonal and yearly variations.

The difference in the currents between each phase in a multiphase line also can affect the magnetic field. This difference is called phase unbalance. For a constant load, a statistical analysis of this phase unbalance can be made to determine its effect on the magnetic field. Close to the line, there is very little effect. However, the phase unbalance slows the rate at which the magnetic field decreases with distance from the line.

### **EFFECT OF CONDUCTOR CONFIGURATION ON MAGNETIC FIELDS**

In the transmission and distribution of power, utilities like PPL EU presently use both three-phase and single-phase lines. Each phase on a three-phase power line has either a single conductor or a bundle of two or more conductors. In a three-phase system, the ground-level magnetic field is a result of the fields produced by the currents in each of the phases. Placing the three phases as close together as possible (compaction) creates some field cancellation, and the ground-level magnetic field is reduced. However, appropriate phase separation is required for the reliable operation of the line. In addition, the arrangement of the phases can create some; field cancellation and reduction of the ground-level magnetic field.

### **EFFECT OF DISTANCE FROM THE MAGNETIC FIELD SOURCE**

Magnetic field strength diminishes with the vertical and lateral distances from the magnetic field source. Increasing the height of the conductors above ground is useful for magnetic field reduction at ground level, but may result in increased structure costs and increased aesthetic impact of the structures. Another possible method of increasing the distance to the magnetic field source is to increase the right-of-way requirements. By keeping buildings off increased rights of way, thereby requiring the public to live and work further away from lines, exposure to magnetic fields produced by the lines can be reduced. Increases in right of way are not always practical and may increase costs significantly, however.

## **SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM**

Under its Magnetic Field Management Program, PPL EU has changed the way it builds and rebuilds some of its transmission and distribution lines. These design changes reduce magnetic field levels (assuming balanced circuit loadings and phase currents) by up to 69 percent in most of the company's new transmission lines. These guidelines now are being applied to new and reconstructed transmission facilities, based on this program.

The distribution component of the program focuses on 12 kV lines, the company's standard distribution voltage. It concentrates on the three-phase, primary 12 kV lines, since these are the most heavily loaded facilities and often are located in densely populated areas. The guidelines in this program are being applied to these three-phase, primary 12 kV lines.

A maximum 3-5 percent change in estimated cost was used as the limit for the guidelines since this value is consistent with low cost, is within estimating accuracy and is likely to have little impact on overall line costs.

The magnetic field calculations used in this document for the design of PPL EU's overall magnetic field management plan assume balanced load conditions among the phases and a fixed level of current, not necessarily representative of specific transmission or distribution lines. These levels were calculated using the Electric Power Research Institute's ENVIRO computer program. Under actual operating conditions, the magnetic field levels that result may vary due to such things as actual load per circuit, overall current on each phase conductor and the electrical configuration and operation of each line.

# MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES

The guidelines for magnetic field management are noted below, with discussion points for each.

## **OVERHEAD LINES**

---

### **NEW OR REBUILT TRANSMISSION LINES**

1. **Balance transmission circuit loads and phase currents as much as possible.**
  - PPL EU should continue to make every effort to balance loadings between the two circuits of a double circuit line when planning new or rebuilt facilities to maximize the effects of reverse phasing.
  - PPL EU should continue the practice of balancing single-phase loads across the three phases of the distribution system. (Unbalanced phase currents on the distribution system are reflected through to the transmission system.)
    - Unbalanced phase currents result in higher magnetic fields that do not drop off as quickly with distance as do the fields resulting from balanced phase currents.
    - For a 5 percent phase current unbalance, the magnetic field 50 feet from the centerline of a single circuit 138 kV line could be more than twice the value than if the same line had balanced phase circuits.
  - Balanced phase currents on each three-phase distribution circuit also reduce magnetic fields from the distribution circuits themselves. In addition, they reduce magnetic fields on the transmission system from which the distribution system circuits are supplied and connected through substations.
  - Apart from magnetic field considerations, balanced phase currents on each three-phase distribution circuit also reduce line losses and improve the system voltage.

2. **Continue with the present practice of using long-span construction as the PPL EU 138/69 kV standard**

- Structure designs for short-span and long-span construction are illustrated on Charts I and II, respectively.
  - Short-span design does not significantly reduce magnetic fields when compared to long-span design even though it is more compact than long-span design. Comparison of the magnetic field values from Chart III indicates essentially the same values. Therefore, short-span design should not be used solely to reduce magnetic fields.
  - PPL EU will continue to use long-span construction for 138/69 kV double-circuit lines and for single-circuit/future-double-circuit lines.
  - For single-circuit/future-double-circuit lines, PPL EU will continue to install two conductors on the top positions and one in the middle position as shown in Chart IV.
    - This arrangement minimizes magnetic fields as shown in Chart V by placing the three initial conductors higher on the structure, which increases the ground clearances, and by placing the conductors in a triangular configuration.

3. **Compact design structures are not a low-cost alternative and should be used for magnetic field reduction only in special applications.**

Chart VI illustrates the compact design structure.

- The compact design increases the initial installation costs by 79 percent when compared to the long-span design but reduces the magnetic field from 9 mG to 3 mG (about 67 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.

4. **Reverse phase new or rebuilt double-circuit transmission lines for all voltage levels.**

- Reverse phasing was adopted by PPL EU in March 1991 for double-circuit 138/69 kV transmission lines and in April 1992 for all other double circuit transmission lines. Reverse phasing is shown in Chart VII. Reverse phasing will reduce the magnetic fields when the current flow on both circuits is in the same

direction. Calculated values contained here are based on balanced and equal phase currents on both circuits.

- Reverse phasing reduces the magnetic field of a double circuit 138 kV single pole transmission line from 29 mG to 9 mG (about 69 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.
- Reverse phasing reduces the magnetic field of a double circuit 230 kV single pole transmission line from 49 mG to 16 mG (about 67 percent) at the edge of the 150-foot-wide right of way as shown on Chart VIII.
- Reverse phasing reduces the magnetic field of a double-circuit 500 kV single pole transmission line from 37 mG to 21 mG (about 43 percent) at the edge of the 200-foot-wide right of way as shown on Chart IX.
- When new or rebuilt double-circuit lines require tapping existing double-circuit lines, PPL EU will review the existing lines to determine if reverse phasing can be provided at low cost.
- Computer modeling is required to develop the optimum phasing and overall conductor arrangements for lines added to, or rebuilt in, multiple-line corridors.
  - Merely adding a reverse-phase double-circuit line to an existing transmission line corridor or reverse phasing a rebuilt line in the multiple-line corridor will not necessarily produce lower magnetic field levels at the edge of the corridor right of way.
  - The corridor must be computer modeled with all the lines, existing phase conductor locations and currents. Then, magnetic field calculations must be made varying the phase arrangements of the new or reconstructed line to determine the appropriate phasing arrangement.
  - Current flow direction on a line also must be considered. For example, a reverse-phased line should have the current flowing in the same direction on both circuits. If the current flow is in the opposite direction for one circuit, reverse phasing will not produce the lowest magnetic field and another phase arrangement that produces lower fields may need to be utilized.

**5. Increase the minimum ground clearance for all new transmission lines.**

**138/69 kV Transmission Lines**

- Increasing the minimum line design ground clearance from 25 feet to 30 feet may add up to about 5 percent to the installed cost of a new double-circuit single pole 138/69 kV line. For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. With long-span reverse-phase design, the magnetic field is reduced from 9 mG to 7 mG (about 22 percent) at the edge of a 100-foot-wide right of way as shown in Chart X.
  - In the actual design of transmission lines to include higher minimum ground clearances, there may be limited segments (such as highway crossings, severe slopes and transmission line crossing locations) where National Electrical Safety Code (NESC) minimum ground clearances may need to be used. The NESC minimum ground clearances are less than the increased ground clearance discussed previously.

**230 kV Transmission Lines**

- Increasing the minimum line design ground clearances from 27 feet to 32 feet may add up to about 5 percent to the cost of a single-circuit single-pole line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 30 mG to 28 mG (about 7 percent) at the edge of a 150-foot-wide right of way.
- Increasing clearances from 27 feet to 32 feet could theoretically add up to about 2.8 percent to the cost of a double-circuit single-pole line (current standard) and reduce the magnetic field of a reverse-phase line from 16 mG to 15 mG (about 6 percent) at the edge of a 150-foot-wide right of way. Chart XI is a summary of this data.
- Studies are required for each new 230 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such

studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced phase spacing (a "Delta" configuration on a single-circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

#### **500 kV Transmission Lines**

- Increasing ground clearances from 33 feet to 53 feet may add up to about 4.5 percent to the cost of a single-circuit "H-frame" line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 42 mG to 35 mG (about 17 percent) at the edge of a 200-foot-wide right of way.
- Increasing ground clearances from 33 feet to 53 feet could theoretically add up to 2.8 percent to the cost of a double-circuit "H-frame" line (current standard) and reduces the magnetic field of a reverse-phase line from 21 mG to 16 mG (about 24 percent) at the edge of a 200-foot-wide right of way. Chart XII is a summary of this data.
- Studies are required for each new 500 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced-phase spacing (a "Delta" configuration on a single circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

## **RECONDUCTORING OR ADDING ADDITIONAL CIRCUITS TO EXISTING TRANSMISSION LINES**

**When reconductoring or adding additional circuits to existing transmission lines, PPL EU will evaluate low-cost or no-cost options for magnetic field management on a case-by-case basis.**

When reconductoring existing transmission lines or adding additional circuits, low-cost alternatives may not exist; however, the following steps will be taken:

- For a single-circuit line, the use of a Delta arrangement or other modifications on the existing structure, with reduced-phase spacing, will be evaluated.
- For double-circuit lines, application of reverse phasing may reduce the magnetic field under the line and within the right of way and will be evaluated.
- For single- and double-circuit lines, evaluate using higher conductor tensions that can increase the minimum line design ground clearance.

## **DISTRIBUTION LINES**

**At the 12 kV distribution level, new main three-phase lines will continue to be constructed with five feet of additional ground clearance.**

- Main lines are the most heavily loaded sections of a distribution line and therefore have the highest magnetic fields associated with them.
- Increasing the ground clearance by five feet reduces the magnetic field under the line from 14 mG to 11 mG using the standard eight-foot crossarm design. These values are based on increasing pole heights from 45 feet to 50 feet and a typical operating current of 300 amps per phase.
- Chart XIII is a summary of this data. Increasing ground clearance by five feet could theoretically add about 5 percent to the cost of a typical distribution line.


## **UNDERGROUND TRANSMISSION LINES**

---

**Underground transmission lines are required due to environmental or land use factors or restrictions on available clearances, PPL EU will evaluate options for magnetic field management techniques on a case-by-case basis.**


- The phase arrangement that produces the lowest field will be determined.
- The depth of burial of the line will be determined considering the cost of excavation and the location of other buried utilities in the area.
- The use of steel pipe ferromagnetic shielding that reduces magnetic fields will be evaluated.

# Short-Span Construction



- More compact design
- Should not be used solely to reduce magnetic fields
- Typical conductor data:
  - 1 3/8" HS steel overhead ground wire - 7.3 feet sag
  - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 10.0 feet sag
  - Average span - 400 feet

# Long-Span Construction Remains PPL EU 138 kV Standard




- Lower cost alternative
- Reduces magnetic fields due to higher structures
- Typical conductor data:
  - 1 3/8" HS steel overhead ground wire - 17.3 feet sag
  - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 23.0 feet sag
  - Average span - 600 feet

**138/69 KV REVERSE-PHASE TRANSMISSION LINES  
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SHORT SPAN (CHART I)	30
SHORT SPAN (REVERSE PHASE)	8
LONG SPAN (CHART II)	29
LONG SPAN (REVERSE PHASE)	9
COMPACT (CHART VI)	14
COMPACT (REVERSE PHASE)	3

The edge of right of way is 50 feet from the line centerline.  
 The 400 ampere phase current is balanced between phases.  
 Calculations are based on a minimum ground clearance of 25 feet.  
 LONG SPAN, SHORT SPAN and COMPACT are double-circuit lines.

# Typical Single-Circuit Structure Designs




——— initial single circuit  
- - - - - future second circuit

**138/69 kV SINGLE CIRCUIT TRANSMISSION LINES  
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
TOP/MIDDLE/BOTTOM	20
VERTICAL	17
TOP/MIDDLE	12


The edge of right of way is 50 feet from the line centerline.  
The 400 ampere phase current is balanced between phases.  
Calculations are based on a minimum ground clearance of 25 feet.

# Compact Design Structure



- **Minimize magnetic fields due to compact design**
- **Not a low-cost alternative**
- **Typical conductor data:**
  - 1 3/8" HS steel overhead ground wire - 9.0 feet sag
  - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 9.0 feet sag
  - Average span - 300 feet

# Reverse Phasing of Double-Circuit Transmission Lines



From:  $\longrightarrow$   $\longrightarrow$   $\longrightarrow$   $\longrightarrow$  To:

Reverse phasing also can be one of the following phase arrangements:

A	B		B	A		B	C		C	A		C	B
C	C	or	C	C	or	A	A	or	B	B	or	A	A
B	A		A	B		C	B		A	C		B	C

**230 kV REVERSE-PHASE TRANSMISSION LINES  
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	49
DOUBLE CIRCUIT POLE (REVERSE-PHASE)	16

The edge of right of way is 75 feet from the line centerline.  
The 800 ampere phase current is balanced between phases.  
Calculations are based on a minimum ground clearance of 27 feet.

**500 kV REVERSE-PHASE TRANSMISSION LINES  
CALCULATED MAGNETIC FIELDS AT 1100 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	37
DOUBLE CIRCUIT POLE (REVERSE PHASE)	21

The edge of right of way is 100 feet from the line centerline.  
The 1,100 ampere phase current is balanced between phases.  
Calculations are based on a minimum ground clearance of 33 feet.

**INCREASED 138/69 kV MINIMUM GROUND CLEARANCE  
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	25	12
SINGLE CIRCUIT TOP/MIDDLE	30	10
LONG SPAN	25	29
LONG SPAN	30	26
LONG SPAN (REVERSE PHASE)	25	9
LONG SPAN (REVERSE PHASE)	30	7

The edge of right of way is 50 feet from the line centerline.  
The 400 ampere phase current is balanced between phases.

**INCREASED 230 kV MINIMUM GROUND CLEARANCE  
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	27	30
SINGLE CIRCUIT TOP/MIDDLE	32	28
DOUBLE CIRCUIT POLE	27	49
DOUBLE CIRCUIT POLE	32	46
DOUBLE CIRCUIT POLE (REVERSE PHASE)	27	16
DOUBLE CIRCUIT POLE (REVERSE PHASE)	32	15

The edge of right of way is 75 feet from the line centerline.  
The 800 ampere phase current is balanced between phases.

**INCREASED 500 kV MINIMUM GROUND CLEARANCE  
CALCULATED MAGNETIC FIELDS AT 1,100 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT "H" STRUCTURE	33	42
SINGLE CIRCUIT "H" STRUCTURE	53	35
DOUBLE CIRCUIT POLE	33	37
DOUBLE CIRCUIT POLE	53	31
DOUBLE CIRCUIT POLE (REVERSE PHASE)	33	21
DOUBLE CIRCUIT POLE (REVERSE PHASE)	53	16

The edge of right of way is 100 feet from the line centerline.  
The 1,100 ampere phase current is balanced between phases.

**12 KV DISTRIBUTION LINES  
CALCULATED MAGNETIC FIELDS AT 300 AMPERES**

TYPE CONSTRUCTION	POLE HEIGHT FEET	MAGNETIC FIELD IN MILLIGAUSS*	
		AT CENTERLINE	AT 30 FEET FROM CENTERLINE
STANDARD CROSSARM	45	14	7
STANDARD CROSSARM	50	11	6

\* Field level under the line at mid-span based on 300 amps, balanced loading, one meter above ground level.

# **Attachment**

**6**

**ATTACHMENT "6"**

**LIST OF INVOLVED GOVERNMENTAL AGENCIES, MUNICIPALITIES  
AND OTHER PUBLIC ENTITIES**

---

Pennsylvania Historical and Museum Commission  
Bureau for Historic Preservation  
Commonwealth Keystone Building, Second Floor  
400 North Street  
Harrisburg, Pennsylvania 17120-0053  
Attn: Mr. Douglas C. McLearen, Chief

Pennsylvania Department of Transportation  
Commonwealth Keystone Building  
400 North Street, 8<sup>th</sup> Floor  
Harrisburg, Pennsylvania 17120  
Attn: The Honorable Allen D. Biehler, P.E., Secretary

Department of Environmental Protection  
P.O. Box 2063  
Market Street State Office Building  
Harrisburg, Pennsylvania 17105-2063  
Attn: Office of Field Operations

Upper Macungie Township Board of Supervisors  
8330 Schantz Road  
Breinigsville, PA 18031  
Attn: Kathy Rader

Lower Macungie Township  
Mr. Bruce Fosselman, Manager  
3400 Brookside Road  
Macungie, PA 18062

Lower Milford Township  
Ms. Ellen Koplun, Manager  
7607 Chestnut Hill Church Road  
Coopersburg, PA 18036

Upper Milford Township  
Mr. Dan DeLong, Manager  
5671 Chestnut Street  
PO Box 210  
Old Zionsville, PA 18068

Lehigh Valley Planning Commission  
Mr. Mike Kaiser, Executive Director  
961 Marcon Boulevard, Suite 310  
Allentown, PA 18109

Lehigh County Commissioners  
Mr. Dean Browning, Chair  
17 South Seventh Street  
Allentown, PA 18101

Lehigh County  
Mr. Don Cunningham, Executive  
17 South Seventh Street  
Allentown, PA 18101

# **Attachment**

**7**

ATTACHMENT "7"

HOSENSACK -WESCOSVILLE #3 230 kV LINE REPLACEMENT

LIST OF INVOLVED PROPERTY OWNERS

PPL Electric Utilities  
2 N 9Th St.  
Allentown, PA 18101-1139

Edward A & Pamela A  
Kordeck  
1224 Shiloh Dr.  
Allentown, PA 18106-8646

James J & Colette F Lenner  
1428 Shiloh Rd.  
Allentown, PA 18106-8749

Rever John O Barres  
Bishop of the Roman Catholic  
Diocese  
PO Box F  
Allentown, PA 18105-1538

Bret J Levi & Monica L  
Torrano  
1238 Shiloh Rd.  
Allentown, PA 18106

Angelo M & Jacqueline  
Fernandez  
1122 Morning Star Dr.  
Allentown, PA 18106

Andrew Residuary Trust Yastishok  
Mary & Mark Yastishok Co-  
Trustees  
6500 Chapmans Rd.  
Allentown, PA 18106-9200

Scott J Zolotsky  
1254 Shiloh Rd.  
Allentown, PA 18106

Francis J & Jean A Szabo  
1478 Shiloh Rd.  
Allentown, PA 18106

Lower Macungie Twp  
3400 Brookside Rd.  
Macungie, PA 18062-1428

Mary Bianchini  
1274 Shiloh Rd.  
Allentown, PA 18106

Tyrone Major & K L Smith-  
Major  
1492 Shiloh Rd.  
Allentown, PA 18106-8748

Ray W. Walbert  
6851 Kings Highway S  
Zionsville, PA 18092

Joseph & Silvana Ciccarello  
1288 Shiloh Rd  
Allentown, PA 18106

Patrick J & Nicola A Slattery  
1072 Morning Star Dr.  
Allentown, PA 18106-8761

Richard C. Lutz  
6922 Vera Cruz Rd S  
Zionsville, PA 18092-2051

Gretchen Pearl  
1200 Morning Star Dr.  
Allentown, PA 18106

Albert F & Constance E Ernst  
1510 Shiloh Rd.  
Allentown, PA 18106-8749

Jeremy D & Stephanie M Hoch  
6931 Vera Cruz Rd S  
Zionsville, PA 18092

Matthew A & Jane E  
Nussbaum  
1346 Shiloh Rd.  
Allentown, PA 18106

Edward P & Lori A Staniewicz  
1526 Shiloh Rd.  
Allentown, PA 18106-8749

David M Jr. & Emilie A Lobach  
6932 Kings Hwy S  
Zionsville, PA 18092-2812

A G & V Panagopoulos  
1362 Shiloh Rd.  
Allentown, PA 18106-8747

Keith E & Sandra L Eberwein  
1048 Morning Star Dr.  
Allentown, PA 18106-8761

Jeffrey A & Diane K Wenner  
4780 Rock Rd  
Zionsville, PA 18092-2248

Daniel & Roseann Gagliardi  
1380 Shiloh Rd.  
Allentown, PA 18106-8747

Spencer L Hogan  
1542 Shiloh Rd.  
Allentown, PA 18106

David Averill & Susan E Bell  
7166 Kings Hwy S  
Zionsville, PA 18092-2816

Keith B & Margie K Wenner  
7258 Kings Hwy S  
Zionsville, PA 18092-2818

Ronald K Walsh  
1192 Shiloh Rd.  
Allentown, PA 18106

Adrienne M & Thomas L Maio  
1206 Shiloh Rd.  
Allentown, PA 18106-8746

Donna M & Dale G Raudenbush  
Batz  
1700 Lamplighter Dr.  
Macungie, PA 18062

Edward T & Ann L Zablocki  
1720 Lamplighter Dr.  
Macungie, PA 18062-9076

Michael A & Donna M Hersch  
1734 Lamplighter Dr.  
Macungie, PA 18062-9076

Michael & Karen E Forziati  
1750 Lamplighter Dr.  
Macungie, PA 18062-9076

John J & Dianne C Donofrio  
1770 Lamplighter Dr.  
Macungie, PA 18062-9076

Robert J & Maureen A Calder  
1786 Lamplighter Dr.  
Macungie, PA 18062-9076

Ioannis M Giannaris  
1800 Lamplighter Dr.  
Macungie, PA 18062-9076

Barry W & Sandra L Kuder  
1152 Morning Star Dr.  
Allentown, PA 18106

Michael & Robyn Koprowicz  
1396 Shiloh Rd.  
Allentown, PA 18106-8747

Theodore & Lyssa M Busolits  
Bigatel  
1136 Morning Star Dr.  
Allentown, PA 18106

Robert D & Sandra A Boag  
1410 Shiloh Rd.  
Allentown, PA 18106-8749

Brookside Road LP 2050  
937 Oplinger Rd.  
Allentown, PA 18106-9702

Mannino Brothers Partnership  
1985 Brookside Rd.  
Macungie, PA 18062-9730

Faith Evan Free Church  
6528 Hamilton Blvd  
Allentown, PA 18106-9754

Brendan J & Katherine O'Brien  
5090 Lower Macungie Rd  
Macungie, PA 18062-9700

Liv Hope Orthodox Presb  
Church  
816 Chestnut St  
Emmaus, PA 18049-2020

Wild Cherry Knoll LP  
4445 Harriet Ln  
Bethlehem, PA 18017-8418

David W & Lisa Helmer  
3008 Macungie Rd.  
Macungie, PA 18062-9707

Larry I & Andrea T Evans  
1060 Morning Star Dr.  
Allentown, PA 18106-8761

Marc H & Michele L Friedman  
1650 Lamplighter Dr.  
Macungie, PA 18062-9076

Gregory P & Candice-Leigh  
Douglass  
1670 Lamplighter Dr.  
Macungie, PA 18062-9076

Bert H Jr & Suellen C Blanton  
1684 Lamplighter Dr.  
Macungie, PA 18062-9076

Randal S & Susan F Bernhard  
4986 Waterfall Dr.  
Macungie, PA 18062-9770

Eric J. & Anabella C Wewer  
Schmoyer  
3231 Macungie Rd.  
Macungie, PA 18062-9703

John A & Tonya M Capizzi  
4978 Waterfall Dr.  
Macungie, PA 18062

Matthew J. & Sharon A  
Rowlands  
4964 Waterfall Dr.  
Macungie, PA 18062-9748

Mark A & Katherine A  
Lichtenwalner  
4939 Indian Creek Rd.  
Macungie, PA 18062-9778

Ira Lehrich Construction Co Inc  
PO Box 223  
Emmaus, PA 18049-0223

Pennsylvania Lines LLC  
C-O Norfolk Southern Railway  
Co.  
110 Franklin Rd. SE  
Roanoke, VA 24042-0028

Michael R & Marla J Bleiler  
1812 Lamplighter Dr.  
Macungie, PA 18062-9076

Huy & Loan Phan Bui  
1826 Lamplighter Dr.  
Macungie, PA 18062-8837

Day-Timers Inc  
PO Box 6  
East Texas, PA 18046-0006

Dale B & Joan Snyder  
5281 Lower Macungie Rd.  
Macungie, PA 18062-9745

Michael Harned  
4893 Buckeye Rd.  
Emmaus, PA 18049-0344

Joseph L & Evelyn M Sadrovitz  
4875 Buckeye Rd.  
Emmaus, PA 18049-1032

Kahlon Enterprises LLC  
4911 Buckeye Rd.  
Emmaus, PA 18049-1015

Linda K Schmick  
4927 Buckeye Rd.  
Emmaus, PA 18049-1015

Herbert E Jr & Beverly A Seibert  
185 Main St.  
Emmaus, PA 18049-4017

John H. & Nancy D Hinnerschietz  
4512 Mill Rd.  
Emmaus, PA 18049-5239

O'Donnell Family Trust  
Bernard R & Betty J O'Donnell  
Trstees  
4836 Buckeye Rd.  
Emmaus, PA 18049-1031

Sauerkraut Lane LP  
937 Oplinger Rd.  
Allentown, PA 18106-9702

Macungie Road LP  
937 Oplinger Rd.  
Allentown, PA 18106-9702

Contel of Pennsylvania Inc  
C-O GTE North Incorporated  
PO Box 152206  
Irving, TX 75015-2206

Budd W & Wendy M Kahler  
5008 Waterfall Dr.  
Macungie, PA 18062-9770

Julia Two Corp.  
1708 Locust St.  
Philadelphia, PA 19103-6107

Douglas S & Mark J Feiertag  
Barcza  
4280 Chestnut St.  
Emmaus, PA 18049-5368

Lobar, Inc.  
1 Old Mill Rd.  
PO Box 50  
Dillsburg, PA 17019-0050

Johnathan Herbein  
4790 Mill Rd.  
Emmaus, PA 18049

Thomas F. Bull  
4301 Chestnut St.  
Emmaus, PA 18049-5356

John E & Marlene I Herbein  
4401 Chestnut St.  
Emmaus, PA 18049-5356

Frank & Pearl N Beck  
C-O Beck Brothers  
4555 Chestnut St.  
Emmaus, PA 18049-5360

Chelsea Sandwich LLC  
PO Box 9161  
Waltham, MA 02454-9161

Jason Adams & Robert  
Newman Jr  
Box 395  
Old Zionville, PA 18068-0395

Davis Scott D Et Al  
C-O Davis Construction & Steel  
Erec  
4870 Raymond Ct  
Emmaus, PA 18049-1033

Walter F & Donna A Yext  
3893 Tank Farm Rd.  
Emmaus, PA 18049-1009

George & Edeltrud R Madtes  
4831 Beck Rd.  
Emmaus, PA 18049-5204

Stephen T Mogck  
4811 Beck Rd.  
Emmaus, PA 18049-5204

Robert C Jr & Merideth L  
Schmeltzle  
4781 Beck Rd.  
Emmaus, PA 18049-5202

William G Jr. Billger  
4786 Beck Rd.  
Emmaus, PA 18049-5201

Robert P & Sandra L  
Hausknecht  
4742 Beck Rd.  
Emmaus, PA 18049-5201

Kenneth P. & Deborah M  
Schuler  
4710 Beck Rd.  
Emmaus, PA 18049-5201

Richard L Jr & Bonita L  
Tremmel  
4745 Shimerville Rd.  
Emmaus, PA 18049-4951

Hinnerschietz John Et Al  
C-O Hinnerschietz Recon Inc  
4892 Buckeye Rd.  
Emmaus, PA 18049-1003

Sharlene R Schellenberg  
4463 Linda Ln  
Emmaus, PA 18049

Jerome C. & Bonnie K. West  
4733 Shimerville Rd.  
Emmaus, PA 18049-4951

Buckeye Pipe Line Company LP  
C-O Five Tek Park  
9999 Hamilton Blvd  
Breinigsville, PA 18031

Raymond J & Katherine M  
Flaugh  
4461 Linda Ln  
Emmaus, PA 18049

Cherri L Mogck  
4776 Shimerville Rd.  
Emmaus, PA 18049-4950

Todd M & Suzanne M Garloff  
4117 Ford Dr.  
Emmaus, PA 18049-5365

John A & L Pierangeli  
4459 Linda Ln  
Emmaus, PA 18049

Henry M & Loriann M Long  
4722 Shimerville Rd.  
Emmaus, PA 18049-4950

Bryan Smith  
4702 Chestnut St.  
Emmaus, PA 18049-5356

Tyler B & Tracy Eberts  
4457 Linda Ln  
Emmaus, PA 18049-5263

David & Bonnie Jean Schaf  
4758 Shimerville Rd.  
Emmaus, PA 18049-4950

Stephanie L. & Timothy G. Hilmer  
4121 Ford Dr.  
Emmaus, PA 18049-5365

Thomas J Schellenberg  
4453 Linda Ln  
Emmaus, PA 18049-5260

Bailey Wade H Et Al  
4740 Shimerville Rd.  
Emmaus, PA 18049-4950

Edward J Jr. & Sue M Newett  
4743 Hale Ln  
Emmaus, PA 18049-4944

Angela K Buck  
5695 German Rd  
Emmaus, PA 18049-4910

Jeffrey L & Deborah L Dershem  
7632 Kings Hwy  
Zionsville, PA 18092-2511

Nancy L. O'Brien  
4701 Hale Ln  
Emmaus, PA 18049-4944

Adam R & Jennifer B  
Kernechel  
5689 German Rd  
Emmaus, PA 18049-4908

Dean S Bruch  
4679 Scout Rd.  
Zionsville, PA 18092-2648

Todd R. & Sallyann M. Huddleston  
4722 Hale Ln  
Emmaus, PA 18049-4944

County of Lehigh  
17 S. 7th St.  
Allentown, PA 18101-2400

Fetzer Linda R Et Al  
4525 Scout Rd.  
Zionsville, PA 18092-2646

Rudolf R Jr George  
4690 Hale Ln  
Emmaus, PA 18049-4942

Dennis K & Linda D Moyer  
4640 Churchview Rd  
Zionsville, PA 18092-2001

Philadelphia Electric Co.  
PO Box 8699  
Philadelphia, PA 19101-8699

Donald R & Kathy M Hunt  
5202 Milford Rd.  
Emmaus, PA 18049-4960

Eastern Rail Lines Inc Penn  
96 S George St  
York, PA 17401-1434

Kathy Z Poole-Price  
6702 Vera Cruz Rd S  
Zionsville, PA 18092-2048

Dale Hetrick  
4701 Main Rd W.  
Emmaus, PA 18049-4928

Peter A & Julie A Emerich  
6424 Vera Cruz Rd S  
Zionsville, PA 18092-2045

John F. Mitchell  
6781 Vera Cruz Rd S  
Zionsville, PA 18092-2049

Ruth E & Michael D Ecker  
5234 Milford Rd.  
Emmaus, PA 18049-4960

Christine L & Matthew R  
Erney Blaine  
4571 Queens Cir  
Zionsville, PA 18092-2034

Tracy L Dreher  
6876 Vera Cruz Rd S  
Zionsville, PA 18092-2050

Vernon F Jr & Alma A Goodman  
4560 Main Rd W  
Emmaus, PA 18049-4923

Geoffrey C & Susan L Wainwright  
5337 German Rd  
Emmaus, PA 18049

Donald P & Louisa A De Lorenzo  
5540 German Rd.  
Emmaus, PA 18049-4905

Jeffrey A & Mali M Bartges  
5430 German Rd  
Emmaus, PA 18049-4903

Sarah M Garwood & Todd R  
Farnand  
5707 German Rd  
Emmaus, PA 18049-4910

Gerald W & Arlene F Wachter  
7369 Sweetwood Dr  
Macungie, PA 18062-9116

Peter M & Laura A Goldy Brown  
4558 Queens Ln  
Zionsville, PA 18092-2035

Forrest H Jr. & Tina N Dottery  
4581 Queens Ln  
Zionsville, PA 18092-2037

Phyllis L Kline  
6902 Vera Cruz Rd S  
Zionsville, PA 18092-2051