



Before the
Pennsylvania Public Utility Commission

**HARWOOD – JENKINS
#1 & #2 138/69 kV LINE
RECONSTRUCTION**

**Attachments in Support of the
Letter of Notification**

Application Docket No. _____

Submitted by: PPL Electric Utilities Corp.

SUMMARY

This filing is submitted by PPL Electric Utilities Corporation (PPL Electric) pursuant to the Pennsylvania Public Utility Commission's (PUC or the Commission) regulations at 52 Pa. Code §§ 57.71 through 57.77 for PUC approval to reconstruct a 1.4 mile long section of the existing single-circuit Harwood-Jenkins #2 69 kV Transmission Line and a 0.6 mile long section of the existing single-circuit Harwood-Jenkins #1 69 kV Transmission Line, and to replace them with a double-circuit 138/69 kV transmission line. Completion of this project will add an additional circuit to the Harwood – Jenkins line. In order to connect the new circuit to the existing 138/69 kV switch yard at the Harwood Substation, PPL Electric will also construct 1,700 feet of new 138/69 kV line on PPL Electric property. The new circuit will be named the Harwood – Jenkins #1 138/69 kV Line. All new line construction will be designed and built for 138 kV operation, although all circuits initially will operate at 69 kV. The project is located in Hazle Township, Luzerne County.¹

This project is required for two primary reasons. First, the project will prevent overloading either the Harwood-Jenkins #1 or #2 69 kV Transmission Line if an outage occurs on the other circuit. Second, the modifications will prevent PPL Electric from dropping an amount of load that exceeds its Reliability Principles and Practices guidelines if there were a simultaneous outage of both the Harwood-Jenkins #1 and #2 69 kV Lines.

The estimated cost to modify the Harwood – Jenkins #1 & #2 69 kV Lines, and to construct 1,700 feet of new transmission line, is \$2,082,000. Construction is scheduled to begin in January, 2012 to support the project's in-service date of November, 2012.


This document, which describes the need for the project and discusses the engineering and siting analysis for the proposed construction, consists of the following exhibits and appendices:

- Attachment "1" - Necessity Statement
- Attachment "2" - Engineering Description

¹ As part of the Project, the existing Harwood – Jenkins #1 Line will be severed at the Valmont Taps. It will remain connected with the Valmont 69 kV Tap #1. The resulting line will be renamed the Harwood – Valmont 69 kV Line. This portion of the Project is not a subject of the Letter of Notification because it will continue to be designed to operate at 69 kV and is therefore not subject to the siting regulations.

- Attachment "3" - Environmental Assessment
- Attachment "4" - PPL Design Criteria and Safety Practices
- Attachment "5" - Magnetic Field Management at PPL
- Attachment "6" - List of Involved Governmental Agencies, Municipalities,
and Other Public Entities
- Attachment "7" - List of Property Owners Within the Proposed Right-of-
Way

PPL ELECTRIC UTILITIES SERVICE TERRITORY



Attachment 1

ATTACHMENT "1"

**HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION
NECESSITY STATEMENT**

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	INTRODUCTION.....	1
B.	EXISTING SYSTEM.....	2
C.	DEFINITION OF THE PROBLEM.....	2
D.	PROPOSED SOLUTION.....	3
E.	FUNCTIONAL ALTERNATIVES.....	4

LIST OF FIGURES

FIGURE 1	ONE LINE DIAGRAM SHOWING EXISTING HARWOOD- JENKINS #1 AND #2 69 kV LINES FROM HARWOOD SUBSTATION TO THE VALMONT TAPS	5
FIGURE 2	ONE LINE DIAGRAM SHOWING PROPOSED HARWOOD- JENKINS #1 AND #2 69 kV LINES FROM HARWOOD SUBSTATION TO THE VALMONT TAPS	6

MAP

MAP 1	PPL ELECTRIC SYSTEM MAP	Attachment "1" Map Pocket
-------	-------------------------	------------------------------

ATTACHMENT “1”
HARWOOD–JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION
NECESSITY STATEMENT

A. INTRODUCTION

PPL Electric is requesting PUC approval to reinforce the 138/69 kV transmission facilities in Luzerne County by constructing a third transmission line between the Harwood Substation and the Valmont Taps. Installation of a third circuit will be accomplished by reconstructing a 1.4 mile portion of the existing single-circuit Harwood – Jenkins #2 69 kV Transmission Line for double-circuit 138/69 kV operation and a 0.6 mile portion of the existing Harwood – Jenkins #1 69 kV Transmission Line, for double circuit 138/69 kV operation. In addition, approximately 1,700 feet of new 138/69 kV single-circuit line will be installed on PPL Electric property in order to terminate the new third circuit into the existing Harwood 138/69 kV Switchyard. The new lines will be designed and constructed for 138 kV operation, although both initially will operate at 69 kV. The lines will be converted to 138 kV operation when the increasing demand for electricity makes this conversion appropriate.

This project is required to avoid overloading of one of the Harwood – Jenkins 69 kV Lines if an outage occurs on the other line, and to prevent PPL Electric from dropping an amount of load that exceeds the Company’s Reliability Principles and Practices (RP&P) guidelines if both Harwood – Jenkins #1 and #2 69 kV Lines were out of service.

The estimated cost to design and construct the new transmission line facilities is approximately \$2,082,000. Construction is scheduled to commence in January, 2012 to meet a required in-service date of November, 2012. The required in-service date is defined as the date that the proposed facility must be placed in service to prevent overloads that could potentially damage equipment and result in service interruptions to customers.

A PPL Electric system map showing existing transmission facilities with a design voltage of 35 kV or greater is included in the Attachment “1” map pocket. This filing addresses only the existing and proposed transmission systems in this portion of Luzerne County.

B. EXISTING SYSTEM

Currently, the Harwood – Jenkins #1 and #2 69 kV Lines are built on separate structures and take independent routes from Harwood Substation to the Valmont Taps. The line sections from the Valmont Taps to the Jenkins Substation are built as a double-circuit 138/69 kV design on common structures. Currently, the Harwood – Jenkins #1 and #2 Lines terminate on separate buses in the existing 69 kV yard at PPL Electric’s Harwood Substation. Figure 1 shows the section of the Harwood – Jenkins #1 and #2 69 kV Lines from Harwood Substation to the Valmont Taps.

C. DEFINITION OF THE PROBLEM

Due to increasing load in the area, transmission planning studies project, for 2012 and beyond, that if either of the Harwood – Jenkins #1 or #2 Transmission Lines were removed from service as a result of an unplanned outage (contingency), during periods of peak usage, the remaining in-service line will experience an overloaded condition. Each of the existing lines has an emergency summer rating of 124 MVA². An unplanned outage would require the remaining line to carry a projected 136 MVA combined peak load, which the line could not do. Operating the remaining line in an overloaded condition, above its emergency rating, would initially damage the conductors and would ultimately cause a failure of those conductors.

Furthermore, if both the Harwood – Jenkins #1 and #2 69 kV Lines were out of service, the amount of load interrupted would exceed two of PPL Electric’s RP&P guidelines established for maximum acceptable load loss. The first provides that no more than 120 MVA may be interrupted for an outage of this type. The second requires that no more than 45 MVA remain out of service until the lines are repaired. By 2012, under peak loading, a double-circuit failure of the Harwood – Jenkins #1 and #2 Lines would initially lose 136 MVA of load, 16 MVA above the RP&P guideline. Even after transferring customers to alternate sources, more than 45 MVA of load will remain out of service until repairs are made.

² Million volt-amperes.

Specifically, the transmission planning studies project that, during peak summer and winter periods, line overloading and an excessive amount of load interruption will occur under the following unplanned line outage scenarios:

- Loss of the Harwood-Jenkins #1 69 kV Line would cause an overload on the Harwood-Jenkins #2 69 kV Line.
- Loss of the Harwood-Jenkins #2 69 kV Line would cause an overload on the Harwood-Jenkins #1 69 kV Line.
- Loss of both the Harwood-Jenkins #1 and #2 69 kV Lines would cause excessive load to be shed (interrupted).

All of these scenarios would violate the reliability standards of the North American Electric Reliability Corporation, ReliabilityFirst Corporation, and PJM Interconnect LLC, as well as PPL Electric's RP&P.

D. PROPOSED SOLUTION

To resolve the issues described above, PPL Electric proposes the following:

- Approximately 1.4 miles of the existing Harwood – Jenkins #2 69 kV Line will be reconstructed between the Harwood Substation and the Valmont Taps. The Harwood – Jenkins #1 Line will also be rebuilt between the Harwood Substation and the Valmont Taps. The existing single-circuit 69 kV lines will be rebuilt for double-circuit 138/69 kV operation. Both circuits will initially operate at 69 kV.
- To avoid impacting wetlands near the Valmont Taps, the new Harwood – Jenkins #1 138/69 kV Line will cross under the Harwood – Jenkins #2 138/69 kV Line. The renamed Harwood – Valmont 69 kV Line, and approximately 3000 feet of Harwood – Jenkins #1 138/69 kV Line will be built on common structures.
- The existing Harwood – Jenkins #1 69 kV Line will be disconnected from the Jenkins to Harwood section of the circuit at the Valmont Taps but it will remain connected to the #1 Valmont 69 kV Tap. It will continue to serve the Valmont Substation. This line segment from the Harwood Substation to the Valmont Substation will be renamed the Harwood – Valmont 69 kV Line.

- Approximately 1,700 feet of new, single-circuit, 138/69 kV transmission line will be constructed in order to connect the new Harwood – Jenkins #1 Circuit to Bay 3S in the existing 138/69 kV switchyard in PPL Electric’s Harwood Substation. This line will provide a source to the distribution substations located along the Harwood to Jenkins 138/69 kV corridor, and will no longer feed the Valmont Substation.

Figure 2 shows the proposed PPL Electric transmission facilities between the Harwood Substation and the Valmont Taps.

The total estimated cost for the proposed work is approximately \$2,211,000, which includes approximately \$129,000 for the substation work at Harwood, and \$2,082,000 for the transmission line work.

E. FUNCTIONAL ALTERNATIVES

PPL Electric considered one functional alternative that did not involve reconstructing the existing Harwood – Jenkins #1 & #2 69 kV Lines. This alternative would have required converting the existing Harwood – Jenkins #1 and #2 Lines from the Harwood Substation to the Jenkins Substation to 138 kV operation, a distance of approximately 32.5 miles. This would require PPL Electric to replace the 230-69 kV transformers at the Harwood Substation with 230–138 kV transformers, install two 230-138 kV transformers at the Jenkins Substation, and replace seventeen, 69-12 kV transformers at the distribution substations served by the two lines with 138–12 kV transformers. A new 230–138 kV yard would also be required at the Jenkins Substation to provide the 138 kV voltage source. This alternative would be significantly more expensive, estimated at over \$50 million dollars, versus rebuilding portions of the existing Harwood – Jenkins # 1 & # 2 69 kV Lines, as proposed above. Due to the extreme price difference between the two projects, PPL Electric determined that rebuilding the Harwood – Jenkins #1 and #2 69 kV Transmission Lines was the preferred alternative.

Figure 1 – ONE LINE DIAGRAM SHOWING EXISTING AND/OR APPROVED HARWOOD-JENKINS #1 AND #2 69 kV LINES FROM HARWOOD SUBSTATION TO THE VALMONT TAPS






Figure 2 – ONE LINE DIAGRAM SHOWING PROPOSED HARWOOD – JENKINS #1 AND #2 138/69 KV LINES FROM HARWOOD SUBSTATION TO THE VALMONT TAPS



SUBSTATION LISTING

1	WEST WILLIAMSPORT	151	CRACKERSPORT	301	CENTER CITY
2	FAIRFIELD	152	SCHNECKSVILLE	302	NEW KINGSTOWN
3	MONTGOMERY	153	HENDOCK	303	REAMSTOWN
4	VARDEN	154	MT. ALLEN	304	DUPONT
5	HONESDALE	155	PRINCE	305	HUMBOLDT
6	JERSEY SHORE	156	WAKEFIELD	306	CEJAR AVE
7	LIGONOTON	157	COOPERSBURG	307	INDIAN ORCHARD
8	VALMONT	158	VERTZVILLE	308	NOTTINGHAM
9	RIVER	159	WEST CARLISLE	309	NORTH COOLBAUGH
10	LIMESTONE	160	BENVENUE	310	LETORT
11	NORTHUMBERLAND	161	HEGINS	311	EAST MOUNTAIN
12	REED	162	LEOLA	312	JERMYN
13	WRIGHT	163	YATESVILLE	313	BLOOMSBURG
14	ST. JEHNS	164	CENTRAL ALLENTOWN	314	MIFFLINTOWN
15	FREELAND	165	DBERLIN	315	RIDGE ROAD
16	GILBERT	166	STRASBURG	316	SUSQUEHANNA
17	CHERRY HILL	167	T-10 SW. YD.	317	KIMBLES
18	SUSQUEHANNA 230KV	168	BROOKSIDE	318	CHRISTMANS
19	TAMMEND	169	WILLIAMSTOWN	319	JACK CREEK
20	WHITE HILL	170	E. PETERSBURG	320	STEELE
21	PALMERTON	171	TERNERSVILLE	321	MCDOVERNILLE
22	HAMILTON	172	N. BETHLEHEM	322	ROBESONIA
23	HUNTER	173	W. ALLENTOWN	323	S. FOGELSVILLE
24	FAIRVIEW	174	MECKESVILLE	324	ELROY
25	MONTOUR PUMP	175	DONERVILLE	325	BUSHKILL
26	MT. CARMEL	176	MILLERSVILLE	326	WALLENPAUPACK
27	SPORTING HILL	177	SHILLINGTON	327	ELK MOUNTAIN
28	MAHANY CITY	178	MCALLISTERVILLE	328	JACK FRIST
29	GREENWOOD	179	NEWBUNDLAND	329	HARWOOD 230/69KV
30	ALTDAMOUNT	180	MARLIN	330	HARWOOD 69/12KV
31	HAMLIN	181	WEST BERWICK	331	NAZARETH
32	ASHFIELD	182	KEYSER AVENUE	332	ALBURTIS
33	SOUTH SLATINGTON	183	MICKLEYS	333	FRACKVILLE
34	WALKER	184	EAST ALLENTOWN	334	ELIMSPORT
35	MORGANTOWN	185	PINE RIDGE	335	ALLENWOOD
36	EGYPT	186	DALWATIA	336	GRATZ
37	GRESSINA	187	PENNSBORO	337	HOCKERSVILLE
38	SOUTH WHITEHALL	188	NORTH COLUMBIA	338	BLOOMING GROVE
39	EAST TOMHICKEN	189	HUGHESVILLE	339	MONROE
40	BEAR GAP	190	SOUTH ALLENTOWN	340	LACKAWANNA ##
41	WALSBURY	191	WEISSPORT	341	STANTON
42	SOUTH MILTON	192	HONEYBROOK	342	JACKSON
43	HEIDELBERG	193	MOSCOW	343	EAST PALMERTON
44	WAGNER	194	ROSSMOYNE	344	SIEGFRIED
45	UPPER HANOVER	195	NORTHAMPTON	345	HOSENSACK 230/69KV
46	RICHLAND	196	WILKES-BARRE	346	HOSENSACK 500KV
47	MACADA	197	BUCK	347	CONESTOGA
48	ROCKVILLE	198	MT. BETHEL	348	MANDR
49	THOMPSONTOWN	199	ASHEFIELD	349	CLINTON
50	PAXTON	200	SCRANTON	350	EXCHANGE
51	EAST ELIZABETHTOWN	201	TWIN LAKES	351	MILTON
52	WARWICK	202	HARLIGH	352	DAUPHIN
53	EARL	203	TAFON	353	QUARRY SUB.
54	HEPFBURG	204	BEAR CREEK	354	STEELTON
55	EAST LANCASTER	205	DRWIGSBURG	355	JUNIATA 300/230KV
56	KINZER	206	EAST TOWNSHIP	356	JUNIATA 230/69KV
57	MT. PLENO	207	CANDENSIS	357	CUMBERLAND
58	PENNS	208	LINDEN	358	DONEGAL
59	GOULDSBORO	209	WEST JOY	359	JENKINS 230/69KV
60	DILLERVILLE	210	WEST BLOOMSBURG	360	JENKINS CTG
61	GIRARD MANDR	211	MINSI TRAIL	361	VILKES-BARRE
62	KENMAR	212	LAKE NAOMI	362	BUXMONT
63	GOWEN CITY	213	LANARK	363	BLUMMERTON
64	ELLIOT HEIGHTS	214	MONTOURSVILLE	364	SOUTH AKRON 230/138/69KV
65	HARRERSSTOWN	215	PORT CARBON	365	SOUTH AKRON 69/12KV
66	MACHINGIE	216	BLYTHEBURN	366	SOUTH MANHEIM 69/12KV
67	EAST HAZLETON	217	MILFORD	367	SOUTH MANHEIM 230/69KV
68	WAGNERS	218	TREICHLERS	368	ENGLISHTIDE
69	EAST CARBONDALE	219	ROSEVILLE	369	COLUMBIA
70	EVING	220	RUTHERFORD	370	DANVILLE
71	MINDOKA	221	HARTLAND	371	SUNBURY
72	OLD FORGE	222	PARRISH	372	HUMMELS WHARF
73	FOUNTAIN SPRINGS	223	WEST NEW HOLLAND	373	LYCOMING
74	SULLIVAN TRAIL	224	POINT	374	LOCK HAVEN CTG
75	SWATARA	225	INDOLIN	375	LOCK HAVEN 69/12KV
76	HEPBURN	226	MIDDLETON	376	HUMMELSTOWN
77	WATSON	227	STATE HILL	377	WEST SHORE
78	FRANCINIA	228	MILLVILLE	378	MONTAGE
79	EMMAUS	229	TINKER	379	SOUTH FARMERSVILLE
80	MORGAN	230	LAKEVILLE	380	WESCOSVILLE
81	THROOP	231	NORTH MANHEIM	381	FISHBACH
82	CHAPMAN	232	HATTFIELD	382	BERKS
83	SUBURBAN	233	HERSHY	383	MONTOUR
84	PROVIDENCE	234	S. HERSHEY	384	SUBURBAN YARD
85	AVOCA	235	S. WILLIAMSPORT	385	MACK
86	CASS	236	FOGELSVILLE	386	WILLIAMSPORT
87	CATASAGUA	237	WINDSOR	387	HARRISBURG
88	SUSQUEHANNA 500KV	238	W. WILLOW	388	ELDRED
89	SEIDERSVILLE	239	ESTEGATE	389	MILLWOOD
90	ROSEMONT	240	ELDELA	390	TELFORD
91	QUARRYVILLE	241	SUMMERDALE	391	TWIN VALLEY
92	LAWNTON	242	DORNEYVILLE	392	DEVONSHIRE
93	LITITZ	243	BOHEMIA	393	JESSUP
94	RENOVO	244	WHITE HAVEN	394	BELTZVILLE
95	WALNUT	245	LAURELTON	395	SCHOENECK
96	VATSON	246	LINGLESTOWN	396	HAWLEY
97	TREXELTOWN	247	PECONIC FARMS	397	EFFORT MOUNTAIN
98	LAVING	248	HICKORY RUN	398	COPPERSTONE
99	SPRING	249	BLOOMING GLEN	399	RED FRONT
100	COLONIAL PARK	250	SHERMANSDALE	400	APPENZEL
101	WEST LANCASTER	251	LARRYS CREEK	401	BLUE MOUNTAIN
102	MADISONVILLE	252	SPANGLER HILLS	402	DAPPERS 69-12KV
103	NEFFSVILLE	253	E. DANVILLE	403	MEISERVILLE
104	BEAVERTOWN	254	DELAND	404	
105	BELMONT	255	CARBON	405	
106	LAKE HARMONY	256	SELLERSVILLE	406	
107	GEORGETOWN	257	MECHANICSBURG	407	
108	SCOTT	258	CARLISLE		
109	N. HARRISBURG	259	BENTON		
110	MOUNT ROCK	260	NEWPORT		
111	GREENLAND	261	HALIFAX		
112	LANDISVILLE	262	MILLERSBURG		
113	GREEN PARK	263	MUNY		
114	SELINSGRIVE	264	HAUTO		
115	SUNNER	265	BERWICK		
116	AUBURN	266	SHENANDDAH		
117	ROHSBURG	267	PINE GROVE		
118	DERRY	268	FRIDRUBSBURG		
119	EAST GREENVILLE	269	ALLENTOWN		
120	WEST DAMASCUS	270	BINGEN		
121	NEW COLUMBIA	271	SHREWS		
122	FARMERSVILLE	272	CLEVELAND		
123	GREENFIELD	273	LITTLE GAP		
124	NORTH FREDRUBSBURG	274	DRYVILLE		
125	TANNERSVILLE	275	TUSCARORA		
126	ELIZABETHVILLE	276	BARTONSVILLE		
127	WYOMISSING	277	ALTON PARK		
128	EXETER	278	SALEM		
129		279	NORTH BRIDGEPORT		
130		280	HAMPDEN		
131		281	CAMELBACK		
132		282	SILVER SPRING		
133		283	BRECKNOCK		
134		284	BENTON		
135		285	MCMICHAELS		
136		286	HUGHESSTOWN		
137		287	NEWVILLE		
138		288	POINTE NORTH		
139		289	MARIETTA		
140		290			



INTERCONNECTIONS

PS PUBLIC SERVICE ELECTRIC AND GAS CO. OF N.J.
 ME METROPOLITAN EDISON CO. (FIRST ENERGY)
 PE PHILADELPHIA ELECTRIC CO. (PECO ENERGY)
 BC BALTIMORE GAS AND ELECTRIC CO.
 SH SAFE HARBOR WATER POWER CORPORATION
 UP THE UNITED GAS IMPROVEMENT CO. LUZERNE ELECTRIC DIVISION
 PN PENNSYLVANIA ELECTRIC CO. (FIRST ENERGY)
 JC JERSEY CENTRAL POWER AND LIGHT CO. (FIRST ENERGY)

- COMBUSTION TURBINE
- HYDRO ELECTRIC
- COMBINATION
- FIRM SALES
- SUBSTATION / SWITCHING STATION
- STEAM ELECTRIC
- NON-UTILITY GENERATION
- INDEPENDENT POWER PRODUCERS
- 500KV OPERATION
- 230KV OPERATION
- 138KV OPERATION
- 69KV OPERATION

* - SUBSTATIONS THAT HAVE BEEN RETIRED.
 ## - SITE OF THE EXISTING 230KV SUBSTATION AND PROPOSED 500KV SUBSTATION

ACCT - 805201	ELECTRICAL SYSTEM MAP		
SCALE - NONE	HARWOOD - JENKINS #1 & #2 138/69KV REBUILD		
BY - CDW	APPROVED G. HAKUN III	DATE 7/17/85	PPL ELECTRIC UTILITIES
PPL DRAWING NO. D191830	SHEET NO.	REV.	
		1	87

NO.	DATE	ACCT.	DESCRIPTION	BY	REVIEWED	APPROVED
84	4/8/11	169004	ADDED ELROY - HATFIELD #1 & #2 138/69 KV LINE.	MG	RWM	DJG
87	4/19/11	10014284	ADDED HARWOOD - JENKINS #1 & #2 138/69KV REBUILD	MG	RWM	DLH
86	4/15/11	10013847	ADDED HOSENSACK - WESCOSVILLE #3 230KV LINE REPLACEMENT	MG	RWM	DLH
85	4/13/11	169004	ADDED ELROY #2 500KV TIE LINE	MG	RWM	DG

Attachment

2

ATTACHMENT “2”
HARWOOD-JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION
ENGINEERING DESCRIPTION

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	DESCRIPTION OF PROPOSED LINE	1
B.	MAGNETIC FIELD MANAGEMENT.....	4
C.	RIGHT-OF-WAY STATUS.....	4
LIST OF TABLES		
TABLE 1	DESIGN MINIMUM CONDUCTOR CLEARANCES.....	2
TABLE 2	CONDUCTOR THERMAL RATINGS	3
MAP 1	AERIAL EXHIBIT MAPS FOR THE HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION.....	ATTACHMENT “2” MAP POCKET

ATTACHMENT "2"

HARWOOD-JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION ENGINEERING DESCRIPTION

A. DESCRIPTION OF PROPOSED LINE

PPL Electric proposes to reconstruct portions of the existing single-circuit Harwood – Jenkins #1 & #2 69 kV Transmission Lines between the Harwood Substation and the Valmont Taps for double-circuit 138/69 kV operation. The total distance of reconstructed line will be approximately 2.0 miles. This proposed project adds an additional circuit to the area which will provide a direct source from the Harwood Substation to the Valmont Substation. In addition to the reconstruction, PPL Electric proposes to construct approximately 1,700 feet of new, single-circuit, 138/69 kV transmission line on property owned in fee by the Company. The new portion of the line is required to reterminate the reconstructed Harwood – Jenkins #1 Line into the Harwood 138/69 kV Switchyard.

Approximately 1.4 miles of the existing Harwood – Jenkins #2 Transmission Line will be reconstructed beginning at the Harwood Substation. The existing lattice structures, averaging 85 feet tall, will be removed and replaced with double-circuit, weathering steel monopoles equipped with upswept weathering steel arms and polymer 138 kV insulator assemblies. Six 556.5 kcmil,³ 24/7 stranding, ACSR⁴ conductors and one 0.752 inch diameter Optical Ground Wire (OPGW) will be used to provide lightning protection and for communication between circuit breakers that remove the line from service when a faulted line is detected. The tangent poles used in this segment of the project will be direct embedded. Angle poles and the poles on both sides of I-81 will be installed on concrete foundations. The twelve new monopoles will have an average height of 95 feet above ground level. This segment of line will be completed under existing PPL Electric Right-of-Way Agreements and within existing easements. This section of reconstructed 138/69 kV transmission line will contain both Harwood – Jenkins circuits.

³ Kcmil stands for thousand circular mills. Kcmil wire size is the equivalent cross sectional area in thousands of circular mils. A circular mil is the area of a circle with a diameter of one thousandth (.001) of an inch.

⁴ ACSR stands for aluminum conductor steel reinforced.

In addition, approximately 0.6 miles of the existing Harwood – Jenkins #1 transmission line will be reconstructed using components similar to the Harwood – Jenkins #2 line segment described above. The height of the five new steel monopoles will average 95 feet above ground. Tangent structures will be direct embedded and angle structures will be installed on concrete foundations. This segment of line will be completed under existing PPL Electric Right-of-Way Agreements and within existing easements. This section of reconstructed 138/69 kV transmission line will contain the Harwood – Jenkins #1 Line and the Harwood – Valmont 69 kV Line.

To terminate the additional circuit into the Harwood 138/69 kV Switchyard, approximately 1,700 feet of new, single-circuit, transmission line will be constructed. This segment will use six new single-circuit, weathering steel monopoles with horizontal line post polymer 138 kV insulator assemblies. The proposed tangent poles for this segment of the project will be direct embedded. The two angle structures will be installed on concrete foundations. The new monopoles will have an average height of 80 feet above ground level. There will be three 556.5 kcmil, 24/7 stranding, ACSR conductors, and one 0.752 inch diameter OPGW for lightning protection and for communication between circuit breakers that remove the line from service when a faulted line is detected. This segment of line will be installed entirely on property owned in fee by PPL Electric.

The project is located in Hazle Township, Luzerne County. A plot plan for the transmission line project is provided in the Attachment “2” map pocket.

The proposed line will be designed to, and will generally exceed, National Electrical Safety Code (NESC) minimum standards. Design specifications and safety rules practiced by PPL Electric are included in Attachment 4. The minimum conductor to ground clearance will be 30 feet, which occurs at a maximum thermal conductor temperature of 125 degrees Celsius.

The designed minimum conductor clearances and conductor thermal ratings for the line are as follow:

TABLE 1
DESIGN MINIMUM CONDUCTOR CLEARANCES
FOR 556.5 KCMIL 24/7 STRANDING ACSR*

<u>Condition</u>	Transmission Double-Circuit Design <u>Clearance-to-Ground</u>
Normal load; average weather (16°C ambient temperature)	36 feet
Predicted extreme thermal load (125°C conductor temperature)	30 feet
Predicted extreme wind load (25lb wind, 16°C ambient temperature)	42 feet
Predicted extreme weather conditions (1-inch ice, 4 lbs. wind, -9°C)	33 feet

*Clearances based on a maximum tension of 9900 pounds and a ruling span of 600 feet.

TABLE 2
CONDUCTOR THERMAL RATING
556.5 KCMIL 24/7 STRANDING ACSR
(257°F) 125°C MAXIMUM CONDUCTOR TEMPERATURE

Condition	Ambient Temperature	Wind Speed	Ampacity
	<u>°C</u>	<u>Knots</u>	<u>Amps</u>
Summer Normal	35	0	815
Winter Normal	10	0	926
Summer Emergency	35	1 1/2	1,041
Winter Emergency	10	1 1/2	1,163


B. MAGNETIC FIELD MANAGEMENT

PPL Electric's Magnetic Field Management Program, summarized in Attachment 5, is applied to new and reconstructed transmission line projects. To reduce magnetic field exposures, the program generally prescribes the use of a line design that provides five feet higher ground clearance and reverse phasing of new double-circuit lines where it is feasible to do so at low or no cost.

The 1.4 and 0.6 mile line sections will be reconstructed for double circuit operation and will utilize reverse phasing, in accordance with PPL Electric's policy. Additional reduction of magnetic fields is anticipated through the use of greater ground clearance. The 1,700 foot section of line into the Harwood Switchyard is only being built for single circuit operation and, therefore, reverse phasing is not possible. However, five foot higher ground clearances will be utilized on that portion, resulting in some reduction of the magnetic field.

C. RIGHT-OF-WAY STATUS

All work will be completed on existing easements or land owned in fee by PPL Electric. No additional right-of-way or other property interest is required.



EXISTING VALMONT
69 KV LINES

EXISTING HARWOOD-JENKINS #1 &
#2 138/69 KV LINES

EXISTING HARWOOD-JENKINS #2
69 KV LINE

EXISTING HARWOOD-JENKINS #1 69 KV LINE
TO BE REBUILT TO THE
HARWOOD-JENKINS #1 & HARWOOD-VALMONT
138/69 KV LINE

PROPOSED LINE CROSSINGS TO
AVOID WETLANDS AT THE
VALMONT TAPS

EXISTING HARWOOD-JENKINS #1
69 KV LINE
TO BE RENAMED HARWOOD-
VALMONT 69 KV LINE

EXISTING HARWOOD-JENKINS #2 69 KV LINE
TO BE REBUILT TO THE
HARWOOD JENKINS #1 & #2 138/69 KV LINE

EXISTING HARWOOD - JENKINS #1
138/69 KV LINE

NEW HARWOOD 138/69 KV
SWITCHYARD

EXISTING HARWOOD 230-69 KV
SUBSTATION

EXISTING HARWOOD 69-12 KV
SUBSTATION

PROPOSED HARWOOD-JENKINS #2
138/69 KV LINE

LEGEND

- EXISTING RIGHT OF WAY 240' ———
- EXISTING TRANSMISSION LINE ———
- REBUILD TRANSMISSION LINE ———
- EXISTING PROPERTY LINE ———

Line Number	Property Owner
1	PPL ELECTRIC UTILITIES 140 NORTH NORTH STREET ALLENTOWN, PA 18101
2	GREAT HAZELTON CAN SO INC. 1 SOUTH CHURCH ST, SUITE 200 HAZELTON, PA 18201
3	J & J DAN PATRICKS 128 WARDEN STREET HENTONSVILLE, PA 17754
4	GREAT HAZELTON COMMUNITY AREA (CAN 20) NEW DEVELOPMENT ORGANIZATION INC 1 SOUTH CHURCH ST, SUITE 200 HAZELTON, PA 18201
5	MAGNETTE ENTERPRISES INC 44 PUBLIC SQUARE, SUITE 600 WILKE BARRE, PA 18781-2609
6	PENNSYLVANIA LINES LLC C/O NORFOLK SOUTHERN RAILWAYS CO 110 FRANKLIN ROAD, SE ROANOK, VA 24060-2008
7	GREEN RIDGE REALTY COMPANY MR. JOSEPH H. KRCS 310 WINTERS AVENUE WEST HAZELTON, PA 18207

ATTACHMENT 2

**AERIAL EXHIBIT
SHEET 1**

**HARWOOD - JENKINS #1 & #2
138/69KV LINE REBUILD**
HAZEL TOWNSHIP
LOZBURG COUNTY, PA.

SCALE: 1" = 800'

PREPARED BY:
PPL ELECTRIC UTILITIES CORP.

Attachment 3

ATTACHMENT "3"

**HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION
ENVIRONMENTAL ASSESSMENT**

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	INTRODUCTION.....	1
B.	LAND USE.....	1
C.	CULTURAL RESOURCES.....	2
D.	NATURAL FEATURES.....	2
E.	THREATENED AND ENDANGERED SPECIES.....	3

ATTACHMENT "3"

HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION ENVIRONMENTAL ASSESSMENT

A. INTRODUCTION

To alleviate conductor overloading between the Harwood 138-69 kV Substation and the Jenkins 230-69 kV Substation, PPL Electric is requesting PUC approval to install an additional transmission circuit between the Harwood Substation and the Valmont Taps. To accommodate this circuit, PPL Electric is proposing to reconstruct approximately 1.4 miles of the existing Harwood – Jenkins #2 Transmission Line and 0.6 miles of the existing Harwood – Jenkins #1 Transmission Line for double-circuit operation. In addition, 1,700 feet of new, single-circuit 138/69 kV transmission line will be constructed on PPL Electric property in order to terminate the new line into the existing Harwood 138/69 kV Switchyard. The proposed lines will accommodate 138 kV operation, although all circuits will initially operate at 69 kV. The project, as proposed, will resolve the issues discussed in the Necessity Statement found in Attachment "1".

This proposed project was reviewed with Hazle Township and Luzerne County, and neither had any objection. A list of involved governmental agencies, municipalities and other public entities is presented in Attachment 6.

B. LAND USE

The existing Harwood – Jenkins #1 and #2 69 kV Transmission Lines are located in Hazle Township, Luzerne County. The proposed project will be reconstructed entirely within existing PPL Electric rights-of-way or on property owned in fee by PPL Electric. The proposed double-circuit steel pole line is generally located in wooded areas, away from residential properties. The proposed project will cross eleven properties held by five property owners. Existing access roads will be used, although new roads may be needed in some locations during construction. The 1,700 feet of new line will be constructed entirely on property owned in fee by PPL Electric. That property already contains numerous transmission related facilities.

No communications towers, pipelines or other utilities will be affected by the proposed project. The reconstructed line, as proposed, will use existing railroad and highway crossing locations. Appropriate permits and licenses will be obtained for all crossings, as required, and PPL Electric will comply with any conditions placed on those permits.

The nearest airport, Hazleton Municipal Airport, is located approximately 1.7 miles away from the proposed project site. PPL Electric will file the appropriate documentation with the Federal Aviation Administration and PennDOT Bureau of Aviation to ensure that the proposed reconstructed lines will not be a hazard to the airport's flight operations. No hazards are anticipated, however, due to the existing transmission lines currently in the area.

C. CULTURAL RESOURCES

The project was reviewed by the Pennsylvania Historical and Museum Commission (PHMC). The PHMC has determined that there are no National Register eligible or listed historic or archaeological properties in the area (File No. ER 2011-0251-079-A). Therefore, there are no anticipated impacts to such resources, and no further investigation is required.

D. NATURAL FEATURES

The proposed project will not affect any unique geological, scenic, or natural areas. No parks or recreational facilities are located near the project area. Minimal tree clearing is required to rebuild this line because construction will take place on pre-existing cleared right-of-way or on property owned in fee by PPL Electric. To minimize the impacts of any required clearing, PPL Electric will apply its "Specification For Initial Clearing and Control Maintenance of Vegetation on or Adjacent To Electric Line Right-of-Way through Use of Herbicides, Mechanical, And Hand-Clearing Techniques."

The proposed double-circuit Harwood – Jenkins #1 & #2 138/69 kV Transmission Line will cross three wetlands near the Valmont Taps. PPL Electric has contracted Woodland Design Consultants to delineate all water bodies and wetlands in the project area. To minimize environmental impacts in the area, PPL Electric has designed the Project to avoid impacting wetlands and endangered plant species located near the Valmont Taps by spanning those

areas. PPL Electric will obtain all required permits and will comply with any conditions placed on the permits.

E. THREATENED AND ENDANGERED SPECIES

PPL Electric has coordinated with relevant state and federal agencies to obtain information regarding endangered and threatened species that may be located in the study area. A review of the Pennsylvania Natural Diversity Inventory (PNDI) records indicated that there are six potential conflicts in the project area. The Pennsylvania Game Commission identified potential conflicts with the Eastern Small-footed Myotis (*Myotis Leibii*) and the Northern Myotis (*Myotis Septentrionalis*). The Pennsylvania Department of Conservation and Natural Resources (DCNR) identified potential conflicts with Screw-stem (*Bartonia Paniculata*), Bog Copper (*Lycaena Epixanthe*), Fall Dropseed Muhly (*Muhlenbergia Uniflora*), and Ridgetop Dwarf-tree Forest (*Quercus Llicifolia-kalmia Latifolia-p. Rigida*).

PPL Electric has contracted Mellon Biological Services, LLC (Mellon) to work with these agencies to avoid affected areas and to mitigate any impacts caused by the construction and operation of the proposed facilities. A report prepared by Mellon was submitted to DCNR on April 19, 2011 to address potential conflicts with endangered plant species. This report proposed construction strategies that would avoid impacts to endangered plant species. DCNR's May 9, 2011 response accepted the strategies proposed by Mellon, and added that if strict Erosion and Sedimentation Control Plans are implemented, no impact to endangered plant species is anticipated.

By letter dated February 4, 2011 the Pennsylvania Game Commission advised that any tree cutting or trimming should occur only during the period from November 16th to March 31st. PPL Electric will comply with this request. (PNDI No. 20100915262551).

Attachment

4

LIST OF ATTACHMENTS

- ATTACHMENT 4 - PPL Electric Design Criteria and Safety Practices
- ATTACHMENT 5 - Magnetic Field Management at PPL Electric
- ATTACHMENT 6 - List of Involved Governmental Agencies, Municipalities, and Other Public Entities
- ATTACHMENT 7 - List of Owners of Property Within the Right-of-Way

ATTACHMENT 4

PPL DESIGN CRITERIA AND SAFETY PRACTICES

The National Electrical Safety Code (NESC) is a set of rules to safeguard people during the installation, operation, and maintenance of electric power lines. The NESC contains the basic provisions considered necessary for the safety of employees and the public. Although it is not intended as a design specification, its provisions establish minimum design requirements. PPL Electric Utilities Corp. (PPL Electric) has developed design specifications and safety rules which meet or surpass all provisions specified by the NESC.

Engineering Design Criteria and Parameters

The NESC includes loading requirements and clearances for the design, construction, and operation of power lines. The "loads" on conductors and supporting structures are the mechanical forces that develop from the weight of the conductors, the weight of ice on the conductors, plus wind pressure on the conductors and supporting structures. Loading requirements are the loads on the conductors and structures that are anticipated assuming certain ice and wind conditions. Loading requirements always contain "safety factors" to allow for unknown or unanticipated contingencies. The clearances and loading requirements contained in the NESC were developed to ensure public safety and welfare.

PPL Electric transmission line design standards meet or surpass the NESC standards. For example, the relative order of grades of construction for conductors and supporting structures is B, C, and N; Grade B being the highest. According to the NESC standards, construction Grades B, C, or N may be used for transmission lines (except at crossings of railroad tracks and limited access highways where Grade B construction is specified). However, PPL Electric designs all of its transmission lines for Grade B construction. The use of Grade B design and construction specifies such things as larger-minimum crossarm dimensions, larger-minimum conductor size, and increased safety factors.

Another example is the design parameters utilized to account for ice and wind loadings on the overhead ground wire (OHGW) and power conductors. The NESC standard ice and wind design magnitudes for the PPL Electric's territory are 0.5 inch thickness of radial ice combined with four pounds per square foot horizontal wind pressure (equivalent to 40-mile per hour wind velocity). The conductor sags and tensions used in line designs are the result of various ice and wind combinations, depending on the elevation at the line location and line design voltage. The conductor sags and tensions used in the design of all PPL Electric transmission lines are at least 0.5-inch ice combined with eight pounds wind pressure (equivalent to 57 miles per hour wind velocity). This means that PPL Electric lines are designed to operate safely and reliably during inclement weather even more severe than assumed by the NESC. In addition, PPL Electric transmission lines are designed with more clearance to the ground than required by the NESC. The tables below compare PPL Electric and NESC ground clearances for lines of various voltages.

138 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	21 Ft.	30 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	21 Ft.	30 Ft.
Spaces accessible to pedestrians only	17 Ft.	30 Ft.
Railroad tracks	31 Ft.	35 Ft.

230 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	23 Ft.	32 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	23 Ft.	32 Ft.
Spaces accessible to pedestrians only	19 Ft.	32 Ft.
Railroad tracks	31 Ft.	36 Ft.

500 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	28 Ft.	53 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	28 Ft.	53 Ft.
Spaces accessible to pedestrians only	24 Ft.	53 Ft.
Railroad tracks	38 Ft.	53 Ft.

A relay protection system is used to protect the public safety and welfare as well as equipment and the transmission system. Relay protection is installed for all transmission lines to automatically de-energize the line in the unlikely event that the line or supporting structure fails and the line contacts the ground.

Periodic Maintenance Program on All Transmission Lines

To ensure continued public safety and integrity of service, a periodic maintenance and inspection program is implemented for every transmission line. The program is administered through the use of helicopter patrols, with supplemental foot and structure climbing patrols. Helicopter patrols are performed on all lines annually. The two-man helicopter crew flies parallel, to the left, and above the line so that the observer, who sits to the right of the pilot, can look for signs of line damage or deterioration and observe clearances between vegetation and conductors. The observations are included in a report that is forwarded to the appropriate department for corrective action.

Foot and structure climbing patrol programs for a transmission line begin approximately three to five years after the line is energized, unless a helicopter patrol reports a need for earlier action. The frequency of foot patrols varies from once every year to once every several years depending on line type and age.

An assigned foot patroller checks right-of-way conditions, including access roads, bridges, pole washouts, tower footers, vegetation height and clearance to conductors, pole and tower deterioration and, with the use of binoculars, insulators, and condition of hardware. Identified problems are included in a report that is forwarded to the appropriate department for corrective action.

A scheduled line outage is required to perform an overhead patrol so that hardware can be inspected safely. Overhead patrols of transmission lines are conducted on a schedule determined by line age, operating record, and observed general condition. Any necessary repairs are also done during the inspection outage.

Personnel Safety Rules

The following are a few of the PPL Electric safety rules that demonstrate the Company's concern for employee safety:

- Work procedures have been developed to allow work to be performed on energized facilities in a safe manner. When lines or apparatus are removed from service to be worked on, the Energy Control Process system is applied. This system provides that a red tag must be physically placed on the control handle of the de-energized equipment. The red tag may be removed only after proper authorization to energize the equipment. Various other tags are used for limited operations and informational purposes. Employees will not apply or remove a tag or change the status of tagged equipment unless authorized.
- Temporary safety grounds are used on de-energized facilities for employee safety during maintenance, construction, or reconstruction work. Safety grounds are wires connecting the de-energized facility to an electrical ground. If the facility should be energized, the safety grounds will divert the current directly to ground and reduce the likelihood of personal injury. The conductor size and attachment clamps of temporary safety grounds must be capable of conducting anticipated fault currents. Rubber gloves, rubber sleeves, and additional rubber protective equipment are used as required when applying or removing temporary safety grounds to or from the lines or apparatus to be grounded. An approved nonconductive working stick of sufficient length to allow workers to maintain the following required minimum clearances is used to test that the line has been de-energized and to apply temporary safety grounds:

Voltage-kV

Minimum Clearance

138

3'-7"

230

5'-3"

500

11'-3"

Before applying grounds, a test is done to confirm that the line is de-energized. The voltage test device is checked before and after use to assure reliability. When ground pins are used to establish proper ground points, they are driven to a depth of not less than four feet as near vertical as possible.

- Poles or structures are inspected and examined for structural integrity before climbing. If there is any reason to believe that a pole is unsafe, it is stabilized before work is performed. Appropriate safety gear in the form of body belts, safety straps, hard hats, gloves, etc., is worn by linemen during line work activity.

Attachment

5



**MAGNETIC
FIELD
MANAGEMENT**
**PPL Electric Utilities
Corporation**

DECEMBER 2004

TABLE OF CONTENTS

INTRODUCTION	1
DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	6
VARIABLES THAT AFFECT MAGNETIC FIELDS	6
Effect of Phase Current on Magnetic Fields	6
Effect of Conductor Configuration on Magnetic Fields	7
Effect of Distance from the Magnetic Field Source	7
SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	8
MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES	9
Overhead Lines	9
New or Rebuilt Transmission Lines	9
Reconductoring or Adding Additional Circuits to Existing Transmission Lines	14
Distribution Lines	14
Underground Transmission Lines.....	15
CHARTS.....	16

INTRODUCTION

At PPL Electric Utilities Corp. (PPL EU), magnetic field management means investigating and implementing methods at low or no cost to reduce magnetic fields in new or rebuilt transmission and distribution lines. This document explains PPL EU's Magnetic Field Management Program, which is part of PPL EU's larger Electric and Magnetic Fields (EMF) policy.

PPL EU's View

Some people are worried that electric and magnetic fields are harming their health. Others think the scientific research does not show a problem at all, and still others believe there's just too much scientific uncertainty to draw any conclusions.

Here's what we do know now. Various panels of scientists that have reviewed the EMF research generally have drawn two main conclusions. First, the large body of evidence does not demonstrate that EMF are harmful. Second, additional research is recommended to explore questions raised in some studies.

Given these conclusions, PPL EU is taking a reasoned approach in responding to the EMF issue. PPL EU's approach to the EMF issue consists of five elements:

- Providing EMF information to customers and employees
- Providing magnetic field measurements
- Establishing and implementing a magnetic field management program to reduce magnetic fields in new or rebuilt facilities when it can be done at no, or low, cost
- Integrating EMF in the public involvement process that PPL EU undertakes in the siting of transmission lines
- Have supported additional research

EMF Are All Around Us

Electric and magnetic fields occur in nature and in all living things. The earth, for instance, has a magnetic field, which makes the needle on a compass point north.

Electric fields and magnetic fields of a different type also surround every wire that carries electricity. In everyday life, these EMF arise from several basic sources, including power lines, electrical appliances, home and building wiring, other utility lines and cables, and currents flowing on water pipes. Though they often occur together, EMF are made up of two separate components:

Electric Fields

Electric fields are produced by the voltage—or electrical pressure—on a wire. The higher the voltage, the higher the electric field. As long as a wire is energized—has voltage present—an electric field is present (see Figure 1). In other words, an appliance, or an electric power line, doesn't actually have to be turned on to create an electric field. It just has to be plugged in. Electric fields diminish with distance and can be blocked or partially shielded by objects such as trees and houses.

Magnetic Fields

Magnetic fields are created by the current or flow of electricity through a wire. Generally speaking, the higher the current, the higher the magnetic field. Because they only occur when current is flowing, magnetic fields are present only when the power is turned on (see Figure 1). Magnetic fields also diminish with distance, but—unlike electric fields—are not blocked by common objects. In recent years, public and scientific interest has turned toward the magnetic field component of EMF because of some scientific studies regarding these fields.

Figure 1




Figure 2









Magnetic field strengths decrease with distance		Source: "EMF in Your Environment", U.S. Environmental Protection Agency 1992		
Magnetic fields are measured in milligauss		At 6 inches	At 1 foot	At 2 feet
Clothes dryer		2 to 10	* to 3	*
Microwave oven		100 to 300	1 to 200	1 to 30
Toaster		5 to 20	* to 7	*
Power drill		100 to 200	20 to 40	3 to 6
Can opener		500 to 1500	40 to 300	3 to 30
Mixer		30 to 600	5 to 100	* to 10
Hair dryer		1 to 700	* to 70	* to 10
Color television		Data not available	* to 20	* to 8

FIGURE 2 * The magnetic field measurement at this distance from the operating appliance could not be distinguished from background measurements taken before the appliance had been turned on.

Measuring Magnetic Fields

Magnetic fields usually are measured in a unit called a milligauss. Magnetic field levels found in the living areas of homes typically range from less than 1 milligauss to about 4 milligauss according to the U.S. Environmental Protection Agency. They can be higher in some cases. The levels next to appliances can exceed 1,000 milligauss (1 gauss). Figures 2 and 3 show how the strength of the field falls off as you move away from the source, just as the heat of a campfire grows weaker as you walk away from it. For overhead power lines, the strength of the magnetic fields is dependent upon a number of factors that will be explained later. Those factors produce a magnetic field that drops off rapidly as you move away from the power line.

Figure 3

Sample Magnetic Field Levels in Milligauss				
Type of Overhead Power Line	Distance from the line			
	Under the line	50 ft.	100 ft.	200 ft.
220 kV and 500 kV	5-400	5-250	1-75	0.5-20
69 kV and 138 kV	3-80	0.5-2.5	0.1-10	0.1-3
12 kV and below	0.4-20	0.1-1	-	-

The magnetic field values provided in this table represent a general range of values associated with the types of overhead power lines listed and are provided for illustration. There will be circumstances in which there will be magnetic field levels above or below the range of values provided due to variations in such factors as height of the wires, current flow and so on.

DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

One element of our response to EMF concerns expressed by some of our customers is PPL EU's Magnetic Field Management Program. The program was initiated in March 1991 because PPL EU believes it makes good sense, as a matter of policy, to respond to the concerns expressed by some of our customers and to reduce magnetic fields in new and rebuilt facilities where it can be done with either no-cost or low-cost design changes.

This document updates the original program which has been revised several times since 1991. These guidelines were developed by PPL EU's EMF Working Group.

VARIABLES THAT AFFECT MAGNETIC FIELDS

Magnetic fields from transmission and distribution lines are a function of a number of design variables. The following parameters affect the magnetic field levels produced by transmission and distribution lines:

- Current
- Height of conductors above ground
- Configuration of conductors
- Distance from the line

EFFECT OF PHASE CURRENT ON MAGNETIC FIELDS

At power frequencies (i.e., 60 hertz), the magnetic field level is a function of the current or flow of electricity through a wire. Keeping all other parameters the same, the magnetic field is proportional to the current. Hence, if the current increases by 25 percent, the resulting magnetic field level will increase by 25 percent.

The overall load current on any line varies with the demand for power. It's usually highest during daytime hours and lowest at night. There also are weekly, monthly, seasonal and yearly variations.

The difference in the currents between each phase in a multiphase line also can affect the magnetic field. This difference is called phase unbalance. For a constant load, a statistical analysis of this phase unbalance can be made to determine its effect on the magnetic field. Close to the line, there is very little effect. However, the phase unbalance slows the rate at which the magnetic field decreases with distance from the line.

EFFECT OF CONDUCTOR CONFIGURATION ON MAGNETIC FIELDS

In the transmission and distribution of power, utilities like PPL EU presently use both three-phase and single-phase lines. Each phase on a three-phase power line has either a single conductor or a bundle of two or more conductors. In a three-phase system, the ground-level magnetic field is a result of the fields produced by the currents in each of the phases. Placing the three phases as close together as possible (compaction) creates some field cancellation, and the ground-level magnetic field is reduced. However, appropriate phase separation is required for the reliable operation of the line. In addition, the arrangement of the phases can create some; field cancellation and reduction of the ground-level magnetic field.

EFFECT OF DISTANCE FROM THE MAGNETIC FIELD SOURCE

Magnetic field strength diminishes with the vertical and lateral distances from the magnetic field source. Increasing the height of the conductors above ground is useful for magnetic field reduction at ground level, but may result in increased structure costs and increased aesthetic impact of the structures. Another possible method of increasing the distance to the magnetic field source is to increase the right-of-way requirements. By keeping buildings off increased rights of way, thereby requiring the public to live and work further away from lines, exposure to magnetic fields produced by the lines can be reduced. Increases in right of way are not always practical and may increase costs significantly, however.

SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

Under its Magnetic Field Management Program, PPL EU has changed the way it builds and rebuilds some of its transmission and distribution lines. These design changes reduce magnetic field levels (assuming balanced circuit loadings and phase currents) by up to 69 percent in most of the company's new transmission lines. These guidelines now are being applied to new and reconstructed transmission facilities, based on this program.

The distribution component of the program focuses on 12 kV lines, the company's standard distribution voltage. It concentrates on the three-phase, primary 12 kV lines, since these are the most heavily loaded facilities and often are located in densely populated areas. The guidelines in this program are being applied to these three-phase, primary 12 kV lines.

A maximum 3-5 percent change in estimated cost was used as the limit for the guidelines since this value is consistent with low cost, is within estimating accuracy and is likely to have little impact on overall line costs.

The magnetic field calculations used in this document for the design of PPL EU's overall magnetic field management plan assume balanced load conditions among the phases and a fixed level of current, not necessarily representative of specific transmission or distribution lines. These levels were calculated using the Electric Power Research Institute's ENVIRO computer program. Under actual operating conditions, the magnetic field levels that result may vary due to such things as actual load per circuit, overall current on each phase conductor and the electrical configuration and operation of each line.

MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES

The guidelines for magnetic field management are noted below, with discussion points for each.

OVERHEAD LINES

NEW OR REBUILT TRANSMISSION LINES

1. **Balance transmission circuit loads and phase currents as much as possible.**
 - PPL EU should continue to make every effort to balance loadings between the two circuits of a double circuit line when planning new or rebuilt facilities to maximize the effects of reverse phasing.
 - PPL EU should continue the practice of balancing single-phase loads across the three phases of the distribution system. (Unbalanced phase currents on the distribution system are reflected through to the transmission system.)
 - Unbalanced phase currents result in higher magnetic fields that do not drop off as quickly with distance as do the fields resulting from balanced phase currents.
 - For a 5 percent phase current unbalance, the magnetic field 50 feet from the centerline of a single circuit 138 kV line could be more than twice the value than if the same line had balanced phase circuits.
 - Balanced phase currents on each three-phase distribution circuit also reduce magnetic fields from the distribution circuits themselves. In addition, they reduce magnetic fields on the transmission system from which the distribution system circuits are supplied and connected through substations.
 - Apart from magnetic field considerations, balanced phase currents on each three-phase distribution circuit also reduce line losses and improve the system voltage.

2. Continue with the present practice of using long-span construction as the PPL EU 138/69 kV standard

- Structure designs for short-span and long-span construction are illustrated on Charts I and II, respectively.
 - Short-span design does not significantly reduce magnetic fields when compared to long-span design even though it is more compact than long-span design. Comparison of the magnetic field values from Chart III indicates essentially the same values. Therefore, short-span design should not be used solely to reduce magnetic fields.
 - PPL EU will continue to use long-span construction for 138/69 kV double-circuit lines and for single-circuit/future-double-circuit lines.
 - For single-circuit/future-double-circuit lines, PPL EU will continue to install two conductors on the top positions and one in the middle position as shown in Chart IV.
 - This arrangement minimizes magnetic fields as shown in Chart V by placing the three initial conductors higher on the structure, which increases the ground clearances, and by placing the conductors in a triangular configuration.

3. Compact design structures are not a low-cost alternative and should be used for magnetic field reduction only in special applications.

Chart VI illustrates the compact design structure.

- The compact design increases the initial installation costs by 79 percent when compared to the long-span design but reduces the magnetic field from 9 mG to 3 mG (about 67 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.

4. Reverse phase new or rebuilt double-circuit transmission lines for all voltage levels.

- Reverse phasing was adopted by PPL EU in March 1991 for double-circuit 138/69 kV transmission lines and in April 1992 for all other double circuit transmission lines. Reverse phasing is shown in Chart VII. Reverse phasing will reduce the magnetic fields when the current flow on both circuits is in the same

direction. Calculated values contained here are based on balanced and equal phase currents on both circuits.

- Reverse phasing reduces the magnetic field of a double circuit 138 kV single pole transmission line from 29 mG to 9 mG (about 69 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.
- Reverse phasing reduces the magnetic field of a double circuit 230 kV single pole transmission line from 49 mG to 16 mG (about 67 percent) at the edge of the 150-foot-wide right of way as shown on Chart VIII.
- Reverse phasing reduces the magnetic field of a double-circuit 500 kV single pole transmission line from 37 mG to 21 mG (about 43 percent) at the edge of the 200-foot-wide right of way as shown on Chart IX.
- When new or rebuilt double-circuit lines require tapping existing double-circuit lines, PPL EU will review the existing lines to determine if reverse phasing can be provided at low cost.
- Computer modeling is required to develop the optimum phasing and overall conductor arrangements for lines added to, or rebuilt in, multiple-line corridors.
 - Merely adding a reverse-phase double-circuit line to an existing transmission line corridor or reverse phasing a rebuilt line in the multiple-line corridor will not necessarily produce lower magnetic field levels at the edge of the corridor right of way.
 - The corridor must be computer modeled with all the lines, existing phase conductor locations and currents. Then, magnetic field calculations must be made varying the phase arrangements of the new or reconstructed line to determine the appropriate phasing arrangement.
 - Current flow direction on a line also must be considered. For example, a reverse-phased line should have the current flowing in the same direction on both circuits. If the current flow is in the opposite direction for one circuit, reverse phasing will not produce the lowest magnetic field and another phase arrangement that produces lower fields may need to be utilized.

5. Increase the minimum ground clearance for all new transmission lines.

138/69 kV Transmission Lines

- Increasing the minimum line design ground clearance from 25 feet to 30 feet may add up to about 5 percent to the installed cost of a new double-circuit single pole 138/69 kV line. For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. With long-span reverse-phase design, the magnetic field is reduced from 9 mG to 7 mG (about 22 percent) at the edge of a 100-foot-wide right of way as shown in Chart X.
- In the actual design of transmission lines to include higher minimum ground clearances, there may be limited segments (such as highway crossings, severe slopes and transmission line crossing locations) where National Electrical Safety Code (NESC) minimum ground clearances may need to be used. The NESC minimum ground clearances are less than the increased ground clearance discussed previously.

230 kV Transmission Lines

- Increasing the minimum line design ground clearances from 27 feet to 32 feet may add up to about 5 percent to the cost of a single-circuit single-pole line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 30 mG to 28 mG (about 7 percent) at the edge of a 150-foot-wide right of way.
- Increasing clearances from 27 feet to 32 feet could theoretically add up to about 2.8 percent to the cost of a double-circuit single-pole line (current standard) and reduce the magnetic field of a reverse-phase line from 16 mG to 15 mG (about 6 percent) at the edge of a 150-foot-wide right of way. Chart XI is a summary of this data.
- Studies are required for each new 230 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such

studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced phase spacing (a "Delta" configuration on a single-circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

500 kV Transmission Lines

- Increasing ground clearances from 33 feet to 53 feet may add up to about 4.5 percent to the cost of a single-circuit "H-frame" line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 42 mG to 35 mG (about 17 percent) at the edge of a 200-foot-wide right of way.
- Increasing ground clearances from 33 feet to 53 feet could theoretically add up to 2.8 percent to the cost of a double-circuit "H-frame" line (current standard) and reduces the magnetic field of a reverse-phase line from 21 mG to 16 mG (about 24 percent) at the edge of a 200-foot-wide right of way. Chart XII is a summary of this data.
- Studies are required for each new 500 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced-phase spacing (a "Delta" configuration on a single circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

RECONDUCTORING OR ADDING ADDITIONAL CIRCUITS TO EXISTING TRANSMISSION LINES

When reconductoring or adding additional circuits to existing transmission lines, PPL EU will evaluate low-cost or no-cost options for magnetic field management on a case-by-case basis.

When reconductoring existing transmission lines or adding additional circuits, low-cost alternatives may not exist; however, the following steps will be taken:

- For a single-circuit line, the use of a Delta arrangement or other modifications on the existing structure, with reduced-phase spacing, will be evaluated.
- For double-circuit lines, application of reverse phasing may reduce the magnetic field under the line and within the right of way and will be evaluated.
- For single- and double-circuit lines, evaluate using higher conductor tensions that can increase the minimum line design ground clearance.

DISTRIBUTION LINES

At the 12 kV distribution level, new main three-phase lines will continue to be constructed with five feet of additional ground clearance.


- Main lines are the most heavily loaded sections of a distribution line and therefore have the highest magnetic fields associated with them.
- Increasing the ground clearance by five feet reduces the magnetic field under the line from 14 mG to 11 mG using the standard eight-foot crossarm design. These values are based on increasing pole heights from 45 feet to 50 feet and a typical operating current of 300 amps per phase.
- Chart XIII is a summary of this data. Increasing ground clearance by five feet could theoretically add about 5 percent to the cost of a typical distribution line.

UNDERGROUND TRANSMISSION LINES

Underground transmission lines are required due to environmental or land use factors or restrictions on available clearances, PPL EU will evaluate options for magnetic field management techniques on a case-by-case basis.


- The phase arrangement that produces the lowest field will be determined.
- The depth of burial of the line will be determined considering the cost of excavation and the location of other buried utilities in the area.
- The use of steel pipe ferromagnetic shielding that reduces magnetic fields will be evaluated.

Short-Span Construction



- **More compact design**
- **Should not be used solely to reduce magnetic fields**
- **Typical conductor data:**
 - 1 3/8" HS steel overhead ground wire - 7.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 10.0 feet sag
 - Average span - 400 feet

Long-Span Construction Remains PPL EU 138 kV Standard




- Lower cost alternative
- Reduces magnetic fields due to higher structures
- Typical conductor data:
 - 1 3/8" HS steel overhead ground wire - 17.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 23.0 feet sag
 - Average span - 600 feet

**138/69 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**


TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SHORT SPAN (CHART I)	30
SHORT SPAN (REVERSE PHASE)	8
LONG SPAN (CHART II)	29
LONG SPAN (REVERSE PHASE)	9
COMPACT (CHART VI)	14
COMPACT (REVERSE PHASE)	3

The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 25 feet.
LONG SPAN, SHORT SPAN and COMPACT are double-circuit lines.

Typical Single-Circuit Structure Designs



Top/Middle



Vertical



Top/Middle/Bottom


——— initial single circuit
- - - - future second circuit

**138/69 kV SINGLE CIRCUIT TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
TOP/MIDDLE/BOTTOM	20
VERTICAL	17
TOP/MIDDLE	12


The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 25 feet.

Compact Design Structure



- **Minimize magnetic fields due to compact design**
- **Not a low-cost alternative**
- **Typical conductor data:**
 - 1 3/8" HS steel overhead ground wire - 9.0 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 9.0 feet sag
 - Average span - 300 feet

Reverse Phasing of Double-Circuit Transmission Lines



From: → → → → To:

Reverse phasing also can be one of the following phase arrangements:

A	B		B	A		B	C		C	A		C	B
C	C	or	C	C	or	A	A	or	B	B	or	A	A
B	A		A	B		C	B		A	C		B	C

CHART VIII

**230 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	49
DOUBLE CIRCUIT POLE (REVERSE-PHASE)	16

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 27 feet.

CHART IX

**500 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 1100 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	37
DOUBLE CIRCUIT POLE (REVERSE PHASE)	21

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 33 feet.

**INCREASED 138/69 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	25	12
SINGLE CIRCUIT TOP/MIDDLE	30	10
LONG SPAN	25	29
LONG SPAN	30	26
LONG SPAN (REVERSE PHASE)	25	9
LONG SPAN (REVERSE PHASE)	30	7

The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.

**INCREASED 230 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	27	30
SINGLE CIRCUIT TOP/MIDDLE	32	28
DOUBLE CIRCUIT POLE	27	49
DOUBLE CIRCUIT POLE	32	46
DOUBLE CIRCUIT POLE (REVERSE PHASE)	27	16
DOUBLE CIRCUIT POLE (REVERSE PHASE)	32	15

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.

**INCREASED 500 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 1,100 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT "H" STRUCTURE	33	42
SINGLE CIRCUIT "H" STRUCTURE	53	35
DOUBLE CIRCUIT POLE	33	37
DOUBLE CIRCUIT POLE	53	31
DOUBLE CIRCUIT POLE (REVERSE PHASE)	33	21
DOUBLE CIRCUIT POLE (REVERSE PHASE)	53	16

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.

**12 kV DISTRIBUTION LINES
CALCULATED MAGNETIC FIELDS AT 300 AMPERES**

TYPE CONSTRUCTION	POLE HEIGHT FEET	MAGNETIC FIELD IN MILLIGAUSS*	
		AT CENTERLINE	AT 30 FEET FROM CENTERLINE
STANDARD CROSSARM	45	14	7
STANDARD CROSSARM	50	11	6

* Field level under the line at mid-span based on 300 amps, balanced loading, one meter above ground level.

Attachment

6

ATTACHMENT 6

HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION LIST OF INVOLVED GOVERNMENTAL AGENCIES, MUNICIPALITIES AND OTHER PUBLIC ENTITIES

Pennsylvania Historical and Museum Commission
Bureau for Historic Preservation
Commonwealth Keystone Building, Second Floor
400 North Street
Harrisburg, Pennsylvania 17120-0053
Attn: Mr. Douglas C. McLearn, Chief

Pennsylvania Department of Transportation
Commonwealth Keystone Building
400 North Street, 8th Floor
Harrisburg, Pennsylvania 17120
Attn: The Honorable Allen D. Biehler, P.E., Secretary

Department of Environmental Protection
P.O. Box 2063
Market Street State Office Building
Harrisburg, Pennsylvania 17105-2063
Attn: Office of Field Operations

Adrian Merolli, Director
Luzerne County Planning Commission
Penn Place
20 N. Pennsylvania Avenue
Wilkes-Barre, PA. 18711

William J. Gallagher, Chair
Hazle Township Board of Supervisors
P.O. Box 506
Harleigh, PA. 18225

Luzerne County Commissioners
200 North River Street
Wilkes-Barre, PA 18711-1001

Paul Matulevich
Hazle Township Planning Department
PO Box 506
Harleigh, PA 18225

Attachment

7

ATTACHMENT 7

**HARWOOD – JENKINS #1 & #2 138/69 kV TRANSMISSION LINE RECONSTRUCTION
LIST OF OWNERS OF PROPERTY WITHIN THE RIGHT-OF-WAY**

PPL Electric Utilities
2 North Ninth St
Allentown, PA 18101

Greater Hazleton Cando Inc
1 South Church St
Hazleton, PA 18201

JandJ Inn Partners
195 Warren Street
Montoursville, PA 17754

Gr Haz Comm Area New Dev Org Inc, CAN DO Inc.
1 South Church St
Hazleton, Pa 18201-6259

Pagnotti Enterprises, Inc.
46 Public Square
Suite 600
Wilkes Barre, PA, 18701-2609

Green Ridge Realty Company
Mr Joseph H Kress
1010 Winters Ave
West Hazleton, PA, 18202