



An Exelon Company

Richard G. Webster, Jr.
Director
Rates and Regulatory Affairs

Telephone 215.841.4000 ext 5777
Fax 215.847.6208
www.exeloncorp.com
dick.webster@exeloncorp.com

PECO Energy Company
2301 Market Street, S15
Philadelphia, PA 19103

Mail To: 8699
Philadelphia, PA 19101-8699

September 27, 2011

RECEIVED

SEP 27 2011

FedEx

Mr. James McNulty, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Second Floor
Harrisburg, Pennsylvania 17120

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

**Re: PUC Docket No. M-0991220
Request for Major Event Exclusion**

Dear Secretary McNulty:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed are an original and one copy of PECO's Request for Exclusion of a Major Outage for reliability reporting purposes.

The major event occurred August 27, 2011 through September 3, 2011 and was caused by rain and high winds attributed to Hurricane Irene. The combination caused damage to aerial electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Webster".

cc: Bureau of Technical Utility Services
Bureau of Audits
Darren Gill, Bureau of Conservation, Economics and Energy Planning
John Hartenstein (PECO)

enclosures

amm

SEP 27 2011

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR PA PUBLIC UTILITY COMMISSION
 RELIABILITY REPORTING PURPOSES TO
 PENNSYLVANIA PUBLIC UTILITY COMMISSION
 P O BOX 3265
 HARRISBURG, PA 17105-3265
 SECRETARY'S BUREAU

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy
 Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:

John Hartenstein
(Name)

Reliability Manager
(Title)

3. Telephone number: 215-841- 5608
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 511,102 (sustained)

Total number of customers in service territory 1,683,939 as of August 1 ,2011

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

BUCKS COUNTY- 131,037

CHESTER COUNTY - 134,036

DELAWARE COUNTY - 109,392

MONTGOMERY COUNTY- 67,899

PHILADELPHIA COUNTY - 57,158

YORK COUNTY -11,580

TOTAL - 511,102

(c) Reason for interruption or outage, including weather data where applicable:

Heavy rain and wind from Hurricane Irene caused damage to vegetation that brought down aerial electric facilities.

- (d) The number of utility workers and others assigned specifically to the repair work:
 - Peco Field - 614
 - Gas Mechanics / Foreman - 118
 - Contractors - 587
 - Tree Trimmers - 766
 - Other Utilities - 214
 - PECO Back Office - 1,324

(e) The date and time of the first notification of a service interruption: 8/27/2011 at 12:44

(f) The actual time that service was restored to the last affected customer: 9/3/2011 at 15:14

Remarks: Contract crews from Pittsburgh, Florida, and Michigan along with utility workers from ComEd and Duquesne Light assisted in the restoration efforts.
