



Before the
Pennsylvania Public Utility Commission

**FOUNTAIN HILL #1 & #2
138/69 kV TAP LINE**

ATTACHMENTS IN SUPPORT OF THE
Letter of Notification

Application Docket No. _____

Submitted by: PPL Electric Utilities Corporation

SUMMARY


A Letter of Notification is being submitted by PPL Electric Utilities Corporation (PPL Electric) pursuant to the Pennsylvania Public Utility Commission's (PUC or the Commission) regulations at 52 Pa. Code §§ 57.71 through 57.77 for approval to site and construct the Fountain Hill #1 & #2 138/69 kV Tap Line (Fountain Hill Tap) to serve the planned Fountain Hill 69-12 kV Substation (Fountain Hill Substation). Together, the Tap Line and Substation are required to improve reliability of service in the Fountain Hill area of Lehigh County. This Project is located in Salisbury Township, Lehigh County. The proposed tap line will be approximately 700 feet in length. Initially, it will be a double tap-single feed configuration and designed for 138 kV operation. Initially, the tap will operate at 69 kV. Later, when future load increases make it appropriate, a second circuit will be extended into the Fountain Hill substation, and the operating voltage will be increased to 138 kV.

The total estimated cost of the proposed transmission work associated with this Project is approximately \$106,000. In addition, PPL Electric estimates that it will spend approximately \$1.620 million (including the transformer cost) for the substation and \$440,000 for distribution work associated with this Project. Subject to the Commission's approval, this Project has a scheduled construction start date of April 2012, in order to meet an in-service date of May 2013.

This document, which describes the need for the Project and explains the engineering and siting analysis for the proposed construction, consists of the following:

Attachment "1"	Necessity Statement
Attachment "2"	Engineering Description
Attachment "3"	Environmental Assessment
Attachment "4"	PPL Electric Design Criteria and Safety Practices
Attachment "5"	PPL Electric Magnetic Field Management Program
Attachment "6"	List of Involved Governmental Agencies, Municipalities
Attachment "7"	List of Owners of Property Within the Right of Way

PPL ELECTRIC UTILITIES SERVICE TERRITORY



Attachment

1

ATTACHMENT 1
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
NECESSITY STATEMENT

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
A.	INTRODUCTION.....	1
B.	EXISTING SYSTEM.....	2
C.	DEFINITION OF THE PROBLEM.....	2
D.	PROPOSED SOLUTION.....	4

LIST OF FIGURES

FIGURE 1	FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING TRANSMISSION FACILITIES.....	6
FIGURE 2	FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED TRANSMISSION FACILITIES.....	7
FIGURE 3	FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING DISTRIBUTION FACILITIES.....	8
FIGURE 4	FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED DISTRIBUTION FACILITIES.....	9

MAP 1	PPL ELECTRIC TRANSMISSION FACILITY MAP	ATTACHMENT 1 MAP POCKET
-------	--	----------------------------

ATTACHMENT 1
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
NECESSITY STATEMENT

A. INTRODUCTION

PPL Electric is requesting PUC approval to site and construct the Fountain Hill #1 and #2 138/69 kV Tap Line (Fountain Hill Tap). The proposed facilities are required to meet the load growth in the Fountain Hill area. The purpose of the proposed tap line is to supply the proposed Fountain Hill 69-12 kV Substation (Fountain Hill Substation). In order to energize the proposed Tap, both circuits on the Elliot Heights #1 & #2 138/69 kV Transmission Tap Line will be tapped through two Load Sectionalizing Air Break (LSAB) switches to a common point. From this point, a single circuit will be extended to the proposed new Fountain Hill Substation. The proposed tap will be constructed using two LSAB switches so that service can be maintained or restored quickly in the event of an outage on either circuit on the Elliot Heights #1 or #2 138/69 kV Transmission Tap Line.

The Fountain Hill Tap will be built for future 138 kV operation but will initially operate at 69 kV. In addition, a second circuit will be extended into the substation, and the tap will be upgraded to 138 kV operation when future demand for electricity warrants this construction.

The estimated cost to design and construct the proposed Fountain Hill Tap is approximately \$106,000. In addition, PPL Electric estimates that it will spend approximately \$1.620 million (including the transformer cost) for the substation and \$440,000 for distribution work associated with this Project. The total cost of the Project is estimated to be \$2.166 million.

The required in-service date for this Project is May 2013. The required in-service date is defined as the date the proposed facility needs to be placed in service to prevent equipment overloads that have the potential to damage existing facilities,

and, thereby, cause the interruption of service to customers. In order to meet this in-service date, subject to the Commission's approval, construction is scheduled to start in May, 2012.

A PPL Electric system map showing existing transmission facilities with a design voltage of 35 kV or greater is included in the map pocket at the end of Attachment 1. This filing addresses only the existing and proposed 138/69 kV system in the Fountain Hill area.

B. EXISTING SYSTEM

Presently the Elliot Heights and Seidersville 69 – 12 kV Substations provide service to the area of concern. The Elliot Heights 69 – 12 kV Substation has two 69 – 12 kV transformers that are energized from the two circuits of the Elliot Heights #1 and #2 138/69 kV Transmission Tap Line. The Elliot Heights Substation currently supplies five 12 kV distribution lines, which serve a total of nearly 9,000 customers.

The Seidersville 69 – 12 kV Substation has two 69 – 12 kV transformers that are energized from the Hosensack – Quarry #1 and #2 138/69 kV Transmission Line. The Seidersville 69 – 12 kV Substation currently supplies five 12 kV distribution lines, which in total serve about 8,000 customers.

C. DEFINITION OF THE PROBLEM

PPL Electric plans its system in accordance with its Reliability Principles and Practices (RP&P) guidelines, so that PPL Electric can sustain probable contingencies and disturbances with minimal customer service interruptions and so that it can adequately serve each customer's needs with regard to capacity, voltage and reliability for all load levels throughout the daily load cycle. System Planning is the process which assures that PPL Electric's regional system can

supply electricity to all customer load in a manner that is reliable and economic. In addition, the system is planned so that system reliability can be maintained to prevent large scale, long term, or frequent service interruptions in order to avoid adverse effects and hazards to the public.

The planning process begins with the development of a computer model of the future system. A specific study year is chosen. The future system model is then developed using the existing system plus any planned modifications to the transmission system scheduled to be in service prior to the study year. Load levels used in the system model are based on the latest forecast prepared annually by PPL Electric. Forecasts take into account ambient temperatures and humidity indices.

Once the system model is complete, comprehensive power flow simulations are performed to determine the ability of the system to comply with the PPL Electric transmission planning reliability criteria. All conditions where the system is not in conformance with the reliability criteria are identified, and system reinforcements are added to the model to bring the system into conformance. Also identified are estimated costs and lead-times to implement the required reinforcements. Computer simulations of the system with the identified reinforcement alternatives are completed to identify the best overall reinforcement that will meet the needs of the region in a reliable and economic manner.

Due to the increasing demand for electricity, the Elliot Heights 69 – 12 kV Substation is expected to serve a peak load of approximately 37 MVA in the summer of 2012, which exceeds its rating of 35.5 MVA determined by its 12 kV underground transformer cables. If in the event that all load at Elliot Heights must be served by one transformer, the underground cables could fail interrupting nearly 5,000 customers until repairs can be made.

In addition to the concerns with loading at Elliot Heights Substation, the Seidersville 39-2 12 kV Distribution Line is expected to serve a peak load of 9.9 MVA in the summer of 2015. A portion of this line is composed of 2/0 Copper conductor which has a normal planning guideline of 8 MVA in the RP&P. If this guideline is exceeded there could be possible conductor damage or failure that would interrupt customers until repairs could be made.

The Seidersville 39-2 Distribution Line is particularly important because it is the principal source of supply for the Saint Lukes' Hospital. In the event of an outage of the Seidersville 39-2 Distribution Line, the Hospital can be served through the Seidersville 39-4 Distribution Line, but when the load is transferred, the load on the Seidersville 39-4 Distribution Line exceeds its emergency planning guideline for a portion of the line. Exceeding the emergency planning guideline can result in damage to the line and could result in an outage.

Also, the Elliot Heights 12-4 12 kV Distribution Line has been one of PPL Electric's worst performing circuits in terms of outages in recent years.

D. PROPOSED SOLUTION

To resolve the projected conductor overload and reliability issues discussed in Section C, PPL Electric proposes construction of the new Fountain Hill Substation, which will be supplied by the Fountain Hill Tap which is proposed in this Letter of Notification. PPL Electric will own, operate and maintain the new Fountain Hill Substation and the Fountain Hill Tap.

Two new 12 kV circuits which will be supplied from the Fountain Hill Substation will initially be installed. The new Fountain Hill Substation and the new 12 kV distribution circuits will allow transfer of load to relieve the projected overloading on the Elliot Heights Substation and the Seidersville 39-2 Distribution Line.


The Fountain Hill Substation and new 12 kV distribution lines will tap into the Elliot Heights 12-4 12 kV distribution line, picking up its entire load. This load transfer will reduce loading at the Elliot Heights Substation by about 5.8 MVA. The addition of motorized switching on this new line will reduce restoration times on the former Elliot Heights 12-4 12 kV distribution line during outages by allowing remote operation of switching devices.

The second new circuit from the Fountain Hill Substation will tap into the Seidersville 39-2 Distribution Line picking up approximately 3.1 MVA bringing load on the 2/0 Copper section well within its planning guidelines.

Presently, Saint Luke's Hospital is supplied by the Seidersville 39-2 12 kV Distribution Line. After the completion of the Fountain Hill Tap and Substation, it will be supplied by one of the new Fountain Hill circuits. Therefore, in addition to reducing the load on the Seidersville 39-2 12 kV distribution line, Saint Luke's Hospital will be supplied from two separate substations served by two separate transmission lines. The Hospital will be supplied by two separate distribution lines, thus further improving the reliability of electric service to this critical human needs customer because, with transmission lines, two substations and two feeds, service can be maintained or quickly restored in the event of an outage of either source of supply.

The new substation will provide an additional source for load transfers between distribution circuits, which will improve the reliability and operating flexibility on the Elliot Heights and Seidersville 12 kV Distribution Lines.

**FIGURE 1
FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING
TRANSMISSION FACILITIES**




LEGEND:

- Existing Construction
- New Construction
- ⌋ Load Air Break Switch
- Normally Open
- ⋯ Customer Sub

**Fountain Hill Area
Existing Transmission Facilities**

DSR 11/14/11

**FIGURE 2
FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED
TRANSMISSION FACILITIES**



LEGEND:

- Existing Construction
- New Construction
- ⌋ Load Air Break Switch
- Normally Open
- Customer Sub

**Fountain Hill Area
Existing and Proposed New
Transmission Facilities**

DSR 11/14/11

FIGURE 3 FUNCTIONAL ONE-LINE DIAGRAM OF EXISTING DISTRIBUTION FACILITIES





FIGURE 4 FUNCTIONAL ONE-LINE DIAGRAM OF PROPOSED DISTRIBUTION FACILITIES



SUBSTATION LISTING

1. WEST WILLIAMSPORT	136. SELINGROVE	271. HALIFAX	404. APPENZEL
2. FAIRFIELD	137. SUMNER	272. MILLERSBURG	405. BLUE MOUNTAIN
3. MONTGOMERY	138. AUBURN	273. MUNCY	406. DAPPERS 69/12KV
4. VARDEN	139. ROHRSBURG	274. HAUTO	407. MEISERVILLE
5. HONESDALE	140. DERRY	275. BERWICK	408. LEDGEDALE
6. JERSEY SHORE	141. EAST GREENVILLE	276. SHENANDOAH	409. EAST TAMMERSVILLE
7. LOGANTON	142. WEST DAMASCUS	277. PINE GROVE	410. TRUMBACHERVILLE
8. VALMONT	143. NEW COLUMBIA	278. STROUDSBURG	411. WEST TREXLERTOWN
9. RIVER	144. FARMERSVILLE	279. FREEMANSBURG	412. FOUNTAIN HILL
10. LIMESTONE	145. GREENVILLE	280. ALLENTOWN	
11. NORTHUMBERLAND	146. NORTH STROUDSBURG	281. BINGEN	
12. REED	147. TANNERSVILLE	282. RHEEMS	
13. WRIGHT	148. ELIZABETHVILLE	283. CLEVELAND	
14. ST. JOHNS	149. WYOMISSING	284. LITTLE GAP	
15. FREELAND	150. EXETER	285. ORVILLE	
16. *	151. CRACKERSPORT	286. TUSCARORA	
17. GILBERT	152. SCHNECKSVILLE	287. BARTONSVILLE	
18. *	153. HEMLOCK	288. ALTON PARK	
19. CHERRY HILL	154. MT. ALLEN	289. SALEM	
20. SUSQUEHANNA 230KV	155. PRINCE	290. NORTH BRIDGEPORT	
21. TAMAMEND	156. WAKEFIELD	291. HAMPDEN	
22. WHITE HILL	157. COOPERSBURG	292. CAMELBACK	
23. PALMERTON	158. WERTZVILLE	293. SILVER SPRING	
24. HAMILTON	159. WEST CARLISLE	294. BRECKNOCK	
25. HUNTER	160. BENVENUE	295. BENTON	
26. FAIRVIEW	161. HEGINS	296. MCMICHAELS	
27. *	162. LEOLA	297. HIGHTSTOWN	
28. *	163. YATESVILLE	298. NEWVILLE	
29. MONTOUR PUMP	164. CENTRAL ALLENTOWN	299. POINTE NORTH	
30. MT. CARMEL	165. OBERLIN	300. MARIETTA	
31. KELLY	166. STRASBURG	301. CENTER CITY	
32. SPORTING HILL	167. ATGLEN	302. NEW KINGSTOWN	
33. NAHANCY CITY	168. BROOKSIDE	303. REANSTOWN	
34. GREENWOOD	169. WILLIAMSTOWN	304. DUPONT	
35. MOWERY	170. EAST PETERSBURG	305. HUMBOLT	
36. ALTMOUNT	171. WERNERSVILLE	306. CEDAR AVE.	
37. HAMLIN	172. NORTH BETHLEHEM	307. INDIAN ORCHARD	
38. ASHFIELD	173. WEST ALLENTOWN	308. NOTTINGHAM	
39. SOUTH SLATINGTON	174. FLEMINGTON	309. NORTH COOLBAUGH	
40. SOUTH MIDDLEBURG	175. MECKESVILLE	310. LETORT	
41. WALKER	176. DONERVILLE	311. EAST MOUNTAIN	
42. FRAILEY	177. MILLERSVILLE	312. JERMYN	
43. MORGANTOWN	178. SCHILLINGTON	313. BLOOMSBURG	
44. EGYPT	179. MILKE	314. MIFFLINTOWN	
45. CRESSONA	180. MCALLISTERVILLE	315. RIDGE ROAD	
46. SOUTH WHITEHALL	181. NEWFOUNDLAND	316. SUSQUEHANNA	
47. EAST TOMHICKEN	182. MARLIN	317. KIMBLE	
48. BEAR GAP	183. WEST BERWICK	318. CHRISTMANS	
49. SALISBURY	184. KEYSER AVENUE	319. OTTER CREEK	
50. SOUTH MILTON	185. NICKLEYS	320. STEEL CITY	
51. HEIDELBERG	186. EAST ALLENTOWN	321. MCGOVERNVILLE	
52. LYKENS	187. PINE RIDGE	322. ROBESONIA	
53. UPPER HANOVER	188. DALMATIA	323. SOUTH FOGELSVILLE	
54. RICHLAND	189. PENNSBORO	324. ELROY	
55. MACADA	190. NORTH COLUMBIA	325. BUSHKILL	
56. ROCKVILLE	191. HUGHSVILLE	326. WALLENPAUPACK	
57. THOMPSONTOWN	192. SOUTH ALLENTOWN	327. ELK MOUNTAIN	
58. PAXTON	193. WEISSPORT	328. JACK FROST	
59. COCALICO	194. HONEYBROOK	329. HARWOOD 230/69KV	
60. EAST ELIZABETHTOWN	195. MOSCOW	330. HARWOOD CTG	
61. WARWICK	196. *	331. HARWOOD 69/12KV	
62. EARL	197. ROSSMOYNE	332. NAZARETH	
63. HEMPFIELD	198. NORTHAMPTON	333. ALBURTIS	
64. EAST LANCASTER	199. WOOLRICH	334. FRACKVILLE	
65. KINZER	200. FAXON	335. *	
66. MT. NERO	201. ELIZABETHTOWN	336. ELMSPORT	
67. MT. POCONO	202. ENOLA	337. ALLENWOOD	
68. PENNS	203. TERRE HILL	338. *	
69. GOULDSBORO	204. BUCK	339. GRATZ	
70. DILLERVILLE	205. MT. BETHEL	340. HOCKERSVILLE	
71. GIRARD MANOR	206. FRIEFLD	341. BLOOMING GROVE	
72. KENMAR	207. SCRANTON	342. MONROE	
73. GOWEN CITY	208. TWIN LAKES	343. LACKAWANNA #	
74. *	209. HARLEIGH	344. STANTON	
75. ELLIOT HEIGHTS	210. TAFTON	345. JACKSON	
76. ROHRERSTOWN	211. BEAR CREEK	346. EAST PALMERTON	
77. NAELUNGIE	212. ORWIGSBURG	347. SIEGFRIED	
78. EAST HAZLETON	213. EAST TEXAS	348. HOSENSACK 230/69KV	
79. WAGNERS	214. CANDENSIS	349. HOSENSACK 500KV	
80. EAST CARBONDALE	215. LINDEN	350. CONESTOGA	
81. EYNOX	216. MT. JOY	351. MANOR	
82. MINOOKA	217. WEST BLOOMSBURG	352. CLINTON	
83. OLD FORGE	218. MINSI TRAIL	353. EXCHANGE	
84. FOUNTAIN SPRINGS	219. LAKE NAOMI	354. MILTON	
85. SULLIVAN TRAIL	220. LANARK	355. DAUPHIN	
86. *	221. *	356. QUARRY SUB.	
87. SWATARA	222. MONTAUSVILLE	357. STEELTON	
88. *	223. PORT CARBON	358. JUNIATA 500/230KV	
89. HEPBURN	224. BLYTHEBURN	359. JUNIATA 230/69KV	
90. *	225. MILFORD	360. CUMBERLAND	
91. *	226. TREICHLERS	361. DONEGAL	
92. FRANCONIA	227. ROSEVILLE	362. JENKINS 230/69KV	
93. EMMAUS	228. RUTHERFORD	363. JENKINS CTG	
94. MORGAN	229. HARTLAND	364. WILKES-BARRE	
95. THROOP	230. PARRISH	365. BUXMONT	
96. *	231. WEST NEW HOLLAND	366. SOUTH AKRON 230/138/69KV	
97. *	232. POINT	367. SOUTH AKRON 69/12KV	
98. CHAPMAN	233. LINCOLN	368. SOUTH MANHEIM 69/12KV	
99. SUBURBAN	234. MIDDLETON	369. SOUTH MANHEIM 230/69KV	
100. *	235. STATE HILL	370. ENGLESTIDE	
101. *	236. MILLVILLE	371. COLUMBIA	
102. *	237. TINKER	372. DANVILLE	
103. PROVIDENCE	238. LAKEVILLE	373. SUNBURY	
104. *	239. NORTH MANHEIM	374. HUMMELS WHARF	
105. AVOCA	240. HATFIELD	375. LYCOMING	
106. *	241. HERSHEY	376. LOCK HAVEN CTG	
107. CASS	242. SOUTH HERSHEY	377. LOCK HAVEN 69/12KV	
108. CATASQUA	243. SOUTH WILLIAMSPORT	378. HUMMELSTOWN	
109. *	244. FOGELSVILLE	379. WEST SHORE	
110. SUSQUEHANNA 500KV	245. WINDSOR	380. MONTAGE	
111. SEIDERSVILLE	246. WEST WILLOW	381. SOUTH FARMERSVILLE	
112. ROSEMONT	247. WESTGATE	382. WESCOSVILLE	
113. QUARRVILLE	248. EDELA	383. FISHBACH	
114. LAWRTON	249. SUMMERDALE	384. BERKS	
115. LITITZ	250. DORNEVILLE	385. MONTOUR	
116. RENOVO	251. BOHEMIA	386. SUBURBAN YARD	
117. WALNUT	252. WHITE HAVEN	387. *	
118. WATSON	253. LAURELTON	388. *	
119. TREXLERTOWN	254. LINGLESTOWN	389. MACK	
120. LAVINO	255. POCONO FARMS	390. WILLIAMSPORT	
121. SPRING	256. HICKORY RUN	391. HARRISBURG	
122. COLONIAL PARK	257. BLOOMING GLEN	392. ELDRER	
123. WEST LANCASTER	258. SHERMANDSDALE	393. *	
124. MADISONVILLE	259. *	394. MILLWOOD	
125. NEFFSVILLE	260. LARRYS CREEK	395. TELFORD	
126. BEAVERTOWN	261. SPANGLER MILLS	396. TWIN VALLEY	
127. BELMONT	262. EAST DANVILLE	397. DEVONSHIRE	
128. LAKE HARMONY	263. DELANO	397. JESSUP	
129. GEORGETOWN	264. CARBON	398. BELTZVILLE	
130. SCOTT	265. SELLERSVILLE	399. SCHOENECK	
131. NORTH HARRISBURG	266. MECHANICSBURG	400. HAWLEY	
132. MOUNT ROCK	267. CARLISLE	401. EFFORT MOUNTAIN	
133. GREENLAND	268. CEDAR	402. COPPERSTONE	
134. LANDISVILLE	269. ARROWHEAD	403. RED FRONT	
135. GREEN PARK	270. NEWPORT		


* - SUBSTATIONS THAT HAVE BEEN RETIRED.

** - SITE OF THE EXISTING 230KV SUBSTATION AND PROPOSED 500KV SYBSTATION.

INTERCONNECTIONS

- PS PUBLIC SERVICE ELECTRIC AND GAS CO. OF N.J.
- ME METROPOLITAN EDISON CO. (FIRST ENERGY)
- PE PHILADELPHIA ELECTRIC CO. (PECO ENERGY)
- BC BALTIMORE GAS AND ELECTRIC CO.
- SH SAFE HARBOR WATER POWER CORPORATION
- UT THE UNITED GAS IMPROVEMENT CO. - LUZERNE ELECTRIC DIVISION
- PN PENNSYLVANIA ELECTRIC CO. (FIRST ENERGY)
- JC JERSEY CENTRAL POWER AND LIGHT CO. (FIRST ENERGY)

- COMBUSTION TURBINE
- HYDRO ELECTRIC
- COMBINATION
- FIRM SALES
- SUBSTATION / SWITCHING STATION
- STEAM ELECTRIC
- NON-UTILITY GENERATION
- INDEPENDENT POWER PRODUCERS
- 500KV OPERATION
- 230KV OPERATION
- 138KV OPERATION
- 69KV OPERATION



FOUNTAIN HILL #1 & #2 138/69KV TAP

ACCT- 805201	ELECTRICAL SYSTEM MAP	
SCALE- NONE	FOUNTAIN HILL 69-12 KV SUBSTATION	
BY- CDW	FOUNTAIN HILL #1 & #2 138/69 KV TAP	
REVIEWED	APPROVED	DATE
	G. HAKUN III	7/17/85
PPL DRAWING NO.	SHEET NO.	REV.
D191830	1	100

NO.	DATE	ACCT.	BY	REVIEWED	APPROVED
100	12/19/11	10013359	ADDED FOUNTAIN HILL 69-12 KV SUB AND FOUNTAIN HILL #1 & #2 138/69KV TAP	mjg	DJG
99	12/09/11	10016114	ADDED WEST TREXLERTOWN 69-12 KV SUB AND WEST TREXLERTOWN #1 & #2 69/130KV TAP	mjg	DJG
98	12/02/11	10016984	ADDED SUSQUEHANNA - HARWOOD #1 & #2 230KV LINES PROJECT LOCATION	mjg	KBK
97	11/20/11	169989	ADDED WEST SHORE - HARRISBURG #1 & #2 138/69KV LINE - PROJECT LOCATION	mjg	KBK

Attachment

2

**ATTACHMENT “2”
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
ENGINEERING DESCRIPTION**

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
A. Description of Proposed Line	1
B. Magnetic Field Management.....	3
C. Right-of-Way Status	4

List of Tables

Table 1: Design Minimum Conductor Clearances for 556.5 kcmil 24/7 Stranding ACSR.....	2
Table 2: Conductor Thermal Rating 556.5 kcmil 24/7 Stranding ACSR.....	3

List of Figures

Figure 1: Typical Double Circuit Tap Structure	5
Figure 2: Typical Double Circuit 138/69 kV Angle Structure	6
Figure 3: Typical Double Circuit 138/69 kV Switch Structure	7

Map

Map 1: Aerial Exhibit Drawing	ATTACHMENT “2” MAP POCKET
-------------------------------------	---------------------------

ATTACHMENT “2”
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
ENGINEERING DESCRIPTION

A. DESCRIPTION OF PROPOSED LINE

PPL Electric proposes to construct the Fountain Hill Tap, which will extend approximately 800 feet in length and connect the existing the Elliot Heights #1 & #2 Transmission Tap Line to the planned Fountain Hill Substation. The proposed Fountain Hill Tap will be located in Salisbury Township, Lehigh County. The location of these proposed facilities is shown on the Aerial Attachment at the end of Attachment “2.”

The Fountain Hill Tap will be designed as a double tap-single feed for 138 kV operation. Initially, however, it will be operated at 69 kV. The circuit will operate at 138 kV and a complete second circuit between the Elliot Heights #1 & #2 Transmission Tap Line and the Fountain Hill Substation will be added when future load increases make it appropriate to maintain service reliability.

The Fountain Hill Tap will be supported by steel mono-poles. The double-circuit tap structure will consist of a high pole that is approximately 125 feet tall and a low pole that is approximately 85 feet tall and they will be installed on concrete foundations. The double-circuit tap poles will be located in-line with the existing Elliot Heights #1 & #2 Transmission Tap Line (see Figure 1). The remaining steel poles will range in height from to approximately 50 to 70 feet (see Figure 2). Angle structures will either be self-supporting on foundations or direct embedded and guyed. Tangent, or no-angle, structures will be direct embedded.

The Fountain Hill #1 & #2 138/69 kV Transmission Tap Line initially will be a double-tap, single feed configuration and will contain six power conductors between the tap and the point where the single feed begins. Three more power conductors will be installed parallel to the single feed when the second circuit is

added. There will be one or two overhead ground wire(s). The power conductors will be 556.5 kcmil,¹ 24/7 strand ACSR.² A 3/8-inch steel overhead ground wire(s) will provide lightning protection for the proposed tap line. In addition, two Load Sectionalizing Air Brake (LSAB) switch poles will be installed in the proposed Fountain Hill Tap (see Figure 3).

The new Fountain Hill Tap will be designed according to, and will generally surpass, National Electrical Safety Code (“NESC”) minimum standards. Additional design criteria and safety rules practiced by PPL Electric are explained in Attachment 4. The minimum conductor-to-ground clearance will be 30 feet for the new Tap. This minimum clearance occurs at a maximum thermal conductor temperature of 125°C. The design minimum conductor ground clearances and conductor thermal ratings are as follow:

**TABLE 1
DESIGN MINIMUM CONDUCTOR CLEARANCES
FOR 556.5 KCMIL 24/7 STRAND ACSR³**

<u>Condition</u>	<u>Single-circuit Design Clearance-to-Ground</u>
Normal load, average weather (16°C ambient, 60°F temperature)	33.3 feet
Predicted extreme thermal load (125°C conductor, 257°F temperature)	30 feet
Predicted NESC extreme wind load conditions (25 lbs., 16°C, 60°F temperature)	32.3 feet
Predicted extreme weather conditions, 0°F (1-inch ice, 4 lbs. wind, -18°C)	32 feet

¹ A kcmil is a thousand circular mils. A circular mil is the cross-sectional area of a wire one mil in diameter, where 1 kcmil = 0.5067 mm².

² Aluminum conductor steel reinforced.

³ Clearances based on a maximum tension of 7,000 pounds and a ruling span of 279 feet.

TABLE 2
CONDUCTOR THERMAL RATING 556.5 KCMIL 24/7 ACSR
125°C MAXIMUM CONDUCTOR TEMPERATURE

<u>Condition</u>	Ambient Temperature <u>°C</u>	Wind Speed <u>Knots</u>	Ampacity <u>Amps</u>
Summer Normal	35	0	815
Winter Normal	10	0	926
Summer Emergency	35	1.5	1041
Winter Emergency	10	1.5	1103

B. MAGNETIC FIELD MANAGEMENT

PPL Electric’s Magnetic Field Management Program is summarized in Attachment 5 and applied to reconstruction and new line projects. In order to lower magnetic field exposures, the program generally prescribes a line design that provides 5 feet higher ground clearances than required under the NESC and reverse phasing of new double-circuit lines where it is feasible to do so at low or no cost. The implementation of additional modifications will be considered, provided those modifications can be made at low or no cost and will not interfere with the operation of the line.

Increased structure height will be utilized in the design of the new line to reduce magnetic field exposures. Reverse phasing cannot be utilized at this time because only one circuit will be installed. Reverse phasing requires a double-circuit line. Reverse phasing will be considered when a second circuit is added in the future.

C. RIGHT-OF-WAY STATUS

The Fountain Hill Tap will be constructed on property owned by Lehigh County. PPL Electric will acquire sufficient right-of-way from the County to contain the tap line and maintain all required NESC clearances. The Substation will be constructed on property that PPL Electric will acquire in fee from the County. PPL Electric and Lehigh County have an agreement in principle for right-of-way for the Tap and a fee interest in the property for the substation.

FIGURE 1
PROPOSED 138/69 kV DOUBLE CIRCUIT TAP STRUCTURE
APPROXIMATE HEIGHT OF HIGH POLE - 125'
APPROXIMATE HEIGHT OF LOW POLE - 85'



FIGURE 2
PROPOSED 138/69 kV TANGENT STRUCTURE
APPROXIMATE HEIGHT – 70'






FIGURE 3
PROPOSED 138/69 kV LSAB SWITCH STRUCTURE
APPROXIMATE HEIGHT – 70'





LEGEND

- EXISTING TRANSMISSION LINE —
 - PROPOSED TRANSMISSION TAP —
 - EXISTING PROPERTY LINE (APPROX.) —
 - PROPOSED - PROPERTY LINE (APPROX.) —
 - SUBSTATION FENCED AREA (APPROX.) —
 - PROPOSED RIGHT-OF-WAY (APPROX.) —
- SCALE 1" = 200'

AERIAL EXHIBIT

FOUNTAIN HILL SUBSTATION
 SALISBURY TOWNSHIP
 LEHIGH COUNTY, PA.



PREPARED BY:
 PPL ELECTRIC UTILITIES CORP.

PPL ELECTRIC UTILITIES

Attachment

3

**ATTACHMENT “3”
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
ENVIRONMENTAL ASSESSMENT**

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
A. Introduction.....	1
B. Land Use	1
C. Cultural Resources	2
D. Natural Features	3
E. Threatened and Endangered Species	4

ATTACHMENT “3”
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
ENVIRONMENTAL ASSESSMENT

A. INTRODUCTION

To meet the increasing demand for electricity and improve reliability, PPL Electric is proposing to construct the Fountain Hill Tap to supply the proposed Fountain Hill 69-12 kV Substation. The Project involves the installation of approximately 700 feet of new transmission line and associated poles and load sectionalizing air breaks. The tap will be designed for double-circuit 138 kV operation, although it initially will be constructed as a double-tap, single feed tap operated at 69 kV. The Fountain Hill Tap and the Substation will be constructed, on land currently owned by the County. PPL Electric and the County have reached an agreement in principle under which PPL Electric will acquire a right-of-way for the Fountain Hill Tap and a tract of land in fee for the Fountain Hill Substation.

PPL Electric provided information describing the Project to Salisbury Township and Lehigh County, and neither the Township nor the County objects to the Project. A list of involved governmental agencies, municipalities, and other public entities is presented in Attachment 6.

B. LAND USE

The proposed tap line and substation will be located on a 1.9-acre parcel in Salisbury Township, Lehigh County that PPL Electric is in the process of purchasing. The proposed lot is presently part of a larger 123-acre lot owned by Lehigh County and zoned CR for Conservation – Residential use. The entire 123-acre tract has been placed into a conservation easement. Due to the existing conservation easement on the property which PPL Electric plans to purchase, PPL

Electric is required to mitigate impacts by replacing the land on a one to one basis. Thus, in order to terminate the conservation easement, PPL Electric is required to transfer ownership of an equal sized lot to the County in exchange for the tract of land on which the Fountain Hill Tap and Substation will be constructed. As part of the agreement, PPL Electric will transfer to the County ownership of a 2.1 acre parcel within the center of the park.

The property which PPL Electric will purchase is partially traversed by the existing Elliot Heights #1 & #2 138/68 kV Transmission Tap Line. The property is bordered by county owned property to the north and east. Residential properties are located to the south and west of the subject property. To the south the property is bordered by Long Lane and to the west by Tillage Road. Due to the existing transmission lines and the proposed substation facilities on this parcel, the incremental visual impacts of the proposed tap line will be minimal.

No communication towers, pipelines, or other utilities will be affected by the proposed Project. Lehigh Valley International Airport in Allentown, PA, located approximately 3.1 miles north of the Project site, is the nearest airport to the Project. Impact to this airport is not expected due to the distance between the Project and the airport. Nonetheless, the appropriate notifications will be filed with the Federal Aviation Administration and PennDOT Bureau of Aviation to confirm that the proposed tap line will not be a hazard to the airport's flight operations.

C. CULTURAL RESOURCES

The Project was reviewed by the Pennsylvania Historical and Museum Commission (PHMC). The PHMC has identified no significant archeological sites in the proximity of the proposed Project and has determined that additional studies are not warranted (File No. ER 2011-1917-077A).

D. NATURAL FEATURES

The Project will not affect any unique geological, scenic, or natural areas. The nearest public recreational areas are Dodson Park and Lehigh Mountain Park (Upland Section) which are both located immediately adjacent to the proposed Project site. Dodson Park is a small 5-acre park that is utilized by local youth sport groups. The park contains two baseball fields, soccer field, and volleyball area. The proposed Project is not anticipated to have a significant impact to Dodson Park because the proposed substation and tap line will not interfere with the park's current uses. Additionally, PPL Electric will work with Lehigh County to install measures to mitigate impacts.

Lehigh Mountain Park (Upland Section) is an approximately 230-acre tract comprised of relatively undisturbed second growth forest that is used primarily for hiking and mountain biking. The #1 and #2 Elliot Heights 138/69 kV Transmission Tap Line, a PPL Electric distribution line and underground gas pipeline all traverse the park adjacent to the site that PPL Electric will purchase for the substation.

As a result of the land exchange described above, it not anticipated that the proposed Project will have a net adverse impact on this park since the size of the park will remain substantially the same and a lower value area is being replaced with a higher value area.

Tree clearing is not required for this Project since the property is presently being utilized for agricultural uses. PPL Electric will apply its "Specifications for Initial Clearing and Control of Vegetation on or Adjacent to Electric Right-of-Way Through Use of Herbicides, Mechanical, and Hand Clearing Techniques" if minor tree or brush clearing is required along the edges of the property..

The transmission tap line will not cross any wetlands or areas designated as “Waters of the U.S.” or “Waters of the Commonwealth.” PPL Electric will acquire and comply with any required soil erosion and sedimentation control permit conditions. Additionally, any required permits will be obtained from the Pennsylvania Department of Environmental Protection and the United States Army Corps of Engineers prior to construction and PPL Electric will comply with all conditions placed on the permits.

E. THREATENED AND ENDANGERED SPECIES

PPL Electric has coordinated with different state and federal agencies to obtain information regarding threatened and endangered species in close proximity to the Project area. A review of the Pennsylvania Natural Diversity Inventory (PNDI) records indicates the potential presence of threatened and endangered species and/or special concern species and resources (PNDI Search ID: 20111007320187). Based on the initial PNDI response, PPL Electric contracted Mellon Biological Services to conduct a survey of the entire property to determine whether the identified species were present. Based on this survey, the identified species was not found on the portion of the property where these proposed facilities will be constructed. The results of the survey were submitted to Pennsylvania Fish and Boat Commission (PFBC) for its review, along with a recommendation that no further investigation be conducted on this portion of the property. On October 26, 2011 PFBC issued a letter concurring with the recommendations of the report and agreeing that the proposed Project would not have an adverse impact on the identified species.

Attachment

4

ATTACHMENT "4"
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
PPL ELECTRIC DESIGN CRITERIA AND SAFETY PRACTICES

The National Electrical Safety Code (NESC) is a set of rules to safeguard people during the installation, operation, or maintenance of electric power lines. The NESC contains the basic provisions considered necessary for the safety of employees and the public. Although it is not intended as a design specification, its provisions establish minimum design requirements. PPL Electric has developed design specifications and safety rules which meet or surpass all provisions specified by the NESC.

Engineering Design Criteria and Parameters

The NESC includes loading requirements and clearances for the design, construction, and operation of power lines. The "loads" on conductors and supporting structures are the mechanical forces that develop from the weight of the conductors, the weight of ice on the conductors, plus wind pressure on the conductors and supporting structures. Loading requirements are the loads on the conductors and structures that are anticipated assuming certain ice and wind conditions. Loading requirements always contain "safety factors" to allow for unknown or unanticipated contingencies. The clearances and loading requirements contained in the NESC were developed to ensure public safety and welfare.

PPL Electric transmission line design standards meet or surpass the NESC standards. For example, the relative order of grades of construction for conductors and supporting structures is B, C, and N; Grade B being the highest. According to the NESC standards, construction Grades B, C, or N may be used for transmission lines (except at crossings of railroad tracks and limited access highways where Grade B construction is specified). However, PPL Electric designs all of its transmission lines for Grade B construction. The use of Grade B design and construction specifies such things as larger-minimum cross arm dimensions, larger-minimum conductor size, and increased safety factors.

Another example is the design parameters utilized to account for ice and wind loadings on the overhead ground wire (OHGW) and power conductors. The NESC standard ice and wind design magnitudes for the PPL Electric territory are 0.5 inch thickness of radial ice combined with four pounds per square foot horizontal wind pressure (equivalent to 40-mile per hour wind velocity). The conductor sags and tensions used in line designs are the result of various ice and wind combinations, depending on the elevation at the line location and line design voltage. The conductor sags and tensions used in the design of all PPL Electric transmission lines are at least 0.5-inch ice combined with eight pounds wind pressure (equivalent to 57 miles per hour wind velocity). This means that PPL Electric lines are designed to operate safely and reliably during inclement weather even more severe than assumed by the NESC. In addition, PPL Electric transmission lines are designed with more clearance to the ground than required by the NESC. The tables below compare PPL Electric and NESC ground clearances for lines of various voltages.

138 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	21 Ft.	30 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	21 Ft.	30 Ft.
Spaces accessible to pedestrians only	17 Ft.	30 Ft.
Railroad tracks	31 Ft.	35 Ft.

230 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	23 Ft.	32 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	23 Ft.	32 Ft.
Spaces accessible to pedestrians only	19 Ft.	32 Ft.
Railroad tracks	31 Ft.	36 Ft.

500 kV

<u>Surface Underneath Conductors</u>	<u>Vertical Clearance to Ground</u>	
	<u>NESC Standard</u>	<u>PPL Electric Design</u>
Roads, streets, alleys	28 Ft.	53 Ft.
Other land traversed by vehicles (such as cultivated field, forest, etc.)	28 Ft.	53 Ft.
Spaces accessible to pedestrians only	24 Ft.	53 Ft.
Railroad tracks	38 Ft.	53 Ft.

A relay protection system is used to protect the public safety and welfare as well as equipment and the transmission system. Relay protection is installed for all transmission lines to automatically de-energize the line in the unlikely event that the line or supporting structure fails and the line contacts the ground.

Periodic Maintenance Program on All Transmission Lines

To ensure continued public safety and integrity of service, a periodic maintenance and inspection program is implemented for every transmission line. The program is administered through the use

of helicopter patrols, with supplemental foot and structure climbing patrols. Numerous helicopter patrols are performed on all lines annually. The two-man helicopter crew flies parallel, to the left, and above the line so that the observer can look for signs of line damage or deterioration and observe clearances between vegetation and conductors. The observations are included in a report that is forwarded to the appropriate department for corrective action.

Foot and structure climbing patrol programs for a transmission line begin approximately three to five years after the line is energized, unless a helicopter patrol reports a need for earlier action. The frequency of foot patrols varies from once every year to once every several years depending on line type and age.

An assigned foot patroller checks right-of-way conditions, including access roads, bridges, pole washouts, tower footers, vegetation height and clearance to conductors, pole and tower deterioration and, with the use of binoculars, insulators, and condition of hardware. Identified problems are included in a report that is forwarded to the appropriate department for corrective action.

A scheduled line outage is required to perform an overhead patrol because of "hands-on" inspection of hardware. Overhead patrols are conducted on a schedule determined by line age, operating record, and observed general condition. The necessary repairs are also done during the inspection outage.

Personnel Safety Rules

The following are a few of the PPL Electric safety rules that demonstrate the Company's concern for employee safety:

- Work procedures have been developed to allow work to be performed on energized facilities in a safe manner. When lines or apparatus are removed from service to be worked on, the Energy Control Process system is applied. This system provides that a red tag must be physically placed on the control handle of the de-energized equipment. The red tag may be removed only after proper authorization to energize the equipment. Various other tags are used for limited operations and informational purposes. Employees will not apply or remove a tag or change the status of tagged equipment unless authorized.

- Temporary safety grounds are used on de-energized facilities for employee safety during maintenance, construction, or reconstruction work. Safety grounds are wires connecting the de-energized facility to an electrical ground. If the facility should be energized, the safety grounds will divert the current directly to ground and reduce the likelihood of personal injury. The conductor size and attachment clamps of temporary safety grounds must be capable of conducting anticipated fault currents. Rubber gloves, rubber sleeves, and additional rubber protective equipment are used as required when applying or removing temporary safety grounds to or from the lines or apparatus to be grounded. An approved nonconductive working stick of sufficient length to allow workers to maintain the following required minimum clearances is used to test that the line has been de-energized and to apply temporary safety grounds:

<u>Voltage-kV</u>	<u>Minimum Clearance</u>
138	3'-7"
230	5'-3"
500	11'-3"

Before applying grounds, a test is done to confirm that the line is de-energized. The voltage test device is checked before and after use to assure reliability. When ground pins are used to establish proper ground points, they are driven to a depth of not less than four feet as near vertical as possible.

- Poles or structures are inspected and examined for structural integrity before climbing. If there is any reason to believe that a pole is unsafe, it is stabilized before work is performed. Appropriate safety gear in the form of body belts, safety straps, hard hats, gloves, etc., is worn by linemen during line work activity.

Attachment

5



**MAGNETIC
FIELD
MANAGEMENT**
**PPL Electric Utilities
Corporation**

DECEMBER 2004

TABLE OF CONTENTS

INTRODUCTION	1
DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	6
VARIABLES THAT AFFECT MAGNETIC FIELDS	6
Effect of Phase Current on Magnetic Fields	6
Effect of Conductor Configuration on Magnetic Fields	7
Effect of Distance from the Magnetic Field Source	7
SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM.....	8
MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES	9
Overhead Lines	9
New or Rebuilt Transmission Lines	9
Reconductoring or Adding Additional Circuits to Existing Transmission Lines	14
Distribution Lines	14
Underground Transmission Lines.....	15
CHARTS.....	16

INTRODUCTION

At PPL Electric Utilities Corp. (PPL EU), magnetic field management means investigating and implementing methods at low or no cost to reduce magnetic fields in new or rebuilt transmission and distribution lines. This document explains PPL EU's Magnetic Field Management Program, which is part of PPL EU's larger Electric and Magnetic Fields (EMF) policy.

PPL EU's View

Some people are worried that electric and magnetic fields are harming their health. Others think the scientific research does not show a problem at all, and still others believe there's just too much scientific uncertainty to draw any conclusions.

Here's what we do know now. Various panels of scientists that have reviewed the EMF research generally have drawn two main conclusions. First, the large body of evidence does not demonstrate that EMF are harmful. Second, additional research is recommended to explore questions raised in some studies.

Given these conclusions, PPL EU is taking a reasoned approach in responding to the EMF issue. PPL EU's approach to the EMF issue consists of five elements:

- Providing EMF information to customers and employees
- Providing magnetic field measurements
- Establishing and implementing a magnetic field management program to reduce magnetic fields in new or rebuilt facilities when it can be done at no, or low, cost
- Integrating EMF in the public involvement process that PPL EU undertakes in the siting of transmission lines
- Have supported additional research

EMF Are All Around Us

Electric and magnetic fields occur in nature and in all living things. The earth, for instance, has a magnetic field, which makes the needle on a compass point north.

Electric fields and magnetic fields of a different type also surround every wire that carries electricity. In everyday life, these EMF arise from several basic sources, including power lines, electrical appliances, home and building wiring, other utility lines and cables, and currents flowing on water pipes. Though they often occur together, EMF are made up of two separate components:

Electric Fields

Electric fields are produced by the voltage—or electrical pressure—on a wire. The higher the voltage, the higher the electric field. As long as a wire is energized—has voltage present—an electric field is present (see Figure 1). In other words, an appliance, or an electric power line, doesn't actually have to be turned on to create an electric field. It just has to be plugged in. Electric fields diminish with distance and can be blocked or partially shielded by objects such as trees and houses.

Magnetic Fields

Magnetic fields are created by the current or flow of electricity through a wire. Generally speaking, the higher the current, the higher the magnetic field. Because they only occur when current is flowing, magnetic fields are present only when the power is turned on (see Figure 1). Magnetic fields also diminish with distance, but—unlike electric fields—are not blocked by common objects. In recent years, public and scientific interest has turned toward the magnetic field component of EMF because of some scientific studies regarding these fields.

Figure 1




Figure 2









Magnetic field strengths decrease with distance Magnetic fields are measured in milligauss		Source: "EMF In Your Environment", U.S. Environmental Protection Agency 1992		
		At 6 inches	At 1 foot	At 2 feet
Clothes dryer		2 to 10	* to 3	*
Microwave oven		100 to 300	1 to 200	1 to 30
Toaster		5 to 20	* to 7	*
Power drill		100 to 200	20 to 40	3 to 6
Can opener		500 to 1500	40 to 300	3 to 30
Mixer		30 to 600	5 to 100	* to 10
Hair dryer		1 to 700	* to 70	* to 10
Color television		Data not available	* to 20	* to 8

FIGURE 2 * The magnetic field measurement at this distance from the operating appliance could not be distinguished from background measurements taken before the appliance had been turned on.

Measuring Magnetic Fields

Magnetic fields usually are measured in a unit called a milligauss. Magnetic field levels found in the living areas of homes typically range from less than 1 milligauss to about 4 milligauss according to the U.S. Environmental Protection Agency. They can be higher in some cases. The levels next to appliances can exceed 1,000 milligauss (1 gauss). Figures 2 and 3 show how the strength of the field falls off as you move away from the source, just as the heat of a campfire grows weaker as you walk away from it. For overhead power lines, the strength of the magnetic fields is dependent upon a number of factors that will be explained later. Those factors produce a magnetic field that drops off rapidly as you move away from the power line.

Figure 3

Sample Magnetic Field Levels in Milligauss				
Type of Overhead Power Line	Distance from the line			
	Under the line	50 ft.	100 ft.	200 ft.
220 kV and 500 kV	5-400	5-250	1-75	0.5-20
69 kV and 138 kV	3-80	0.5-2.5	0.1-10	0.1-3
12 kV and below	0.4-20	0.1-1	-	-

The magnetic field values provided in this table represent a general range of values associated with the types of overhead power lines listed and are provided for illustration. There will be circumstances in which there will be magnetic field levels above or below the range of values provided due to variations in such factors as height of the wires, current flow and so on.

DEVELOPMENT OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

One element of our response to EMF concerns expressed by some of our customers is PPL EU's Magnetic Field Management Program. The program was initiated in March 1991 because PPL EU believes it makes good sense, as a matter of policy, to respond to the concerns expressed by some of our customers and to reduce magnetic fields in new and rebuilt facilities where it can be done with either no-cost or low-cost design changes.

This document updates the original program which has been revised several times since 1991. These guidelines were developed by PPL EU's EMF Working Group.

VARIABLES THAT AFFECT MAGNETIC FIELDS

Magnetic fields from transmission and distribution lines are a function of a number of design variables. The following parameters affect the magnetic field levels produced by transmission and distribution lines:

- Current
- Height of conductors above ground
- Configuration of conductors
- Distance from the line

EFFECT OF PHASE CURRENT ON MAGNETIC FIELDS

At power frequencies (i.e., 60 hertz), the magnetic field level is a function of the current or flow of electricity through a wire. Keeping all other parameters the same, the magnetic field is proportional to the current. Hence, if the current increases by 25 percent, the resulting magnetic field level will increase by 25 percent.

The overall load current on any line varies with the demand for power. It's usually highest during daytime hours and lowest at night. There also are weekly, monthly, seasonal and yearly variations.

The difference in the currents between each phase in a multiphase line also can affect the magnetic field. This difference is called phase unbalance. For a constant load, a statistical analysis of this phase unbalance can be made to determine its effect on the magnetic field. Close to the line, there is very little effect. However, the phase unbalance slows the rate at which the magnetic field decreases with distance from the line.

EFFECT OF CONDUCTOR CONFIGURATION ON MAGNETIC FIELDS

In the transmission and distribution of power, utilities like PPL EU presently use both three-phase and single-phase lines. Each phase on a three-phase power line has either a single conductor or a bundle of two or more conductors. In a three-phase system, the ground-level magnetic field is a result of the fields produced by the currents in each of the phases. Placing the three phases as close together as possible (compaction) creates some field cancellation, and the ground-level magnetic field is reduced. However, appropriate phase separation is required for the reliable operation of the line. In addition, the arrangement of the phases can create some; field cancellation and reduction of the ground-level magnetic field.

EFFECT OF DISTANCE FROM THE MAGNETIC FIELD SOURCE

Magnetic field strength diminishes with the vertical and lateral distances from the magnetic field source. Increasing the height of the conductors above ground is useful for magnetic field reduction at ground level, but may result in increased structure costs and increased aesthetic impact of the structures. Another possible method of increasing the distance to the magnetic field source is to increase the right-of-way requirements. By keeping buildings off increased rights of way, thereby requiring the public to live and work further away from lines, exposure to magnetic fields produced by the lines can be reduced. Increases in right of way are not always practical and may increase costs significantly, however.

SUMMARY OF PPL EU's MAGNETIC FIELD MANAGEMENT PROGRAM

Under its Magnetic Field Management Program, PPL EU has changed the way it builds and rebuilds some of its transmission and distribution lines. These design changes reduce magnetic field levels (assuming balanced circuit loadings and phase currents) by up to 69 percent in most of the company's new transmission lines. These guidelines now are being applied to new and reconstructed transmission facilities, based on this program.

The distribution component of the program focuses on 12 kV lines, the company's standard distribution voltage. It concentrates on the three-phase, primary 12 kV lines, since these are the most heavily loaded facilities and often are located in densely populated areas. The guidelines in this program are being applied to these three-phase, primary 12 kV lines.

A maximum 3-5 percent change in estimated cost was used as the limit for the guidelines since this value is consistent with low cost, is within estimating accuracy and is likely to have little impact on overall line costs.

The magnetic field calculations used in this document for the design of PPL EU's overall magnetic field management plan assume balanced load conditions among the phases and a fixed level of current, not necessarily representative of specific transmission or distribution lines. These levels were calculated using the Electric Power Research Institute's ENVIRO computer program. Under actual operating conditions, the magnetic field levels that result may vary due to such things as actual load per circuit, overall current on each phase conductor and the electrical configuration and operation of each line.

MAGNETIC FIELD MANAGEMENT PROGRAM GUIDELINES

The guidelines for magnetic field management are noted below, with discussion points for each.

OVERHEAD LINES

NEW OR REBUILT TRANSMISSION LINES

1. **Balance transmission circuit loads and phase currents as much as possible.**
 - PPL EU should continue to make every effort to balance loadings between the two circuits of a double circuit line when planning new or rebuilt facilities to maximize the effects of reverse phasing.
 - PPL EU should continue the practice of balancing single-phase loads across the three phases of the distribution system. (Unbalanced phase currents on the distribution system are reflected through to the transmission system.)
 - Unbalanced phase currents result in higher magnetic fields that do not drop off as quickly with distance as do the fields resulting from balanced phase currents.
 - For a 5 percent phase current unbalance, the magnetic field 50 feet from the centerline of a single circuit 138 kV line could be more than twice the value than if the same line had balanced phase circuits.
 - Balanced phase currents on each three-phase distribution circuit also reduce magnetic fields from the distribution circuits themselves. In addition, they reduce magnetic fields on the transmission system from which the distribution system circuits are supplied and connected through substations.
 - Apart from magnetic field considerations, balanced phase currents on each three-phase distribution circuit also reduce line losses and improve the system voltage.

2. Continue with the present practice of using long-span construction as the PPL EU 138/69 kV standard

- Structure designs for short-span and long-span construction are illustrated on Charts I and II, respectively.
 - Short-span design does not significantly reduce magnetic fields when compared to long-span design even though it is more compact than long-span design. Comparison of the magnetic field values from Chart III indicates essentially the same values. Therefore, short-span design should not be used solely to reduce magnetic fields.
 - PPL EU will continue to use long-span construction for 138/69 kV double-circuit lines and for single-circuit/future-double-circuit lines.
 - For single-circuit/future-double-circuit lines, PPL EU will continue to install two conductors on the top positions and one in the middle position as shown in Chart IV.
 - This arrangement minimizes magnetic fields as shown in Chart V by placing the three initial conductors higher on the structure, which increases the ground clearances, and by placing the conductors in a triangular configuration.

3. Compact design structures are not a low-cost alternative and should be used for magnetic field reduction only in special applications.

Chart VI illustrates the compact design structure.

- The compact design increases the initial installation costs by 79 percent when compared to the long-span design but reduces the magnetic field from 9 mG to 3 mG (about 67 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.

4. Reverse phase new or rebuilt double-circuit transmission lines for all voltage levels.

- Reverse phasing was adopted by PPL EU in March 1991 for double-circuit 138/69 kV transmission lines and in April 1992 for all other double circuit transmission lines. Reverse phasing is shown in Chart VII. Reverse phasing will reduce the magnetic fields when the current flow on both circuits is in the same

direction. Calculated values contained here are based on balanced and equal phase currents on both circuits.

- Reverse phasing reduces the magnetic field of a double circuit 138 kV single pole transmission line from 29 mG to 9 mG (about 69 percent) at the edge of the 100-foot-wide right of way as shown on Chart III.
- Reverse phasing reduces the magnetic field of a double circuit 230 kV single pole transmission line from 49 mG to 16 mG (about 67 percent) at the edge of the 150-foot-wide right of way as shown on Chart VIII.
- Reverse phasing reduces the magnetic field of a double-circuit 500 kV single pole transmission line from 37 mG to 21 mG (about 43 percent) at the edge of the 200-foot-wide right of way as shown on Chart IX.
- When new or rebuilt double-circuit lines require tapping existing double-circuit lines, PPL EU will review the existing lines to determine if reverse phasing can be provided at low cost.
- Computer modeling is required to develop the optimum phasing and overall conductor arrangements for lines added to, or rebuilt in, multiple-line corridors.
 - Merely adding a reverse-phase double-circuit line to an existing transmission line corridor or reverse phasing a rebuilt line in the multiple-line corridor will not necessarily produce lower magnetic field levels at the edge of the corridor right of way.
 - The corridor must be computer modeled with all the lines, existing phase conductor locations and currents. Then, magnetic field calculations must be made varying the phase arrangements of the new or reconstructed line to determine the appropriate phasing arrangement.
 - Current flow direction on a line also must be considered. For example, a reverse-phased line should have the current flowing in the same direction on both circuits. If the current flow is in the opposite direction for one circuit, reverse phasing will not produce the lowest magnetic field and another phase arrangement that produces lower fields may need to be utilized.

5. Increase the minimum ground clearance for all new transmission lines.

138/69 kV Transmission Lines

- Increasing the minimum line design ground clearance from 25 feet to 30 feet may add up to about 5 percent to the installed cost of a new double-circuit single pole 138/69 kV line. For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. With long-span reverse-phase design, the magnetic field is reduced from 9 mG to 7 mG (about 22 percent) at the edge of a 100-foot-wide right of way as shown in Chart X.
 - In the actual design of transmission lines to include higher minimum ground clearances, there may be limited segments (such as highway crossings, severe slopes and transmission line crossing locations) where National Electrical Safety Code (NESC) minimum ground clearances may need to be used. The NESC minimum ground clearances are less than the increased ground clearance discussed previously.

230 kV Transmission Lines

- Increasing the minimum line design ground clearances from 27 feet to 32 feet may add up to about 5 percent to the cost of a single-circuit single-pole line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 30 mG to 28 mG (about 7 percent) at the edge of a 150-foot-wide right of way.
- Increasing clearances from 27 feet to 32 feet could theoretically add up to about 2.8 percent to the cost of a double-circuit single-pole line (current standard) and reduce the magnetic field of a reverse-phase line from 16 mG to 15 mG (about 6 percent) at the edge of a 150-foot-wide right of way. Chart XI is a summary of this data.
- Studies are required for each new 230 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such

studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced phase spacing (a "Delta" configuration on a single-circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

500 kV Transmission Lines

- Increasing ground clearances from 33 feet to 53 feet may add up to about 4.5 percent to the cost of a single-circuit "H-frame" line (current standard). For a given project, such cost may be substantially less, however. In fact, PPL EU frequently uses higher-than-minimum ground clearances due to such features as road crossings, line crossings and site-specific terrain. By increasing the clearances, the magnetic field is reduced from 42 mG to 35 mG (about 17 percent) at the edge of a 200-foot-wide right of way.
- Increasing ground clearances from 33 feet to 53 feet could theoretically add up to 2.8 percent to the cost of a double-circuit "H-frame" line (current standard) and reduces the magnetic field of a reverse-phase line from 21 mG to 16 mG (about 24 percent) at the edge of a 200-foot-wide right of way. Chart XII is a summary of this data.
- Studies are required for each new 500 kV line to determine optimum structure types, ground clearances, configurations and designs to reduce field levels. Such studies could include analysis of reduction measures such as additional minimum ground clearances, increasing conductor tensions, using reduced-phase spacing (a "Delta" configuration on a single circuit line), installing the second circuit initially, and/or adding a second set of conductors that are reverse phased and operated in parallel with the first set (bundled/split phase).

RECONDUCTORING OR ADDING ADDITIONAL CIRCUITS TO EXISTING TRANSMISSION LINES

When reconductoring or adding additional circuits to existing transmission lines, PPL EU will evaluate low-cost or no-cost options for magnetic field management on a case-by-case basis.

When reconductoring existing transmission lines or adding additional circuits, low-cost alternatives may not exist; however, the following steps will be taken:

- For a single-circuit line, the use of a Delta arrangement or other modifications on the existing structure, with reduced-phase spacing, will be evaluated.
- For double-circuit lines, application of reverse phasing may reduce the magnetic field under the line and within the right of way and will be evaluated.
- For single- and double-circuit lines, evaluate using higher conductor tensions that can increase the minimum line design ground clearance.

DISTRIBUTION LINES

At the 12 kV distribution level, new main three-phase lines will continue to be constructed with five feet of additional ground clearance.


- Main lines are the most heavily loaded sections of a distribution line and therefore have the highest magnetic fields associated with them.
- Increasing the ground clearance by five feet reduces the magnetic field under the line from 14 mG to 11 mG using the standard eight-foot crossarm design. These values are based on increasing pole heights from 45 feet to 50 feet and a typical operating current of 300 amps per phase.
- Chart XIII is a summary of this data. Increasing ground clearance by five feet could theoretically add about 5 percent to the cost of a typical distribution line.

UNDERGROUND TRANSMISSION LINES

Underground transmission lines are required due to environmental or land use factors or restrictions on available clearances, PPL EU will evaluate options for magnetic field management techniques on a case-by-case basis.


- The phase arrangement that produces the lowest field will be determined.
- The depth of burial of the line will be determined considering the cost of excavation and the location of other buried utilities in the area.
- The use of steel pipe ferromagnetic shielding that reduces magnetic fields will be evaluated.

Short-Span Construction



- More compact design
- Should not be used solely to reduce magnetic fields
- Typical conductor data:
 - 1 3/8" HS steel overhead ground wire - 7.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 10.0 feet sag
 - Average span - 400 feet

Long-Span Construction Remains PPL EU 138 kV Standard




- Lower cost alternative
- Reduces magnetic fields due to higher structures
- Typical conductor data:
 - 1 3/8" HS steel overhead ground wire - 17.3 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 23.0 feet sag
 - Average span - 600 feet

**138/69 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SHORT SPAN (CHART I)	30
SHORT SPAN (REVERSE PHASE)	8
LONG SPAN (CHART II)	29
LONG SPAN (REVERSE PHASE)	9
COMPACT (CHART VI)	14
COMPACT (REVERSE PHASE)	3

The edge of right of way is 50 feet from the line centerline.
 The 400 ampere phase current is balanced between phases.
 Calculations are based on a minimum ground clearance of 25 feet.
 LONG SPAN, SHORT SPAN and COMPACT are double-circuit lines.

Typical Single-Circuit Structure Designs




——— initial single circuit
- - - - - future second circuit

**138/69 kV SINGLE CIRCUIT TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
TOP/MIDDLE/BOTTOM	20
VERTICAL	17
TOP/MIDDLE	12


The edge of right of way is 50 feet from the line centerline.
 The 400 ampere phase current is balanced between phases.
 Calculations are based on a minimum ground clearance of 25 feet.

Compact Design Structure



- Minimize magnetic fields due to compact design
- Not a low-cost alternative
- Typical conductor data:
 - 1 3/8" HS steel overhead ground wire - 9.0 feet sag
 - 6-556.5 KCMIL 24/7 ACSR power conductors - (PARAKEET) 9.0 feet sag
 - Average span - 300 feet

Reverse Phasing of Double-Circuit Transmission Lines



From: $\longrightarrow \longrightarrow \longrightarrow \longrightarrow$ To:

Reverse phasing also can be one of the following phase arrangements:

A	B		B	A		B	C		C	A		C	B
C	C	or	C	C	or	A	A	or	B	B	or	A	A
B	A		A	B		C	B		A	C		B	C

**230 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	49
DOUBLE CIRCUIT POLE (REVERSE-PHASE)	16

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 27 feet.

**500 kV REVERSE-PHASE TRANSMISSION LINES
CALCULATED MAGNETIC FIELDS AT 1100 AMPERES**

TYPE CONSTRUCTION	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
DOUBLE CIRCUIT POLE	37
DOUBLE CIRCUIT POLE (REVERSE PHASE)	21

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.
Calculations are based on a minimum ground clearance of 33 feet.

**INCREASED 138/69 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 400 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	25	12
SINGLE CIRCUIT TOP/MIDDLE	30	10
LONG SPAN	25	29
LONG SPAN	30	26
LONG SPAN (REVERSE PHASE)	25	9
LONG SPAN (REVERSE PHASE)	30	7

The edge of right of way is 50 feet from the line centerline.
The 400 ampere phase current is balanced between phases.

**INCREASED 230 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 800 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT TOP/MIDDLE	27	30
SINGLE CIRCUIT TOP/MIDDLE	32	28
DOUBLE CIRCUIT POLE	27	49
DOUBLE CIRCUIT POLE	32	46
DOUBLE CIRCUIT POLE (REVERSE PHASE)	27	16
DOUBLE CIRCUIT POLE (REVERSE PHASE)	32	15

The edge of right of way is 75 feet from the line centerline.
The 800 ampere phase current is balanced between phases.

**INCREASED 500 kV MINIMUM GROUND CLEARANCE
CALCULATED MAGNETIC FIELDS AT 1,100 AMPERES**

TYPE CONSTRUCTION	MINIMUM GROUND CLEARANCE FEET	MAGNETIC FIELD IN MILLIGAUSS AT THE EDGE OF THE RIGHT OF WAY
SINGLE CIRCUIT "H" STRUCTURE	33	42
SINGLE CIRCUIT "H" STRUCTURE	53	35
DOUBLE CIRCUIT POLE	33	37
DOUBLE CIRCUIT POLE	53	31
DOUBLE CIRCUIT POLE (REVERSE PHASE)	33	21
DOUBLE CIRCUIT POLE (REVERSE PHASE)	53	16

The edge of right of way is 100 feet from the line centerline.
The 1,100 ampere phase current is balanced between phases.

**12 KV DISTRIBUTION LINES
CALCULATED MAGNETIC FIELDS AT 300 AMPERES**

TYPE CONSTRUCTION	POLE HEIGHT FEET	MAGNETIC FIELD IN MILLIGAUSS*	
		AT CENTERLINE	AT 30 FEET FROM CENTERLINE
STANDARD CROSSARM	45	14	7
STANDARD CROSSARM	50	11	6

* Field level under the line at mid-span based on 300 amps, balanced loading, one meter above ground level.

Attachment

6

ATTACHMENT "6"

FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE

**LIST OF INVOLVED GOVERNMENTAL AGENCIES, MUNICIPALITIES AND
OTHER PUBLIC ENTITIES**

Pennsylvania Historical and Museum Commission
Bureau for Historic Preservation
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120
Attn: Mr. Douglas C. McLearn, Chief

Honorable Barry Schoch, P.E., Secretary
Pennsylvania Department of Transportation
c/o Office of Chief Counsel
Commonwealth Keystone Building
400 North Street, 9th Floor
Harrisburg, PA 17120
Attn: Andrew Gordon

Department of Environmental Protection
P. O. Box 2063
Market Street Office Building
Harrisburg, Pennsylvania 17105-2063
Attn: Office of Field Operations

Lehigh County Commissioners
17 S. Seventh Street
Allentown, PA 18101
Attn: Mr. Dean N. Browning, Chairman

Lehigh Valley Planning Commission
961 Marcon Boulevard, Suite 310
Allentown, PA 18103
Attn: Steven L. Glickman, Chairman

Salisbury Township Board of Commissioners
2900 South Pike Avenue
Allentown, PA 18103
Attn: James Brown, President

Salisbury Township Planning Board
2900 South Pike Avenue
Allentown, PA 18103
Attn: Charles Beck, Chairperson

Attachment

7

ATTACHMENT "7"
FOUNTAIN HILL #1 & #2 138/69 kV TAP LINE
LIST OF OWNERS OF PROPERTY WITHIN THE RIGHT OF WAY

County of Lehigh
17 S. Seventh Street
Allentown, PA 18101