



Duquesne Light

Our Energy...Your Power

Legal Department
411 Seventh Avenue, 16-1
Pittsburgh, PA 15219

Tel 412-393-6851
Fax 412-393-1418
jallison@duqlight.com

Jennifer L. Allison
Attorney

March 15, 2012

Via U.S. Mail

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

RE: Maria Gonda Caiaccia v. Duquesne Light Company,
Docket No. F-2011-2263256

RECEIVED
2012 MAR 19 AM 11:30
PACUBU
SECRETARY'S BUREAU

Dear Secretary Chiavetta:

In accordance with Administrative Law Judge Mary D. Long's Interim Order Requiring Supplementation of the Record, the parties in the above-referenced matter have cooperated in scheduling and performing a meter inspection at Complainant's residence. The inspection occurred on March 12, 2012. It included a meter test, grounds check, foreign load check, and a survey and analysis of the appliances on the premise.

The Meter Inspection Report is enclosed. It has been labeled Respondent's Exhibit 6, and it is supported by the Affidavit of Richard Lachimia, a Senior Engineer at Duquesne Light who was present for the meter inspection.

Sincerely,

Jennifer L. Allison
Duquesne Light Company

encs

cc: Administrative Law Judge Mary D. Long (w/enclosures)
Maria Gonda Caiaccia (w/enclosures)

ACCOUNT NUMBER 000120795000 TYPE SMI BC PREPARED DATE 03/05/12 STATUS ACTIVE SERV DISC F
SERV NAME / USING ADDRESS CAIACCIA MAILING ADDRESS PRES ACCT NEW NAME AND MAIL ADDRESS

00703 BERKSHIRE AVE PO BOX 6 SEWICKLEY PA 15143-0006 GEO CODE GEO LOCATION

PITTSBURGH PA 15226 15143-0006 726 EDGE BROOK
RDG DATE RC READING DEM RDG RC KVAR RDG COMPT BY TIME MTR NUMBER MULT
3.12.12 9048 STACK

Table with columns: RC, DATE, DAYS, READING, USAGE, KW, DEM, AMOUNT, AVR/DAY, RDG, SEQ, METER LOC. Rows include dates from 02/13/12 to 12/13/10 and various meter readings and locations like OS-FRONT, MD SEALED, etc.

DIVISION DIST SOUTHERN CURRENT BAL 00000000206.07 RATE RIDER CHG RATE TO
METER RDG DIRECTIONS SPECIAL INST 010 000
METER NO G60165188 SMI CMPLNT-HI BILL PUC O
RDER

Appmt Monday 3/12/12
8:00 AM
DIRECTIONS

RECEIVED

MAR 19 2012

PREMISE NO 2000230388 DIRECT MEMO TO PH NO 000 000 0000
FIELD INQUIRY

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU


FIELD RESOLUTION G 60165188 DIAL = 9048
09629106 FRT = 9098

NOTES CONTACT PH 412 393 8713

PERSON CALLING BACKDATED INFORMATION
M&T NEW CUSTOMER
INITIAL CONTACT..... HOME PHONE
CUST ADVISED OF CHAP 56 WORK PHONE
OTHER ACTION PEND..... NEW ACCT NO
PROP\OWNER REAL EST PYMTS MADE BY.....
P. O. PH NO PYMTS MADE AFTER CANC..

TOU METER
ACTUAL RDG
MECH DIAL RDG
DISPLAY
DAY OF WEEK
JULIAN DATE
TIME OF DAY
TOTAL KWHS
ON PEAK DEM
OFF PEAK DEM
ACT TIME RDG

10sec



0001207950001

***** 15-03 PREMISE DATA *****

POTENTIAL LOAD FROM '600' HEAT LOAD TO 6000 WATT KW

TYPE HEAT 4 SPACE HEATERS HEAT PUMP SIZE _____ TONS
 TYPE AC 3 WINDOW UNITS AC SIZE _____ TONS

RANGE (ELECT) _____ KW DISHWASHER _____
 REFRIGERATOR _____ CU FT _____ HOT TUB _____
 _____ FREEZER _____ CU FT _____ DEHUMIDIFIER _____
 _____ DRYER (ELECT) _____ KW _____ TYPE OF LIGHT _____
 _____ ELEC WATER TANK _____ GAL _____ SODIUM _____ MERCURY VAPOR _____ INCANDESCENT
 _____ FURNACE MOTOR _____ HP _____ MISC COMMENT _____
 _____ WATER BED HEATER _____ WATTS _____
 SPACE HEATER 1500 EACH WATTS _____
 WASHER _____
 TELEVISION 1 SETS _____ NUMBER IN HOUSEHOLD _____
 _____ ELEC POOL HEATER _____ BTU 6 ROOMS _____
 _____ SWIM POOL FILTER _____ HP 1 ADULTS _____
 _____ GUTTER CABLES _____ FT _____ TEENS _____
 _____ ELEC AIR CLEANER _____ CHILDREN _____

NEW APPLIANCES ADDED _____

TERMOSTAT SETTING
 FURNACE DAY _____
 FURNACE NIGHT _____
 AIR CONDITIONING _____

FOREIGN WIRING No
 WATTAGE _____
 REMARKS NONE FOUND AT THIS TIME.

***** METER EXCHANGE INFORMATION *****

METER INSTALLED _____ KWH RDG _____ RC _____ DEM RDG _____ RC _____ KVAR RDG _____ RC _____ CT RATIO _____ PT RATIO _____ AT RATIO _____

SERVICE VOLTAGE _____ METER LOCATION _____

***** REASON FOR EXCHANGE *****

PERIODIC TEST _____ REWIRE _____ DAMAGED _____ SAMPLE TEST _____ PLAIN TO DEM _____
 OBSOLETE _____ DEFECTIVE _____ FIRE _____ CHANGE MULT _____ IDLE / RZ BLDG _____

REMARKS / FURTHER ACTION BASED ON THE RESULTS OF THE NAV TEST, THE METER IS ACCURATE. BASED ON THE RESULTS OF OUR APPLIANCE APPRAISAL, WE FOUND NO OTHER WAY TO HEAT THE HOUSE OTHER THAN THE 4 ELECTRIC SPACE HEATERS.

GAS METER REMOVED PRIOR. GAS FURNACE NOT FUNCTIONAL.

GROUND TO CIRCUIT YES _____ NO WATTAGE _____ DISCONNECTED YES _____ NO _____ CLEARED YES _____ NO _____ DISCUSSED WITH CUSTOMER YES NO _____ CUSTOMER SATISFIED YES NO _____

CUSTOMER SIGNATURE [Signature] (CUSTOMER)

REGISTERING CORRECTLY YES NO _____ IRREGULARITY YES _____ NO _____ UNMETERED YES _____ NO _____ ESTIMATE YES _____ NO _____ REBILL YES _____ NO _____ RECHECK YES _____ NO _____

LCWR / NO FURTHER CO. ACTION _____ YES _____ NO _____ SEAL NO. AS LEFT.. E-0882086
 LOCKED AS FOUND _____ YES _____ NO _____ SEAL COLOR _____
 LOCKING DEVICE INSTALLED _____ SEAL AS FOUND D808639
 MD - NS (M-S) (M-S) M - NS

METER WAS INSPECTED AND/OR TESTED AT INSTALLATION (30 DAY PUC REGULATION) YES NO _____ DATE 3.12.12

TOU METER INSTALLED

ACTUAL RDG 9048
 MECH DIAL RDG 9048
 DISPLAY _____
 DAY OF WEEK MONDAY
 JULIAN DATE 3.12.12
 TIME OF DAY 8:00 AM
 TOTAL KWHS _____
 ON PEAK DEM _____
 OFF PEAK DEM _____
 ACT TIME RDG _____

METER DID NOT CREEP.

METER TEST RESULTS

FULL LOAD _____ 99.9
 LIGHT LOAD _____ 99.3
 LOAD AT INSP TIME .. 2592 WATTS
 POWER FACTOR _____
 STANDARD NO. 00023A

- READING CODES
- A. RDG AT METER INSTALLATION
 - B. RDG AT METER EXCHANGE
 - C. MANUALLY SET RDG
 - J. NORMAL RDG
 - K. VERIFIED RDG
 - M. MANUALLY READ HEX
 - S. CUSTOMER CARD RDG
 - T. CUSTOMER CALLED RDG
 - W. CONSUMER SERVICE REP
 - X. CONSUMER SERVICE ORDERMAN

Before the
PENNSYLVANIA PUBLIC UTILITY COMMISSION

RECEIVED

MAR 19 2012

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

MARIA GONDA CAIACCIA,)
)
 Complainant,)
)
 v.)
)
 DUQUESNE LIGHT COMPANY,)
)
 Respondent)

Docket No. F-2011-2263256

AFFIDAVIT OF RICHARD LACHIMIA

Now comes Richard Lachimia, being duly sworn and cautioned pursuant to law, deposes and states the following:

I am adult individual and have direct knowledge of the statements set forth below.

I am currently employed by Duquesne Light Company and my job title is Senior Engineer.

I make this Affidavit in support of Respondent's Exhibit 6.


This Affidavit outlines the most recent efforts undertaken by Respondent to inspect Complainant's meter.


I was present for a meter inspection conducted on March 12, 2012 for Meter Number G60165188, located at Complainant's residence.

The results of the aforementioned meter inspection were recorded in the report labeled Respondent's Exhibit 6.


I have reviewed Respondent's Exhibit 6, and I affirm that the information contained therein is accurate. The meter tested at 99.9% at full load and at 99.3% at light load. The meter also passed a no load creep test. The investigation did not reveal any grounds to circuit or any foreign wiring. A survey of the premise revealed the potential load attributable to heating to be between 600 and 6,000 watts, or approximately 432 to 4320 kilowatt hours of energy consumption per month, depending on usage of electric space heaters. This potential load calculation only applies to months when space heaters are in use, and it does not include load attributable to other appliances.

Further affiant sayeth naught.




Richard Lachimia

Sworn to and subscribed before
me this 14TH day of March, 2012



RECEIVED
2012 MAR 19 AM 11:30
P.A.L.U.C.
SECRETARY'S BUREAU

2012 MAR 19 AM 11:30

U.S.
SECRETARY'S BUREAU



Legal Department
411 Seventh Avenue, 16-1
Pittsburgh, PA 15219

Return Service Requested

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

 **Duquesne Light**