

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Re: Application Of PPL Electric Utilities :
Corporation Filed Pursuant To 52 Pa. Code :
Chapter 57, Subchapter G, For Approval Of : Docket No. A-2012-_____**
**The Siting And Construction Of The :
Blooming Grove – Jackson and Peckville – :
Jackson 138/69 kV Transmission Line In :
Monroe County, Pennsylvania :**

NOTICE OF FILING

The above-captioned Application will be filed with the Pennsylvania Public Utility Commission (“Commission”) on May 14, 2012. PPL Electric Utilities Corporation (“PPL Electric”) is seeking Commission approval to site and construct a new 3.8 mile long double-circuit transmission line located in Jackson and Pocono Townships, Monroe County in order to reduce the electrical load on the existing Blooming Grove – Jackson 138/69 kV circuit (“the Project”).

PPL Electric proposes to reduce the electrical load on the existing Blooming Grove – Jackson 138/69 kV circuit and provide operating flexibility and improved reliability for customers in Jackson, Pocono, and Tobyhanna Townships in Monroe County. In its current configuration, the transmission and distribution systems in the area violate the reliability guidelines established in PPL Electric’s Reliability Principles and Practices (“RP&P”). To resolve the identified RP&P violations, PPL Electric, with approval from the Commission, plans to construct a new double-circuit 138/69 kV line from the 138-69 kV Jackson Substation (“Jackson Substation”), north to the Lake Naomi Tap pole, a distance of approximately 3.8 miles. PPL Electric will design the new line to current 138 kV standards, but operate the line at 69 kV initially. In addition, in the Jackson Substation 69 kV Yard, PPL Electric will install a new line terminal, breaker bay, and circuit breaker.

The proposed Line will begin at PPL Electric's Jackson Substation in Jackson Township, Monroe County and will extend north to the Lake Naomi Tap pole in Pocono Township, Monroe County. The preferred route for the new double-circuit line will travel, in general, along the edge of the existing right-of-way of the existing double-circuit Blooming Grove - Jackson and Peckville - Jackson 138/69 kV Transmission Line through Jackson and Pocono Townships in Monroe County. The existing line will be renamed the Jackson-Wagners #1 & #2 138/69 kV Line as a result of this Project.


A complete copy of the above-captioned Application, including all Attachments, is available for public inspection weekdays during normal business hours at the following locations:

Jackson Township Board of Supervisors
2162 Route 715
PO Box 213
Reeders, Pennsylvania 18352

Pocono Township Municipal Building
112 Township Road
Tannersville, PA 18372

Pursuant to the Commission's Siting Regulations, 52 Pa. Code §§ 57.71 *et seq.*, we have enclosed a map showing the Route of the Project across your property. You are not required to appear or participate in this matter, but you may request Commission permission to intervene.

Sincerely,



David B. MacGregor (ID # 28804)
Post & Schell, P.C.
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, PA 19103-2808
Phone: 215-587-1197
Fax: 215-320-4879
E-mail: dmacgregor@postschell.com

Paul E. Russell (ID # 21643)
Associate General Counsel
PPL Services Corporation
Office of General Counsel
Two North Ninth Street
Allentown, PA 18106
Phone: 610-774-4254
Fax: 610-774-6726
E-mail: perussell@pplweb.com

John H. Isom (ID # 16569)
Jessica R. Rogers (ID # 309842)
Post & Schell, P.C.
17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
Phone: 717-731-1970
Fax: 717-731-1985
E-mail: jisom@postschell.com
E-mail: jrogers@postschell.com

Of Counsel:

Post & Schell, P.C.

Date: May 15, 2012

Attorneys for PPL Electric Utilities Corporation