



17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
717-731-1970 Main
717-731-1985 Main Fax
www.postschell.com

Jessica R. Rogers

jrogers@postschell.com
717-612-6018 Direct
717-731-1985 Direct Fax
File #: 2507/140074

September 21, 2012

VIA E-MAIL & REGULAR MAIL

Honorable Susan D. Colwell
Administrative Law Judge
PA Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
PO Box 3265
Harrisburg, PA 17105

RE: Stefan Cohen v. PPL Electric Utilities Corporation; Docket No. C-2012-2276818

Dear Judge Colwell:

On August 27, 2012, PPL Electric Utilities Corporation ("PPL Electric") attended a telephonic hearing in the above-captioned proceeding. At that hearing, PPL Electric's witness Aaron Lynn agreed to undertake an investigation of the costs associated with providing the Complainant in the above-captioned matter with underground distribution service. PPL Electric has completed its investigation. The Exhibit, which was prepared under Mr. Lynn's supervision, provides a detailed estimate of the costs associated with providing underground service to Complainant's residence. The document is labeled as PPL Electric's Exhibit AL-9. PPL Electric requests that this Exhibit be included as part of the record associated with the above-captioned case.

As indicated on the certificate of service, copies have been served on the parties in the manner indicated.

Respectfully Submitted,

Jessica R. Rogers

JRR/jl

Enclosures

cc: Rosemary Chiavetta, Secretary (for filing)
Certificate of Service

ALLENTOWN HARRISBURG LANCASTER PHILADELPHIA PITTSBURGH PRINCETON WASHINGTON, D.C.

A PENNSYLVANIA PROFESSIONAL CORPORATION

10050933v1


CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing has been served upon the following persons, in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

VIA E-MAIL & FIRST CLASS MAIL

Stefan T. Cohen
388 Tamarack Drive
Allentown, PA 18104

Date: September 21, 2012



Jessica R. Rogers

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Stefan T. Cohen,	:	
	:	
Complainant,	:	
	:	
v.	:	Docket No. C-2011-2276818
	:	
PPL Electric Utilities Corporation,	:	
	:	
Respondent.	:	

PPL ELECTRIC EXHIBIT AL – 9

The cost estimate provided here is for installing underground electric service from the padmounted transformer across the street from 388 Tamarck Drive to that residence. The overall cost of installing underground electric service would be the same, if not more, if service was provided from the closest padmounted transformer on the same side of Tamarack Drive as the side on which Mr. Cohen resides. This project requires the following: 400 feet of boring, 400 feet of three inch flexible corrugated plastic pipe, 420 feet of service cable,¹ and a splice box. Additional costs associated with the project include traffic control, preparation of underground facilities, the labor associated with pulling cable and removing existing service, excavation and backfill, as well as engineering and overhead costs.

Line Item Description	Estimated Cost ²
Traffic Control	\$248.28
Boring	\$11,450.87
Service cable	\$2,696.68
Splice Box	\$417.71
Removal of existing facilities	\$1,100.00
Engineering and Overhead Expenses	\$2,586.46
Total	\$18,500

¹ Conductors used would be 350 kcmil phase conductors, 4/0 neutral. A circular mil is the cross-sectional area of a wire one mil in diameter, where 1 kcmil = 0.5067 mm².

² The estimated cost includes material and labor.