



CITIZENS' ELECTRIC COMPANY

1775 INDUSTRIAL BLVD • P.O. BOX 551 • LEWISBURG, PA 17837-0551 • (570) 524-2231 • FAX: (570) 524-5887

September 24, 2010

M-2009-2094773

RECEIVED

SEP 24 2010

**PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU**

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
PO Box 3265
Harrisburg, PA 17105-3265

Dear Ms. Chiavetta,

Enclosed please find an original and three copies of the Biennial Inspection, Maintenance, Repair and Replacement Plan for Citizens' Electric Company for the period January 1, 2012 – December 21, 2013.

Please contact me at 570-522-6143 or kelchnerj@citizenselectric.com if I can answer any questions.

Sincerely,

A handwritten signature in black ink that reads "John A. Kelchner". The signature is fluid and cursive, with a long horizontal stroke at the end.

John A. Kelchner, PE
Vice President, Engineering & Operations

cc: Darren Gill (via email)

**Biennial Inspection, Maintenance, Repair and Replacement Plan
of Citizens' Electric Company of Lewisburg, PA**

For the period of January 1, 2012 – December 31, 2013

RECEIVED

SEP 24 2010

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

Submitted by:
John A. Kelchner
Vice President, Engineering & Operations
PO Box 551
Lewisburg, PA 17837
(570) 524-2231
kelchnerj@citizenselectric.com

Dated: October 1, 2010

Contents

Introduction 3

§ 57.198(n)(1). Vegetation management..... 4

 Program Description..... 4

 Inspection Plan 4

 Justification..... 4

§ 57.198(n)(2). Pole inspections..... 5

 Program Description..... 5

 Inspection Plan 6

 Justification..... 6

§ 57.198(n)(3). Pole inspection failure. 7

 Corrective Maintenance 7

 Justification..... 7

§ 57.198(n)(4). Distribution overhead line inspections. 8

 Program Description..... 8

 Inspection Plan 8

 Justification..... 8

§ 57.198(n)(5). Inspection failure..... 9

 Corrective Maintenance 9

 Justification..... 9

§ 57.198(n)(6). Distribution transformer inspections. 10

 Program Description..... 10

 Inspection Plan 11

 Justification..... 11

§ 57.198(n)(7). Recloser inspections..... 12

 Program Description..... 12

 Inspection Plan 12

 Justification..... 12

§ 57.198(n)(8). Substation inspections..... 13

 Program Description..... 13

 Inspection Plan 13

 Justification..... 13

§ 57.198(n)(1). Vegetation management.

The statewide minimum inspection and treatment cycle for vegetation management is between 4-8 years for distribution facilities. An EDC shall submit a condition-based plan for vegetation management for its distribution system facilities explaining its treatment cycle.

Program Description

Citizens' Electric Company performs a comprehensive visual inspection of all overhead primary lines on an annual basis. During this inspection, the condition of vegetation is assessed, and treatment needs for the current year are quantified. The inspection also provides an opportunity to identify any off right-of-way "hazard" trees and work with affected property owners to secure removals.

Vegetation maintenance work is specified to achieve a four-year treatment cycle across all parts of the Company's service territory. However, flexibility is maintained to trim any high-priority "hot spots" identified during the annual inspection. Specific work requirements are identified in Company document "Distribution Vegetation Management Specification." Following tree-related service interruptions, affected areas are assessed to determine whether any out-of-cycle maintenance is required.

Inspection Plan

All primary circuits will be inspected each year.

Vegetation Inspection Distribution Circuit Name	Total Overhead Circuit Miles	Inspection Plan (Miles to be Inspected)	
		2012	2013
Bucknell	3.6	3.6	3.6
Linntown	5.3	5.3	5.3
St. Mary St.	6.3	6.3	6.3
Rt. 192	42.9	42.9	42.9
Rt. 45	62.5	62.5	62.5
Rt. 15	20.6	20.6	20.6
Buffalo Road	6.7	6.7	6.7
Moore	7.7	7.7	7.7
Eastern	5.6	5.6	5.6
Total	161.2	161.2	161.2

Justification

Vegetation management is performed in accordance with ANSI A300 and Z133 standards, utilizing generally accepted industry practices. The National Arbor Day Foundation has recognized Citizens' Electric as a "Tree Line USA" utility for the past 8 years. This plan complies with § 57.198(n)(1). No waiver is being requested.

§ 57.198(n)(2). Pole inspections.

Distribution poles shall be inspected at least as often as every 10–12 years except for the new southern yellow pine creosoted utility poles which shall be initially inspected within 25 years, then within 12 years annually after the initial inspection. Pole inspections must include:

- (i) Drill tests at and below ground level.*
- (ii) A shell test.*
- (iii) Visual inspection for holes or evidence of insect infestation.*
- (iv) Visual inspection for evidence of unauthorized backfilling or excavation near the pole.*
- (v) Visual inspection for signs of lightning strikes.*
- (vi) A load calculation.*

Program Description

Citizens' Electric Company conducts pole inspections on a ten year cycle. All poles in the cycle receive a visual inspection to identify conditions of deterioration or potential hazards. Poles are inspected for items including but not limited to:

- evidence of decay
- lightning damage
- insect infestation
- presence of vines or other vegetation
- unauthorized excavation
- missing guy guards
- damaged pole hardware
- broken ground wires

In addition to the visual inspection, all poles receive a sound and bore test to detect internal decay at or near the ground line. For poles older than 10 years, a ground line excavation is conducted to visually inspect the pole's condition just below the ground line. After excavation, an external treatment is applied to protect the pole from future deterioration at the ground line area.

When indicated by the inspection, poles are treated internally with insect and decay inhibitors to help extend remaining life. Based on data obtained during the inspections, remaining pole strength is calculated. Detailed inspection requirements are identified in Company document "*Wood Pole Inspection & Maintenance Program.*"

Inspection Plan

To maximize efficiency, pole inspections are scheduled by dividing the service territory into geographic grids. To the extent possible, an effort has been made to equalize the number of poles inspected each year. However, some quantity variation occurs on a year-to-year basis. On a system-wide basis, all poles are inspected every ten years. The total number of distribution poles in Citizens' Electric's system is 5,855.

Pole Inspection Map Section	Number of Poles to be Inspected	
	2012	2013
21852900	268	
21852800	223	
21752700	18	
21853000		176
21752800		251
21652800		150
Total	509	577

Justification

This plan complies with inspection intervals specified in § 57.198(n)(2) and with generally accepted industry practices. However, a waiver is being requested for § 57.198(n)(2)(vi) relating to pole load calculations.

In an effort to reduce inventory costs, Citizens' Electric Company has standardized on the purchase of class 3 poles for typical primary pole sizes. This results in a decreased number of inventory items, an increase in inventory turnover and a corresponding savings in carrying costs. It also results in poles having strength in excess of the minimum required by the NESC at the time of installation. Remaining strength is calculated as part of the pole inspection process, to ensure the pole is still capable of performing as required.

The Company is not aware of any pole failures on record. Through the comprehensive inspection and maintenance programs in place, deteriorated poles are detected and replaced prior to failure. The inclusion of pole loading calculations when performing pole inspections would result in a significant cost increase, with no corresponding improvement in reliability.

§ 57.198(n)(3). Pole inspection failure.

If a pole fails the groundline inspection and shows dangerous conditions that are an immediate risk to public or employee safety or conditions affecting the integrity of the circuit, the pole shall be replaced within 30 days of the date of inspection.

Corrective Maintenance

Poles which are found to be deficient during the inspection process are categorized as priority, reinforceable and regular reject. Priority poles are those which are identified as posing an imminent risk of failure. Priority poles are reported to the Company immediately when found. These poles are promptly replaced, typically within 7 days, in all cases within 30 days.

Justification

This plan complies with the requirements of § 57.198(n)(3). No waiver is being requested.

§ 57.198(n)(4). Distribution overhead line inspections.

Distribution lines shall be inspected by ground patrol a minimum of once every 1-2 years. A visual inspection must include checking for:

- (i) Broken insulators.
- (ii) Conditions that may adversely affect operation of the overhead transformer.
- (iii) Other conditions that may adversely affect operation of the overhead distribution line.

Program Description

Citizens' Electric Company performs a comprehensive visual inspection of all overhead primary lines on an annual basis. During this inspection, an assessment is made of the overall condition of equipment such as insulators, transformers, crossarms, and pole hardware. This inspection also provides an opportunity to check for other adverse conditions such as excavation near poles, easement encroachments, etc.

Inspection Plan

All primary circuits will be inspected each year.

Overhead Line Inspection Distribution Circuit Name	Total Overhead Circuit Miles	Inspection Plan (Miles to be Inspected)	
		2012	2013
Bucknell	3.6	3.6	3.6
Linntown	5.3	5.3	5.3
St. Mary St.	6.3	6.3	6.3
Rt. 192	42.9	42.9	42.9
Rt. 45	62.5	62.5	62.5
Rt. 15	20.6	20.6	20.6
Buffalo Road	6.7	6.7	6.7
Moore	7.7	7.7	7.7
Eastern	5.6	5.6	5.6
Total	161.2	161.2	161.2

Justification

This plan complies with the requirements of § 57.198(n)(4). No waiver is being requested.

§ 57.198(n)(5). Inspection failure.

If critical maintenance problems are found that affect the integrity of the circuits, they shall be repaired or replaced no later than 30 days from discovery.

Corrective Maintenance

Deficiencies identified during the overhead line inspection are addressed according to their severity. Issues which Citizens' Electric could reasonably expect to affect the reliability of the circuit will be repaired within 30 days.

Justification

This plan complies with the requirements of § 57.198(n)(5). No waiver is being requested.

§ 57.198(n)(6). Distribution transformer inspections.

Overhead distribution transformers shall be visually inspected as part of the distribution line inspection every 1-2 years. Above-ground pad-mounted transformers shall be inspected at least as often as every 5 years and below-ground transformers shall be inspected at least as often as every 8 years. An inspection must include checking for:

- (i) Rust, dents or other evidence of contact.*
- (ii) Leaking oil.*
- (iii) Installation of fences or shrubbery that could adversely affect access to and operation of the transformer.*
- (iv) Unauthorized excavation or changes in grade near the transformer.*

Program Description

Citizens' Electric Company performs a visual inspection of overhead transformers as part of its annual overhead line inspection program. Overhead transformers are evaluated for items including:

- Bushing condition (check for cracks, burns or other signs of problems)
- Tank condition (rust, dents, leaks, etc.)
- Condition of cutouts, arrestors and other associated hardware

Above-ground pad-mounted devices, including transformers and primary cabinets are inspected every four years. Items evaluated include but are not limited to:

- Accessibility (bushes, fences or other obstructions which would limit access)
- Warning labels
- Oil leaks
- Security (operation of 2 locking mechanisms, erosion, animal damage or grade changes which might allow unauthorized access)
- Condition of cable terminations and arrestors
- Overall tank condition

Citizens' Electric Company does not utilize any below-ground transformers.

Inspection Plan

All overhead transformers will be inspected each year as part of the annual overhead line inspection program.

Overhead Transformer Inspection Distribution Circuit Name	Total Overhead Transformers	Inspection Plan (Transformers to be Inspected)	
		2012	2013
Bucknell	65	65	65
Linntown	185	185	185
St. Mary St.	118	118	118
Rt. 192	400	400	400
Rt. 45	546	546	546
Rt. 15	245	245	245
Buffalo Road	115	115	115
Moore	148	148	148
Eastern	63	63	63
Total	1,885	1,885	1,885

Above-grade pad-mounted devices, including transformers and primary cabinets, will be inspected every four years in accordance with the following schedule:

Pad-Mounted Device Inspection Cycle	Subdivisions	Inspection Plan (Devices to be Inspected)	
		2012	2013
Inspection Cycle 4	Spruce Hills, Fox Hollow, Wyndham Hills, and others	168	
Inspection Cycle 1	Gilead Mt. Estates, Countryside, Wildflower, and others		205
Total		168	205

Citizens' Electric Company has a total of 748 pad-mounted devices in service.

Justification

This plan complies with the requirements of § 57.198(n)(6). No waiver is being requested.

§ 57.198(n)(7). Recloser inspections.

Three-phase reclosers shall be inspected on a cycle of 8 years or less. Single-phase reclosers shall be inspected as part of the EDC's individual distribution line inspection plan.

Program Description

Citizens' Electric Company performs a visual inspection of all reclosers as part of its annual overhead line inspection program. In addition, all reclosers are visited at least once a year for a more in-depth inspection to identify any emerging problems and address them before system reliability is affected. The inspection includes but is not limited to the following:

- Condition of bushings, tank, arrestors and associated hardware
- Condition and rating of bypass equipment
- Counter reading

Inspection Plan

All reclosers will be inspected annually in accordance with the following plan.

Recloser Inspection Distribution Circuit Name	Total No. of Reclosers	Inspection Plan (Reclosers to be Inspected)	
		2012	2013
Bucknell	1	1	1
Linntown	0	0	0
St. Mary St.	2	2	2
Rt. 192	11	11	11
Rt. 45	18	18	18
Rt. 15	11	11	11
Buffalo Road	1	1	1
Moore	4	4	4
Eastern	1	1	1
Total	49	49	49

Justification

This plan complies with the requirements of § 57.198(n)(7). No waiver is being requested.

§ 57.198(n)(8). Substation inspections.

Substation equipment, structures and hardware shall be inspected on a cycle of 5 weeks or less.

Program Description

Citizens' Electric Company performs monthly substation inspections. These inspections are intended to detect any emerging problems or trends so they can be resolved before system reliability is impacted. Inspections include but are not limited to:

- Power transformers
- Station reclosers
- Structures and related equipment including bus, arrestors, switches and insulators
- Control equipment
- Battery statuses
- Security and alarm equipment
- Communications equipment
- Control house
- Fence/gates

In addition, comprehensive voltage, current, pressure, oil level and operations counter readings are recorded.

Inspection Plan

Monthly substation inspections will be completed.

Substation Inspection Substation Name	Inspection Plan (Inspections to be completed)	
	2012	2013
St. Mary St.	12	12
Total	12	12

Justification

This plan complies with the requirements of § 57.198(n)(8). No waiver is being requested.

CITIZENS' ELECTRIC COMPANY
1775 Industrial Boulevard
P.O. Box 551
Lewisburg, PA 17837



7010 0290 0000 7750 1520



Ms. Rosemary Chiavetta, Secretary
Pennsylvania PUC
PO Box 3265
Harrisburg, PA 17105-3265