

TrAILCo Response to OCA Interrogatory Set I, No. 17
Sponsor: Lawrence Hozempa
Response Date: July 3, 2007

**IN RE: APPLICATION OF TRANS-ALLEGHENY INTERSTATE LINE COMPANY
PaPUC Docket No. A-110172 et al.**

2008 APR 14 PM 1:37
PA PUC
SECRETARY'S BUREAU

RECEIVED

OFFICE OF CONSUMER ADVOCATE Set I, No. 17:

- OCA-I-17. Please refer to Statement No. 2, page 6 at lines 8-11.
- Please list the alternatives to the Prexy Facilities that were considered.
 - Please provide a cost breakdown for the Prexy Facilities.
 - Please provide a cost breakdown for each of the alternatives to the Prexy Facilities that were considered.
 - Please provide load flow saved cases compatible with Siemens PTI PSS/E Version 30 that reflect the base cases including each of the alternatives to the Prexy Facilities that were considered.
 - Please provide a copy of any other studies, analyses, etc. that were used to evaluate the alternatives to the Prexy Facilities that were considered.
 - Please provide a copy of all the reliability planning criteria used in the evaluation of the need for the Prexy Facilities and in the evaluation of the alternatives to the Prexy Facilities that were considered.

RESPONSE:

- The study examined at two alternatives to serve the load center around the original Prexy Substation site. The present distribution load, within a 10 mile radius of the original Prexy Substation location, will exceed 500 MVA in 2009. The alternates studied were to serve the load from within the load center or from outside the load center. The first alternative involved tapping the Wylie Ridge – Harrison 500 kV line and installing a 500/138 kV substation in western Washington County. The second alternative involved building the center portion of the original Harrison – Yukon 500 kV line (502 Junction – Prexy) and installing a 500/138 kV substation in Northern Washington County (Prexy).
- A breakdown of the cost of the Prexy Facilities follows.
 - 138kV portion of Prexy Substation - \$35.98 million (includes 138kV capacitor)

- ii. Prexy to Houston-Manifold 138kV line - \$11.21 million
 - iii. Prexy to Union Junction-Peters 138kV line - \$12.25 million
 - iv. Prexy to Washington-Charleroi 138kV line - \$9.91 million
 - v. 500kV portion of Prexy Substation - \$24.10 million (includes 500/138kV transformer)
 - vi. 502 Junction-Prexy 500kV line (36 miles) - \$107.15 million
 - vii. Install 500kV breakers at 502 Junction Substation - \$12.92 million
 - viii. Total cost of Prexy Facilities - \$213.52 million
- c. A cost estimate was not completed on the second alternative since it was electrically unacceptable.
- d. See case files on Attachment OCA-I-17-A which is confidential and will be provided in accordance with the terms and conditions of any protective order issued in this proceeding.
- e. See other studies, analyses, etc. are on Attachment OCA-I-17-A which is confidential and will be provided in accordance with the terms and conditions of any protective order issued in this proceeding.
- f. Allegheny Power's planning criteria used in the evaluation of the need for the Prexy Facilities is based on Allegheny Power's 2005 FERC Form 715 Part 4 which is included on Attachment OCA-I-17-A. Attachment OCA-I-17-A is confidential and will be provided in accordance with the terms and conditions of any protective order issued in this proceeding.

THE GENERAL ASSEMBLY OF PENNSYLVANIA

HOUSE RESOLUTION

No. 297 Session of 2007

INTRODUCED BY DeWEESE, SOLOBAY, MUNDY, EACHUS, BELFANTI, BRENNAN, CALTAGIRONE, CASORIO, FABRIZIO, GIBBONS, HARHAI, KORTZ, LEVDANSKY, LONGIETTI, MAHONEY, OLIVER, SAYLOR, SHAPIRO, SHIMKUS, SIPTROTH, DALEY, WANSACZ, J. WHITE, YUDICHAK, KIRKLAND, YEWIC, SCAVELLO, READSHAW, WOJNAROSKI, GALLOWAY, GEORGE, FREEMAN, DALLY, JOSEPHS, YOUNGBLOOD, PASHINSKI AND HORNAMAN, MAY 24, 2007

REFERRED TO COMMITTEE ON CONSUMER AFFAIRS, MAY 24, 2007

A RESOLUTION

1 Opposing the designation of national interest electric
2 transmission corridors and memorializing the Congress of the
3 United States to repeal or modify certain provisions of the
4 Energy Policy Act of 2005.

5 WHEREAS, The Energy Policy Act of 2005 (EPact) was passed by
6 the Congress on July 29, 2005, and signed into law on August 8,
7 2005; and

8 WHEREAS, The EPact was promoted as a comprehensive approach
9 to growing energy needs and designed to guarantee development of
10 domestic fuel production and energy supply, thereby ending
11 United States dependence on foreign oil; and

12 WHEREAS, Provisions of the omnibus legislation touch on
13 nearly every segment of energy production and use, including
14 nuclear power, electricity, natural gas, fossil fuels, renewable
15 energy and competitive generation; and

16 WHEREAS, A provision of Title XII of the EPact, Electric

SECRETARY'S BUREAU
APR 14 PM 1:37
RECEIVED

1 however, preempts what have long been fundamental powers of
2 state and local governments; and

3 WHEREAS, Section 1221, for example, transfers the authority
4 to approve the siting of certain transmission lines from state
5 governments and their political subdivisions to agencies of the
6 Federal Government; and

7 WHEREAS, Section 1221(a) of EPact directs the United States
8 Secretary of Energy to, in consultation with states, conduct
9 periodic nationwide studies of electric transmission congestion;
10 and

11 WHEREAS, The Secretary of Energy released its initial
12 National Electric Transmission Congestion study in August 2006;
13 and

14 WHEREAS, Based upon the findings of any congestion study, the
15 Secretary of Energy may designate "any geographical area
16 experiencing electric energy transmission capacity constraints
17 or congestion that adversely affects customers" as a "national
18 interest electric transmission corridor" or national corridor;
19 and

20 WHEREAS, Section 1221(b) further conveys to the Federal
21 Energy Regulatory Commission (FERC) the authority to issue
22 permits for construction or modification of electric
23 transmission facilities situated or proposed to be situated in
24 any Department of Energy designated national interest electric
25 transmission corridor; and

26 WHEREAS, The FERC would be able to override the authority of
27 the Pennsylvania Public Utility Commission to issue a
28 certificate of public convenience to approve and locate a
29 transmission line in a Department of Energy designated national
30 interest electric transmission corridor if:

1 (1) the Pennsylvania Public Utility Commission had no
2 authority to approve a specified transmission line proposal
3 or would fail to consider interstate benefits of the proposed
4 transmission line;

5 (2) the applicant would not qualify for a certificate of
6 public convenience issued by the Pennsylvania Public Utility
7 Commission because it does not serve end-use customers in the
8 Commonwealth of Pennsylvania;

9 (3) the Pennsylvania Public Utility Commission would fail
10 to act on an application for approval to locate and construct
11 the new transmission line within one year of the filing of an
12 application or one year after designation as a national
13 interest electric transmission corridor, whichever is later;
14 or

15 (4) the Pennsylvania Public Utility Commission would
16 condition its approval in such a manner that the proposed
17 construction or modification would not significantly reduce
18 transmission congestion or would not be economically
19 feasible;

20 and

21 WHEREAS, The Pennsylvania Public Utility Commission and its
22 predecessor, the Public Service Commission, have had
23 jurisdictional and regulatory authority over public utilities
24 and public utility service, including the review and approval of
25 applications for the location and construction of transmission
26 lines in the Commonwealth of Pennsylvania since 1913, or for 94
27 years; and

28 WHEREAS, The designation of national interest electric
29 transmission corridors in the Commonwealth of Pennsylvania,
30 coupled with FERC "backstop" authority to issue permits to site

1 a transmission line and thereby override the recommendations of
2 the Pennsylvania Public Utility Commission, would give electric
3 utilities access to Federal eminent domain authority; and

4 WHEREAS, If FERC would institute its "backstop" authority,
5 the holder of a FERC-issued permit would be empowered to
6 exercise the right of eminent domain to condemn and acquire
7 private property to locate and construct the transmission line;
8 and

9 WHEREAS, On March 6, 2006, Allegheny Power and the PJM
10 Interconnection, the Regional Transmission Organization that
11 coordinates the movement of wholesale electricity in all or
12 parts of 13 states and the District of Columbia, including the
13 Commonwealth of Pennsylvania, filed for early designation as a
14 national interest electric transmission corridor a 240-mile, 500
15 kV transmission line which would extend from southwestern
16 Pennsylvania, traverse West Virginia and terminate in northern
17 Virginia; and

18 WHEREAS, On October 10, 2006, the PJM Interconnection
19 submitted another request to the Department of Energy for early
20 designation of three additional national interest electric
21 transmission corridors that will encompass nearly all of the
22 Mid-Atlantic region; and

23 WHEREAS, The early request filed with the United States
24 Department of Energy by Allegheny Power and the PJM
25 Interconnection, if granted, will include significant acreage of
26 land in the Commonwealth of Pennsylvania; and

27 WHEREAS, On April 26, 2007, the United States Department of
28 Energy released drafts of two national interest electric
29 transmission corridor designations, including the Mid-Atlantic
30 Area National Corridor; and

1 WHEREAS, The Mid-Atlantic Area National Corridor designation
2 includes counties in Ohio, West Virginia, Pennsylvania, New
3 York, Maryland, Virginia and includes all of New Jersey,
4 Delaware and the District of Columbia; and

5 WHEREAS, Fifty of the Commonwealth of Pennsylvania's 67
6 counties, or 75% of the land within the Commonwealth's
7 geographic borders, are included in the Mid-Atlantic Area
8 National Corridor designation; and

9 WHEREAS, In its release announcing the draft national
10 interest electric transmission corridor designations, the
11 Department of Energy revealed that it would convene three public
12 meetings during a 60-day comment period; and

13 WHEREAS, In its April 26, 2007, announcement, the Department
14 of Energy revealed that public meetings would be held in New
15 York, Virginia and California during the 60-day comment period;
16 and

17 WHEREAS, Some local governments, citizens and preservation
18 groups that would be directly impacted by the designation of
19 national interest electric transmission corridors in the
20 Commonwealth of Pennsylvania and some other affected states
21 contacted the Department of Energy to express their
22 disappointment and concern that no public meetings were planned
23 for Pennsylvania and other affected states during the 60-day
24 comment period; and

25 WHEREAS, On May 8, 2007, the Department of Energy announced
26 that it would hold four additional meetings during the 60-day
27 public comment period in some states, including the Commonwealth
28 of Pennsylvania, that would be impacted by the national interest
29 electric transmission corridor designations; and

30 WHEREAS, The Pennsylvania public meeting will be convened in

1 the month of June in Pittsburgh, Pennsylvania; and

2 WHEREAS, The 60-day comment period for the Mid-Atlantic Area
3 National Corridor designations is scheduled to end on July 6,
4 2007; and

5 WHEREAS, It is alleged that the transmission lines proposed
6 to be located and constructed in the Mid-Atlantic Area National
7 Corridor would be used to relieve energy congestion and
8 constraints and improve electric reliability in population
9 centers of the East Coast; and

10 WHEREAS, Designation of national interest electric
11 transmission corridors in the Commonwealth of Pennsylvania could
12 diminish or eliminate the role of the Pennsylvania Public
13 Utility Commission, the administrative agency of the
14 Commonwealth that has regulatory authority over the approval of
15 applications for the location and construction of transmission
16 lines; and

17 WHEREAS, Designation of national interest electric
18 transmission corridors would also adversely limit or completely
19 eliminate the roles of the Office of Consumer Advocate and the
20 Office of Small Business Advocate; and

21 WHEREAS, The Office of Consumer Advocate and the Office of
22 Small Business Advocate are administrative agencies of the
23 Commonwealth of Pennsylvania that were expressly established by
24 Pennsylvania statute to represent the interests of consumers and
25 small businesses, respectively, in proceedings before the
26 Pennsylvania Public Utility Commission, including certain
27 matters related to the location and construction of transmission
28 lines; and

29 WHEREAS, Designation of national interest electric
30 transmission corridors and FERC's accompanying "backstop"

1 authority could diminish or even eliminate the roles of other
2 administrative agencies of the Commonwealth of Pennsylvania that
3 were established for the express purpose of protecting
4 Pennsylvania's economic, natural, historical, cultural and
5 recreational resources, including the Departments of
6 Environmental Protection, Conservation and Natural Resources,
7 Agriculture and Transportation as well as the Game Commission
8 and the Historical and Museum Commission; and

9 WHEREAS, Designation of national interest electric
10 transmission corridors in the Commonwealth of Pennsylvania would
11 undermine and in some cases eliminate the Commonwealth's ability
12 to determine, manage and control land use policies, including
13 land use policies on its agricultural lands, forest reserves,
14 recreational areas, game lands and other natural and
15 environmentally sensitive areas; therefore be it

16 RESOLVED, That the House of Representatives of the
17 Commonwealth of Pennsylvania recognize fully the energy and
18 environmental challenges facing the Commonwealth of Pennsylvania
19 in general and the United States in particular; and be it
20 further

21 RESOLVED, That the House of Representatives believe that
22 demand for energy continues to be a concern nationwide,
23 especially in major population centers, and that an effective
24 national energy policy must include increased emphasis on
25 conservation, renewable energy, energy-efficient alternatives,
26 demand-side management, innovations and new technologies while
27 simultaneously providing incentives to increase domestic
28 production and supply; and be it further

29 RESOLVED, That the House of Representatives recognize that an
30 effective energy policy must be addressed nationally but should

1 reflect traditional state and local authority over environmental
2 and energy matters; and be it further

3 RESOLVED, That the House of Representatives oppose the
4 provisions of EPact which preempt the authority of the
5 Commonwealth of Pennsylvania and its political subdivisions to
6 determine land use policies and which usurp the traditional and
7 fundamental authority of the Pennsylvania Public Utility
8 Commission to review and approve applications for the location
9 and construction of transmission lines in the Commonwealth of
10 Pennsylvania; and be it further

11 RESOLVED, That the House of Representatives urge the members
12 of the Pennsylvania Congressional Delegation to support
13 legislation to repeal section 1221 of EPact and thereby preserve
14 the fundamental rights of the Commonwealth of Pennsylvania and
15 its people to determine the future of land use policies; and be
16 it further

17 RESOLVED, That copies of this resolution be transmitted to
18 the presiding officers of each house of Congress and to each
19 member of Congress from Pennsylvania.

RESOLUTIONS ADOPTED AT THE CCAP 2007 ANNUAL CONFERENCE

The following resolutions were adopted by the delegates in attendance at the CCAP Annual Conference in York at the business meeting on August 7, 2007. In italics after each resolution is a description of its content and intent. The resolutions are available electronically on the Government Relations section of the Association's web site, www.pacounties.org, and are incorporated as amendments to the Association's cumulative policy statement, the *Pennsylvania County Platform*, also available at the web site.

RESOLUTION NO. 1 (*Submitted by the Assessment and Taxation Committee, as amended by the Resolutions Committee and with recommendations by the Assessors Association of Pennsylvania Assessment Reform Committee*) -- The Association supports uniformity and equity in property reassessment, and to that end supports enactment of a new assessment law containing the following elements:

- a. Consolidation of existing assessment laws into a single statute;
- b. Maintenance of the base year assessment methodology, with tools to maintain uniformity and equity of assessments between full-scale reassessments. Such tools may include use of the common level ratio, statistical revaluation, and allowing counties to use current market values to calculate and implement adjustments to values in areas of the county that have appreciated at a faster or slower rate than the remainder of the county, or classes of property that have appreciated at a faster or slower rate than the other classes, without such adjustments being considered spot reassessment;
- c. Provide for an appropriate state agency to oversee the assessment function, including development of attainable standards of fair and equitable assessments, administration of funding programs for county assessment, and auditing sales transactions and other factors used in determining formulas and ratios;
- d. Adequate testing and evaluation of assessments utilizing standards no less stringent than those established by the International Association of Assessment Officials;
- e. Improved building permit reporting systems providing consistent municipal permit issuance thresholds and mandatory reporting to the county;
- f. Effective representation of counties in the development and administration of state functions relating to property assessment;
- g. Statewide uniform assessment ratio based on the base year of, and implemented concurrent with, the county's reassessment;
- h. Maintain minimum training, certification, and recertification standards for county-appointed assessors, with state funding for training costs and with encouragement to counties to authorize training above minimum standards;
- i. Authority to use statistical revaluation, with appropriate standards, as a methodology for performing reassessments;
- j. Standards for appeals that are appropriate and equitable for each class of property, and include the ability to use stratified common level ratios pertinent to each class of property;
- k. A grant of the greater of twenty-five percent of the state share of realty transfer tax collections generated in the county or \$15 per parcel to any county achieving or maintaining the required measure of equity in its assessment program; Independent verification of the formula and sampling standards used to determine the coefficient of dispersion and the common level ratio;

RECEIVED
2008 APR 14 PM 1:37
SECRETARY'S BUREAU

- m. The establishment of a state grant fund or revolving loan fund to assist counties in performing reassessments;
- n. In the case of assessment errors or unreported property improvements that have resulted in underassessment of a property, to allow the taxing jurisdictions to recover underpaid taxes from the time of the error or improvement, to a maximum of five tax years;
- o. Provide limitations on challenges to assessors' professional certifications that are based solely on dissatisfaction with an individual's assessment, and provide for county indemnification of legal costs for successful defense of such challenges; and
- p. Provide and encourage training for members of boards of appeals and for auxiliary boards on fundamental assessment law and the conduct of quasi-judicial hearings.

This is a comprehensive rewrite of the Association's assessment resolution. Its changes include:

- *A new subsection b written to affirm support of base year assessment, with means to maintain equity between reassessments (incorporating all of former subsection o). It also recognizes that appreciation and depreciation vary over time by property class as well as by neighborhood.*
- *Subsection c (formerly b) is amended to call for designation of a state agency, comparable to agencies in several other states, with ability to enforce standards and to audit figures supplied for use in formula calculations.*
- *Subsection d (formerly e) is rewritten to provide that the IAAO standard is the minimum for assessments.*
- *Former subsection d calling for standards for assessor certification was addressed in amendments to the Assessors Certification Law (Act 28 of 1992).*
- *Subsection h (formerly i) is clarified to provide that the uniform standard is implemented only at the time of the county's next reassessment.*
- *Subsection i (formerly h) is rewritten to provide for state funding participation rather than responsibility so that no impression is made that the state controls the training program, and to encourage counties to allow assessors to attend training courses beyond the minimum standards.*
- *Subsection j (formerly i) is rewritten to call for clear statutory authority to do statistical revaluations. Former language relating to maintenance of values between assessments is placed in new subsection b.*
- *Subsection k (formerly j) calls for a more equitable appeals process, including the ability to recognize that different classes of properties can appreciate at different rates and so should be valued with a different but supportable common level ratio.*
- *Former subsection k, providing for a voluntary standard for reassessment based on equity (coefficient of dispersion) rather than timeline, is deleted as a matter to be considered instead in the context of mandatory reassessment.*
- *Subsection m, relating to independent formula verification is rewritten to add sampling and coefficient of dispersion.*
- *Subsection n provides for state grants in addition to loans.*
- *New subsection q seeks training for boards of appeals.*

RESOLUTION NO. 2 *(Submitted by the CCAP Resolutions Committee and the Assessors Association of Pennsylvania Assessment Reform Committee) – The Association supports mandatory reassessment for real property, but only if all conditions are met:*

- a. *Mandatory reassessment is triggered only when a county's coefficient of dispersion exceeds a pre-set standard for two successive years;*
- b. *Tools are provided to enable counties to maintain uniformity and equity of assessments between full-scale reassessments. Such tools may include use of*

- the common level ratio, statistical revaluation, and allowing counties to use current market values to calculate and implement adjustments to values in areas of the county that have appreciated at a faster or slower rate than the remainder of the county, without such adjustments being considered spot reassessment;
- c. The Commonwealth establishes a state grant fund or revolving loan fund to assist counties in performing reassessments; and
 - d. Annual incentive payments for counties that achieve and maintain standards of assessment equity.

The resolution supports mandatory reassessment, but only if a specific list of conditions are met. The list of conditions addresses the key issues that typically inhibit county decisions on reassessment.

RESOLUTION NO. 3 *(Submitted by the Resolutions Committee)* -- The Association supports the assignment of standardized valuations for underground oil and natural gas storage facilities so that they may be assessed for real property tax purposes pursuant to the applicable assessment law, or provision of a fee or other means to generate revenue from such facilities in an amount equivalent to the tax revenue that would be available for counties, municipalities, and schools in which such facilities are located.

Land owners generate fees on underground storage of oil and natural gas based on volume, but this land value is not currently assessable. The prior resolution called for assessment of these facilities, but the new version adds consideration of other means to generate revenue based on value.

RESOLUTION NO. 4 *(Submitted by the County Governance Committee)* -- The Association recognizes that salary information for public officials and employees is a public record but opposes legislation to require publication of individual salary information on the internet, out of concern that the information would be too freely accessible and too prone to use for illegal or improper purposes.

The resolution opposes attempts to require publication of official and employee salary information on the internet. Although the information is public record and available for inspection at the courthouse, publication on the internet results in an ease of access that can expose private individuals to harassment, embarrassment, fraud, or other criminal victimization. Internet information can quickly become outdated, and for some counties can be a burdensome administrative duty. The statute could also set the precedent for the Commonwealth to require publication of other records on the internet.

RESOLUTION NO. 5 *(Submitted by the County Governance Committee)* -- The Association supports state legislation to permanently extend the window offered under Act 174 of 2006 for counties to adopt 1/50 or 1/40 pension benefit levels.

CCAP successfully achieved the prior resolution, reopening the 1/50 and 1/40 pension benefit option, by enactment of Act 174 of 2006. That act reopened the window through June 30, 2007. The resolution proposes to make the provision permanent.

RESOLUTION NO. 6 (*Submitted by the Energy, Environment and Land Use Committee*) -- The Association supports programs to promote use of alternatives to fossil-based transportation fuels, including incentives for counties and mass transit agencies to deploy hybrid vehicles and vehicles operated by alternative fuels.

The resolution is updated to clearly reflect support for incentives for alternative fuels in mass transit vehicles as well as county vehicle fleets.

RESOLUTION NO. 7 (*Submitted by the Energy, Environment and Land Use Committee as amended by the Resolutions Committee*) -- The Association supports development of alternative energy sources in Pennsylvania to generate electricity, including wind, solar, hydropower, clean coal and alternative coal, hydrogen, biomass, natural gases including methane, and nuclear technologies. The Association also supports state technical and financial assistance to help counties install generating facilities to offset electricity requirements for county buildings, as well as laws and regulations that assure customer generators receive fair market value for the electricity generated.

Although the Association adopted a position in 2006 on alternative transportation fuels, the Platform was silent about alternative sources of energy for electricity. The resolution is a statement of support for alternative energy sources for electricity in general, as well as for state assistance to help counties install appropriate alternative sources to generate their own electricity and reduce energy costs.

RESOLUTION NO. 8 (*Submitted by the Energy, Environment and Land Use Committee*) -- The Association supports permanent reauthorization of the Municipal Waste Planning, Recycling and Waste Reduction Act (Act 101 of 1988) state tip fee.

The Association supports legislation to grant counties authority to fund county solid waste and recycling programs through a fee on trash collected within the county.

This update to the prior resolution better reflects efforts by CCAP to correct a Commonwealth Court decision which ruled county administrative fees illegal. Because counties are not seeking authority for a tip fee, but instead a fee on every ton of trash that is collected within the county in order to fund supplemental recycling programs, the Association's position is made more clear by dividing the prior single resolution into its two constituent parts.

RESOLUTION NO. 9 (*Submitted by the Energy, Environment and Land Use Committee*) -- The Association supports study and planning for future energy needs, but it opposes federal laws that pre-empt state and local control over land use policies for the siting of electric transmission lines. Siting decisions for electric transmission lines should be compatible with local land use policies, including protections for preserved farmland and open space, and other natural and environmentally significant areas.

The federal Energy Policy Act of 2005 authorized studies to designate National Interest Electric Transmission Corridors. A National Corridor designation means that if the state denies siting authority, Federal Energy Regulatory Commission could conduct a review and determine whether to issue a permit and authorize construction. The federal permit authorizes the use of eminent domain, if the generator can't negotiate an agreement with a landowner and, although eminent domain cannot be exercised over federal or state-owned land, it can still supersede local land use plans and decision-making processes.

RESOLUTION NO. 10 (*Submitted by the Agriculture Committee and Energy, Environment and Land Use Committee*) -- The Association supports legislation that would provide incentives for private entities to invest in best management practices for agricultural operations and storm water management in order to reduce nutrient loads in Pennsylvania's waterways and enhance water quality.

A proposal has been introduced in the House and Senate that would give farmers and other private entities a tax credit for investing in best management practices that reduce nutrient levels in Pennsylvania waterways. Improved agriculture practices are recognized as the most inexpensive method to reduce nutrient loads. Storm water is another important component of water quality, for which counties and municipalities are responsible. The resolution supports incentives for private entities to invest in improving water quality, and this would reduce costs for the local taxpayer.

RESOLUTION NO. 11 (*Submitted by the Human Services Committee*) -- The Association supports the ability of local governments to enact and enforce ordinances stricter than what is required through any statewide ban on smoking in public places.

The Association opposes any legislative effort mandating county responsibility and financial burden for enforcement and prosecution of any state smoking law.

Many counties are considering the adoption of county-wide smoking bans, and several have been enacted and implemented, with the courts then overturning local decisions based on the absence of statewide or local statutory authority. This set of resolutions supports local ability to enact more stringent ordinances based on local conditions (implicitly rejecting state preemption), and opposes a proposal to require counties to be the enforcement entity for state restrictions.

RESOLUTION NO. 12 (*Submitted by the Human Services Committee*) -- The Association supports aggressive intervention with the Department of Public Welfare and its Office of Developmental Programs to satisfactorily resolve issues that surround the roles and responsibilities of county MH/MR Programs and those of the state.

In order to maintain Pennsylvania's Medicaid waivers for mental retardation services, the Department of Public Welfare made a number of assurances to the Centers for Medicare and Medicaid Services. This has caused significant changes to the mental retardation system, and DPW's Office of Developmental Programs (formerly the Office of Mental Retardation) has not moved quickly to implement the changes by providing policy bulletins that counties must use to manage the programs. Now, ODP plans to discontinue the allocation of waiver dollars to counties and directly pay providers from the state treasury, beginning in 2009. This reduces the authority of the county in managing the purchase of services and also will result in a significant loss of interest earned by counties; during Fiscal Year 2005-2006, counties earned more than \$6.8 million which was then spent on services. Over the last two years, ODP has been very slow to issue its allocation letters to county programs. These letters tell programs how much money from the legislative appropriation the counties can spend on their mental retardation programs. The last fiscal year had ended long before ODP released the letters. This has resulted in uncertainty and delays in year end reporting and completion of audits.

RESOLUTION NO. 13 (*Submitted by the Human Services Committee*) -- The Association supports coordination between counties and the Department of Public Welfare in the administration and services to individuals with autism who are also diagnosed with mental retardation and/or behavioral health issues.

The resolution recognizes the increasing interest in policy for autism services, allowing the counties to act as stakeholders in the decisions being made regarding service delivery.

RESOLUTION NO. 14 *(Submitted by the Human Services Committee) --*

Juvenile Detention

1. The Association supports a long-term funding solution for juvenile detention services consisting of an increase in the Act 148 reimbursement rate from 50% State / 50% Counties, to a 90% State /10 Counties, with a commensurate increase in Act 148 funding.
2. The Association supports the Department of Public Welfare, Office of Children, Youth and Families in finding a stable, state-level funding source for the development and ongoing administration of a comprehensive training program which meets the training requirements defined by the 3800 regulations including the current training needs of juvenile detention and shelter care facilities.
3. The Association, in recognition of the growing number of juveniles with behavioral health needs being placed in juvenile detention:
 - a. Supports the aggressive development of additional community based behavioral health services for adjudicated delinquents within the state;
 - b. Supports adequately training detention center staff to manage the needs of these youth by providing stable, state-level funding for the development and ongoing administration of a comprehensive training program for secure juvenile detention centers that would provide training on behavior management, crisis intervention skills, cognitive functioning and psychopathology;
 - c. Supports providing behavioral health services to juveniles while in detention to maintain their safety, effectively meet their needs and help prevent the exacerbation of problems; and
 - d. Supports the examination of systemic issues around access to services, ability to obtain services and models for responding to the behavioral health needs of detained juveniles.
4. The Association supports quality year-round education for youth in juvenile detention and shelter care facilities.

The resolution creates a new section in the Human Services article of the Platform, recognizing the increasing challenges and unique needs counties face in the provision of juvenile detention services, and representing an effort to identify and provide guidance around the specialized needs of juvenile detention.

RESOLUTION NO. 15 *(Submitted by the Courts and Corrections Committee) --* The Association supports legislation requiring the Department of Corrections to cover any medical costs and medically related transportation costs for any inmate temporarily in county custody who has been sentenced to a state correctional facility but not yet transferred.

The Department of Corrections has recently refused to reimburse counties for any costs incurred in cases of state-sentenced inmates requiring medical treatment prior to their transfer to a state facility. The resolution gives the DOC full responsibility for these inmates.

RESOLUTION NO. 16 (*Submitted by the Courts and Corrections Committee*) -- The Association believes Act 57 of 2005 requires the Commonwealth to reimburse counties for 65% of the salaries of full time district attorneys, regardless of the funding source. While the Association will consider support of legislation to provide a dedicated funding source, in the interim, and at any time dedicated funds are insufficient, the Association insists that annual appropriations be made from the Commonwealth General Fund and that reimbursements be made expeditiously.

Governor Rendell proposed his 2007-2008 budget without any funding for Act 57 and resisted legislative attempts to add funding back in, instead insisting that payments would be contingent on passage of a dedicated funding source. New legislation (Act 30 of 2007) relies on increases in fines and fees which will take some time to generate sufficient revenues. The resolution permits the Association to support a dedicated fund, but insists on general fund appropriations in the interim.

RESOLUTION NO. 17 (*Submitted by Armstrong County*) -- The Association supports imposition by Congress of a moratorium on all new trade agreements, to investigate and review all current free trade agreements and policies of the United States, to investigate and review participation of the United States in international trade organizations, and to ensure that the agreements, policies, and participation are in the best interests of the citizens of Pennsylvania and the United States.

The resolution asks for a Congressional moratorium on free trade agreements pending review of current agreements and their effect on Pennsylvania and the United States. It does not oppose such agreements per se.

RESOLUTION NO. 18 (*Submitted by the Agriculture Committee*) -- The Association supports state funding for Cooperative Extension services at historic levels, including annual cost of living increases.

Governor Rendell's proposed budgets have cut the cooperative extension line item for the last several years. Since many counties partner with the state and the University to fund local cooperative extension offices, this resolution encourages the state to keep up its share of funding for these services.

RESOLUTION NO. 19 (*Submitted by the Community and Economic Development Committee*) -- The Association urges the Department of Community and Economic Development to consult with the Association, as well as with the affected county governing bodies and tourism agencies, prior to consolidation of promotional agencies, urges the Department to provide voluntary incentives for consolidation rather than forced mergers, and supports, with appropriate safeguards for individual county tourism promotion programs, priority distribution of a portion of Commonwealth tourism promotion grants based on regional approaches and consistency with Commonwealth tourism promotion efforts.

The Administration is considering changes to the Tourism Promotion Grant program that will allocate part of the funding on a priority basis to regional tourism promotion activities, including especially those that are consistent with and complementary to the state's tourism promotion efforts.

RESOLUTION NO. 20 *(Submitted by the County Governance Committee)* -- The Association supports federal, state, and local efforts to enhance emergency and disaster response and recovery capabilities for all hazards, including specialized planning and response for bioterrorism, chemical terrorism, weapons of mass destruction, pandemics, and nuclear events.

The resolution amends the current all-hazards plank to add pandemic planning.

RESOLUTION NO. 21 *(Submitted by the County Governance Committee)* -- The Association supports legislation to require all responders to be trained in and use the National Incident Management System.

The resolution is a technical amendment updating the resolution to current standards.

RESOLUTION NO. 22 *(Submitted by the County Governance Committee)* -- The Association supports legislation providing for universal intrastate mutual aid, including:

- a. Commonwealth maintenance of contact and capability information;
- b. County activation and incident management;
- c. Provisions for appropriate assignment and indemnification of liability, workers' compensation, and property and casualty coverage;
- d. Clear chain of command; and
- e. Accommodation of existing mutual aid agreements.

The Pennsylvania Emergency Management Agency is developing legislation to provide for universal intrastate mutual aid, although allowing municipalities to individually opt out. The resolution reinforces the county role in managing mutual aid and incident management.

RESOLUTION NO. 23 *(Submitted by Armstrong County)* -- The Association supports Congress, the Commonwealth, NACo, each Pennsylvania county, and counties nationwide joining the Sudden Cardiac Arrest Association and other heart-related agencies in adopting a resolution designating the first week in October as "Sudden Cardiac Arrest Awareness Week", increasing awareness of CPR, Automated External Defibrillators, and Implantable Cardioverter Defibrillators, and their availability or need among emergency and other medical treatments.

CCAP has at least two members whose survival is credited to the availability and prompt use of AEDs. CCAP has AEDs available at each of its offices, regularly affirms with hotels and other meeting facilities the availability of AED equipment, and has trained more than 75% of its staff on CPR and AED usage. The resolution calls on a coalition of groups to support greater public awareness and greater deployment of these devices.

*Pgh TX A-110172 #6
3/03/08*

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

IN RE: APPLICATION OF TRANS-ALLEGHENY :
INTERSTATE LINE COMPANY FOR :
(I) A CERTIFICATE OF PUBLIC CONVENIENCE :
TO OFFER, RENDER, FURNISH AND/OR :
SUPPLY TRANSMISSION SERVICE IN THE :
COMMONWEALTH OF PENNSYLVANIA; :
(II) AUTHORIZATION AND CERTIFICATION :
TO LOCATE, CONSTRUCT, OPERATE AND :
MAINTAIN CERTAIN HIGH VOLTAGE ELECTRIC :
TRANSMISSION LINES AND RELATED ELECTRIC :
SUBSTATION FACILITIES; (III) AUTHORITY :
TO EXERCISE THE POWER OF EMINENT :
DOMAIN FOR THE CONSTRUCTION AND :
INSTALLATION OF AERIAL ELECTRIC :
TRANSMISSION FACILITIES ALONG THE :
PROPOSED TRANSMISSION LINE ROUTES :
IN PENNSYLVANIA; (IV) APPROVAL OF AN :
EXEMPTION FROM MUNICIPAL ZONING :
REGULATION WITH RESPECT TO THE :
CONSTRUCTION OF BUILDINGS; AND :
(V) APPROVAL OF CERTAIN RELATED :
AFFILIATED INTEREST ARRANGEMENTS :

Docket Nos. A-110172
A-110172F0002
A-110172F0003
A-110172F0004
G-00071229

**DIRECT TESTIMONY OF
JOHN R. BODENSCHATZ, P.E.**

RECEIVED
PA PUC
SECRETARY'S BUREAU

2008 APR 14 PM 1:36

**Re: The Design, Engineering, Construction, Operation
and Maintenance of TrAIL; Exemption from Local Zoning**

April 13, 2007

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is John R. Bodenschatz. My business address is 800 Cabin Hill Drive,
3 Greensburg, Pennsylvania 15601-1689.

4
5 DUTIES AND RESPONSIBILITIES

6 Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

7 A. I am employed by Allegheny Energy Service Corporation, and my title is Senior
8 Engineer, Extra High Voltage ("EHV") Projects. My time is devoted to
9 engineering and design tasks for the Allegheny Energy, Inc. ("Allegheny")
10 companies, including Trans-Allegheny Interstate Line Company ("TrAILCo").

11
12 EXPERIENCE AND EDUCATION

13 Q. PLEASE DESCRIBE YOUR PROFESSIONAL EXPERIENCE AND
14 EDUCATIONAL BACKGROUND.

15 A. I am a graduate of Pennsylvania State University, where I earned a Bachelor of
16 Science degree from the College of Civil and Environmental Engineering. I am a
17 registered professional engineer in the states of Maryland, Ohio, Virginia,
18 Pennsylvania, and West Virginia and hold a Council Record with the National
19 Council of Examiners for Engineering and Surveying. I have been employed by
20 Allegheny Energy for over thirteen years. For assigned transmission line and
21 substation projects, I have been responsible for siting, permitting and engineering
22 survey coordination, civil design, engineering, scheduling and project
23 management, and design and material standards coordination. My current

1 responsibilities include the tasks just listed, with a concentrated focus on EHV
2 transmission line and substation projects.

3
4

PURPOSE OF TESTIMONY

5 Q. ON WHOSE BEHALF ARE YOU PROVIDING THIS TESTIMONY?

6 A. I am providing this testimony on behalf of TrAILCo.

7 Q. PLEASE DESCRIBE THE PURPOSE OF YOUR TESTIMONY?

8 A. The purpose of my testimony is to describe TrAILCo's plans for designing,
9 engineering, and constructing TrAIL. I will also explain the plans for operating
10 and maintaining the line, including the removal and control of vegetation and trees
11 along the line's right-of-way.

12 Q. HOW IS YOUR TESTIMONY ORGANIZED?

13 A. My testimony addresses, in order, the following topics:

- 14 • a general description of the TrAIL project;
- 15 • the planned configuration for TrAIL;
- 16 • a description of the detailed design specifications for the
17 line and the line's safety features;
- 18 • a general description of the planned construction activities;
- 19 • the plan for clearing and preparing the TrAIL right-of-way;
- 20 • the plans for controlling vegetation in and along TrAIL's
21 right-of-way after construction is complete and the line is in
22 service;
- 23 • TrAILCo's technical capacity to meet the public need for
24 which TRAIL will be constructed and operated; and,
25
26
27
28

- 1 • TrAILCo's request for a waiver from the Commission from
2 certain applicable local municipal zoning regulations for the
3 new substation facilities necessary for the project.
4

5 Q. IS YOUR TESTIMONY INTENDED TO ADDRESS ANY OF THE FILING
6 REQUIREMENTS OF 52 PA. CODE § 57.1 and §§ 57.1 – 57.77 GOVERNING
7 THE SITING AND CONSTRUCTION OF HIGH VOLTAGE (“HV”)
8 TRANSMISSION LINES?

9 A. Yes. As noted in the Application, information in this direct testimony is
10 responsive to the requirements of 52 Pa. Code § 57.72(c)(6) (safety considerations
11 to be incorporated into the design, construction and maintenance of the proposed
12 HV line), (c)(13)(ii) (an engineering and design-based description of the proposed
13 line), and (c)(13)(iii) (a simple drawing of a cross section of the proposed right-
14 of-way of the HV line showing the placement of supporting structures at typical
15 locations, with structure sizes, right-of-way widths, and the lateral distances
16 between the conductors and the edge of the right-of-way indicated).

17 Q. WILL THE USE OF VARIOUS TERMS IN YOUR TESTIMONY BE
18 CONSISTENT WITH THE DEFINITIONS ASSIGNED TO THOSE TERMS IN
19 THE TABLE OF NOMENCLATURE ATTACHED TO TRAILCO WITNESS
20 FLITMAN'S TESTIMONY AS EXHIBIT DEF-1?

21 A. Yes. In addition, I will also define and use a number of other terms in this
22 testimony.

1 EXHIBITS

2 Q. PLEASE IDENTIFY AND DESCRIBE THE EXHIBITS TO YOUR
3 TESTIMONY AND SUMMARIZE THE CONTENTS OF THOSE EXHIBITS.

4 I am sponsoring four exhibits with my direct testimony:

- 5 • TrAILCo Exhibit No. JRB-1 - a ten-page document that details the project
6 design criteria for TrAIL;
- 7
- 8 • TrAILCo Exhibit No. JRB-2 – consisting of twelve pages, each of which
9 is a graphical engineering design sketch of one of the types of
10 transmission structures that will be utilized for TrAIL;
- 11
- 12 • TrAILCo Exhibit No. JRB-3 – a three-page document of graphical
13 engineering sketches for TrAIL, one page showing a right-of-way
14 configuration for a typical lattice steel horizontal structure line with no
15 adjacent transmission lines, the second page showing a right-of-way
16 configuration for those instances when the TrAIL right-of-way may be
17 adjacent to an existing 138 kilovolt (“kV”) line, and the third page
18 showing the right-of-way configuration for 138 kV line routes that are part
19 of the TrAIL project; and
- 20
- 21 • TrAILCo Exhibit No. JRB-4 - consisting of four pages of graphical
22 engineering sketches that show transmission structure and circuit
23 identification designs.
- 24

25 GENERAL DESCRIPTION OF TRAIL

26 Q. WILL YOUR ENGINEERING AND CONSTRUCTION TESTIMONY
27 ADDRESS THE TRAIL PROJECT AS IT IS DESCRIBED IN THE
28 APPLICATION AND THE TESTIMONIES OF OTHER TRAILCO
29 WITNESSES?

30 A. Yes, it will.

1 Q. WHAT PORTION OF TRAIL WILL BE LOCATED WITHIN
2 PENNSYLVANIA?

3 A. As indicated in the Line Route Evaluation ("LRE") attached to the testimony of
4 TrAILCo witness Halpern as TrAILCo Exhibit No. JH-1, approximately 38 miles
5 of TrAIL's 500 kV line segments will be constructed within Pennsylvania,
6 consisting of approximately 36.5 miles from the Prexy Substation to the 502
7 Junction Substation and approximately 1.2 miles extending south from the 502
8 Junction Substation to the Pennsylvania-West Virginia state line. The five
9 segments of new Prexy 138 kV lines will total approximately 25.4 circuit miles,
10 consisting of a double-circuit 138 kV line over an approximately 4.8 mile route
11 (9.6 miles of circuit) extending south from the Prexy Substation to Allegheny
12 Power's VANWA Junction-Charleroi line, a double-circuit 138 kV line over an
13 approximately 5.5 mile route (11.0 miles of circuit) extending generally northeast
14 from the Prexy Substation to Allegheny Power's Crossgates-Peters line, and a
15 third single-circuit 138 kV line extending generally west from the Prexy
16 Substation for approximately 4.8 miles to Allegheny Power's Manifold-Houston
17 line.

18
19

DESIGN CONFIGURATION FOR THE PROPOSED LINE

20 Q. PLEASE DESCRIBE THE GENERAL DESIGN CONFIGURATION
21 PLANNED FOR TRAIL.

22 A. For the 500 kV segments, TrAIL will be an alternating current ("AC") single circuit
23 500 kV transmission line, consisting of three electrical phases (a "three-phase"

1 system) elevated above the ground by self-supporting lattice steel tower structures.
2 Each phase will consist of three conductors (each of which is called a
3 "subconductor") spaced 18 inches apart and arranged in a triangular bundle, with the
4 apex point down. Additionally, the three conductor phases will be attached to the
5 towers in a horizontal phase configuration. The Prexy 138 kV Lines will be AC
6 double circuit three-phase 138 kV transmission lines, elevated above the ground by
7 self-supporting single pole tubular steel structures, with the three conductor phases
8 attached to each side of the supporting structure in a vertical phase configuration.
9 Each 138 kV structure is designed to carry two three-phase circuits.

10 Q. ARE ANY OTHER TYPES OF TOWER STRUCTURES ANTICIPATED OR
11 PLANNED FOR THE TRAIL PROJECT?

12 A. While it is anticipated that lattice steel towers will be the principal structure for
13 the 500 kV line, it is possible that other structure types may be required due to
14 possible design constraints that are not defined at this time, but will be addressed
15 in the detailed engineering phase of the project.

16 Q. WHAT WIDTH OF RIGHT-OF-WAY IS PLANNED FOR TRAIL?

17 A. All rights-of-way for 500 kV TrAIL segments in Pennsylvania will be 200 feet
18 unless an isolated circumstance requires a wider or narrower width, with the path of
19 the line situated in the center of this width unless unique design conditions dictate
20 otherwise. The 138 kV lines will be situated within 100 foot-wide rights-of-way.
21 Where the 500 kV and 138 kV lines are parallel to each other, a 290 foot-wide right-
22 of-way will be required and the lines will have a 140 foot centerline to centerline
23 separation, as shown on Figure 2 of my TrAILCo Exhibit No. JRB-3. All proposed

1 TrAIL right-of-way configurations that are presently anticipated in Pennsylvania are
2 shown in TrAILCo Exhibit No. JRB-3.

3 Q. WHAT SIZE AND TYPE OF SUBCONDUCTOR IS PLANNED FOR TRAIL?

4 A. After an extensive study of available conductors and based on a number of
5 performance parameters that included audible noise, electrical loading capabilities,
6 conductor sag, and structural loading among others, TrAILCo is specifying the use
7 of a subconductor named "Finch – High Strength" with a cross-sectional area of
8 1,113 thousand Kcmils for the 500 kV line segments. This subconductor consists of
9 aluminum strands supported by steel strands, referred to by the acronym "ACSS,"
10 and is rated for operation up to a temperature of 250 degrees Celsius. The diameter
11 of the Finch semiconductor is 1.29 inches, and its weight is 1.43 lbs. per foot, which
12 equates to 4.29 lbs. per foot of three-wire conductor. The rated breaking strength of
13 each high strength Finch subconductor is 33,200 pounds. The planned three Finch
14 subconductor phase bundle meets TrAILCo's electrical performance objectives for
15 TrAIL and will integrate well with Dominion Virginia Power's planned design for
16 the Loudoun Segment. For the Prexy 138 kV Lines, TrAILCO is specifying the use
17 of an aluminum conductor that is steel reinforced. This type of conductor is referred
18 to in the electric industry by the acronym "ACSR" and is rated to operate at
19 temperatures of up to 100 degrees Celsius. The ACSR conductor for the 138 kV
20 lines is 954.0 thousand circular mils ("Kcmil") and referred to by the code name
21 "Rail." The Rail conductor specified for the 138 kV lines is a standard conductor
22 specified in Allegheny Power standards for use on the construction of new 138 kV
23 lines. I will explain in detail later in my testimony how Allegheny Power standards

1 will be incorporated into the TrAIL project. Rail has a diameter of 1.17 inches,
2 weighs 1.08 pounds per foot, and has a rated breaking strength of 25,900 pounds.
3 The 138 kV lines will only have one Rail conductor per structure phase position.

4 Q. WILL TRAIL INCLUDE ANY ADDITIONAL OVERHEAD WIRES AND, IF
5 SO, WHAT WILL BE THE PURPOSE OF THOSE WIRES?

6 A. Two shield wires, also referred to as overhead ground wires, will be installed above
7 the 500 kV conductors planned for TrAIL. Shield wires provide lightning protection
8 for transmission circuits by intercepting direct lightning strikes that would otherwise
9 terminate on the conductors. Any such lightning strikes will, instead, travel along
10 the shield wire in each direction to the adjacent grounded support towers and then
11 dissipate into the ground through the towers, thus protecting the circuit's operation
12 from the effects of lightning. For the Prexy 138 kV Lines, the standard shield wire
13 will be a 12.5 M aluminum-clad steel wire which has properties that are nearly the
14 same as 7#9 aluminum-clad wire. The 12.5 M aluminum-clad wire is 0.34 inches in
15 diameter, weighs 0.21 pounds per foot, and has a minimum breaking strength of
16 12,500 pounds. The 12.5 M aluminum-clad wire is also an Allegheny Power
17 standard shield wire for constructing new 138 kV lines.

18 Q. WILL THE LINE INCORPORATE ANY OF ALLEGHENY POWER'S
19 EXISTING ENGINEERING AND DESIGN STANDARDS?

20 A. Yes. Collectively, Allegheny Power's three operating companies – Mon Power,
21 Potomac Edison, and West Penn Power Company – operate and maintain
22 approximately 700 miles of 500 kV lines throughout its service territory. Moreover,
23 Allegheny Power operates and maintains over 4,000 miles of high voltage

1 transmission lines operating at 138 kV and above. TrAILCo will adopt all
2 applicable construction standards, material and service specifications, and
3 maintenance practices that Allegheny Power already has in place to construct,
4 operate, and maintain its transmission system.

5
6 DETAILED SPECIFICATIONS

7 Q. PLEASE DESCRIBE THE "HORIZONTAL CONFIGURATION" FOR THE
8 THREE CONDUCTOR PHASES AND WHY THIS CONFIGURATION WAS
9 SELECTED FOR THE TRAIL 500 KV SEGMENTS.

10 A. A horizontal configuration indicates that the three separate conductor phases are
11 attached to the tower structures in a horizontal plane such that each phase is
12 equidistant from the ground. The horizontal phase configuration is consistent with
13 the type of tower structure planned for TrAIL and is also consistent with much of
14 the existing transmission facilities on Allegheny Power's system. This
15 configuration was selected for TrAIL because Allegheny Power currently operates
16 slightly less than 700 miles of transmission circuits in this type of configuration,
17 and it has proven to be extremely reliable over more than 40 years of operations.
18 Moreover, this configuration will also provide a structure with similar
19 maintenance and restoration characteristics to those that already exist on
20 Allegheny Power's 500 kV system. Allegheny Power's maintenance crews are
21 trained for and experienced with conductor phases in the horizontal configuration,
22 including the conduct of maintenance while the line is energized. Some of these
23 same crews will also provide these services to TrAILCo.

1 Q. PLEASE DESCRIBE WHAT IS MEANT BY A "VERTICAL
2 CONFIGURATION" FOR THE THREE CONDUCTOR PHASES FOR THE
3 PREXY 138 KV LINES AND WHY THIS CONFIGURATION WAS
4 SELECTED FOR THESE SEGMENTS OF TRAIL.

5 A. A vertical configuration indicates that the three separate conductor phases are
6 attached to the supporting structure in a near vertical plane such that each phase
7 is an equidistant vertically above the other. This type of configuration allows a
8 double circuit or two parallel lines to be placed on a narrower right-of-way when
9 both circuits are attached to a single structure. For example, a double circuit line
10 *configured in horizontal arrangement on separate structures would require a 170*
11 *foot wide right-of-way, whereas right-of-way can be reduced to 100 feet when in*
12 *a vertical configuration and both circuits are attached to one structure as is*
13 *proposed for the TrAIL 138 kV lines coming out of the Prexy Substation.*

14 Q. PLEASE DESCRIBE THE SPECIFIC DESIGN OF THE TOWER
15 STRUCTURES PLANNED FOR THE 500 KV SEGMENTS OF TRAIL.

16 A. As I have already indicated, TrAILCo plans to utilize self-supporting lattice steel
17 towers as the support structures for the transmission line conductors. TrAILCo
18 anticipates using various tower heights ranging anywhere from less than 70 feet
19 to over 200 feet in height above ground level. The towers will be made up of
20 either suspension towers or dead-end towers depending on the strength
21 requirements at each specific structure location. A suspension tower is designed
22 to equally balance the horizontal component of the conductor tension on each
23 side of the suspension tower, similar to a clothes prop holding up a clothesline.

1 A dead-end tower, on the other hand, is designed to terminate the full horizontal
2 tension of the conductors at the conductor attachment point on the structure,
3 similar to a clothes line tied off to a house or pole. Moreover, the dead-end tower
4 is designed to support this horizontal design tension imbalance on the structure
5 indefinitely. The suspension towers will be capable of supporting line deflection
6 angles up to 30 degrees and dead-end towers will be capable of supporting line
7 deflection angles up to 90 degrees. The towers for TrAIL will be designed to
8 accommodate span lengths – the distance from one tower to the next – in excess
9 of 2,000 feet to allow for the flexibility that will be required by the different
10 terrain conditions, elevations, and river or other crossing lengths that will be
11 faced during the course of TrAIL's actual construction. The average height of all
12 500 kV towers over the entire length of TrAIL is anticipated to be approximately
13 125 feet. TrAILCo Exhibit No. JRB-2 to my testimony is a twelve-page
14 document consisting of graphical engineering sketches for each of the five 500
15 kV tower types planned for use on TrAIL, along with five 500 kV tubular pole
16 structures that will be used if design constraints are encountered during the
17 detailed engineering phase of TrAIL.

18 Q. PLEASE DESCRIBE THE SPECIFIC DESIGN OF THE TUBULAR STEEL
19 STRUCTURES PLANNED FOR THE PREXY 138 KV LINE SEGMENTS OF
20 TRAIL.

21 A. TrAILCO will utilize self-supporting tubular steel mono-poles for the Prexy 138
22 kV Line segments, which is a structure that is used throughout Allegheny
23 Power's operating system to support 138 kV facilities. The structures will be

1 fabricated using CorTen[®] weathering steel having properties that meet ASTM
2 Specification A588. Allegheny Power has a very good performance history
3 using tubular steel structures fabricated with weathering steel, and the structures
4 blend in well with the surrounding environment. The structures will form a
5 uniform protective rust coating that turns dark brown after a few weeks of
6 exposure to the elements. Allegheny Power has received positive feed back after
7 the installation of this type of structure in its mainly rural service territories.
8 Unlike lattice steel towers, which are fabricated to support a specified range of
9 loads, tubular steel structures are usually designed for site-specific loads. Two
10 types of 138 kV structure configurations will be used for the 138 kV lines that are
11 part of TrAIL. The first is a suspension structure, which is mainly used to
12 support the lines along route segments where there is no line angle. A suspension
13 structure can also be designed, however, to support loads from line angles in
14 excess of 30 degrees. The second tubular steel structure will be a dead-end or
15 strain structure. This type of structure is normally used at locations where the
16 line will change directions in excess of 30 degrees or to hold down the line
17 conductors when there is a potential uplift load. Based on preliminary
18 engineering and past designs, the average height of the 138 kV tubular structures
19 is estimated to be around 110 feet above ground, and the maximum width of the
20 structure is estimated to be approximately 26 feet across at the middle conductor
21 attachment arm. The typical range of sizes for all proposed structures can be
22 found in TrAILCo Exhibit No. JRB-2 attached to my testimony.

1 Q. HOW MANY TOWER STRUCTURES WILL TRAIL REQUIRE?

2 A. TrAILCo presently estimates that approximately 900 individual structures will be
3 required for the 500 kV segments of TrAIL, and of the 900 structures, around
4 160 are estimated to be located within Pennsylvania. Based on past designs and
5 the proposed route for TrAIL, the preliminary estimate is that approximately 15
6 percent of all TrAIL towers will be of the dead-end design described above for
7 those instances when the project's right-of-way changes direction from a
8 substantially straight stretch of travel. A more exact proportion of dead-end
9 versus suspension towers for the entire length of TrAIL will not be known,
10 however, until the detailed design and construction phases for the project. For
11 the Prexy 138 kV Lines, TrAILCo presently estimates approximately 100
12 individual structures will be required, all located within Washington County,
13 Pennsylvania.

14 Q. PLEASE DESCRIBE THE STRUCTURAL MATERIALS AND DIMENSIONS
15 FOR THE LATTICE STEEL TOWERS.

16 A. The lattice steel towers will be fabricated from mainly 36 and 50 ksi galvanized
17 steel. Based on preliminary engineering, a typical structure will be
18 approximately 40 to 45 feet in width at the base and nearly 85 feet in width at the
19 cross-arm.

20 Q. WHAT OTHER DESIGN PARAMETERS WILL THE TOWERS
21 ACCOMMODATE?

22 A. All tower structures for TrAIL will meet or exceed all of the design parameters
23 for such facilities, as defined in latest edition of the National Electric Safety Code

1 ("NESC"). Section 010 of the NESC, for example, states that "[t]he purpose of
2 these rules is the practical safeguarding of persons during the installation,
3 operation, or maintenance of electric supply and communication lines and
4 associated equipment. These rules contain the basic provisions that are
5 considered necessary for the safety of employees and the public under the
6 specified conditions." All TrAIL towers will be designed to meet the ice and
7 wind loads for heavy loading districts under the NESC. The towers will also be
8 designed to carry the maximum conductor loads anticipated at each structure
9 location for the design conductors and line configuration. The towers will also
10 be designed to provide sufficient clearances between the three conductor phases
11 to allow for the performance of service and maintenance with the conductors
12 energized ("live" line work). Finally, all towers will provide sufficient height to
13 allow adequate conductor to ground clearance for the safe and reliable operation
14 of TrAIL. The detailed design requirements for TrAIL are presented in my
15 TrAILCo Exhibit No. JRB-1.

16 Q. PLEASE DESCRIBE THE PLANNED FOUNDATIONS FOR THE TOWER
17 STRUCTURES.

18 A. The 500 kV tower structures will be anchored in place either by concrete
19 foundations or grillage foundations. The most common type will be the concrete
20 caisson foundation. Other types of concrete foundations will be a pad-and-pier
21 foundation and a micro pile and cap foundation. The grillage foundations are
22 essentially a reinforced steel mat that is buried below ground to support or
23 restrain the loads transferred through the tower leg to the foundation. Overall site

1 and soil conditions will dictate the appropriate foundation required at each
2 footing location. The 138 kV steel pole structures will utilize a single concrete
3 foundation for support. The most common type of foundation used for this type
4 of construction across Allegheny Power's service territories is the concrete
5 caisson foundation. A pad-and-pier foundation or rock socket foundation may
6 also be employed for this type of structure if the geotechnical conditions warrant
7 their use. Like the 500 kV structures, overall site and soil conditions will dictate
8 the appropriate foundation required at each footing location on the 138 kV lines.

9 Q. PLEASE DESCRIBE THE VOLTAGE, AMPACITY, TEMPERATURE AND
10 OTHER ELECTRICAL PARAMETERS AT WHICH THE 500 KV
11 CONDUCTORS WILL OPERATE AND HOW THESE PARAMETERS WILL
12 CONFORM TO THE NESC.

13 A. First, the voltage of the 500 kV line segments is rated at a nominal voltage of 500
14 kV and will be denoted on all engineering drawings and system maps as a 500
15 kV line. This is the root mean square phase-to-phase operating voltage of the
16 line. Based on the nominal 500 kV voltage, a maximum over voltage of 110
17 percent of the nominal voltage is used for NESC clearance calculations.
18 Therefore, 550 kV phase-to-phase voltage or the equivalent phase-to-ground or
19 crest operating voltage is used to determine the minimum electrical clearances
20 required. The ampacity of the line is the current-carrying capacity of an electric
21 conductor under stated thermal conditions and is measured in amperes (amps).
22 Based on the line rating methodology adopted for TrAIL, the line conductors will
23 be graded to operate safely operate at a maximum temperature of 250 degrees

1 Celsius (482 degrees Fahrenheit). The resulting 250 degrees Celsius will be the
2 maximum thermal operating limit of the conductors and all design clearances to
3 ground will be based on the conductor design temperature of 250 degrees
4 Celsius. The 250 degree Celsius design temperature is the design condition which
5 produces the maximum sag in the Finch-HS ACSS conductor. Therefore, as per
6 Section 232.A of the NESC, this condition will be used for vertical clearance
7 calculations of the conductors above ground, roadways, railroads, and water
8 surfaces. In summary, (i) the design voltage is used to calculate the amount of
9 clearance required per the NESC, (ii) the rated amperage or electrical loading of
10 the line is the design variable that is used to calculate the thermal operating
11 temperature of the conductor, and (iii) the operating temperature is the design
12 variable that is used to calculate the maximum sag of the line at high operating
13 temperatures. Finally, all three of these design criteria are used collectively to
14 insure that the required NESC clearances are not violated.

15 Q. PLEASE DESCRIBE THE VOLTAGE, AMPACITY, TEMPERATURE AND
16 OTHER ELECTRICAL PARAMETERS AT WHICH THE 138 KV
17 CONDUCTORS WILL OPERATE AND HOW THESE PARAMETERS WILL
18 CONFORM TO THE NESC.

19 A. First, the voltage of the 138 kV line segments is rated at a nominal voltage of 138
20 kV and will be denoted on all engineering drawings and system maps as 138 kV
21 lines. As previously stated, this again is the root mean square phase-to-phase
22 operating voltage of the lines. Based on the nominal 138 kV voltage, a maximum
23 over voltage of 105 percent of the nominal voltage is used for NESC clearance

1 calculations. Therefore, 144.9 kV phase-to-phase voltage or the equivalent
2 phase-to-ground or crest operating voltage is used to determine the minimum
3 electrical clearances required. Based on the line rating methodology adopted for
4 TrAIL, the 138 kV line conductors will be graded to safely operate at a maximum
5 temperature of 100 degrees Celsius (212 degrees Fahrenheit). The resulting 100
6 degrees Celsius will be the maximum thermal operating limit of the conductors
7 and all design clearances to ground will be based on the conductor design
8 temperature of 100 degrees Celsius. As with the 500 kV lines mentioned
9 previously, the 100 degree Celsius design temperature is the design condition
10 which produces the maximum sag in the Rail ACSR conductor. Pursuant to
11 Section 232.A of the NESC, therefore, this condition will be used for vertical
12 clearance calculations of the conductors above ground, roadways, railroads, and
13 water surfaces. Since the Rail conductor is a standard conductor for new 138 kV
14 lines in Allegheny Power's operating territories, the ampacity of the 138 kV lines
15 will be based on standard operating load tables that will ensure that the thermal
16 limits of the line are not exceeded during routine operation.

17 Q. PLEASE DESCRIBE THE MINIMUM LINE TENSION AND SAG
18 PARAMATERS FOR THE CONDUCTORS PLANNED FOR THE PROJECT.

19 A. The line tensions are also governed by the NESC. The NESC allows the
20 conductor to be loaded up to 60 percent of the conductor's ultimate strength
21 rating at the NESC defined loading case, which is the heavy loading case for the
22 TrAIL project area. However, the conductor tensions for TrAIL will be kept well
23 below the NESC permitted conductor loading. TrAIL maximum design loading

1 will be around the 40 percent of maximum design range. The conductor design
2 tensions for TrAIL will be limited to the lower ranges of maximum design
3 strengths for these materials to control the Aeolian vibration effects on the
4 conductors. This, in turn, will allow TrAILCo to keep the required strength of
5 the dead-end tower structures within a reasonable range. Aeolian vibration is a
6 high frequency low amplitude vibration caused by wind on the conductors. The
7 mechanical energy resulting from the vibration is dissipated by the use of
8 mechanical damping devices or lowering the tension in the conductors as much is
9 practical, or a combination of both. If left unchecked, this phenomenon causes
10 premature conductor and hardware failures on a line that is not properly
11 designed. As stated in my responses to the two previous questions, this line will
12 be designed to operate with conductor temperatures of up to 250 degrees and 100
13 degrees Celsius for the 500 kV and 138 kV lines, respectively. The tension of the
14 line is inversely related to temperature. As the operating temperature of the line
15 increases, the tension of the line decreases. Therefore, at maximum operating
16 temperatures, the lines will be at their lowest operating tensions. Similarly, the
17 tension is also inversely related to conductor sag. As the tension decreases, the
18 sag increases. Consequently, the right-of-way for the line will be graded and
19 individual tower structures will be placed along the right-of-way such that TrAIL
20 will meet NESC design clearances when at their minimum tensions or maximum
21 sags.

1 Q. PLEASE DESCRIBE THE MINIMUM CONDUCTOR-TO-GROUND
2 CLEARANCES UNDER MAXIMUM OPERATING CONDITIONS THAT
3 TRAIL'S DESIGN WILL MEET.

4 A. The conductor to ground clearances for TrAIL, both the 500 kV and the 138 kV
5 segments, will exceed the clearance requirements outlined in Section 23 of the
6 NESC. Minimum clearance requirements will vary based upon the type of terrain
7 or obstacle TrAIL crosses. For example, the minimum NESC conductor to
8 ground clearance for roads, spaces subject to pedestrian traffic, and other land
9 areas is 25.9 feet for 500 kV lines and 20.9 feet for 138 kV lines. The required
10 clearance over water areas not suitable for boating is 24.4 feet for 500 kV lines
11 and 19.1 feet for 138 kV lines. A complete listing of minimum clearances for
12 TrAIL is presented in Tables 1a and -b of TrAILCo Exhibit No. JRB-1 to my
13 testimony.

14 Q. PLEASE DESCRIBE THE INSULATORS AND OTHER ATTACHING
15 HARDWARE THAT WILL BE SELECTED FOR TRAIL.

16 A. For reliability purposes, porcelain or toughened glass insulators will be used for
17 TrAIL's 500 kV lines. This type of insulator will also be used on the 138 kV
18 lines' dead-end structures. The 138 kV suspension structures will utilize a
19 polymer or synthetic insulator pursuant to Alleghney Power's specifications for
20 these lines. All conductor attachment hardware will be standard galvanized steel
21 hardware. All clamps will be aluminum alloy connectors capable of supporting
22 conductors in operation up to 250 degrees Celsius. All 138 kV conductor clamps

1 will be aluminum alloy connectors capable of supporting conductors in operation
2 up to 100 degrees Celsius.

3 Q. PLEASE DESCRIBE, IN MORE DETAIL, THE TYPE AND SIZE OF
4 CONDUCTOR PLANNED FOR THE SHIELD WIRES.

5 A. One of the two shield wires on the 500 kV circuits may be a 7#6 aluminum clad
6 conductor. Aluminum-clad wire is a steel wire with a bonded outer layer of
7 aluminum which acts as a protective coating and electrical conductor. The 7#6
8 aluminum-clad conductor is 0.49 inches in diameter and has a unit weight of 0.42
9 pounds per foot. The rated breaking strength of the 7#6 aluminum-clad
10 conductor is 22,730 pounds. The other shield wire, or possibly both, will be an
11 optical ground wire referred to by the acronym "OPGW." The OPGW conductor
12 serves a dual purpose. First, as with the 7#6 aluminum clad shield wire, the OPGW
13 protects the phase conductors from direct lightning strikes. This is done with the
14 outer strands of the OPGW, which are aluminum-clad wire strands similar to those
15 used for the 7#6 aluminum-clad shield wire. Secondly, the OPGW conductor also
16 contains fiber optics in the core of the conductor protected by a hollow steel or
17 aluminum core. The fiber optics will be used for communication and control
18 functions and are not harmed by lightning strikes. The specific physical
19 parameters of the OPGW conductor are not known as this time, but the OPGW will
20 have design characteristics similar to the 7#6 aluminum-clad shield wire. For the
21 138 kV circuits, two 12.5 M aluminum-clad shield wires are used if OPGW is not
22 required. The 12.5 M aluminum-clad steel wire has properties that are nearly the
23 same as 7#9 aluminum-clad wire. The 12.5 M aluminum-clad wire is 0.34 inches in

1 diameter, weighs 0.21 pounds per foot, and has a minimum breaking strength of
2 12,500 pounds. The 12.5 M aluminum-clad wire is also an Allegheny Power
3 standard shield wire for new construction of 138 kV lines. As with the 500 kV
4 portion of TrAIL, one, or both of the 138 kV shield wires may be OPGW. If
5 OPGW is used, it will have mechanical design characteristics similar to the 12.5 M
6 aluminum-clad shield wire.

7 Q. WHAT SAFETY FEATURES HAVE BEEN INCORPORATED INTO THE
8 DESIGN AND CONSTRUCTION OF THE LINES?

9 A. The main safety features of TrAIL, once in operation, will be based on adhering to
10 the design parameters set forth in the latest edition of the NESC throughout the
11 design and engineering phases. Many of the requirements for structural loading,
12 structural strength, and electrical clearances are presented in Exhibit JRB-1 of my
13 testimony. Anticipating the construction phase of TrAIL, the senior management
14 of both TrAILCo and Kenny Construction Company of Chicago, Illinois, the
15 engineering, procurement, construction, and management contractor for TrAIL
16 (“Kenny”), have made it clear that the safety of all workers and the public shall
17 be given the highest priority at all times throughout the project. Both TrAILCo,
18 through Allegheny Power, and Kenny, which will be overseeing the construction
19 of TrAIL, have excellent safety programs already in place for their respective
20 organizations. Furthermore, TrAILCo and Kenny have formed a specific inter-
21 company safety team that is merging the best practices from each to form a safety
22 manual specific to TrAIL. All design personnel and contractors have been or
23 will be drug tested and safety trained before performing work on TrAIL. A field

1 safety audit will be a regular occurrence during all phases of construction and all
2 violations and/or suspect conditions will be logged in a database for trending
3 purposes and remedied immediately.

4 Q. PLEASE DESCRIBE THE RELATIONSHIP OF THE PROPOSED RIGHT-OF-
5 WAY WIDTHS YOU DESCRIBED EARLIER IN YOUR TESTIMONY TO
6 THE DESIGN AND NESC REQUIREMENTS FOR TRAIL.

7 A. The width of a right-of-way easement for transmission lines such as TrAIL is
8 determined by engineering design and NESC requirements. Easement widths are
9 based on the type of structure, expected span lengths, operating voltage of the
10 line, the amount of expected conductor sag, and clearance criteria specified in
11 Rule 234 of the NESC. Based on these design criteria, the right-of-way width for
12 the 500 kV segments in Pennsylvania in most, if not all areas, will be 200 feet, as
13 I stated previously in my testimony. There may be a few isolated spans that may
14 require either more or less right-of-way width. For any isolated cases, the width
15 will be increased or decreased for the specific design requirements of that
16 location. To facilitate the acquisition of right-of-way and to provide consistency
17 in line design, a standard easement width of 200 feet has been established. For
18 the 138 kV line segments, standard easement width will be 140 feet and, as I also
19 stated earlier, a 290 foot easement will be required in those instances where 500
20 kV and 138 kV facilities will be constructed within a single right-of-way.

1 Q. HOW DID TRAILCO DETERMINE THE 290, 200, AND 100 FOOT WIDTHS
2 FOR RIGHTS-OF-WAY?

3 A. Although the 200 foot easement width TrAILCO is planning is not specifically
4 addressed by the NESC, the requirement for horizontal clearance to buildings and
5 other structures is the primary design parameter in the determination of easement
6 widths for transmission lines. Since construction in areas immediately adjacent
7 to the right-of-way is uncontrolled, right-of-way limits must be established to
8 insure adequate clearances when conductors are displaced by wind loads as
9 specified in the NESC. Separation between multiple lines is also determined by
10 NESC requirements for clearances to adjacent structures and between wires
11 carried on different supports. The additional clearance required for increased
12 voltage and its application to conductors displaced by wind loading will generally
13 result in increased width requirements for lines of higher voltage and/or longer
14 spans with their subsequently greater sag and wind displacement. The minimum
15 horizontal clearances for TrAIL are listed in Table 2 of TrAILCO Exhibit No.
16 JRB-1. Graphical engineering sketches depicting the expected right-of-way
17 configurations for TrAIL in Pennsylvania are included in TrAILCo Exhibit No.
18 JRB-3 attached to my testimony.

19 Q. PLEASE DESCRIBE THE ANTICIPATED SLOPE OF THE RIGHTS-OF-
20 WAY FOR THE PENNSYLVANIA SEGMENTS.

21 A. Obviously, the slope at any point along the right-of-way will vary greatly
22 depending on the terrain. For the Pennsylvania line segments, much of the right-
23 of-way will be located in the mountainous and hilly terrain that is typical of

1 southwestern Pennsylvania, which means that in some cases the slope of the
2 right-of-way will exceed twenty degrees. At this time, a detailed topographic
3 aerial survey of the line route is in progress, and once the survey is available,
4 TrAILCo will be able to accurately calculate the amount of right-of-way that
5 exceeds 20 degrees of slope. In anticipation of the rugged terrain that TrAIL will
6 be crossing, the structures will be flown in by helicopter and grillage foundations
7 will be an available design alternate in lieu of concrete caisson foundations where
8 dictated by slope or other conditions. These construction techniques will allow
9 the contractor to minimize the size and quality of access roads required to each
10 *structure location due to the much smaller and lighter weight equipment that is*
11 *required at the structure location when these techniques are employed. This, in*
12 *turn, minimizes the disturbance required to construct the line especially in steep*
13 *slope locations. When the right-of-way areas exceed a 45-degree slope, the*
14 *clearing contractor is instructed to drop the trees and leave them in place where*
15 *they fall. This practice does not require any clearing equipment other than a*
16 *chainsaw operator and a chainsaw, which reduces the disturbance to the right-of-*
17 *way when clearing trees on steep slopes. Where necessary, all access roads will*
18 *be selected to minimize disturbance as much as practical. Finally, an approved*
19 *soil erosion control plan will be put in place to address all land disturbance*
20 *activities throughout the course of construction.*

CONSTRUCTION ACTIVITIES

1

2 Q. WOULD YOU PLEASE DESCRIBE, IN GENERAL TERMS, THE
3 CONSTRUCTION PROCESS FOR TRAIL.

4 A. TrAIL will be constructed according to a well-defined procedure that utilizes
5 *standard construction practices to perform all work safely and in compliance with*
6 OSHA Rules and Regulations, while keeping environmental impact to a
7 minimum. Project activities will include the installation and maintenance of soil
8 erosion and sedimentation control measures, access road construction, right-of-
9 way clearing, foundation, structure and wire installations, and the rehabilitation
10 of all areas disturbed during construction.

11 Q. WILL A CONSTRUCTION PROJECT CONTRACTOR AND/OR MANAGER
12 BE UTILIZED?

13 A. Yes. TrAILCo has awarded a contract for engineering, right-of-way services,
14 procurement, and construction, which is known in the construction industry as an
15 engineering, procurement, management, and construction (“EPC”) contract. The
16 EPC contract will be through one overall project manager who will oversee and
17 coordinate the numerous sub-contractors and service providers that are required
18 to complete a project of this size. As noted above, TrAILCo has selected Kenny
19 as the EPC contractor for TrAIL.

20 Q. HOW WILL TRAILCO OVERSEE AND MONITOR THE CONSTRUCTION
21 COSTS AND PROGRESS OF THE TRAIL PROJECT?

22 A. In addition to Kenny providing project management through the use of a widely
23 used construction project management software application known as Primavera

1 P3e. TrAILCo will require additional and regular reporting that will address,
2 among other things, percentage-of-completion by activity, man-hours utilized,
3 and construction expenditures on scheduled and actual bases.

4 Q. WHAT IS THE ESTIMATED COST TO SITE AND CONSTRUCT TRAIL?

5 A. The current high level total estimated cost to site and construct TrAIL is \$820
6 million. The high level budgetary breakdown of these estimated costs is \$794
7 million for siting, engineering and construction, and \$26 million for
8 administrative and legal expenses. The total estimated cost of the portion of
9 TrAIL within Pennsylvania is \$208 million, with \$204.3 million estimated for
10 siting, engineering, and construction and \$3.7 million for administrative and legal
11 costs.

12 Q. OVER WHAT TIME PERIOD WILL THE TRAIL PROJECT BE
13 CONSTRUCTED?

14 A. TrAILCo estimates that the entire project can be constructed over a four-year
15 period, with TrAIL then going into service during the year 2011, which is a
16 particularly aggressive schedule for siting, constructing, and placing into service
17 a major high voltage transmission line of this length much of which must be
18 constructed over challenging terrain and other conditions.

19 Q. TURNING TO CONSTRUCTION PLANNING, WILL TRAIL BE
20 CONSTRUCTED IN DISTINCT SECTIONS OR COMPONENTS AND, IF SO,
21 IN WHAT ORDER WILL THEY BE BUILT?

22 A. Yes. TrAILCo currently envisions three distinct construction phases for the
23 project, all of which will be built concurrently. The three phases are broadly

1 categorized according to their respective planned in-service-date (“ISD”). Phase
2 I will consist of all the segments of TrAIL with a planned 2009 ISD. Phases II
3 and III will consist of all TrAIL segments with ISDs of 2010 and 2011,
4 respectively. With the very tight construction time frames and the additional
5 complications of multiple regulatory jurisdictions, however, the actual scheduling
6 of construction activities may well need to be adaptable and dynamic. For
7 example, in order to have the entire project in service no later than the year 2011,
8 *initial construction activities may be prioritized towards those sections where*
9 *regulatory approvals have been granted and right-of-way has been acquired.*

10 Q. CAN YOU PROVIDE SOME ADDITIONAL DETAILS REGARDING THE
11 PROJECT SEGMENTS WITHIN EACH PHASE?

12 A. Yes, I can. Phase I will consist of the following project segments, all of which
13 are currently planned for an ISD of 2009 and some of which are described in
14 more detail later in my testimony:

- 15 • Prexy Substation - grade site and install 138kV breakers
- 16 • Prexy 138 kV Lines (five separate 138 kV circuit segments over three
17 routes)
 - 18 ○ Manifold-Houston 138 kV Line
 - 19 ○ Houston-Peters 138 kV Line
 - 20 ○ Prexy-Washington-Charleroi 138 kV Tap

21 Phase II will include all the segments of the project with an ISD of 2010,
22 *including:*

- 23 • Prexy Substation - installation of one 500/138 kV transformer, two 500 kV
24 breakers, and associated line terminals

25

- 1 • 502 Junction Switchyard - grade site, install eight 500 kV breakers for
2 Loudon and two 500 kV breakers for Prexy
3
- 4 • Reconfigure the existing 502 Junction 500 kV lines (Kammer, Harrison
5 and Ft. Martin)
6
- 7 • Prexy Segment (Prexy Substation to 502 Junction 500 kV Line) - install
8 37 miles of new 500 kV line
9

10 Finally, Phase III will be comprised of all the segments of the project with an ISD
11 of 2011, including.

- 12 • 502 Junction – Mt. Storm 500 kV Line (PA) - install one mile of new 500
13 kV line in Pennsylvania
14
- 15 • 502 Junction – Mt. Storm 500 kV Line (WV) - install 67 miles of new 500
16 kV line in West Virginia
17
- 18 • Mt. Storm – Meadow Brook 500 kV Line (WV) - install 50 miles of new
19 500 kV line in West Virginia
20
- 21 • Mt. Storm – Meadow Brook 500 kV Line (VA) - install 10 miles of new
22 500 kV line in Virginia
23
- 24 • Meadow Brook Substation - install two 500 kV terminals
25
- 26 • Meadow Brook – TrAIL End Point 500 kV Line (VA) - install 16 miles of
27 new 500 kV line in Virginia
28

29 Q. WHAT ARE THE SCHEDULED CONSTRUCTION PERIODS FOR THE
30 THREE PHASES YOU JUST DESCRIBED?

31 A. The scheduled construction periods, by phase, are:

- 32 • Phase I – February 2008 through October 2009;
- 33 • Phase II – February 2008 through September 2010; and,
- 34 • Phase III – February 2008 through June 2011.

1 Q. WHAT STEPS ARE PLANNED FOR MINIMIZING THE EFFECTS OF
2 CONSTRUCTION ON AREAS WITHIN AND OUTSIDE OF THE RIGHT-
3 OF-WAY, INCLUDING SUCH THINGS AS TRAFFIC AND OTHER LOCAL
4 COMMUNITY ISSUES?

5 A. All work will commence and be conducted in accordance with all state and local
6 permits, property releases, and approved special conditions. TrAILCo will, at all
7 times, minimize to the greatest extent possible the impacts of construction
8 activities on local communities.

9 RIGHT-OF-WAY CLEARING AND PREPARATION

10 Q. WHAT METHOD OR METHODS WILL BE USED TO CLEAR AND
11 OTHERWISE PREPARE THE RIGHT-OF-WAY FOR CONSTRUCTION?

12 A. The construction specifications adopted for TrAIL are designed to keep
13 environmental impact to a minimum. In addition to the implementation of Best
14 Management Practices (“BMPs”), TrAILCo’s efforts during the right-of-way
15 preparation phase of construction will include the following:

- 16 1. A copy of the Soil Erosion and Sedimentation Control Plan along
17 with the appropriate permit forms will be submitted to the Pennsylvania
18 Department of Environmental Protection for approval.
19
- 20 2. Soil Erosion and Sedimentation Control measures will be installed
21 prior to any earth disturbance.
22
- 23 3. Access roads will be installed in accordance with Allegheny
24 Power’s Specification MS 2500-1.
25
- 26 4. All disturbed soil will be temporarily seeded in accordance with
27 the erosion and sediment control (“E&S”) Plan and Allegheny Power
28 Material and Service Specifications.

1 5. The initial clearing will be performed in accordance with
2 Allegheny Power's Initial Clearing Specification MS 2400-3.

3
4 When required, TrAILCo's standard specifications will be modified and/or
5 amended to comply with all terms of the governing permits required to construct
6 TrAIL.

7 Q. WHAT DISTURBANCE OR DISPLACEMENT OF SOIL, TREES, CROPS OR
8 OTHER LIVING THINGS IS EXPECTED ALONG THE RIGHT-OF-WAY
9 AND HOW WILL TRAILCO DISPOSE OF SUCH MATERIALS?

10 A. In accordance with Allegheny Power Material and Service Specification MS
11 2400-03 – Initial Clearing of Transmission Lines, woody vegetation will be
12 removed from the full width of right-of-way and brush and logs will be piled
13 separately along the edges of the cleared right-of-way unless the right-of-way
14 release to construction specifies otherwise.

15 Soil materials removed from foundation excavations will be spread uniformly on
16 the right-of-way and blended in with the existing topography per Allegheny
17 Power Material and Service Specification MS 2600-02 – Placement of Concrete
18 Foundations. All disturbed areas will be rehabilitated in accordance with
19 Allegheny Power Material and Service Specification MS 2400-4 – Rehabilitation
20 of Right-of-Way.

1 Q. WHAT STEPS WILL BE TAKEN TO UPGRADE, SEED, OR OTHERWISE
2 RESTORE DISTURBED RIGHT-OF-WAY ONCE CONSTRUCTION IS
3 COMPLETE?

4 A. Following construction activities in an area, the right-of-way will be rehabilitated
5 during the various phases of construction in accordance with the Soil Erosion and
6 Sedimentation Control Plan and Allegheny Power Material and Service
7 Specifications MS 2300-3 and MS 2300-4. Soil Erosion and Sedimentation
8 control measures will not be permanently removed until seed germination is
9 sufficient to comply with erosion and sediment control plan requirements.

10 Q. PLEASE DESCRIBE THE STEPS THAT WILL BE TAKEN TO CONTROL
11 EROSION AND THE SILTATION OF STREAMS WHERE THE GROUND IS
12 DISTURBED DURING CONSTRUCTION ACTIVITIES ALONG THE
13 RIGHT-OF-WAY.

14 A. This will be accomplished using the soil erosion and sedimentation control
15 procedures outlined in Allegheny Power's Material and Service Specifications,
16 MS 2400-3, Initial Clearing of Transmission Lines, and MS 2500-1,
17 Construction Roads, Water Bars, and Diversion Channels. In addition, right-of-
18 way clearing equipment will not be permitted to operate near stream banks,
19 which will provide a buffer zone of undisturbed soil that will protect streams
20 from silt. In addition, TrAILCo will establish construction procedures to address
21 all applicable permit requirements as necessary.

TRAIL RIGHT-OF-WAY MAINTENANCE

1

2

Q. PLEASE DESCRIBE THE PROCEDURES THAT WILL BE EMPLOYED TO MAINTAIN TRAIL'S RIGHT-OF-WAY FREE OF VEGETATION AND TREES FOLLOWING THE COMPLETION OF CONSTRUCTION AND THE COMMENCEMENT OF OPERATIONS.

3

4

5

6

A. Allegheny Power currently utilizes three vegetation management contractors to accomplish its vegetation management goals. At any given time, several hundred men and women may be trimming and removing trees, clearing brush, and applying herbicides in an ongoing effort across the cities and suburbs and through the farmlands, forests and parklands within Allegheny Power's service territory and transmission zone, including along Allegheny Power's EHV transmission system. The methods and tools that are utilized may be as commonplace as the chain saw, brush hog, and aerial lift, or as specialized as trimming and herbicide spraying using helicopters. These same tools and methods will be utilized for TrAIL.

7

8

9

10

11

12

13

14

15

16

Q. UNDER WHAT GENERAL PARAMETERS WILL TRAILCO MAINTAIN THE TRAIL PROJECT RIGHT-OF-WAY?

17

18

A. Tall-growth vegetation within the line right-of-way will be removed before it causes a service interruption or interferes with line inspections or repairs. This task – typically referred to as “brush control” - may be accomplished by the use of herbicides, mechanical mowing, or hand cutting. Tree limbs that threaten to intrude into the right-of-way from trees growing outside the right-of-way will be trimmed before they pose a threat or cause damage to the line conductor or other

19

20

21

22

23

1 facilities. This “tree trimming” will be accomplished by a wide variety of
2 mechanical trimmers, manual trimming, or the aerial saw, as conditions require.

3 Entire trees, both within and outside of the right-of-way, will be removed when
4 they exhibit weakness or structural damage and thereby pose a high degree of risk
5 to the line’s uninterrupted service. This tree removal process will apply to any
6 dead or live tree hazard and/or danger tree, and will be accomplished using any
7 tool at TrAILCo’s disposal that can safely and quickly remediate the hazard.
8 TrAILCo’s overarching goal is to prevent all vegetation-caused service
9 interruptions at the lowest possible cost by removing potentially threatening
10 vegetation at the most advantageous time.

11 Q. WILL TRAILCO’S VEGETATION CONTROL PROCEDURES OBSERVE
12 SPECIFIC LEGAL OR REGULATORY STANDARDS?

13 A. Yes. The vegetation management procedures described above are designed to
14 ensure that TrAILCo complies with all required federal, state, and local vegetation
15 management standards. For example, the North American Electric Reliability
16 Corporation (“NERC”) Reliability Standard FAC-003-1 contains, among others, the
17 following requirements:

- 18 • Standard R1 requires TrAILCo to prepare and keep current
19 a formal transmission vegetation management program
20 (“TVMP”). Allegheny Power’s TVMP, which has been
21 adopted for TrAILCo purposes, includes objectives,
22 practices, approved procedures, and work specifications.
23
- 24 • Standard R1.1 requires TrAILCo to establish and adhere to
25 specific schedules for vegetation inspections by both aerial
26 and ground means. These schedules can be sufficiently
27 flexible to adjust for changing conditions and are based on
28 the anticipated growth rates of vegetation and any other

1 environmental or operational factors that could impact the
2 relationship of vegetation to the specific line.

3
4 • Standard R1.2 requires TrAILCo to identify clearances
5 between vegetation and any overhead ungrounded supply
6 conductors, taking into consideration transmission line
7 voltage, the effects of ambient temperature on conductor sag
8 under maximum design loading, and the effects of wind
9 velocities on conductor sway. Based upon these
10 measurements, TrAILCo will establish clearances that must
11 be achieved at the time of vegetation management work and
12 establish and maintain a set of clearances needed to prevent
13 flashover between vegetation and overhead ungrounded
14 supply conductors.

15
16 • Standard R.2 requires TrAILCo to create and implement an
17 annual plan for vegetation management work to ensure the
18 reliability of each line and overall transmission system. This
19 plan describes the methods used, such as manual clearing,
20 mechanical clearing, herbicide treatment, or other actions.
21 The plan must be flexible enough to adjust to changing
22 conditions, taking into consideration anticipated growth of
23 vegetation and all other environmental factors that may have
24 an impact on the reliability of the transmission systems.
25 Adjustments to the plan must be documented as they occur.
26 The plan must take into consideration the time required to
27 obtain permissions or permits from landowners or regulatory
28 authorities. Consequently, TrAILCo will have systems and
29 procedures for documenting and tracking the planned
30 vegetation management work and ensuring that the
31 vegetation management work was completed according to
32 work specifications.

33
34 Q. PLEASE DESCRIBE THE EXPECTED RIGHT-OF-WAY MAINTENANCE
35 CYCLE FOR TRAIL.

36 A. Given a transmission line's potential to affect a large number of customers,
37 Allegheny Power accords transmission line maintenance the highest maintenance
38 priority, and TrAILCo will give this same level of priority to its transmission
39 lines. Consequently, each mile of the TrAIL, along with Allegheny Power's

1 existing transmission circuits, will be inspected by an aerial over-flight not less
2 frequently than once a year. These aerial inspections are conducted by a
3 helicopters moving at a relatively lower ground speed, which enables the
4 experienced Allegheny Power engineering staff who accompany the flight crews
5 to carefully inspect these important transmission facilities. These inspections not
6 only monitor for conductor, splicing, insulator, and other hardware conditions,
7 but inspectors on board the aircraft also look for and note vegetation-growth
8 related concerns. In addition, these inspections are also used to note the
9 existence of potential danger trees outside of the right-of-way. All potential
10 equipment or vegetation issues noted during the inspections are forwarded to the
11 appropriate Allegheny Power transmission maintenance departments for the
12 development of work plans to respond to these conditions.

13 Q. WHAT ORGANIZATION WITHIN TRAILCO WILL MANAGE
14 VEGETATION CONTROL FOR THE TRAIL PROJECT?

15 A. The Transmission Forestry Group for Allegheny Power and TrAILCo will
16 establish a vegetation management plan for TrAIL. Vegetation management
17 plans are dynamic, individual documents that reflect program objectives and
18 vegetation conditions for a specific line. TrAILCo's vegetation management
19 plan will identify land use and vegetation conditions, predict future vegetation
20 management needs, and document variances and restrictions. The Transmission
21 Forestry Group will develop a long-term plan for TrAIL that will reflect a
22 proposed vegetation management schedule summarizing predicted vegetation
23 management needs for this specific line. The long-term plan will be periodically

1 reviewed and updated to incorporate changes required by local conditions and
2 regulatory requirements as they arise. Annual work plans are developed and
3 arise from an evaluation of the line's schedule of vegetation management
4 activities during the current year, the line's long range or long-term plan, and the
5 results of most recent inspections. A transmission forester responsible for
6 vegetation management oversight will be assigned to each line. Although
7 vegetation management cycles are used to predict general average time intervals
8 between maintenance activities, these cycles are to be used only as a guideline
9 for reviewing and planning needed vegetation management. Local conditions
10 will determine actual schedules.

11 Q. IF CHEMICAL SPRAYS OR OTHER CHEMICAL MEANS ARE PLANNED
12 FOR VEGETATION CONTROL, PLEASE DESCRIBE THE PROCEDURES
13 THAT WILL BE FOLLOWED TO PROTECT HUMANS, ANIMALS, AND
14 VEGETATION FROM INJURY OUTSIDE OF THE RIGHT-OF-WAY.

15 A. In addition to tree trimming and tree removal, vegetation management activities
16 will include brush control by either herbicide applications or manual cutting or
17 mowing. TrAILCo supports environmental sensitivity in all aspects of its
18 vegetation management program and will employ only sound management
19 practices. For example, TrAILCo will use herbicides specifically designed to
20 control unwanted plants, in a selective fashion, only in suitable portions of its
21 rights-of-way. Selective herbicide use will not destroy wildlife cover and food
22 supply. Herbicides that will be used on TrAIL have been scientifically designed
23 to work on enzymes found in plants only – not people or animals. TrAILCo will

1 use herbicides that will control targeted plants, since not all plants are affected by
2 every herbicide. For example, plants with woody stems, such as trees and brush,
3 can be targeted for control by choosing herbicides that have been manufactured
4 for that purpose. Herbicides planned for use on TrAIL promote the growth of
5 grasses and low-growing shrubs, the preferred habitat and food source of deer,
6 songbirds, rabbits and other animals.

7 Q. WILL THE SELECTED AND LIMITED USE OF HERBICIDES TO
8 CONTROL VEGETATION ON THE TRAIL RIGHT-OF-WAY POSE A
9 DANGER TO LIVESTOCK OR WILDLIFE?

10 A. No. The ingestion of herbicide-treated foliage by livestock and wildlife should
11 not be a problem. First, it is impossible for the animals to consume treated
12 foliage in amounts sufficient to obtain a harmful amount of any such herbicides
13 used. In addition, a high percentage of any herbicide on forage passes through
14 the animal's body within a short time. Herbicides, which are approved by and
15 registered with the Environmental Protection Agency, are important tools for
16 range and pasture weed and brush control across the country on private and
17 public land (including US Forest Service and Bureau of Land Management).
18 Further ensuring the safety of their use, TrAILCo will utilize trained
19 professionals for herbicide applications and will provide ongoing training to
20 ensure that all products and vegetation management methods are used correctly.
21 Finally, herbicide treatment is required only occasionally and in extremely
22 diluted forms and with modern application technologies. Research, combined

1 with many years of use, have demonstrated that the herbicide products that
2 TrAILCo expects to use are safe and effective.

3
4 TRAILCO'S TECHNICAL CAPACITY TO
5 CONSTRUCT AND OPERATE THE TRAIL PROJECT
6 TO SATISFACTORILY MEET THE PUBLIC NEED
7

8 Q. WOULD YOU ADDRESS TRAILCO'S TECHNICAL CAPABILITIES TO
9 CONSTRUCT AND OPERATE THE TRAIL PROJECT IN A MANNER THAT
10 SATISFACTORILY MEETS THE PUBLIC NEED FOR WHICH THE
11 PROJECT IS INTENDED?

12 A. Allegheny Power, through the affiliate West Penn Power Company, has provided
13 retail electric service to the public in Pennsylvania for many years. As I indicated
14 above in my testimony, Allegheny Power's three operating companies collectively
15 operate and maintain approximately 700 miles of existing 500 kV lines throughout
16 its service territory and over 4,000 miles of high voltage transmission lines operating
17 at 138 kV and above, as well. Through and with the resources of Allegheny Power,
18 TrAILCo will follow the existing engineering, construction, and post-commercial
19 service operations practices that Allegheny Power already has in place to construct,
20 operate, and maintain its transmission system. Consequently, the new facilities
21 under the TrAIL project will be incorporated into Allegheny Power's existing
22 operations in a seamless fashion and at the same high level of performance the
23 companies have continued to demonstrate.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

EXEMPTION FROM LOCAL ZONING REGULATION

Q. WHY IS TRAILCO SEEKING AN EXEMPTION FOR CERTAIN LOCAL ZONING REGULATIONS IN PENNSYLVANIA?

A. As I have been advised by counsel, an exemption is available in Pennsylvania from municipal zoning regulations for “any existing or proposed building, or extension thereof” of a public utility (*i.e.*, the limited extent to which municipal zoning regulation by law applies to the placement of public utility facilities), upon a finding and determination by the Commission “that the present or proposed situation of the building in question is reasonably necessary for the convenience and welfare of the public”. By this application, TrAILCo plans to design, construct, own, and operate the Prexy Substation in Washington County, and the 502 Junction Substation in Greene County, Pennsylvania. Each of these substation sites will have both a control building to house substation electric controls, metering and communications, and a maintenance building that will be used for performing maintenance on the electric equipment. The proposed buildings at the substations will be located within two Pennsylvania municipalities, North Strabane Township, Washington County and Dunkard Township, Greene County, each of which has enacted regulations pertaining to zoning. Since these buildings are clearly necessary and proper for the electric operation of the TrAIL project, they clearly satisfy the standards upon which the Commission may grant exemptions from local zoning regulations – *i.e.*, they are “reasonably necessary for the convenience and welfare of the public.”

1 Accordingly, TrAILCo requests that the Commission grant the necessary
2 exemptions in this proceeding.

3 Q. DOES THIS CONCLUDE YOUR DIRECT TESTIMONY?

4 A. Yes, it does. However, I reserve the right to file such additional testimony or
5 exhibits as may be necessary or appropriate.

**PROJECT DESIGN CRITERIA
TrAIL 500 KV AND 138 KV LINES**

Project Description

The TrAIL project is an overhead 500,000 volt line that will run from Washington County, PA and continue to Loudon, County, VA. A new substation called Prexy Substation will be constructed at the western terminus in Washington County, PA. The line will then proceed in a southern direction to a new switching substation in Green County, PA which will be called 502 Junction Substation. From this point the line will proceed into West Virginia and will continue in a south-southeast direction through West Virginia to an existing substation called Mount Storm; Mount Storm is owned and operated by Dominion Resources. From this point the line continues in an easterly direction out of West Virginia and into Virginia to Allegheny Power's Meadowbrook Substation. From this point will continue in an eastern direction to the Appalachian Trail which is the ownership transition point on the line. From this point Dominion Resources will assume ownership as the line route continues to the eastern terminus at Dominion's Loudon Substation.

In addition to the 500 kV portion of the project, there are three 138 kV line routes that will emanate from Prexy Substation in Washington County, PA and tie into existing 138 kV lines. All three line routes will consists of two electrical circuits per route. The structures proposed for these lines will be weathering tubular steel structures and each structure is capable of carrying two circuits per structure. All three 138 kV line routes will be entirely within Washington County, PA.

Right-of-Way Requirements

The 500 kV line portion of TrAIL will require a 200 foot-wide right-of-way in Pennsylvania. It is anticipated that unless other constraints dictate a change in width, either narrower or wider, the line right-of-way will be 200 feet in width. The 138 kV lines that are part of the TrAIL project will require a 100 foot-wide right-of-way per line route. Where the 500 kV line parallels a 138 kV line route, a 290 foot-wide right-of-way will be required. The Sketches of the proposed right-of-way configurations are contained in Exhibit JRB-3.

Clearances Above Ground, Roadway, Rail, or Water Surfaces

All requirements set forth in the National Electric Safety Code C2-2007 (NESC) for vertical clearances of conductors above ground, roadway, rail, or water surfaces will be met or exceeded. The required clearances will be based on a maximum operating voltage of 550 kV or 10 percent above the nominal rating of the line with the conductor at its maximum sag for the 500 kV line. The required clearances will be based on a maximum operating voltage of 145 kV or 5 percent above the nominal rating of the line with the conductor at its maximum sag for the 138 kV lines. In addition, TrAILCo will apply an applicable construction tolerance and field checks of the conductor sag to insure that all NESC

clearances are met. The minimum NESC vertical clearances for TrAIL are listed in Tables 1a and 1b.

In addition to the clearance requirements above, the clearances of the 500 kV line will be increased when necessary to meet the 5 mA criteria set forth in Rules 232 C.1.c and 232 D.3.c. The 5 mA criteria will be based on the largest state legal truck when the line is crossing a road, or the largest applicable piece of farm equipment anticipated under the line when crossing agricultural areas. As per the NESC, the conductor elevation above ground for the 5 mA criteria will be based on the resulting conductor sag when the operating temperature of the line is at 120 degrees Fahrenheit (50 degrees Celsius).

**Table 1a – 500 kV Vertical Clearance Requirements
When Below 5000 ft. in Elevation**

Nature of the Surface Underneath the Line		Clearance Required by NESC 232.D (ft.)
a.	Track of rails of railroads (except electrified railroads using overhead trolley conductors).	33.9
b.	Streets, alleys, roads, driveways, and parking lots.	25.9
c.	Spaces and ways subject to pedestrians or restricted traffic only	25.9
d.	Other land, such as cultivated, grazing, forest, or orchard, that is traversed by vehicles.	25.9
e.	Water areas not suitable for sail boating or where sail boating is prohibited.	24.4
f.	Water areas suitable for sail boating including lakes, ponds, reservoirs, tidal waters, rivers, streams, and canals with unobstructed surface area.	
f. (1)	Less than 20 acres.	27.9
f. (2)	Over 20 acres to 200 acres.	35.9
f. (3)	Over 200 acres to 2000 acres.	41.9
f. (4)	Over 2000 acres.	47.9
g.	In public or private land and water areas posted for rigging or launching sailboats, the reference height shall be 5 ft. greater than in f above, for the type of water areas serviced by the launching site.	
g. (1)	Less than 20 acres.	32.9
g. (2)	Over 20 acres to 200 acres.	40.9
g. (3)	Over 200 acres to 2000 acres.	46.9
g. (4)	Over 2000 acres.	52.9

**Table 1b – 138 kV Vertical Clearance Requirements
When Below 3300 ft. in Elevation**

	Nature of Surface Underneath Lines	Clearance Required by 232.B (ft.)
1.	Track of rails of railroads (except electrified railroads using overhead trolley conductors).	28.6
2.	Roads, streets, and other areas subject to truck traffic.	20.6
3.	Driveways, parking lots, and alleys.	20.6
4.	Other land traversed by vehicles, such as cultivated, grazing, forest, or orchards, etc.	20.6
5.	Spaces and ways subject to pedestrians or restricted traffic only.	16.6
6.	Water areas not suitable for sail boating or where sail boating is prohibited.	19.1
7.	Water areas suitable for sail boating including lakes, ponds, reservoirs, tidal waters, rivers, streams, and canals with unobstructed surface area.	
7a.	Less than 20 acres.	22.6
7b.	Over 20 acres to 200 acres.	30.6
7c.	Over 200 acres to 2000 acres.	36.6
7d.	Over 2000 acres.	42.6
8.	In public or private land and water areas posted for rigging or launching sailboats, the reference height shall be 5 ft. greater than in f above, for the type of water areas serviced by the launching site.	
8a.	Less than 20 acres.	27.6
8b.	Over 20 acres to 200 acres.	35.6
8c.	Over 200 acres to 2000 acres.	41.6
8d.	Over 2000 acres.	47.6

Clearances from Buildings, Bridges, and Other Installations

In addition to the vertical clearance specified in NESC Rule 232, the lines will be designed to meet the clearance requirements in NESC Rule 234 for the clearance of conductors from buildings, bridges, and other installations. These clearances are listed in Tables 2a and 2b below. Per rule 232A, these clearances shall be met when the conductor is at its maximum sag for vertical clearances and with the conductor displaced by a 6.0 pound per square foot wind (48.4 miles per hour) with the conductor temperature at 60 degrees Fahrenheit. As with the vertical clearance above ground, TrAILCo will apply an applicable construction tolerance and field checks of the conductor sag to insure that all NESC clearances are met.

Table 2a – 500 kV Clearances from Buildings, Bridges, and Other Installations When Below 5000 ft. in Elevation

Clearances of:		Clearance Required by 234.B, C, D, E or H (ft.)
a.	Buildings	
	Horizontal	12.9
	Vertical	20.9
b.	Signs, chimneys, radio and television antennas, tanks, and other installations not classified as bridges or buildings	
	Horizontal	12.9
	Vertical	20.9
c.	Superstructure of bridges	
	Horizontal	12.9
	Vertical	20.9
d.	Supporting structures of another line	
	Horizontal	14.9
	Vertical	17.9
e.	Dimension A of Figure 234-3 for swimming pools	
	Horizontal	
	Vertical	29.9
f.	Dimension B of Figure 234-3 for swimming pools	
	Horizontal	23.9
	Vertical	25.9

Table 2b – 138 kV Clearances from Buildings, Bridges, Rail Cars, Swimming Pools, and Other Installations When Below 5000 ft. in Elevation

Clearance of		Clearance Required by 234.B, C, D, or E (ft.)
Rule 234 B - Other Structures		
Clearance of Wires, Conductors, and Cables From Other Supporting Structures		
1.	Horizontal	7.2
2.	Vertical	7.7
Rule 234 C - Buildings		
1.	Buildings	
a.	Horizontal	
(1)	To walls, projections, and guarded windows	9.7
Table 2b Continued		
Rule 234 C – Buildings Continued		

(2)	To unguarded windows ⁸	9.7
(3)	To Balconies and areas readily accessible to pedestrians ³	9.7
b.	Vertical ¹⁴	
(1)	Over or under roofs or projections not readily accessible to pedestrians ³	14.7
(2)	Over or under balconies and roofs readily accessible to pedestrians ³	15.7
(3)	Over roofs accessible to vehicles but not subject to truck traffic ⁶	15.7
(4)	Over roofs accessible to truck traffic ⁶	20.7
2.	Signs, chimneys, billboards, radio and television antennas, tanks, and other installations not classified as buildings or bridges	
a.	Horizontal ⁴	
(1)	To portions that are readily accessible to pedestrians ³	9.7
(2)	To portions that are not readily accessible to pedestrians ³	9.7
b.	Vertical	
(1)	Over or under catwalks and other surfaces upon which personnel walk	15.7
(2)	Over or under other portions of such installations ⁴	10.2
Rule 234 D - Bridges		
1.	Clearance Over Bridges ¹	
a.	Attached ³	7.7
b.	Not attached	14.7
2.	Clearance beside, under, or within bridge structure ⁶	
a.	Readily accessible portions of any bridge including wing, walls, and bridge attachments ¹	
(1)	Attached ³	7.7
(2)	Not attached	9.7
b.	Ordinarily inaccessible portions of bridges (other than brick, concrete, or masonry) and from abutments ²	
(1)	Attached ^{3,5}	7.7
(2)	Not attached ^{4,5}	8.7
Rule 234 E - Swimming Pools		
A.	Clearance in any direction from the water level, edge of pool, base of diving platform, or anchored raft	27.2
B.	Clearance in any direction to the diving platform or tower	19.2
V.	Vertical clearance over adjacent land	
Table 2b Continued		
Rule 234 - Other Structures (With 6 lb/ft ² Wind at Final Sag at 60° F)		
1.	Clearance of Wires, Conductors, and Cables From Other Supporting Structures	

a.	Horizontal when displaced by wind	6.7
Rule 234 C - Buildings (With 6 lb/ft ² Wind at Final Sag at 60° F)		
1.	Buildings	
a.	Horizontal when displaced by wind	
(1)	To walls, projections, and guarded windows	6.7
(2)	To unguarded windows ⁸	6.7
(3)	To Blconies and areas readily accessible to pedestrians ³	6.7
2.	Signs, chimneys, billboards, radio and television antennas, tanks, and other istallations not classified as buildings or bridges	
a.	Horizontal ⁴ when displaced by wind	
(1)	To portions that are readily accessible to pedestrians ³	6.7
(2)	To portions that are not readily accessible to pedestrians ³	6.7
Rule 234 D - Bridges (With Wind)		
2.	Clearance beside, under, or within bridge structure ⁶	
a.	Readily accessible portions of any bridge including wing, walls, and bridge attachements ¹	
(1)	Attached ³	6.7
(2)	Not attached	6.7
b.	Ordinarily inaccessible portions of bridges (other than brick, concrete, or masonry) and from abutments ²	
(1)	Attached ^{3,5}	6.7
(2)	Not attached ^{4,5}	6.7

Proposed Structure Types

The proposed 500 kV structures will be galvanized self-supporting lattice steel structures with the conductors arranged in a horizontal configuration. This structure type is well suited to the terrain types expected along the proposed line route and has a proven reliability and performance record based on previous installations within Allegheny Power's service territory. Presently, Allegheny Power has just under 700 miles of this type of structure installed, and TrAIL will be using Allegheny Power standards when applicable. In addition to lattice structures, there may be the need for other 500 kV structure configurations when constraints do not permit the use of lattice towers. If or when the need arises, TrAILCo plans to use tubular steel structures to support the line conductors.

For the 138 kV lines, a weathering tubular steel structure capable of carrying two 138 kV circuits per structure is the proposed structure type. Table 3 below contains a summary of the structures that will or can be used on TrAIL. In addition, Exhibit JRB-2 shows a graphical representation of each structure type with typical heights and width ranges for each structure listed.

Table 3 – Structure Types

Structure Description	Construction Type	Material Type	Permissible Line Angle	Exhibit JRB-2 Figure No.
500 kV Horizontal Tangent Suspension Tower	Lattice	Galvanized Steel	0° to 2°	1
500 kV Horizontal 10 Degree Suspension Tower	Lattice	Galvanized Steel	2° to 10°	2
500 kV Horizontal 30 Degree Suspension Tower	Lattice	Galvanized Steel	10° to 30°	3
500 kV Horizontal 50 Degree Dead-end Tower	Lattice	Galvanized Steel	0° to 50°	4
500 kV Horizontal 90 Degree Dead-end Tower	Lattice	Galvanized Steel	50° to 90°	5
500 kV Delta Tangent Suspension	Tubular Steel	Galvanized, Weathering, or Painted	0° to 2°	6
500 kV Delta 10 Degree Suspension Pole	Tubular Steel	Galvanized, Weathering, or Painted	2° to 10°	7
500 kV Delta 30 Degree Suspension Pole	Tubular Steel	Galvanized, Weathering, or Painted	10° to 30°	8
500 kV Vertical 50 Degree Dead-end Pole	Tubular Steel	Galvanized, Weathering, or Painted	0° to 50°	9
500 kV Vertical 90 Degree Dead-end Pole	Tubular Steel	Galvanized, Weathering, or Painted	50° to 90°	10
138 kV Double Circuit Suspension Tubular Steel Pole	Tubular Steel	Galvanized, Weathering, or Painted	0° to 30°	11
138 kV Double Circuit Dead-end Tubular Steel Pole	Tubular Steel	Galvanized, Weathering, or Painted	0° to 90°	12

Structural Design Loads

At a minimum, all structures for TrAIL will be designed to support the loads produced from the load cases defined in Section 25 of the NESC along with the appropriate load factors defined in this section. Furthermore, the structure strength will be reduced by the reduction factors as outlined in Section 26 of the NESC for Grade B construction.

TrAIL falls entirely within the Heavy Loading District defined by the NESC and the loads for TrAIL will be based off of this loading district. However, for the extreme ice with

concurrent wind loading case defined by Rule 250D, TrAIL will cover multiple loading areas. To simplify this loading and to insure a higher level of reliability, TrAIL will use the greatest loading for wind and the greatest loading for ice for all areas within the TrAIL project area. This equates to 0.75 inches of radial ice with a concurrent 40 mile per hour wind.

The load cases, load factors, and strength factors for TrAIL are summarized in Tables 4, 5, and 6 below. These tables are a minimum requirement listing and may be added to or modified for special loading conditions anticipated along the proposed line route.

Table 4 - Load Cases

Load Case	Description	Ambient Temp. (° F)	Wind Pressure (psf)	Radial Ice ¹ (in.)
1	NESC Heavy – Rule 250B	0	4.00	0.50
2	NESC Extream Wind – Rule 250C	60	20.74	0.00
3	NESC Ice w/Wind –Rule 250D	15	4.10	0.75
4a.	500 kV Heavy Vertical	30	0.00	1.50
4b.	138 kV Heavy Vertical	30	0.00	1.25
5	Insulator Strength Check	0	4.00	0.50
6	Deflection Load	60	0.00	0.00
7	Longitudinal Unbalance	0	0.00	0.50
8	Stringing Unbalance	60	0.00	0.00
9	Full NESC Dead-end	0	4.00	0.50
10	Stringing Dead-end	0	0.00	0.00

¹ The unit weight of ice is defined as 57.0 pounds per cubic foot.

Table 5 - Load Factors

Load Case	Description	Vertical Load Factor	Transverse Load Factor	Wire Tension Factor
1	NESC Heavy – Rule 250B	1.50	2.50	1.65
2	NESC Extream Wind – Rule 250C	1.00	1.00	1.00
3	NESC Ice w/Wind –Rule 250D	1.00	1.00	1.00
4a	500 kV Heavy Vertical	1.00	1.00	1.00
4b	138 kV Heavy Vertical	1.00	1.00	1.00
5	Insulator Strength Check	1.00	1.00	1.00
6	Deflection Load	1.00	1.00	1.00
7	Longitudinal Unbalance	1.00	1.00	1.00
8	Stringing Unbalance	1.10	1.10	1.10
9	Full NESC Dead-end	1.50	2.50	1.65
10	Stringing Dead-end	1.25	1.25	1.25

Table 6 – Strength Factors

Load Case	Description	Metal Structures, Crossarms, & Braces	Wood Structures, Crossarms, & Braces	Support Hardware Factor	Guy Wire	Guy Anchor & Foundations	Insulators ¹
1	NESC Heavy – Rule 250B	1.00	0.65	1.00	0.90	1.00	0.00
2	NESC Extream Wind – Rule 250C	1.00	0.75	1.00	0.90	1.00	1.00
3	NESC Ice w/Wind –Rule 250D	1.00	0.75	1.00	0.90	1.00	1.00
4a	500 kV Heavy Vertical	1.00	1.00	1.00	1.00	1.00	1.00
4b	138 kV Heavy Vertical	1.00	1.00	1.00	1.00	1.00	1.00
5	Insulator Strength Check ¹	0.00	0.00	0.00	0.00	0.00	0.50
6	Deflection Load	1.00	1.00	1.00	1.00	1.00	1.00
7	Longitudinal Unbalance	1.00	1.00	1.00	1.00	1.00	1.00
8	Stringing Unbalance	1.00	1.00	1.00	1.00	1.00	1.00
9	Full NESC Dead-end	1.00	1.00	1.00	1.00	1.00	1.00
10	Stringing Dead-end	1.00	0.65	1.00	0.90	1.00	0.00

¹ Only strain and suspension insulators are proposed for this project. If post insulators are used, the strength factor shall be reduced to 0.40 for the vertical cantilever load.

Structure Identification and Safety Signs

All structures will be identified as required by Section 21 of the NESC. TrAIL structures will be marked in accordance with Allegheny Power Transmission & Distribution (“T&D”) Standard 20008. This standard can be referenced in Exhibit JRB-4. In addition, four danger signs stating to keep off of the structure will also be placed on each lattice steel structure which is also in accordance with the previously mentioned Allegheny Power T&D standard.

FIGURE 1 - TYPICAL 500KV TANGENT (0° - 2°) LATTICE SUSPENSION STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 2 - TYPICAL 500KV 10° LATTICE SUSPENSION STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 3 - TYPICAL 500KV 30° LATTICE SUSPENSION STRUCTURE





EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 4 - TYPICAL 500KV 50° LATTICE DEAD END STRUCTURE



NOTE:
FOUNDATION SIZE
WILL VARY DEPENDING
ON SOIL CONDITIONS

EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 5 - TYPICAL 500KV 90° LATTICE DEAD END STRUCTURE




FIGURE 6 - TYPICAL 500KV TANGENT (0° - 2°) STEEL DELTA STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 7 - TYPICAL 500KV 10° STEEL DELTA STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 8 - TYPICAL 500KV 30° STEEL DELTA STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 9 - TYPICAL 500KV 50° VERTICAL STEEL DEAD END STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 10 - TYPICAL 500KV 90° VERTICAL STEEL DEAD END STRUCTURE




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 11 - TYPICAL 138KV DOUBLE CIRCUIT TUBULAR STEEL POLE SUSPENSION STRUCTURE (0° - 30°)




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 12 - TYPICAL 138KV DOUBLE CIRCUIT TUBULAR STEEL DEAD END STRUCTURE (0° - 90°)




EXHIBIT JRB-2
TYPICAL STRUCTURES
SCALE: NTS

FIGURE 1 - TYPICAL 500KV LATTICE STEEL HORIZONTAL STRUCTURE LINE -
200 FOOT ROW, NO ADJACENT LINES




EXHIBIT JRB-3
TYPICAL RIGHT OF WAY
SCALE: NTS

FIGURE 2 - TYPICAL 500KV LATTICE STEEL HORIZONTAL LINE ADJACENT TO
138KV DOUBLE CIRCUIT TUBULAR STEEL VERTICAL LINE - 290 FOOT ROW




EXHIBIT JRB-3
TYPICAL RIGHT OF WAY
SCALE: NTS

FIGURE 3 - TYPICAL 138KV DOUBLE CIRCUIT TUBULAR STEEL VERTICAL LINE - 100 FOOT ROW










EXHIBIT JRB-3
TYPICAL RIGHT OF WAY
SCALE: NTS









ON DOUBLE CCT STRUCTURES A TAG WILL BE PLACED ON THE RIGHT AND LEFT LEGS



ON D. C. STRUCTURE TWO TAGS WILL BE USED. ATTACH TO RIGHT AND LEFT OF CENTER



THE TAGS SHOULD BE ATTACHED TO THE STRUCTURES AS FOLLOWS:
 WOOD - ATTACH WITH 4D AL NAIL (ITEM 290, S.N. 203663, 0.15LB/100)
 METAL - ATTACH WITH SCREW, DRIVE, U-METALLIC (ITEM 294, S.N. 200624)
 USE DRILL #29 (ITEM 295, S.N. 281540)



REASON FOR REVISION: ADDED AND/OR REVISED NOTES/DESCRIPTIONS



**TRANSMISSION
STRUCTURE AND CIRCUIT
IDENTIFICATION**

20008-1


DATE ISSUED:
08-30-2002

M
P
W

TRANS

AERIAL NUMBERING SIGNS

Attach aerial number signs on transverse faces of structure below conductor attachment. See erection drawing for member location.



Attach signs with:

- 3 - 1/2" x 1-1/4" Bolt (Stock No. 200438), Item 292
- 3 - Nut, 1/2" (Stock No. 204468), Item 234



Members may be field punched as needed.

AERIAL PATROL MARKER

Attach aerial patrol markers as near to top of structure as possible using:

- 2 - 1/2" x 1-1/4" Bolt (Stock No. 200438)
- 2 - Nut, 1/2" (Stock No. 204468)

Members may be field punched as needed.



AERIAL NUMBERING SIGNS

Attach with:


- 3 - 1/2" x 1-1/4" Bolt (Stock No. 200438)
- 3 - Nut, 1/2" (Stock No. 204468)

AERIAL PATROL MARKER

Attach each marker to specified structure with:

- 2 - 1/2" x 1-1/4" Bolt (Stock No. 200438)
- 2 - Nut, 1/2" (Stock No. 204468)

Mounting straps are attached to pole by manufacturer.



REASON FOR REVISION: CLARIFIED STOCK No 200428 DESCRIPTION

20008-2

**TRANSMISSION
STEEL TOWERS AND POLES
AERIAL NUMBERING SIGNS
AERIAL PATROL MARKER "X"**




TRANS

M P W DATE ISSUED:
11-10-2006

SINGLE OR MULTIPLE POLE STRUCTURES

SHIELD WIRE ATTACHMENT


VERTICAL NUMBER SIGNS
(Stock No. 104805 and No. 104801)



1. Two signs shall be placed on each structure, one on each longitudinal face of the pole as specified below.
2. On poles where a downlead is used, the downlead shall not touch the sign.
3. Two pole structure shall have vertical signs on the right pole; three pole structures on the center pole; and four pole structures on the right center pole.
4. Each sign is to be attached using:
3 - 5/16" x 2-1/2" lag screws (Stock No. 200903) Item 20
3 - 3/8" washers (Stock No. 208005) Item 22

AERIAL PATROL MARKER
(Stock No. 104807)

1. One sign per specified structure in advance of, and two signs per specified structure immediately before, each aerial hazard. See Engineering Manual Section 32, S.I. 5.0 for detailed information. (See layout below)
2. All warning signs to be visible approaching hazard.
3. Single pole structure - Attach above number, if used, or in number location.
4. Multiple pole structure - Attach to left outside pole, as looking towards approaching hazard.
5. Attachment:
2 - 5/16" x 2-1/2" lag screw (Stock NO. 200903) Item 20
2 - 3/8" washers (Stock No. 208005) Item 22



REASON FOR REVISION: REVISED SINGLE OR MULTIPLE POLE STRUCTURE NOTES





**TRANSMISSION
WOOD STRUCTURES
AERIAL NUMBERING SIGNS
AERIAL PATROL MARKER "X"**

20008-3

DATE ISSUED:
11-10-2006

M
P
W

TRANS



SIGN ATTACHMENT

Field drill, or punch two 7/16" holes for each sign.

NOTE: Can be installed on left face, if installation is better because of direction of steel angles.

BILL OF MATERIAL

ITEM	NUMBER REQUIRED	STOCK NUMBER	DESCRIPTION	NOTE	STANDARD CU-MU REFERENCE
296	8	200415	Bolt, Machine, 3/8" x 1-1/2" w/hex nut, 1-1/8" tread		
233	8	204236	Palnut, 3/8"		
22	8	208005	Washer, 3/8", galv.		
300	4	273819	Sign, "DANGER - KEEP OFF: HAZARDOUS VOLTAGE ABOVE"		

REASON FOR REVISION: REVISE ATTACHMENT MATERIAL

20008-4	TRANSMISSION TOWER DANGER SIGNS		
		M P W	DATE ISSUED: 05-31-2001
TRANSMISSION AND DISTRIBUTION CONSTRUCTION STANDARDS			

4/3/08 Pgh JK A-110172

BEFORE THE

PENNSYLVANIA PUBLIC UTILITY COMMISSION

IN RE: APPLICATION OF TRANS-ALLEGHENY :
 INTERSTATE LINE COMPANY FOR :
 (I) A CERTIFICATE OF PUBLIC CONVENIENCE :
 TO OFFER, RENDER, FURNISH AND/OR :
 SUPPLY TRANSMISSION SERVICE IN THE :
 COMMONWEALTH OF PENNSYLVANIA; :
 (II) AUTHORIZATION AND CERTIFICATION :
 TO LOCATE, CONSTRUCT, OPERATE AND :
 MAINTAIN CERTAIN HIGH VOLTAGE ELECTRIC :
 TRANSMISSION LINES AND RELATED ELECTRIC :
 SUBSTATION FACILITIES; (III) AUTHORITY :
 TO EXERCISE THE POWER OF EMINENT :
 DOMAIN FOR THE CONSTRUCTION AND :
 INSTALLATION OF AERIAL ELECTRIC :
 TRANSMISSION FACILITIES ALONG THE :
 PROPOSED TRANSMISSION LINE ROUTES :
 IN PENNSYLVANIA; (IV) APPROVAL OF AN :
 EXEMPTION FROM MUNICIPAL ZONING :
 REGULATION WITH RESPECT TO THE :
 CONSTRUCTION OF BUILDINGS; AND :
 (V) APPROVAL OF CERTAIN RELATED :
 AFFILIATED INTEREST ARRANGEMENTS :

Docket No. A-110172
 A-110172F0002
 A-110172F0003
 A-110172F0004
 G-000721229

REBUTTAL TESTIMONY OF
 JOHN R. BODENSCHATZ, P.E.

Re: Potential Gas Facility Mitigation Measures

RECEIVED
 2008 APR 14 PM 1:36
 PA PUC
 SECRETARY'S BUREAU

December 10, 2007

REBUTTAL TESTIMONY OF JOHN R. BODENSCHATZ, P.E.

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is John R. Bodenschatz. My business address is 800 Cabin Hill Drive,
3 Greensburg, Pennsylvania 15601-1689.

4

5 Q. HAVE YOU PREVIOUSLY SUBMITTED DIRECT TESTIMONY IN THIS
6 PROCEEDING ON BEHALF OF TRANS-ALLEGHENY INTERSTATE LINE
7 COMPANY ("TrAILCo")?

8 A. Yes.

9

10 Q. PLEASE DESCRIBE THE PURPOSE OF YOUR REBUTTAL TESTIMONY.

11 A. My rebuttal testimony addresses (i) the recommendations contained in the direct
12 testimonies of Columbia Gas of Pennsylvania, Inc. and Columbia Gas
13 Transportation Corporation (individually and collectively, "Columbia") witnesses
14 Richard W. Burke and Michael D. Spencer; (ii) the misconceptions about the
15 average tower heights for the 500 kV portion of TrAIL; (iii) how TrAILCo and
16 Allegheny Power intend to handle the possible impacts of subsidence associated
17 with prior underground mining activities along portions of the proposed TrAIL
18 route; and (iv) some public input testimony regarding the safety issues of gas
19 pipelines and high voltage electric power lines like TrAIL operating in close
20 proximity to each other.

1 Q. WILL THE USE OF VARIOUS TERMS IN YOUR REBUTTAL TESTIMONY
2 BE CONSISTENT WITH THE DEFINITIONS ASSIGNED TO THOSE TERMS
3 IN THE TABLE OF NOMENCLATURE ATTACHED TO TRAILCO
4 WITNESS FLITMAN'S DIRECT TESTIMONY AS TRAILCO EXHIBIT DEF-
5 1?

6 A. Yes. In addition, I may define other terms in my rebuttal testimony.
7

8 RESPONSE TO COLUMBIA GAS WITNESSES

9 Q. PLEASE SUMMARIZE THE COLUMBIA WITNESSES' RECOMMENDATIONS.

10 A. Both Columbia witnesses describe their concerns with potential impacts of TrAIL
11 on Columbia's gas distribution or transmission facilities either by way of "direct
12 physical conflict" or the potential for "interference" with Columbia's facilities
13 from potential corrosion associated with electric currents. Columbia witness
14 Burke recommends that the Commission require TrAILCo to submit detailed
15 engineering studies that will enable Columbia to determine the extent to which the
16 TrAIL route adversely affects Columbia's facilities, along with a specific plan to
17 mitigate any such effects. Columbia witness Spencer recommends that any
18 specific authority issued by the Commission that approves the TrAIL project or
19 TrAILCo's ability to exercise eminent domain should be specifically conditioned
20 upon TrAILCo's agreement to adhere to an acceptable plan to mitigate or
21 eliminate all identified issues created by the proximity of TrAIL project facilities
22 in proximity to Columbia's gas transmission pipelines.

23

1 Q. PLEASE SUMMARIZE ALLEGHENY POWER'S PRACTICE WHEN A NEW
2 ELECTRIC TRANSMISSION FACILITY IS PROPOSED TO BE
3 CONSTRUCTED IN CLOSE PROXIMITY TO AN EXISTING NATURAL GAS
4 PIPELINE AND INDICATE WHETHER TRAILCO WILL ADOPT THIS
5 PRACTICE.

6 A. Allegheny Power's past and current practice is to investigate and determine the
7 need for any alternating current ("AC") or direct current ("DC") mitigation
8 measures, which I will refer to generally as an AC/DC Mitigation Plan, for any
9 existing natural gas pipeline facilities that may come into close proximity with a
10 planned Allegheny Power transmission line. It has been Allegheny Power's
11 practice to address any need for an AC/DC Mitigation Plan as soon as the location
12 of any existing natural gas facilities is identified in close proximity to a planned
13 electric facility during the detailed design process for that new electric
14 transmission line. TrAILCo has adopted and will continue this same practice with
15 respect to TrAIL.

16

17 Q. HAS TRAILCO PREPARED ANY AC/DC MITIGATION PLAN FOR THE
18 TRAIL PROJECT AT THIS TIME?

19 A. No. TrAILCo has not identified any specific needs for AC or DC mitigation
20 measures at this time because the final routing and design for the TrAIL Project is
21 in an early stage and has not yet been completed. For example, the detailed
22 ground survey of the entire proposed TrAIL route is still in progress. Among the
23 primary purposes of this detailed survey will be the identification of marked

1 existing natural gas and any other utility facilities that may run parallel to or be
2 crossed by the final TrAIL route. Once any such facilities are identified, TrAILCo
3 will work with their owners to determine whether TrAIL will affect those facilities
4 and, if so, how to best mitigate any such effects. Where jointly determined to be
5 necessary, the final result of this dialogue would be an agreed AC/DC Mitigation
6 Plan that would be developed during TrAILCo's detailed engineering and design
7 process for TrAIL. Again, this is precisely the approach that has been followed by
8 Allegheny Power and implemented successfully for similar electric projects. To
9 my knowledge, Allegheny Power has never failed to reach a mutually agreeable
10 approach with an existing gas pipeline owner for mitigating the effects of a new
11 electric transmission line on that existing pipeline.

12
13 Q. WHAT ARE TYPICAL AC OR DC MITIGATION MEASURES?

14 A. Typical AC or DC mitigation measures include facilities that are retrofitted onto
15 existing natural gas pipelines or above-ground facilities. For in-ground gas
16 facilities, these measures can include cathodic isolation to protect natural gas
17 pipelines from ground fault currents or sacrificial magnesium or zinc anode systems
18 with a bentonite backfill to protect against corrosion of the existing gas pipeline.
19 For above-ground facilities, equipment such as zinc ribbon spiral systems to protect
20 pipeline employees and other third parties from the effects of induced electrostatic
21 charge on above-ground pipeline facilities have been installed on existing natural
22 gas or other utility facilities during past transmission line projects initiated by
23 Allegheny Power.

1 Q. HOW WOULD TRAILCO IDENTIFY AND DETERMINE ANY AC OR DC
2 MITIGATION MEASURES THAT MAY BE REQUIRED FOR THE TRAIL
3 PROJECT?

4 A. For the purposes of this answer, I will assume that an existing Columbia gas
5 pipeline would be identified as running in parallel with a segment of the final
6 TrAIL route. In such an instance, TrAILCo would work expeditiously with
7 Columbia to jointly determine whether the operation of TrAIL will necessitate any
8 mitigation measures on the Columbia facilities. As has been the past practice,
9 either Columbia or its independent consultant would prepare an electrical effects
10 study, develop a recommended AC/DC Mitigation Plan if the electrical effects
11 study warrants it, and provide cost estimates for installing any necessary
12 mitigation measures on the existing gas facilities. The objective of this study
13 process would be to establish an agreement between TrAILCo and Columbia
14 regarding the need for any mitigation measures and the estimated cost to install
15 them.

16
17 Q. UNDER THE HYPOTHETICAL SITUATION YOU JUST DESCRIBED, WHO
18 WOULD PAY FOR THE COSTS OF THE STUDIES AND THE RESULTING
19 INSTALLATION OF ANY MITIGATION MEASURES?

20 A. Consistent with current Allegheny Power practices, TrAILCo and Columbia would
21 reach an agreement on the costs for the studies and any mitigation measures.
22 Assuming such an agreement, TrAILCo would reimburse Columbia for its actual
23 reasonable costs for developing, or having an outside consultant prepare, the

1 studies that determine the need for any mitigation measures. TrAILCo would also
2 reimburse Columbia for the actual reasonable costs for installing any necessary
3 mitigation measures.

4

5 Q. WHAT WOULD BE THE PROTOCOL IF THE FINAL LOCATION OF TRAIL
6 REQUIRES THE RELOCATION OF ANY EXISTING NATURAL GAS
7 PIPELINE OR OTHER UTILITY FACILITIES?

8 A. If the final TrAIL route parallels or crosses over existing natural gas pipelines or
9 other utility facilities, from our experience, it is extremely unlikely that the
10 relocation of existing utility facilities would be required. For example, TrAILCo
11 would make every effort during the final engineering and design process to avoid
12 the relocation of an existing natural gas pipeline or other utility facility. It would
13 be far less disruptive to the existing utility facility and far more cost-effective for
14 TrAILCo to adjust the final placement of a tower structure during the design phase
15 so as to avoid requiring the relocation of an existing utility facility. In the unlikely
16 event of relocation, however, TrAILCo would negotiate a mutually acceptable
17 agreement with the owner of the existing facility regarding the proper protocol for
18 relocating the existing facility, including developing procedures and designs for
19 the relocation and a related cost estimate. Subject to such an agreement, TrAILCo
20 would reimburse the existing facility owner for the reasonable actual costs for
21 relocating the facilities.

1 Q. SHOULD THE RECOMMENDATIONS OF COLUMBIA'S WITNESSES BE
2 ADOPTED BY THE COMMISSION IN THIS PROCEEDING?

3 A. No. There are three primary reasons why the Commission should not adopt these
4 recommendations. First, the recommendations are unnecessary and, to the extent
5 Columbia requests that TrAILCo be required to adhere to a specific mitigation
6 plan that is acceptable to both Columbia and the Commission, such
7 recommendations could needlessly interfere with and deprive TrAILCo and the
8 existing utility facility owners the flexibility necessary to effectively address the
9 differing circumstances that will likely be presented in the field. Second, the
10 process TrAILCo intends to follow if existing natural gas or other utility facilities
11 are identified in close proximity to TrAIL during the ground survey and the
12 detailed design and engineering for the project, is precisely the same one that
13 Columbia witness Spencer describes as his requested action at page 11 of his
14 direct testimony, and is, in fact, the process that has been followed in similar
15 situations with other utilities, including Columbia. Third, to my knowledge,
16 Allegheny Power has never failed to reach a mutually agreeable approach with an
17 existing gas pipeline owner to mitigate the effects of a new electric transmission
18 line on an existing pipeline. TrAILCo has no reason to believe it will be unable
19 to do so in connection with the final TrAIL route. It is therefore unnecessary for
20 the Commission to condition any final authority to site the TrAIL project as
21 requested by Columbia.

1 AVERAGE TOWER HEIGHT ISSUES

2 Q. OCA WITNESS LANZALOTTA STATES AT PAGE 21 OF HIS DIRECT
3 TESTIMONY THAT THE PREXY 500 KV LINE WOULD BE 160 FEET
4 HIGH, WHILE 138 KV LINES ON THE ALLEGHENY POWER SYSTEM
5 ARE TYPICALLY LESS THAN 60 FEET. ECC WITNESS LOEHR
6 SIMILARLY OBSRVES THAT THE 500 KV TOWERS STRUCTURES FOR
7 TRAIL WILL BE 160 FEET TALL. DO YOU AGREE WITH THEIR
8 STATEMENTS OR CONCLUSIONS?

9 A. No, I do not agree. First, Mr. Lanzalotta overstates the typical height of the tower
10 structures planned for the 500 kV segments of TrAIL, as well as ECC witness
11 Loehr, who similarly states that the 500 kV structures would be 160 feet tall. In
12 fact, this value is 35 feet taller than the average 500 kV lattice tower structure
13 proposed for TrAIL. I previously testified at page 11 of my direct testimony,
14 TrAILCo Statement No. 7, that the average height of all 500 kV tower structures
15 over the entire length of TrAIL is anticipated to be approximately 125 feet. It is
16 still our expectation that the average height of all 500 kV tower structures for
17 TrAIL will be approximately 125 feet. Figures 1 through 5 of TrAILCo Exhibit
18 JRB-2 to my direct testimony graphically depict typical 500 kV lattice towers
19 with a typical height range of 72 to 177 feet above ground. Next, OCA witness
20 Lanzalotta incorrectly assumes that the tower structure for a 138 kV line -
21 described as typically 60 feet in height - would apply to his proposal to follow the
22 paths of existing 138 kV rights-of-way and add new conductors to existing towers
23 where possible. In fact, double circuit 138 kV tower structures would be much

1 taller. As Figures 11 and 12 of TrAILCo Exhibit JRB-2 indicate, the tubular steel
2 towers planned for the double circuit segments of TrAIL's 138 kV lines will be in
3 the range of 110 feet tall. To support their contentions that 138 kV lines would be
4 less intrusive, both witnesses have incorrectly overstated the typical tower
5 structure height planned for the 500 kV segments of TrAIL, and Mr. Lanzalotta
6 understates the 138 kV tower structure heights that would apply to his proposal.
7

8 SUBSIDENCE ISSUES

9 Q. A NUMBER OF WITNESSES AT THE PUBLIC INPUT HEARINGS
10 TESTIFIED ABOUT PREVIOUS MINING ACTIVITIES IN
11 SOUTHWESTERN PENNSYLVANIA AND THEIR POSSIBLE IMPACT ON
12 TRAIL. IF ENCOUNTERED ALONG THE PREFERRED LINE ROUTE, WILL
13 EXISTING DEEP MINES IN SOUTHWESTERN PENNSYLVANIA POSE A
14 RISK TO THE STABILITY OF THE PROPOSED TRANSMISSION
15 STRUCTURES?

16 A. No. A proper design and maintenance plan will virtually eliminate any risk
17 associated with deep mine activities that may be encountered along the preferred
18 TrAIL route. Allegheny Power's Transmission Maintenance Group has
19 effectively dealt with mining activities under its rights-of-way throughout its
20 service territory in Pennsylvania, as well as along transmission line rights-of-way
21 in West Virginia and Maryland. Specifically, Allegheny Power has successfully
22 managed the affects of subsidence from long wall mining activities underneath
23 existing 500 kV lines in Pennsylvania, and expects to do the same with respect to

1 TrAIL. While some minor damage may occur due to subsidence, repairs are
2 made before it would threaten the stability of the structure or the operation of the
3 line. Allegheny Power's experience and demonstrated success in planning for and
4 identifying issues with regard to subsidence will be equally applied to TrAIL.

5

6 Q. PLEASE ELABORATE ON THE ACTIONS TRAILCO WILL TAKE TO
7 MINIMIZE THE EXPOSURE OF TOWER STRUCTURES TO SUBSIDENCE-
8 RELATED INSTABILITY.

9 A. Any existing or proposed deep mines along the preferred TrAIL route can be
10 addressed with a number of design and engineering tools. First, a complete
11 geotechnical analysis of the entire preferred line route is in progress and existing
12 mined areas will be identified. Any deep mines identified will be further assessed
13 according to a number of factors, including the overall depth of the mine and the
14 ground cover over it, the size of the void represented by the mined area, the type
15 of mining that was carried out, and the extent of underground support that has
16 been left by the operator. Even where the line route passes over a deep mined
17 area, it may not pose a problem if the amount and type of existing cover over the
18 mined area is stable, the underground void area is not extensive, or if an adequate
19 amount of support has been left in place. A proactive approach that will be
20 available to TrAILCo, if necessary, would be to purchase and install sufficient
21 coal support under the location of a tower structure. In those instances where this
22 approach is feasible and can be carried out, it provides the benefit of removing
23 any potential risk associated with ongoing or future mining activities.

1 Q. ARE THERE SPECIFIC ENGINEERING AND DESIGN APPROACHES
2 THAT CAN MITIGATE THE RISK OF SUBSIDENCE-RELATED
3 INSTABILITY?

4 A. Yes. When an area that has been mined is identified as a potential subsidence
5 area, several engineering and design options are available to TrAILCo to address
6 and minimize this concern. Of course, the easiest solution is considered first,
7 which is to strive to avoid the placement of tower structures over an area of
8 concern. Where it cannot be avoided, a typical design response could be the use
9 of a "spread," or wider, footing for the tower structure in order to distribute the
10 structure load over a larger area. This serves to reduce the pressure applied by the
11 foundation on the underlying soil and subsidence-exposed area. Foundation
12 structures known as "Micropile" foundations may also be used to transfer the
13 structure loads through the mined void area, thereby eliminating the possibility of
14 foundation settlement if subsidence does occur at ground level. Another approach
15 could be "grout," or fill in, the void area under the structure foundation, which
16 then provides a foundational support to the overburden above the void area. This
17 practice in most cases eliminates the possibility of subsidence and can allow the
18 use of standard foundations.

1 SAFETY ISSUES BETWEEN GAS PIPELINES AND TRAIL

2 Q. WOULD YOU ADDRESS CONCERNS THAT WERE RAISED AT THE
3 PUBLIC INPUT HEARINGS, AND DURING SITE VISITS REGARDING THE
4 POSSIBLE AFFECTS OF TRAIL ON NATURAL GAS PIPELINES THAT
5 MAY ALREADY EXIST ALONG THE TRAIL RIGHT-OF-WAY?

6 A. Yes. At least one property owner – George Goroncy – described his concerns by
7 referring to an existing Equitable Gas pipeline on his property. He claimed that
8 this pipeline would be corroded by TRAIL-related voltages or currents. He also
9 expressed concerns about whether any leaks from his residential gas metering
10 equipment could be ignited by a “static spark or charge” from TrAIL. Mr.
11 Goroncy further claimed that the existing gas pipeline on his property is
12 approximately 300 feet from the proposed TrAIL right-of-way.

13

14 As the Columbia Gas witnesses indicate in their direct testimonies, current
15 mitigation procedures for steel gas lines that will be adjacent to or crossed by a
16 new electric transmission line are readily available and are completely effective as
17 a deterrent to any corrosive effects on those steel lines. As I have stated
18 previously, TrAILCo will cooperate with the owner of any existing gas or other
19 utility facility that may be crossed by TrAIL or situated in close proximity to it to
20 determine if any mitigation is necessary and, if so, to reimburse the facility owner
21 its reasonable costs for installing mitigation measures.

1 Mr. Goroncy's concerns about the effects of a possible static charge are addressed
2 in my direct testimony, TrAILCo Exhibit JRB-1, page 2, where I indicate that
3 TrAIL will conform to the National Electric Safety Code's 5 mA criteria in Rules
4 232 C.1.c and 232 D.3.c. These rules reflect the maximum allowable induced
5 current for TrAIL's right-of-way. Induced current at the 300 foot distance that
6 was described for the residential gas metering facilities would be extremely low,
7 if not undetectable. Consequently, static charge is not likely to be an issue for Mr.
8 Goroncy's residential gas facilities. Moreover, I presume those gas facilities have
9 been properly grounded in accordance with the applicable safety codes, which
10 provide further protection from any static discharge that might occur from any
11 other source.

12

13 Q. DOES THIS CONCLUDE YOUR REBUTTAL TESTIMONY?

14 A. Yes, it does. However, I reserve the right to file such additional testimony or
15 exhibits as may be necessary or appropriate.

TrailCo Rejoinder Statement No. 20-RJ
Witness: Mark S. Allen

4/3/08
Pbg
JIK

BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION

IN RE: APPLICATION OF TRANS-ALLEGHENY :
INTERSTATE LINE COMPANY FOR :
(I) A CERTIFICATE OF PUBLIC CONVENIENCE :
TO OFFER, RENDER, FURNISH AND/OR :
SUPPLY TRANSMISSION SERVICE IN THE :
COMMONWEALTH OF PENNSYLVANIA; :
(II) AUTHORIZATION AND CERTIFICATION :
TO LOCATE, CONSTRUCT, OPERATE AND :
MAINTAIN CERTAIN HIGH VOLTAGE ELECTRIC :
TRANSMISSION LINES AND RELATED ELECTRIC :
SUBSTATION FACILITIES; (III) AUTHORITY :
TO EXERCISE THE POWER OF EMINENT :
DOMAIN FOR THE CONSTRUCTION AND :
INSTALLATION OF AERIAL ELECTRIC :
TRANSMISSION FACILITIES ALONG THE :
PROPOSED TRANSMISSION LINE ROUTES :
IN PENNSYLVANIA; (IV) APPROVAL OF AN :
EXEMPTION FROM MUNICIPAL ZONING :
REGULATION WITH RESPECT TO THE :
CONSTRUCTION OF BUILDINGS; AND :
(V) APPROVAL OF CERTAIN RELATED :
AFFILIATED INTEREST ARRANGEMENTS :

Docket Nos. A-110172
A-110172F0002
A-110172F0003
A-110172F0004
G-000721229

RECEIVED
2008 APR 14 PM 1:36
PA PUC
SECRETARY'S BUREAU

REJOINDER TESTIMONY OF MARK S. ALLEN

Re: Line Clearance and Sag Issues

March 19, 2008

REJOINDER TESTIMONY OF MARK S. ALLEN

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Mark S. Allen and my business address is 120 Tredegar Street
3 Richmond, VA 23219.

4

5 DUTIES AND RESPONSIBILITIES

6 Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

7 A. I am Manager of the Transmission Line Engineering Group for Virginia Electric and
8 Power Company ("Dominion Virginia Power" or "Dominion").

9

10 Q. WHAT ARE YOUR RESPONSIBILITIES AS MANAGER OF TRANSMISSION
11 LINE ENGINEERING?

12 A. I am responsible for the coordination of all high voltage transmission designs
13 (overhead and underground) on the Dominion Virginia Power system. This includes
14 all new designs as well as upgrades and relocations. I manage the engineering
15 activities for each project to ensure completion of construction specifications by the
16 established target date. I am responsible for assuring that all such
17 designs/specifications meet the established criteria for safety, reliability, and cost
18 effectiveness.

1 EDUCATION AND PROFESSIONAL EXPERIENCE

2 Q. PLEASE DESCRIBE YOUR EDUCATIONAL BACKGROUND AND
3 PROFESSIONAL EXPERIENCE.

4 A. I received a Bachelor of Science Degree in Civil Engineering (*magna cum laude*)
5 from West Virginia University of Technology in 1981. I am a Registered
6 Professional Engineer in the states of Arizona, Connecticut, Kentucky, Michigan,
7 Ohio, Pennsylvania, Virginia, Utah and West Virginia. I have 26 years of experience
8 with the Company in both Transmission and Distribution. I started my career with
9 Dominion as a Project Engineer in Transmission Engineering in 1981. In 1985, I
10 moved to Distribution Planning as a Planning Engineer in the Eastern Division and
11 then returned to Transmission Engineering in 1989. I have experience in both
12 overhead and underground transmission design.

13

14 PURPOSE OF REJOINDER TESTIMONY

15 Q. PLEASE DESCRIBE THE PURPOSE OF YOUR REJOINDER TESTIMONY.

16 A. The purpose of my rejoinder testimony on behalf of Trans-Allegheny Interstate Line
17 Company ("TrAILCo") is to respond to ground clearance or line sag issues regarding
18 the 500 kV Mt. Storm-Doubs transmission line raised on page 11 of the surrebuttal
19 testimony of George C. Loehr filed as Energy Conservation Council of Pennsylvania
20 Surrebuttal Statement No. 1.

1 Q. CAN YOU GENERALLY DESCRIBE GROUND CLEARANCE OR LINE SAG
2 CONDITIONS IN CONNECTION WITH ELECTRIC TRANSMISSION LINES
3 AND HOW LINE SAG IMPACTS THOSE FACILITIES?

4 A. The National Electrical Safety Code ("NESC) establishes minimum requirements for
5 ground clearance, meaning the distance between the conductor (wire) and the
6 ground, that must be maintained at all times. Ground clearance for a line is
7 determined by how much the conductor sags between towers. As the temperature of
8 the conductor rises, the metal expands and the sag increases, reducing the ground
9 clearance. The wire temperature is a function of the ambient weather conditions and
10 the amount of current flowing in the conductor.

11

12 Q. DO YOU AGREE WITH MR. LOEHR'S ASSERTION THAT GROUND
13 CLEARANCE ISSUES ON THE MT. STORM-DOUBS LINE COULD BE
14 CORRECTED MERELY BY RETENSIONING THE CONDUCTORS?

15 A. No. I would first point out that the rejoinder testimony of TrAILCo witness
16 Hozempa shows that resolving ground clearance issues on this line would not, as
17 claimed by Mr. Loehr, resolve the reliability issues on this line that have been
18 identified in the planning studies. This is because the applicable maximum operating
19 temperature of 90° for this line would only permit a maximum transfer capability of
20 2910 MVA. Moreover, Mr. Loehr incorrectly assumes that ground clearance
21 violations can be corrected simply by "tightening up" or "retensioning" the

1 conductors, which indicates that he is not familiar with this line. The Mt. Storm-
2 Doubs line was constructed in 1964 using towers of corten steel. Unfortunately, this
3 material has proven to experience inherent corrosion problems that have left the
4 towers incapable of supporting the additional load that would result from
5 retensioning. Increasing the tension of the conductors on this 44 year old line would
6 increase the mechanical load on the deadend structures, which hold the full tension
7 of the conductors, and would require that they be replaced. There are 14 such
8 structures on this line that would have to be replaced. Replacement of these towers
9 and retensioning of the conductors would require a minimum of 30 weeks of outage
10 time. Based on our experience with the heavy loading on this line, including the
11 difficulty we experienced in scheduling even a two-day outage of this line in 2006, it
12 is not reasonable to expect that Dominion would be able to schedule such lengthy
13 and multiple outages on this major 500 kV line, which is nearly fully loaded year-
14 round. Increasing the height of the conductors by retensioning is not a feasible
15 means of addressing ground clearance on this line.

16
17 Q. HAS DOMINION INVESTIGATED THE FEASIBILITY OF INCREASING THE
18 GROUND CLEARANCE OF THIS LINE BY OTHER MEANS?

19 Yes. Dominion has evaluated what it would take to achieve this maximum capacity
20 of 2910 MVA by increasing ground clearance through a combination of grading the
21 ground surface and raising the existing structures without increasing the mechanical

1 load on the structures. Dominion first conducted an aerial survey of the line by using
2 a helicopter equipped with Light Detection and Ranging ("LiDAR") to obtain
3 accurate conductor sag characteristics and accurate ground terrain data. The data
4 from this aerial survey was loaded into PLSCADD, the industry standard
5 transmission design software, and 90 locations were identified with clearance
6 violations. In 40 of these spans, the clearance violation was simply a high spot or
7 knoll under just one phase, or conductor, often on the uphill side of the right of way.
8 We determined that grading or shaving of these high spots could be done to achieve
9 the required clearance. In order to do this work, grading rights must be obtained
10 from the property owners and a grading plan must be developed to minimize the
11 effect on natural topography and to assure positive drainage. This plan, including
12 erosion and sedimentation control measures, must be submitted to the West Virginia
13 Department of Environmental Protection and the Virginia Department of
14 Conservation and Recreation for approval. In the other 50 locations, more extensive
15 violations occurred that extended across the right of way or for long longitudinal
16 runs along the span. In order to correct these violations, 49 structures must be raised
17 and 1 lift structure must be installed. Such a project would take 70 weeks to
18 complete and would require this line to be out of service for 17 weeks. Such an
19 extended outage of this critical, heavily loaded line is no more feasible than the
20 longer outage that would be required for retensioning. The only alternative to such
21 an outage would be to build at least one additional 500 kV transmission line in the

1 same West-East corridor, as is proposed in this proceeding, in order to allow the
2 required outages of the Mt. Storm–Doubs line that would be required to address the
3 ground clearance issues.

4

5 Q. WOULD THE INSTALLATION OF A NEW CONDUCTOR ON THE MT.
6 STORM-DOUBS LINE BE A FEASIBLE ALTERNATIVE TO THE
7 CONSTRUCTION OF THE 502 JUNCTION—LOUDOUN LINE?

8 A. No. The Mt. Storm-Doubs line is 44 years old and suffers from corrosion problems
9 associated with the corten steel as discussed above. While considerable maintenance
10 work has been done over years just to keep the line functional, it would be an
11 imprudent engineering decision to install new conductor on these deteriorated
12 towers. The entire line would have to be rebuilt in order to install new conductors,
13 which would require a much longer outage of the line than either of the ground
14 clearance approaches discussed above.

1 Q. DOES THIS CONCLUDE YOUR REJOINDER TESTIMONY?

2 A. Yes. However, I reserve the right to file additional testimony as may be necessary or

3 appropriate.