



An Exelon Company

**Richard G. Webster, Jr.**  
Vice President  
Regulatory Policy and Strategy

Telephone 215.841.4000 ext 5777  
Fax 215.841.6208  
www.peco.com  
dick.webster@peco-energy.com

PECO  
2301 Market Street, S15  
Philadelphia, PA 19103

July 25, 2014

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street  
Second Floor  
Harrisburg, Pennsylvania 17120

RECEIVED

JUL 25 2014

PA PUBLIC UTILITY COMMISSION  
SECRETARY'S BUREAU

**Re: PUC Docket No. M-0991220**  
**Request for Major Event Exclusion**

Dear Secretary Chiavetta:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed are an original and one copy of PECO's Request for Exclusion of a Major Outage for reliability reporting purposes.

The major event occurred July 8, 2014 through July 11, 2014 and was caused by heavy winds, lightning, and rain. The combination caused damage to aerial and underground electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,

*Richard G. Webster, Jr. /RAS*

cc: Denis P. Hosler, Bureau of Audits  
Darren Gill, Bureau of Technical Utility Services  
Joe McKain (PECO)

Enclosures

mec

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR  
RELIABILITY REPORTING PURPOSES TO  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
P O BOX 3265  
HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy Company  
Address: 2301 Market St.  
Philadelphia, Pa 19101

2. Name and title of person making request:  
J Coffman Director of Engineering  
*(Name)* *(Title)*

3. Telephone number: 215-841-4201  
*(Telephone Number)*

**RECEIVED**

JUL 25 2014

PA PUBLIC UTILITY COMMISSION  
SECRETARY'S BUREAU

4. Interruption or Outage:  
(a) Number of customers affected: 236,177  
Total number of customers in service territory: 1,714,560

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
Bucks County	223
Chester County	322
Delaware County	243
Montgomery County	272
Philadelphia	131
York County	14

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds, lightning and rain caused downed tree limbs on power lines and interrupted electric service to 236,177 customers

Forecast issued on Monday 07/07/2014 @ at 07:40

COLD FRONT WILL BEGIN TO MOVE INTO THE REGION TUESDAY NIGHT, CRASHING INTO A HOT AND HUMID AIR MASS. THIS WILL LIKELY RESULT IN THUNDERSTORMS, A FEW STORMS MAY HIT PRIOR TO THE FRONT LATE TUESDAY AFTERNOON, BUT THE HIGHEST THREAT OF THAT WILL BE TO OUR NORTH AND WEST. IN ADDITION, THE FRONT MAY STILL BE CLOSE ENOUGH TO BRING THUNDERSTORMS EARLY WEDNESDAY, ALTHOUGH BY THEN MOST OF THE STORMS WILL BE PUSHING OFF TO THE SOUTH AND EAST..

Forecast issued on Tuesday 7/08/2014 @ 07:37

A TROUGH OF LOW PRESSURE WILL MOVE INTO THE REGION AND BRING SHOWERS AND THUNDERSTORMS. ALTHOUGH THERE IS A SLIGHT THREAT FOR LATE THIS AFTERNOON, THE THUNDERSTORM THREAT WILL BE LIKELY TONIGHT

---

(d) The number of utility workers and others assigned specifically to the repair work:  
2,351

---

(e) The date and time of the first notification of a service interruption: 07/08/2014 at 15:35

---

(f) The actual time that service was restored to the last affected customer: 07/11/2014 at 23:43

---

Remarks:

Crews from Delaware, New Jersey, Maryland, Connecticut, Massachusetts, Ohio, Illinois, South Carolina, Kentucky, Tennessee, Michigan and Wisconsin supported PECO crews in the restoration effort

---