



UGI Utilities, Inc.
2525 North 12th Street
Suite 360
Post Office Box 12677
Reading, PA 19612-2677
1-800-276-2722

VIA E-FILING

February 1, 2015

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

**RE: Quarterly Electric System Reliability Report
12 Months Ending December 31, 2014
Docket Nos. L-00030161 and M-00991220**

Dear Secretary Chiavetta:

Pursuant to the Commission's May 7, 2004 Final Rulemaking Order amending Electric Service Reliability Regulations (52 Pa. Code §§57.191 - 57.197) at Docket Nos. L-00030161 and M-00991220, UGI Utilities, Inc. - Electric Division ("UGI") hereby files its Quarterly System Reliability Report. This report contains SAIDI, SAIFI, and CAIDI results on a 12-month rolling basis for the period ending December 31, 2014 along with the raw data from the same period. Also included is a breakdown of outages by cause for the 12 months ending December 31, 2014. The actual statistics are favorable to both the benchmark and standard adopted for UGI.

The Office of Consumer Advocate, the Office of Small Business Advocate, the Bureau of Audits, and the Bureau of Technical Utility Services have each been served with copies of this filing.

Questions related to the attached report should be directed to Mr. David Lahoff at (610) 796-3520 or email dlahoff@ugi.com.

Sincerely,

A handwritten signature in blue ink that reads "Eric Sorber".

Eric Sorber
Electric Division, Director – Engineering & Operations
Attachment

cc: **VIA FEDERAL EXPRESS**

Tanya J. McCloskey
Office of Consumer Advocate
555 Walnut St.
5th Floor, Forum Place
Harrisburg, PA 17101-1921

John R. Evans
Small Business Advocate
Suite 1102, Commerce Bldg.
300 North Second St.
Harrisburg, PA 17101

Dennis Hosler, Director
Bureau of Audits
Pennsylvania Public Utility Commission
Commonwealth Keystone Bldg.
3rd Floor, F East
Harrisburg, PA 17101

Darren Gill, Deputy Director
Bureau of Technical Utility Services
Commonwealth Keystone Building
3rd Floor
400 North Street
Harrisburg, PA 17120

ELECTRONIC MAIL

Darren Gill, Deputy Director
Bureau of Technical Utility Services
dgill@pa.gov



UGI Utilities, Inc. – Electric Division
System Reliability Report:
Quarterly Update

February 1, 2015

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

§ 57.195(e)(1) – A description of each major event that occurred during the preceding quarter, including the time and duration of the event, the number of customers affected, the cause of the event and any modified procedures adopted in order to avoid or minimize the impact of similar events in the future.

There were no major events during the preceding quarter.

§ 57.195(e)(2) – Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI and if available, MAIFI) for the EDC’s service territory for the preceding quarter. The report shall include the data used in calculating the indices, namely the average number of customers served, the number of sustained customer interruptions, the number of customers affected and the customer minutes of interruption.

The 12 month rolling reliability results for UGI’s service area are as follows:

	SAIDI	SAIFI	CAIDI
12-Month Standard	256	1.12	228
12-Month Benchmark	140	0.83	169
12 months Ended December, 2014	63	.44	144

SAIDI: System Average Interruption Duration Index
SAIFI: System Average Interruption Frequency Index
CAIDI: Customer Average Interruption Duration Index

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

Raw Data: January 2014 - December 2014

Month	SI	TCI	TCB	TMCI
Jan-2014	17	2,054	61,722	148,185
Feb-2014	13	145	61,738	15,794
Mar-2014	16	3,561	61,585	493,075
Apr-2014	34	3,052	61,507	240,757
May-2014	32	4,021	61,210	647,778
Jun-2014	21	2,100	61,060	734,190
Jul-2014	17	2,454	60,985	418,678
Aug-2014	27	1,824	60,972	229,463
Sep-2014	18	1,104	60,896	134,870
Oct-2014	25	2,472	60,939	342,952
Nov-2014	31	3,470	60,903	345,580
Dec-2014	<u>21</u>	<u>628</u>	<u>60,886</u>	<u>111,439</u>
TOTAL	272	26,885	61,200 *	3,862,761

* 12-month arithmetic average

SI: Sustained Interruptions
 TCI: Total Customers Interrupted
 TCB: Total Customer Base
 TMCI: Total Minutes Customer Interruption

SAIDI

The SAIDI value for the 12 months ending December 2014 is 63. This result is 9% lower than results reported through September 2014.

SAIFI

The 12-month rolling SAIFI index decreased 10% from 0.49 in our last quarterly report to 0.44 for the period ending December 2014.

CAIDI

The CAIDI result of 144 for the 12-month reporting period ending December 2014 is up 1% from our last report.

All index values fall below their respective standard and benchmark levels. UGI believes the changes in reliability results compared with the previous reporting periods are due to the natural variation of the events in each period and do not indicate any trends. It is always important to note, however, that weather conditions can have considerable impact on these values.

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

§57.195(e)(5)–Rolling 12 month breakdown and analysis of outage causes during the preceding quarter, including the number and percentage of service outages, the number of customers interrupted, and the customer interruption minutes categorized by outage cause such as equipment failure, animal contact, tree related and so forth. Proposed solutions to identified service problems shall be reported.

Outage by Cause: October 2013 – September 2014

Cause	% of Total Incidents	Number of Interruptions	Customers Interrupted	Minutes Interrupted
Animal	17.65%	48	306	21,512
Company Agent	0.37%	1	27	378
Construction Error	0.00%	0	0	0
Customer Problem	0.37%	1	1	174
Equipment Failure	33.46%	91	5,463	852,087
Lightning	2.21%	6	1,309	145,506
Motor Vehicle	8.46%	23	5,562	602,467
Other	0.37%	1	10	4,000
Public	2.94%	8	2,339	87,136
Structure Fire	1.47%	4	158	14,123
Trees	23.90%	65	11,029	2,044,702
Unknown	5.51%	15	459	52,069
Weather Related	0.74%	2	10	6,596
Weather/Snow	0.74%	2	116	20,344
Weather/Ice	0.74%	2	2	157
Weather/Wind	<u>1.10%</u>	<u>3</u>	<u>94</u>	<u>11,510</u>
TOTAL	100.00%	272	26,885	3,862,761

Proposed Solutions to Identified Problems:

UGI has not identified any specific, significant issues on its system that need attention.