



An Exelon Company

Richard G. Webster, Jr.
Vice President

Telephone 215.841.4000
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

PECO
Regulatory Policy and Strategy
2301 Market Street
S15
Philadelphia, PA 19103

July 15, 2015

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Second Floor
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-0991220
Request for Major Event Exclusion**

Dear Secretary Chiavetta:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes.

The major event occurred June 23, 2015 through June 29, 2015 and was caused by heavy winds, lightning, and rain. The combination caused damage to aerial and underground electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,

Richard G. Webster, Jr. / RAS

cc: Denis P. Hosler, Bureau of Audits
Darren Gill, Bureau of Technical Utility Services
Joe McKain (PECO)

Enclosures

mec

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
RELIABILITY REPORTING PURPOSES TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
P O BOX 3265
HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy Company
Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:
J Coffman Director of Engineering
(Name) *(Title)*

3. Telephone number: 215-841-4201
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 352,763
Total number of customers in service territory: 1,720,209

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
DELAWARE	797
CHESTER	568
MONTGOMERY	298
BUCKS	79
PHILADELPHIA	241
YORK	34

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds, lightning and rain caused downed tree limbs on power lines and interrupted electric service to 352,763 customers

Forecast issued on Monday 07/07/2014 @ at 07:40

COLD FRONT WILL BEGIN TO MOVE INTO THE REGION TUESDAY NIGHT, CRASHING INTO A HOT AND HUMID AIR MASS. THIS WILL LIKELY RESULT IN THUNDERSTORMS, A FEW STORMS MAY HIT PRIOR TO THE FRONT LATE TUESDAY AFTERNOON, BUT THE HIGHEST THREAT OF THAT WILL BE TO OUR NORTH AND WEST. IN ADDITION, THE FRONT MAY STILL BE CLOSE ENOUGH TO BRING THUNDERSTORMS EARLY WEDNESDAY, ALTHOUGH BY THEN MOST OF THE STORMS WILL BE PUSHING OFF TO THE SOUTH AND EAST..

Forecast issued on Tuesday 7/08/2014 @ 07:37

A TROUGH OF LOW PRESSURE WILL MOVE INTO THE REGION AND BRING SHOWERS AND THUNDERSTORMS. ALTHOUGH THERE IS A SLIGHT THREAT FOR LATE THIS AFTERNOON, THE THUNDERSTORM THREAT WILL BE LIKELY TONIGHT

(d) The number of utility workers and others assigned specifically to the repair work: 2,879

(e) The date and time of the first notification of a service interruption:

06/23/2015 at 19:00

(f) The actual time that service was restored to the last affected customer:

06/29/2015 at 21:36

Remarks: PECO employees were joined by more than 1,500 outside workers including utilities from Ohio, Kentucky, West Virginia and New York
