



An Exelon Company

Richard G. Webster, Jr.
Vice President

Telephone 215.841.4000
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

PECO
Regulatory Policy and Strategy
2301 Market Street
S15
Philadelphia, PA 19103

July 16, 2015

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Second Floor
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-0991220
Request for Major Event Exclusion – Replacement Filing**

Dear Secretary Chiavetta:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes.

PECO Energy Company previously made this filing (e-filing Confirmation number 1599512) on July 15, 2015. This letter transmits for filing with the Commission a replacement filing. In the attached report Section C inadvertently listed the incorrect dates and forecast weather data. The enclosed report contains corrected data.

The major event occurred June 23, 2015 through June 29, 2015 and was caused by heavy winds, lightning, and rain. The combination caused damage to aerial and underground electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,

A handwritten signature in black ink that reads "Richard G. Webster, Jr. / RAS".

cc: Denis P. Hosler, Bureau of Audits
Darren Gill, Bureau of Technical Utility Services
Joe McKain (PECO)

Enclosures

mec

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
RELIABILITY REPORTING PURPOSES TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
P O BOX 3265
HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy Company
Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:
J Coffman Director of Engineering
(Name) *(Title)*

3. Telephone number: 215-841-4201
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 352,763
Total number of customers in service territory: 1,720,209

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
DELAWARE	797
CHESTER	568
MONTGOMERY	298
BUCKS	79
PHILADELPHIA	241
YORK	34

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds, lightning and rain caused downed tree limbs on power lines and interrupted electric service to 352,763 customers

Forecast issued on Monday 06/22/2015 @ at 15:12

MOSTLY SUNNY AND DRY TODAY. NEXT CHANCE FOR SHOWERS OR STORMS IS WITH A COOL FRONT MOVING THROUGH LATE TUESDAY. SOME CHANCE FOR AN ISOLATED STRONG STORM. HIGH PRESSURE AND DRY WEDNESDAY AND THURSDAY A NEW WEATHER SYSTEM MAY BRING SHOWERS AND STORMS ON FRIDAY.

Forecast issued on Tuesday 06/23/2015 @ 09:24

THUNDERSTORMS DEVELOPING THIS AFTERNOON WITH SOME SEVERE. MAIN PROBLEM WILL BE WINDS...ISOLATED GUSTS TO 60 POSSIBLE.

(d) The number of utility workers and others assigned specifically to the repair work: 2,879

(e) The date and time of the first notification of a service interruption: 06/23/2015 at 19:00

(f) The actual time that service was restored to the last affected customer: 06/29/2015 at 21:36

Remarks: PECO employees were joined by more than 1,500 outside workers including utilities from Ohio, Kentucky, West Virginia and New York
