

Friday, July 22, 2016

To: The Pa Public Utility Commission Secretary
400 North Street
Harrisburg, PA 17120

From: Ross E. Schell
203 Knollwood Drive
Harrisburg, PA 17109-5515
PH# 717-651-0824
Fax# same but call First.

To Whom this may Concern:

I am writing this brief to validate my request for a interlocutory Commission review Petition. Exhibit 4 Submitted by the Attorney for PPL Ms. Kimberly G. Krupka in regards to dockets

C-2016-2535220, C-2016-2538023, C-2016--2539969

Reasons for Request.

1. Does not state who did the test
2. Does not state where test was done.
3. No Record of the qualifications of the testing personnel
4. Doubt the test conforms to the rules set by the PUC. 52
57.20
5. States a Model number the does not appear on the meter.
6. States a 2 200 amp Main when I have a 200 amp main.
7. Predigests towards PPI in the testing.


My main complaints are the accuracy of my bills and the fact that my electric service goes on and off without a known cause. This exhibit could unduly predigests the Administrative Judge toward ruling against me and towards PPL instead.

I am asking for a stay in the proceedings until this petition is reviewed and answered by the Commission.

A handwritten signature in cursive script, appearing to read "Ross E. Schell".

Ross E. Schell

LANDIS & GYR



KWHR

Rr 27 7/9

68775-3

FM2S CL200 240V 3W 60Hz

PPL

84 492 994



FL08449299415065

DOSSI
IMT-3

7.2KW TA30
KWHRKW

-578

View Meter Test for 84492994

Meter Test Edit Help

Meter

Vendor: Landis & Gyr Type: A01651

Test Group: Size: 2 200

Test Results

Date: 05/02/16 KWH Test Reading:

Method: Shop KW Test Reading:

Status: Passed Power Factor: 10

Reason for Test: Other Shop Test

Irregular Test Condition:

Average Percent Accuracy High: 98.67 % High Not Recording: No

Average Percent Accuracy Low: 99.74 % Low Not Recording: No

Meter Constant

Incorrect Constant in System: No Removed from Test Group: No

Tested Constant: