



August 12, 2016

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

RE: Quarterly Electric System Reliability Report
12 Months Ending June 30, 2016
Docket Nos. L-00030161 and M-00991220

M-2016-2522508

Dear Secretary Chiavetta:

Enclosed, please find UGI Utilities, Inc., Quarterly Electric System Reliability Report for the 12 month period ending June 30, 2016 with an original signature as requested.

Should you have any questions or concerns please contact me at 570-830-1286 or via email at esorber@ugi.com.

Sincerely,

Eric Sorber
Director Engineering & Operations
UGI Utilities, Inc. – Electric Division
One UGI Center
Wilkes-Barre, PA 18701

RECEIVED

AUG 12 2016

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU



UGI Utilities, Inc.
2525 N. 12th Street
Suite 360
PO Box 12677
Reading, PA 19612-2677

610-796-3400

VIA FEDERAL-EXPRESS

July 29, 2016

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

~~RECEIVED
JUL 29 2016
PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU~~

RE: **Quarterly Electric System Reliability Report
12 Months Ending June 30, 2016
Docket Nos. L-00030161 and M-00991220**

Dear Secretary Chiavetta:

M-2016-2522508

Pursuant to the Commission's May 7, 2004 Final Rulemaking Order amending Electric Service Reliability Regulations (52 Pa. Code §§57.191 - 57.197) at Docket Nos. L-00030161 and M-00991220, UGI Utilities, Inc. - Electric Division ("UGI") hereby files its Quarterly System Reliability Report. This report contains SAIDI, SAIFI, and CAIDI results on a 12-month rolling basis for the period ending June 30, 2016 along with the raw data from the same period. Also included is a breakdown of outages by cause for the 12 months ending June 30, 2016. The actual statistics are favorable to both the benchmark and standard adopted for UGI.

The Office of Consumer Advocate, the Office of Small Business Advocate, the Bureau of Audits, and the Bureau of Technical Utility Services are each being served with copies of this filing.

Questions related to the attached report should be directed to Mr. Vince DeGiusto, Jr. at (570) 830-1289 or email vdegiustojr@ugi.com.

Sincerely,

Eric Sorber
Electric Division, Director - Engineering & Operations
Attachment

RECEIVED

AUG 12 2016

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU



UGI Utilities, Inc. – Electric Division
System Reliability Report:
Quarterly Update

~~RECEIVED~~

~~JUL 29 2016~~

~~PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU~~

July 29, 2016

RECEIVED

AUG 12 2016

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

§ 57.195(e)(1) – A description of each major event that occurred during the preceding quarter, including the time and duration of the event, the number of customers affected, the cause of the event and any modified procedures adopted in order to avoid or minimize the impact of similar events in the future.

There were no major events during the preceding quarter.

§ 57.195(e)(2) – Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI and if available, MAIFI) for the EDC’s service territory for the preceding quarter. The report shall include the data used in calculating the indices, namely the average number of customers served, the number of sustained customer interruptions, the number of customers affected and the customer minutes of interruption.

The 12 month rolling reliability results for UGI’s service area are as follows:

	SAIDI	SAIFI	CAIDI
12-Month Standard	256	1.12	228
12-Month Benchmark	140	0.83	169
12 months Ended June, 30 2016	73	.56	129

SAIDI: System Average Interruption Duration Index
SAIFI: System Average Interruption Frequency Index
CAIDI: Customer Average Interruption Duration Index

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

Raw Data: July 2015 - June 2016

Month	SI	TCI	TCB	TMCI
Jul-2015	27	2,582	60,201	247,239
Aug-2015	33	823	60,069	99,527
Sep-2015	33	932	59,978	73,859
Oct-2015	20	1,377	59,903	69,335
Nov-2015	32	3,884	59,914	344,674
Dec-2015	22	348	59,879	40,669
Jan-2016	27	639	59,889	90,830
Feb-2016	40	9,830	59,889	1,258,214
Mar-2016	26	6,973	59,783	831,584
Apr-2016	46	1,672	59,519	449,736
May-2016	27	3,631	59,375	713,329
Jun-2016	38	1,060	60,944	127,727
TOTAL	371	33,751	59,945 *	4,346,723

* 12-month arithmetic average

SI: Sustained Interruptions
 TCI: Total Customers Interrupted
 TCB: Total Customer Base
 TMCI: Total Minutes Customer Interruption

SAIDI

The SAIDI value for the 12 months ending June 2016 is 73. This result is 3% higher than results reported through March 2016.

SAIFI

The 12-month rolling SAIFI index decreased 14% from 0.65 in our last quarterly report to 0.56 for the period ending June 2016.

CAIDI

The CAIDI result of 129 for the 12-month reporting period ending June 2016 is up 18% from our last report.

All index values fall below their respective standard and benchmark levels. UGI believes the changes in reliability results compared with the previous reporting periods are due to the natural variation of the events in each period and do not indicate any trends. It is always important to note, however, that weather conditions can have considerable impact on these values.

**UGI Utilities, Inc. – Electric Division
System Reliability Report**

§57.195(e)(5)–Rolling 12 month breakdown and analysis of outage causes during the preceding quarter, including the number and percentage of service outages, the number of customers interrupted, and the customer interruption minutes categorized by outage cause such as equipment failure, animal contact, tree related and so forth. Proposed solutions to identified service problems shall be reported.

Outage by Cause: July 2015 – June 2016

Cause	% of Total Incidents	Number of Interruptions	Customers Interrupted	Minutes Interrupted
Animal	21.29%	79	836	72,375
Company Agent	0.27%	1	21	231
Construction Error	0.00%	0	0	0
Customer Problem	0.27%	1	1	65
Dig In	0.27%	1	1	238
Equipment Failure	31.27%	116	14,653	1,558,230
Lightning	2.16%	8	1,082	50,682
Motor Vehicle	7.55%	28	4,839	920,471
Other	0.54%	2	6	552
Public	3.23%	12	191	39,302
Structure Fire	0.54%	2	604	13,782
Trees	24.26%	90	7,799	945,696
Unknown	2.43%	9	1,183	116,743
Weather Related	1.89%	7	39	3,432
Weather/Snow	0.00%	0	0	0
Weather/Ice	0.54%	2	616	47,960
Weather/Wind	3.50%	13	1,880	576,964
TOTAL	100.00%	371	33,751	4,346,723

Proposed Solutions to Identified Problems:

UGI has not identified any specific, significant issues on its system that need attention.

cc: **VIA FEDERAL EXPRESS**

Tanya J. McCloskey
Office of Consumer Advocate
555 Walnut St.
5th Floor, Forum Place
Harrisburg, PA 17101-1921

John R. Evans
Small Business Advocate
Suite 1102, Commerce Bldg.
300 North Second St.
Harrisburg, PA 17101

Dennis Hosler, Director
Bureau of Audits
Pennsylvania Public Utility Commission
Commonwealth Keystone Bldg.
3rd Floor, F East
Harrisburg, PA 17101

David Washko, Deputy Director
Bureau of Technical Utility Services
Commonwealth Keystone Building
3rd Floor
400 North Street
Harrisburg, PA 17120

ELECTRONIC MAIL

David Washko, Deputy Director
Bureau of Technical Utility Services
dwashko@pa.gov

RECEIVED

AUG 12 2016

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

RECEIVED

JUL 29 2016

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU



FedEx carbon-neutral envelope shipping

ORIGIN ID:HZLA (570) 830-1286
ERIC SORBER
UGI ELECTRIC
1 UGI CENTER
BLDG A2
WILKES BARRE, PA 18711
UNITED STATES US

SHIP DATE: 12AUG16
ACTWGT: 0.20 LB
CAD: 6990352/SSF01704


Part 0 158297V435 RT2 EXP 07/17 : : :
NBA/7/15/11 875

TO **ATTN MS. ROSEMARY CHIAVETTA, SEC.
PA PUBLIC UTILITY COMMISSION
400 NORTH STREET
COMMONWEALTH KEYSTONE BUILDING
HARRISBURG PA 17120**

(000) 000-0000
THU:
PO:

REF:

DEPT:



FedEx Express



RT 205
FZ
1 10:30
B 3458
08.15

TRK# 7838 0962 3458
0201

MON - 15 AUG 10:30A
PRIORITY OVERNIGHT

SH MDTA

17120
PA-US MDT



CMPC

To: PUC

Agency PUC

Floor:

External Carrier: FEDEX

8/15/2016 9:33:04 AM



783809623458