

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**APPLICATION OF PENNSYLVANIA :
ELECTRIC COMPANY FOR APPROVAL :
TO LOCATE AND CONSTRUCT THE :
BEDFORD NORTH-CENTRAL CITY :
WEST 115 KILOVOLT TRANSMISSION : Docket No.
LINE PROJECT IN CENTRAL CITY :
BOROUGH AND SHADE TOWNSHIP, :
SOMERSET COUNTY, AND NAPIER, :
EAST ST. CLAIR, AND BEDFORD :
TOWNSHIPS, BEDFORD COUNTY, :
PENNSYLVANIA :**

DIRECT TESTIMONY OF

DAVID W. PARKS

ON BEHALF OF

PENNSYLVANIA ELECTRIC COMPANY

STATEMENT NO. 1

**Re: Overview and Routing the
Proposed Bedford North-Central City West
HV Transmission Line Project**

Dated: September 1, 2016

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

Q. ON WHOSE BEHALF ARE YOU PROVIDING THIS TESTIMONY?

A. I am providing this testimony on behalf of Penelec for approval to locate and construct the Bedford North-Central City West 115 kV Transmission Line (“Project”).

Q. WHAT IS YOUR ROLE ON THE PROJECT?

A. I am responsible for coordinating the Applicant’s efforts to obtain the Pennsylvania Public Utility Commission’s (“Commission”) authorization to construct the proposed Project. This includes the Route Selection Study (Exhibit No. 8 in the Application), the preparation of the Application, filing of the Application and acting as the Applicant’s lead technical representative to the Commission throughout the Commission’s regulatory process.

Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?

A. The purpose of my testimony is two-fold. First, I will identify and introduce the other witnesses who are providing direct testimony on behalf of Penelec in this proceeding and identify the subject matter of their testimony. Second, I will provide an overview of the evidence submitted by Penelec in support of its Application for authorization to locate and construct a high-voltage transmission line.

1 (4) That the line will have minimum adverse environmental impact, considering the
2 electric power needs of the public, the state of available technology and the
3 available alternatives.

4 Though the Application and accompanying exhibits and the testimony that I have identified
5 above, Penelec is presenting evidence that satisfies the Commission's regulations in 52 Pa.
6 Code §57.72(c) and its interim guidelines in 52 Pa. Code §§ 69.3102 - 69.3107 and shows
7 that the proposed Project satisfies all of the criteria for Commission siting approval under
8 52 Pa. Code §57.76(a).

9

10 **Q. PLEASE BRIEFLY SUMMARIZE THE EVIDENCE THAT PENELEC IS**
11 **PRESENTING AND HOW IT DEMONSTRATES THAT THE CRITERIA FOR**
12 **SITING APPROVAL ARE MET BY THE PROJECT?**

13
14 A. Penelec's evidence will establish the proposed siting and construction of the Project is
15 necessary to ensure reliable electrical service under industry standards to Somerset County
16 and the surrounding areas and to ensure long-term electric service to customers within
17 PJM.

18

19 Penelec's evidence will also establish that the proposed route for the Project was selected
20 after a detailed assessment which included a comprehensive environmental inventory,
21 identification and analysis of alternative routes, and selection of the preferred route based
22 on appropriate evaluation criteria.

23

24 Penelec's evidence will also show the Project will be constructed, operated and maintained
25 in accordance with all applicable federal and state laws, regulations, and permits. It will

1 meet with or better than the standard 115 kV transmission lines established by the Nation
2 Electric Safety Code.

3

4 **Q. ARE YOU SPONSORING AN EXHIBIT?**

5 A. Yes, I am sponsoring the Application with all of its attachments and exhibits, although
6 some individuals are co-sponsoring certain exhibits and sections of the application.
7 Specifically, I am co-sponsoring Exhibit 8 and sponsoring Exhibit 7, and Exhibits 12
8 through 19. Copies of the Application have previously been distributed to the parties.

9

10 **Q. DOES THIS COMPLETE YOUR DIRECT TESTIMONY?**

11 A. Yes it does. However, I would like to reserve the right to supplement my direct testimony
12 if anything changes with respect to the status of the application.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**APPLICATION OF PENNSYLVANIA :
ELECTRIC COMPANY FOR APPROVAL :
TO LOCATE AND CONSTRUCT THE :
BEDFORD NORTH-CENTRAL CITY :
WEST 115 kV HV TRANSMISSION LINE :
PROJECT IN CENTRAL CITY : Docket No.:
BOROUGH AND SHADE TOWNSHIP, :
SOMERSET COUNTY, AND NAPIER, :
EAST ST. CLAIR, AND BEDFORD :
TOWNSHIPS, BEDFORD COUNTY, :
PENNSYLVANIA :**

**DIRECT TESTIMONY OF

GRANT MARCHEWKA

ON BEHALF OF

PENNSYLVANIA ELECTRIC COMPANY**

STATEMENT NO. 2

**Re: Electrical Need for the Project
and the Project Planning Process**

Dated: September 1, 2016

1 **RESPONSIBILITIES, EXPERIENCE AND EDUCATION**

2 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

3 A. My name is Grant Marchewka and my business address is 800 Cabin Hill Drive,
4 Greensburg, Pennsylvania 15601.

5
6 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

7 A. I am employed by FirstEnergy Service Company as an Engineer IV assigned to the
8 Energy Delivery Planning and Protection group. In this proceeding, I am testifying
9 on behalf of Pennsylvania Electric Company (“Penelec” or “Company”).

10
11 **Q. PLEASE DESCRIBE YOUR PROFESSIONAL EXPERIENCE AND**
12 **EDUCATIONAL BACKGROUND.**

13 A. I received a Bachelor of Science degree in Electrical Engineering from The
14 Pennsylvania State University. I am a registered Professional Engineer in the
15 Commonwealth of Pennsylvania. I have been employed by FirstEnergy Service
16 Company and, prior to the merger of FirstEnergy Corp. and Allegheny Energy, Inc.,
17 by Allegheny Energy Service Corporation, for a combined total of over six years.
18 My current position is Engineer IV in the Transmission Planning group where I am
19 responsible for planning of the transmission system, including the transmission
20 system within Penelec’s service territory, to ensure the system operates reliably
21 over a wide range of conditions.

22

1 **Q. HAVE YOU TESTIFIED PREVIOUSLY BEFORE THIS COMMISSION**
2 **OR OTHER REGULATORY AGENCIES?**

3 A. Yes. I provided testimony before the Pennsylvania Public Utility Commission in
4 support of Penelec’s proceeding at Commission Docket No. A-2016-2529650 for
5 the East Towanda – South Troy 230/115 kV project located in Bradford County,
6 Pennsylvania. I have not testified before other regulatory agencies.

7

8 **PURPOSE OF TESTIMONY**

9 **Q. PLEASE DESCRIBE THE PURPOSE OF YOUR TESTIMONY.**

10 A. The purpose of my testimony is to support the Application of Penelec for Project
11 location and construction, as follows

- 12 • describe in general terms the facilities Penelec proposes to construct;
- 13 • describe the need for the proposed new transmission line facilities; and
- 14 • describe alternatives considered from the perspective of electric planning.

15

16 **EXHIBITS**

17 **Q. PLEASE IDENTIFY AND DESCRIBE THE EXHIBITS YOU WILL REFER**
18 **TO IN YOUR TESTIMONY.**

19 A. Exhibits 4, 5A, and 5B, previously submitted as part of the Application, are Penelec
20 system maps showing the locations and voltages of Penelec transmission facilities
21 (i.e. lines and substations) within Penelec’s service territory. Exhibit 4 contains
22 critical infrastructure information that should not be publically available and,
23 therefore, the Company has requested that the Commission place this exhibit in a
24 non-public folder. Exhibit 21, also previously submitted as part of the Application,

1 contains an excerpt from PJM Interconnection, L.L.C (“PJM”) Transmission
2 Expansion Advisory Committee’s (“TEAC”) January 9, 2014 presentation which
3 discusses the Project.

4

5

ELECTRICAL PERSPECTIVE OF THE PROJECT

6

Q. DESCRIBE THE PROJECT FROM AN ELECTRICAL PERSPECTIVE.

7

A. Penelec proposes to extend the existing Statler Hill – Central City West 115 kilovolt
8 (“kV”) transmission line to the existing Bedford North Substation. The proposed
9 high voltage (“HV”) transmission line is referred to as the “Bedford North – Central
10 City West 115 kV HV Transmission Line Project” (hereinafter, the “Project”). The
11 proposed Project will be approximately 17.6 miles in length. A new 115 kV
12 transmission will be constructed from the Central City West substation to a point
13 on the existing Bedford North – New Baltimore 115 kV line, a distance of
14 approximately 10.4 miles. From this point to the Bedford North substation, a
15 distance of approximately 7.2 miles, the existing Bedford North – New Baltimore
16 115 kV line will be reconstructed as a double circuit line. One circuit will be the
17 existing Bedford North – New Baltimore 115 kV circuit; the second circuit will be
18 the continuation of the new Bedford North – Central City West 115 kV circuit.

19

20

ELECTRICAL NEED

21

Q. PLEASE DESCRIBE THE ELECTRICAL NEED FOR THE PROJECT?

22

A. The Project is needed to mitigate both thermal and voltage reliability criteria
23 violations of both FirstEnergy and PJM Planning Criteria that were identified as

1 part of PJM’s Regional Transmission Expansion Plan (“RTEP”) analysis.
2 Specifically, the project is needed to address thermal and voltage violations
3 identified under North American Electric Reliability Corporation (“NERC”)
4 Category C conditions and to provide adequate transmission capacity to meet
5 current and expected customer needs for electric service in Bedford County,
6 Pennsylvania, and the surrounding areas.

7

8 **Q. IS PENELEC REQUIRED TO PLAN THE TRANSMISSION SYSTEM TO**
9 **MEET MANDATORY RELIABILITY STANDARDS?**

10 A. Yes, pursuant to Section 215 of the Federal Power Act, the Federal Energy
11 Regulatory Commission (“FERC”) has certified NERC as the electric reliability
12 organization to develop and enforce mandatory reliability standards, subject to
13 FERC review and approval. The FERC-approved NERC reliability standards are
14 mandatory.

15

16 PJM, a FERC-approved Regional Transmission Organization (“RTO”), is
17 responsible for ensuring the reliability of the electric transmission system under its
18 functional control and coordinating the movement of wholesale electricity in all or
19 parts of 13 states, including Pennsylvania. PJM is responsible for assuring
20 compliance with NERC standards for the bulk electric system within its control
21 area. NERC reliability standards require that the bulk electric system be designed
22 to operate within applicable thermal and voltage criteria limits, defined in

1 FirstEnergy and PJM Planning Criteria, under various system loading conditions
2 and in consideration of credible outages of elements on the bulk electric system.

3

4 **Q. PLEASE DESCRIBE THE PLANNING CRITERIA USED IN**
5 **ASSESSMENTS PERFORMED BY PENELEC.**

6 A. FirstEnergy's Transmission Planning Criteria, using NERC standards and PJM
7 manuals as guides, state that the following criteria must be met on the bulk electric
8 system. The conditions and associated criteria are defined in NERC standards as
9 follow:

- 10 • NERC Category A, system performance under normal (no contingency)
11 conditions, provides that the planning authority (in this instance, PJM) and
12 transmission planner (in this instance, PJM) shall each demonstrate through
13 a valid assessment that their portion of the interconnected transmission
14 system is planned with all transmission facilities in service and with normal
15 operation to supply projected customer demands and projected firm
16 transmission services at all demand levels over the range of forecasted
17 system demands. This is the normal day-to-day condition and configuration
18 of the bulk electric system.
- 19 • NERC Category B states that the loss of any single generating unit,
20 transmission line, transformer, circuit breaker, capacitor, or single pole of a
21 bipolar DC line will not cause bulk electric system facility loading to exceed
22 the seasonal emergency rating of any facility, violate the maximum
23 deviation, or violate the emergency minimum or maximum voltage criteria.

1 This is also known as N-1, where N is the total number of transmission
2 components in the network under study. Penelec uses a voltage magnitude
3 minimum limit of 0.92 per unit and a maximum limit of 1.05 per unit for
4 facilities within the bulk electric system, except facilities operating at a
5 nominal voltage of 500 kV. A minimum voltage limit of 0.97 per unit and
6 a maximum voltage limit of 1.10 per unit is used for 500 kV facilities.
7 Additionally, voltage deviation following the outage is limited to plus-or-
8 minus 10 percent for bulk electric system facilities with a nominal voltage
9 less than 200 kV, plus-or-minus eight percent for bulk electric system
10 facilities with a nominal voltage of 230 or 345 kV, and plus-or-minus five
11 percent for bulk electric system facilities with a nominal voltage of 500 kV.

- 12 • NERC Category C requires that the loss of any double circuit bulk electric
13 system transmission line, bipolar DC line, faulted circuit breaker, bus
14 section, the combination of facilities resulting from a line fault coupled with
15 a stuck breaker, or the loss of any single generating unit, transmission line,
16 transformer, circuit breaker, capacitor, or single pole of a bipolar DC line
17 followed by the loss of any single generating unit, transmission line,
18 transformer, circuit breaker, capacitor, or single pole of a bipolar DC line
19 (i.e. N-1-1) shall not cause loadings to exceed the seasonal emergency rating
20 of any facility, violate the maximum deviation, or violate the emergency
21 minimum or maximum voltage criteria. Penelec uses the same deviation

1 and emergency voltage limits as NERC Category B contingencies for
2 facilities within the bulk electric system.

3

4 **Q. WERE PLANNING CRITERIA VIOLATIONS IDENTIFIED WHEN**
5 **PERFORMING PLANNING ASSESSMENTS?**

6 A. Yes, FirstEnergy and PJM Transmission Planning have identified Planning Criteria
7 violations. As part of the PJM 2013 RTEP, PJM identified thermal loading Planning
8 Criteria violations on Penelec's Allegheny – Somerset 115 kV transmission line.
9 For the N-1-1 loss of the Hilltop – Krayn – Rachel Hill 115 kV transmission line
10 and the Cambria Slope - Summit 115 kV transmission line the Allegheny –
11 Somerset 115 kV transmission line loads to approximately 102% of its emergency
12 rating. Additionally, voltage on the 115 kV buses at Bedford North and Snake
13 Springs substation is less than the Planning Criteria emergency limit of 0.92 per
14 unit. These violations were identified in a model of expected system conditions for
15 summer 2018. Similar loading on the Allegheny – Somerset 115 kV line occurs
16 with the loss of the Cambria Slope – Summit 115 kV transmission line in
17 combination with the Claysburg – Krayn 115 kV transmission line. Voltage on
18 115 kV buses at Bedford North, Claysburg, Curryville, Osterburg East, Saxton, and
19 Snake Springs substations is below the Planning Criteria emergency limit for this
20 combination of line outages.

21

22 Furthermore, in the 2012 RTEP analysis, following a fault on the Hilltop – Krayn
23 – Rachel Hill 115 kV transmission line in conjunction with a stuck 115 kV circuit

1 breaker at Krayn substation, which also results in the outage of the Claysburg –
2 Krayn 115 kV lines and the wind generation connected to Krayn substation, loading
3 on the Bedford North – New Baltimore 115 kV transmission line increases to
4 approximately 107% of its summer emergency rating. Loading on the Bedford
5 North – New Baltimore 115 kV transmission line also exceeds its emergency rating
6 following a fault on the Cambria Slope – Jackson Road 115 kV transmission line
7 with a stuck 115 kV circuit breaker at Cambria Slope substation, which also results
8 in the outage of the Cambria Slope – Johnstown and Cambria Slope – Summit
9 115 kV lines, the Cambria Slope 115/46 kV transformer, and the generation
10 connected to the Cambria Slope 115 kV bus; a faulted 115 kV bus tie circuit breaker
11 at Rachel Hill substation, which outages the Hooversville – Rachel Hill and
12 Claysburg – Krayn – Rachel Hill 115 kV lines and both 115/23 kV transformers at
13 Rachel Hill; or fault on the Cambria Slope 115 kV bus, which outages the
14 Claysburg – Krayn – Rachel Hill, Cambria Slope – Jackson Road, and Cambria
15 Slope – Johnstown 115 kV lines, the Cambria Slope 115/46 kV transformer, and
16 the generation connected to the Cambria Slope 115 kV bus. All of these violations
17 were identified in PJM’s generation deliverability test.¹ The Project will replace
18 baseline RTEP project b1607 which would have recondored/rebuilt the Bedford
19 North – New Baltimore 115 kV transmission line.

¹ As per PJM Manual 14B, Attachment C, section C.6, this test “is applied to ensure that capacity is not ‘bottled’ from a reliability perspective. This would require that each electrical area be able to export its capacity, at a minimum, during periods of peak load.” PJM Manual 14B, Attachment C, section C.6 details the PJM Generation Deliverability test procedure:
<http://www.pjm.com/~media/documents/manuals/m14b.ashx>

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

Results of the PJM studies have been shared with PJM Stakeholders and the general public. The Project was presented to the PJM TEAC on January 9, 2014. An excerpt from this presentation that discusses the Project is shown in Exhibit No. 21 of the Application and can be found on PJM’s website.² PJM assigned baseline upgrade number “b2450” to the Project.

Q. CAN YOU DESCRIBE THE ELECTRICAL ALTERNATIVES CONSIDERED?

A. Yes, FirstEnergy considered replacing the existing Bedford North – New Baltimore and Allegheny – Somerset 115 kV transmission lines with higher-capacity conductor. Replacing the conductors on these transmission lines would allow the lines to carry more load without exceeding their design capacity. However, this solution would only mitigate the thermal loading Planning Criteria violations, but would not address the voltage violations. Constructing the Project will create a fourth source into the Bedford North region and will mitigate both the loading and voltage violations. Additionally, the Project will allow the bulk electric system to operate reliably, provide capacity to serve future anticipated load growth, and adhere to established NERC standards.

² <http://www.pjm.com/committees-and-groups/committees/teac.aspx>

1 **Q. BASED ON YOUR REVIEWS AND ASSESSMENTS, HAVE YOU**
2 **FORMED AN OPINION REGARDING THE NEED FOR THE PROJECT?**

3 A. Yes. The Project is needed to mitigate potential thermal and voltage violations on
4 the transmission system for various NERC Category C contingencies.

5

6 **THE PLANNING PROCESS**

7 **Q. COULD YOU PLEASE DESCRIBE PJM'S ROLE IN PLANNING FOR THE**
8 **PROJECT?**

9 A. Yes. PJM is the regional transmission planning authority and transmission planner
10 for the Penelec Transmission Zone, which encompasses the geographic area served
11 by Penelec. In this capacity, PJM applies an analytical approach to identify the
12 need and timing for transmission system upgrades to preserve the reliability of the
13 electricity grid. The PJM RTEP process is a comprehensive series of detailed
14 analyses to ensure reliability under the applicable NERC, PJM, and Transmission
15 Owner (i.e., Penelec) reliability criteria. Details of the PJM RTEP process are
16 documented in PJM Manual 14B.

17

18 **Q. HAS PJM INCLUDED THE PROJECT IN ITS RTEP?**

19 A. Yes. PJM presented the Project to the PJM TEAC on January 9, 2014. Exhibit No.
20 21 to the Application contains an excerpt of this presentation that discusses the
21 Project; this presentation can be found on PJM's website.³

22

³ <http://www.pjm.com/committees-and-groups/committees/teac.aspx>

1 **Q. DOES THE PJM ASSESSMENT ADDRESS THE ALLOCATION OF COST**
2 **FOR THE PROJECT?**

3 A. Yes. The PJM cost allocation for the Project, baseline RTEP project b2450, can be
4 found on PJM's website.⁴ The entire cost of the Project was allocated to the Penelec
5 zone.

6

7 **Q. WOULD THE CONSTRUCTION OF IDENTIFIED PJM RTEP OR**
8 **GENERATION PROJECTS EITHER BEFORE OR AFTER THE**
9 **COMPLETION OF THE PROJECT IMPACT THE NEED FOR THE**
10 **PROJECT?**

11 A. No. There are no proposed RTEP or generation projects that would eliminate the
12 need for the Project.

13

14 **Q. DOES THIS CONCLUDE YOUR DIRECT TESTIMONY?**

15 A. Yes, it does. However, I reserve the right to file such additional testimony as may
16 be necessary or appropriate.

⁴ <http://www.pjm.com/planning/rtep-upgrades-status/cost-allocation-view.aspx>

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**APPLICATION OF PENNSYLVANIA :
ELECTRIC COMPANY FOR APPROVAL :
TO LOCATE AND CONSTRUCT THE :
BEDFORD NORTH-CENTRAL CITY :
WEST 115 KILOVOLT TRANSMISSION : Docket No.
LINE PROJECT IN CENTRAL CITY :
BOROUGH AND SHADE TOWNSHIP, :
SOMERSET COUNTY, AND NAPIER, :
EAST ST. CLAIR, AND BEDFORD :
TOWNSHIPS, BEDFORD COUNTY, :
PENNSYLVANIA :**

DIRECT TESTIMONY OF

BARRY A. BAKER

ON BEHALF OF

PENNSYLVANIA ELECTRIC COMPANY

STATEMENT NO. 3

**Re: Concerning Line Route Study
And Environmental Assessment**

Dated: September 1, 2016

1 **I. INTRODUCTION**

2 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

3 A. My name is Barry Alan Baker. My business address is 625 West Ridge Pike, Suite E-
4 100, Conshohocken, PA 19428

5

6 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

7 A. I am employed by AECOM Corporation as an Associate Vice-President and Department
8 Manager for the Impact Assessment & Permitting Department and also serve as a
9 Technical Lead in the AECOM U.S. Transmission & Distribution practice for the Power,
10 Energy and Industrial Business Line.

11

12 **Q. WHAT ARE YOUR PRINCIPAL RESPONSIBILITIES IN THESE POSITIONS?**

13 A. In these roles I am a Certified Project Manager and manage projects for siting and
14 permitting of new transmission lines, power plants, and other facilities. I manage a
15 Department of approximately fifty (50) individuals responsible for environmental and
16 information technology services. Additionally I service as a Technical Lead for
17 Transmission and Distribution services on the east coast of the U.S.

18

19 **Q. PLEASE PROVIDE A SUMMARY OF YOUR EDUCATION AND
20 PROFESSIONAL WORK EXPERIENCE.**

21 A. I received a Bachelor of Science with Honors degree in Environmental Science from the
22 University of East Anglia in Norwich, England in 1996. A key focus was on the use of
23 GIS and computer applications for environmental problem solving. My additional

1 continuing education relevant to my current position includes the following courses and
2 programs:

- 3 • Approximately 50 Project Management Classes necessary for formal certification.
- 4 • Creating and Integrating Data for Natural Resource Applications (ESRI).
- 5 • Geoprocessing with ArcGIS Desktop (ESRI).
- 6 • Spatial Hydrology Using ArcView (ESRI).
- 7 • Introduction to ArcIMS (ESRI).
- 8 • System Architecture Design for GIS (ESRI).

9 I have been employed by AECOM for the last eleven years in the roles previously
10 discussed. In these positions I have been responsible for siting studies both as a Project
11 Manager and as a technical lead for transmission line siting as well as new power
12 development throughout the northeast region of the U.S., including: PA, NJ, MD, NY,
13 CT, OH, IL, VA, DE, and MA. I also manage the Pennsylvania Area Impact Assessment
14 & Permitting Department where I am responsible for a team of biologists, ecologists, and
15 GIS specialists. Additionally, I am an AECOM Technical Lead designated for
16 supporting and developing major transmission opportunities on the U.S. East Coast with
17 a focus in the northeast. Prior to joining AECOM, I held GIS and environmental
18 development positions for other environmental and government consultants.

19
20 **Q. HAVE YOU PREVIOUSLY TESTIFIED IN PUBLIC UTILITY COMMISSION**
21 **PROCEEDINGS?**

22 A. Yes, I have provided siting testimony before the Pennsylvania Public Utility Commission
23 (“Commission”) for

- 1 • PPL Electric Utilities - Northeast Pocono Project.
- 2 • PPL Electric Utilities - Blooming Grove Jackson Project
- 3 • PPL Electric Utilities - Effort Mountain Project
- 4 • PPL Electric Utilities - Appenzell Project

5

6 **Q. HAVE YOU TESTIFIED IN PROCEEDINGS BEFORE OTHER UTILITY**
7 **REGULATORY COMMISSIONS?**

8 A. Yes, I have provided siting testimony before the New Jersey Board of Public Utilities
9 (“BPU”) for:

- 10 • PSE&G - North Central Reliability Project
- 11 • New Jersey Natural Gas – Southern Reliability Link Project

12

13 **Q. WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY IN THIS**
14 **PROCEEDING?**

15 A. My testimony explains the selection of the route for the Bedford North - Central City
16 West transmission line (“Project”).

17

18 **Q. WERE ANY PORTIONS OF THE SITING APPLICATION PREPARED BY YOU**
19 **OR UNDER YOUR SUPERVISION?**

20 A. Yes. I am sponsoring certain attachments to Penelec’s Siting Application for this project
21 filing. Specifically, I am responsible for portions of the following attachments to the
22 Siting Application:

- 23 • Exhibit 1 PUC Cross-Reference

- 1 • Exhibit 2 Project Location Map
- 2 • Exhibit 3 Property Ownership Map
- 3 • Exhibit 8 Route Selection Study
- 4 • Exhibit 9 List of Agency Permit Requirements

5 I was integrally involved in preparing these attachments to the Siting Application or
6 otherwise provided oversight to AECOM technical staff who prepared them. I also
7 provided review for the complete Siting Application prior to assembly and submission to
8 the Commission.

9

10 **Q. WHAT ARE YOUR RESPONSIBILITIES IN CONNECTION WITH THE**
11 **BEDFORD NORTH - CENTRAL CITY WEST TRANSMISSION LINE?**

12 A. I serve as AECOM’s Project Manager, on behalf of Penelec, for the siting and permitting
13 components of the Bedford North - Central City West transmission line. My
14 responsibilities on the Project began in July 2014 and have involved oversight of the
15 AECOM routing efforts that identified six potential routes, including five alternative
16 routes (Routes 1, 3, 4, 5, and 6) and the Proposed Route (Route 2) and that is presented
17 for Commission approval. I oversee the scientists, biologists, planners, cultural resource
18 specialists, Geographic Information Systems (“GIS”) analysts, and other technical
19 specialists that have helped define the routes considered for the proposed transmission
20 line. I also attend numerous teleconferences that take place concerning project-related
21 routing, permitting, and public outreach efforts.

22 For project environmental consultation, I reviewed and helped coordinate the
23 initial agency consultation and survey efforts on behalf of Penelec. These include

1 submission of a Pennsylvania Natural Diversity Inventory (“PNDI”) large project review
2 to the U.S. Fish and Wildlife Service (“USFWS”), Pennsylvania Department of
3 Conservation and Natural Resources (“DCNR”), Pennsylvania Game Commission
4 (“PGC”), and Pennsylvania Fish and Boat Commission (“PFBC”); and wetland
5 delineation activities along the Proposed Route right-of-way.

6
7 **II. ROUTE SELECTION STUDY**

8
9 **Q. PLEASE EXPLAIN HOW THE STUDY AREA WAS DETERMINED AND THE**
10 **DEVELOPMENT OF POTENTIAL AND ALTERNATIVE ROUTES.**

11 A. The Penelec Routing Team conducted a detailed siting analysis to determine a location
12 for the Bedford North - Central City West transmission line that best balances social,
13 environmental, engineering and economic considerations. This analysis included the
14 determination of a Study Area, the compilation of an environmental inventory,
15 identification and analysis of alternative line routes and, finally, selection of a proposed
16 route.

17 The Study Area is the region in which transmission line route alternatives could
18 be sited to practicably meet the Project’s functional requirements and, at the same time,
19 minimize potential environmental impacts and Project costs. The study area was selected
20 based on professional judgment and the geographic characteristics of the region, as well
21 as the physical endpoints of the Project (i.e., substation locations). In this case, the
22 boundaries of the study area were developed based on a review of United States
23 Geological Survey (USGS) maps, state and county road maps, and aerial photographs.

1 Constraints such as major water bodies, urban/developed areas, transportation routes,
2 existing utility corridors, and the locations of the end points played key roles in
3 determining the boundaries of the study area and route candidate selections.

4 Given these considerations, the Routing Team identified a Study Area
5 encompassing approximately 110,080 acres or 172 square miles within Bedford and
6 Somerset Counties, Pennsylvania. The Project Study Area is bounded generally by
7 Gallitzin State Forest to the north; the Bedford North Substation to the east; the existing
8 Bedford North-New Baltimore 115 kV line to the south; and the Central City West
9 Substation to the west. Using this established Study Area, the Routing Team began its
10 efforts to determine Potential Routes for the line.

11
12 **Q. WHAT GUIDELINES WERE USED TO ANALYZE POTENTIAL**
13 **ALTERNATIVE ROUTES?**

14 A. The Routing Team developed basic route selection criteria that would be used to select
15 and analyze potential Alternative Routes. These guidelines included the following
16 criteria:

- 17 • Maximize the use of any existing transmission line rights-of-way and seek rebuild
18 options, e.g. the Bedford North-New Baltimore 115 kV line right-of-way
19 (“ROW”);
- 20 • Avoid or limit circuitous routes and special design requirements;
- 21 • Maximize the distance from and/or minimize impact on dwellings, schools,
22 daycare facilities, hospitals, and other community facilities;

- 1 • Avoid or minimize visibility from scenic roadways or viewpoints;
- 2 • Avoid crossing or minimize impacts to designated public resource lands such as
- 3 national and state forests and parks, recreational lands, nature preserves,
- 4 designated historic resources and sites, and conservation areas;
- 5 • Minimize environmental impact and construction/maintenance cost by selecting
- 6 shorter, direct routes; and route corridors through terrain where economical
- 7 construction and environmental best management practices can be employed, and
- 8 where line operational/maintenance is most feasible (e.g., use existing access
- 9 roads where practicable); and
- 10 • Avoid or minimize new crossings of large lakes, rivers and large wetland
- 11 complexes, critical habitat, and other unique or distinct natural resources.

12 Using these established routing guidelines, the Routing Team identified

13 opportunity and constraint features within the Study Area that would take advantage of

14 existing corridors to the extent practicable and minimize potential impacts to the natural

15 and human (or built) environment. The option to use and/or rebuild portions of the

16 existing Bedford North-New Baltimore 115 kV line was a primary consideration in the

17 routing assessment as using existing ROWs would likely result in fewer environmental

18 impacts and reduce total project costs. This existing transmission ROW has sufficient

19 space to rebuild the existing line as a double-circuit 115 kV line. The Routing Team used

20 this information to develop alternative routes following the general routing and technical

21 guidelines described above. Details of the opportunity and constraints used to develop

22 the alternative routes are included in the Project Route Selection Study, which is attached

23 as Exhibit 8 of the Application.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

Q. CAN YOU DESCRIBE HOW THE ROUTING TEAM DEVELOPED ALTERNATIVE ROUTES?

A. Candidate Segments are an early iteration of the routing process that involves developing conceptually based routes and general consideration of these routes with respect to opportunity and constraints features in the Study Area. During the routing process, the Candidate Segments were further refined and compared by the Routing Team, and a selection of the most suitable links were assembled into Alternative Routes. Alternative Routes are routes that begin and end at similar locations for direct comparison. Potential impacts are assessed and compared with respect to land use, natural and cultural resources, and engineering and construction concerns. Ultimately, through a quantitative and qualitative analysis and comparison of Alternative Routes, a Proposed Route is identified for submittal to the Commission.

Alternative Routes were first developed to use portions of the existing Bedford North-New Baltimore 115 kV line, which can be built to a double-circuit configuration. Options connecting to the existing 115 kV ROW involved cross-county routes that avoided concentrated development and used open agricultural fields and road alignments where practicable. Other potential Routes located north of the existing 115 kV line were developed based on similar avoidance measures, including the potential use of another existing transmission line, Bedford North-Osterburg East 115 kV, which extends north along the eastern edge of the Study Area. After the initial Alternative Routes were identified, the Routing Team conducted field investigations of the routes in spring 2015. These investigations involved the visual examination of the Alternative Routes from

1 public roads and other points of public access to identify residences, outbuildings,
2 commercial buildings, and other potentially sensitive receptors (e.g., cemeteries,
3 churches, and schools).

4 Based on the results of the field investigations, the Routing Team conducted
5 further evaluation and several adjustments were made to the alignments of the Alternative
6 Routes. The Routing Team developed six Alternative Routes (Routes 1 to 6) from the
7 identified segments.

8

9 **Q. PLEASE BRIEFLY DESCRIBE THE ALTERNATIVE ROUTES.**

10 A. The six Alternative Routes are as follows:

11 **Alternative Route 1 (Yellow)**

12 Alternative Route 1 is approximately 21.3 miles in length. From the Bedford North Substation,
13 Route 1 would extend 1.7 miles north as a second circuit on the existing Bedford North-
14 Osterburg East 115 kV line that would be rebuilt as a double circuit transmission line. The route
15 would parallel the east side of Interstate-99 (I-99) and State Route 56 (SR 56). After exiting the
16 Bedford North-Osterburg East 115 kV line, Route 1 crosses I-99 and extends for 7.8 miles
17 predominantly through steep forested lands with few areas of agricultural use and some
18 moderately dense residential properties. Near SR 96, the route extends over a section of an
19 active orchard, which ends near Chestnut Ridge Road. The slope of the land steadily climbs for
20 the next 3.7 miles from an elevation of 1,300' near SR 96 to 2,000' at Buckeye Road. Most of
21 this section would be located within forested lands with few open agricultural areas. At Buckeye
22 Road, the route would turn to the southwest, start a steep 700-foot climb up the Allegheny Front,
23 and extend for 5.5 miles to Central City. Turning to the west, Route 1 would cross into Somerset

1 County, extend over an isolated local road, and then traverse through undeveloped forested
2 lands. The western portion of this section borders lands associated with an active quarry and
3 landfill near Central City. Route 1 continues for 2.6 mile to the northwest and then southwest
4 around the north side of Central City to the Central City West Substation.

5 **Alternative Route 2 (Purple) (Proposed Route)**

6 Alternative Route 2 is approximately 17.6 miles in length. From the Bedford North Substation,
7 Route 2 would extend west for 7.2 miles on the existing Bedford North-New Baltimore 115 kV
8 line that would be rebuilt as a double circuit transmission line. The route would extend over
9 agricultural fields and then span SR 56. After crossing this roadway, the route climbs the steep,
10 forested slopes of the Pigeon Hills and passes over several roads bordered by low density
11 residential development such as Sloan Hollow Road, Point Road, and Harrison Road. After
12 Harrison Road, Route 2 passes over a short (0.1 mile) section of Shawnee State Park, extends
13 through a mix of forested and agricultural lands, and crosses a moderate density residential-lined
14 portion of SR 96 just north of the town of Schellsburg. West of SR 96, the existing Bedford
15 North-New Baltimore 115 kV line turns to the southwest and Route 2 would continue west as
16 new construction in new ROW until the end of the route. For the initial 1.4 miles Route 2
17 traverses across forested and agricultural lands, spans the Shawnee Branch and crosses three low
18 density residential-lined roads. After crossing Hoover Road, Route 2 continues west for 3.0
19 miles to Lambert Mountain Road located at the base of the Allegheny Front. The route extends
20 across active farm lands, through several forested areas, and crosses several low density
21 residential-lined roads such as Anderson Road, Malamphy Road, Miller Road, and Helixville
22 Road. The slope of the land in this section steadily climbs from an elevation of 1,400' near
23 Hoover Road to 2,200' at the intersection of Helixville Road and Lambert Mountain Road.

1 From Lambert Mountain Road, Route 2 extends northwest for 1.4 miles to the State Game Lands
2 #228 boundary. At Lambert Mountain Road, the route traverses straight up the 500-foot forested
3 face of the Allegheny Front, extends west across forested lands into Somerset County, and then
4 crosses an isolated section of Fleegle Road. Turning to the northwest, the route traverses
5 through a mix of forested and agricultural lands before intersecting with the State Game Land
6 boundary. At this point, Route 2 would extend northwest for 1.4 miles across State Game Land
7 property. The route would initially traverse through forested lands before intersecting with the
8 south side of Lambert Mountain Road. Route 2 is conceptually expected to parallel the south-
9 side of Lambert Mountain Road to reduce the number of angles and limit the length of alignment
10 across these protected lands. There are several residential properties on the south side of
11 Lambert Mountain Road at the western edge of State Game Lands #228 that would require the
12 alignment to cross to the north side of the road in this area. From the western edge of State
13 Game Lands #228, Route 2 would extend 1.5 miles through forested lands to the potential
14 alternative route crisscross area located on the eastern edge of Central City. The route would
15 cross to the south side of Lambert Mountain Road near an existing utility line ROW and then
16 parallel the road west past the intersection with Shaffer Mountain Road. Route 2 continues for
17 1.7 miles to the west through central portions of Central City Borough to the Central City West
18 Substation. The route would cross to the north side of Shaffer Mountain Road, span over an
19 undeveloped section of Main Street, span Dark Shade Creek (CWF), and then cross a disturbed
20 area that borders the active Norfolk Southern Railroad. Crossing to the west side of the railroad,
21 Route 2 would parallel the railroad into the town of Central City and across the commercial
22 bordered SR 160 (Sunshine Avenue). West of SR 160, the route would be collocated with an
23 existing electrical distribution line that is located in close proximity to several residential

1 properties that border the railroad ROW. Past this point, the route would follow the electrical
2 distribution line and parallel the railroad as they turn to the north. Just beyond the Central City
3 Borough line, the route would turn sharply to the west following the distribution line over a
4 disturbed abandoned railroad ROW and across sparsely residential-lined School Road. Turning
5 to the northwest, Route 2 crosses a mixed meadow/forest area before extending into the Central
6 City West Substation.

7 **Alternative Route 3 (Blue)**

8 Alternative Route 3 is approximately 19.7 miles in length. Route 3 is a hybrid combination of
9 portions of Route 1 and Route 2 with a 4.3 mile connection between these two alternatives. The
10 route follows the initial 8.8 miles of Route 2 from the Bedford North Substation to Hoover Road
11 near Schellsburg. At this point, Route 3 would be a continuation of new construction in the new
12 right-of-way and turns to the north for 2.0 miles to Shaffer Mountain Road. After crossing a
13 tributary to Shawnee Branch, the route makes a series of three sharp turns to follow the boundary
14 of an active farm property. The route then spans over a low density residential-lined section of
15 Helixville Road and continues north across a mix of agricultural and forested lands to a low
16 density residential-lined section of Shaffer Mountain Road. Turning to the northwest, Route 3
17 extends to intersect with Route 1 on top of the Allegheny Front. The route would traverse
18 through a mix of forested and agricultural lands and pass over several roads bordered by low
19 density residential development such as Kanouff Road, McCreary Road, and Bethel Hollow
20 Road. From this point, Route 3 would follow the Route 1 alignment for 6.6 miles around the
21 north side of Central City and into the Central City West Substation.

22 **Alternative Route 4 (Red)**

1 Alternative Route 4 is approximately 19.2 miles in length. Route 4 uses portions of Route 2 to
2 connect to portions of Route 1. This alternative was developed based on the potential that
3 crossing State Game Lands #228 would be acceptable to the Pennsylvania Game Commission,
4 but use of the railroad ROW through the center of Central City would not be acceptable to
5 Norfolk Southern. This alternative follows Route 2 for 15.7 miles from the Bedford North
6 Substation to the east side of Central City. At this point, Route 4 would be a continuation of new
7 construction in the new right-of-way that extends to the northwest for 0.9 miles to connect to
8 Route 1. This portion of the alignment crosses to the north side of Shaffer Mountain Road in an
9 undeveloped area, spans a tributary to Dark Shade Creek, and then traverses a section of
10 undeveloped forest to intersect with Route 1. From this point, Route 4 would follow the Route 1
11 alignment for 2.6 miles around the north side of Central City and into the Central City West
12 Substation.

13 **Alternative Route 5 (Green)**

14 Alternative Route 5 is approximately 20.6 miles in length. Route 5 uses portions of Route 1 to
15 connect to portions of Route 2. This alternative was developed based on the potential that
16 crossing State Game Lands #228 would not be acceptable to the Pennsylvania Game
17 Commission, but use of the railroad ROW through the center of Central City would be
18 acceptable to Norfolk Southern. This alternative follows Route 1 for 18.3 miles from the
19 Bedford North Substation to the east side of Central City. At this point, Route 5 would be a
20 continuation of new construction in the new right-of-way and extends southwest for 0.7 miles to
21 connect to Route 2. This portion of the alignment traverses a section of undeveloped forest,
22 spans a tributary to Dark Shade Creek, and crosses to the south side of Shaffer Mountain Road in
23 an undeveloped area to intersect with Route 2. From this point, Route 5 would follow the Route

1 2 alignment for 1.6 miles through the center of Central City and into the Central City West
2 Substation.

3 **Alternative Route 6 (Orange)**

4 Alternative Route 6 is approximately 19.0 miles in length. Route 6 uses portions of Route 3 to
5 connect to portions of Route 2. This alternative was developed based on the potential that using
6 the existing Bedford North-New Baltimore 115 kV ROW would be feasible from an engineering
7 perspective, that crossing State Game Lands #228 would not be acceptable to the Pennsylvania
8 Game Commission, but use of the railroad ROW through the center of Central City would be
9 acceptable to Norfolk Southern. This alternative follows Route 3 for 16.7 miles from the
10 Bedford North Substation to the east side of Central City. At this point, Route 6 would be a
11 continuation of new construction in the new right-of-way and extends southwest for 0.7 miles to
12 connect to Route 2. From this point, Route 6 would follow the Route 2 alignment for 1.6 miles
13 through the center of Central City and into the Central City West Substation.

14 **Q. WAS OUTREACH PART OF THE ROUTING PROCESS?**

15 A. Yes. Penelec conducted extensive public outreach throughout the siting process,
16 including initial regulatory agency consultation, public notification and open house
17 meetings, and meetings with property owners.

18 On January 28 and 29, 2015, Penelec held three public open house meetings in the
19 Project Area to present the Alternative Routes and provide information about the Bedford
20 North – Central City West Project. The first open house meeting was held at the Shade-
21 Central City High School in Cairnbrook from 6PM to 8PM. The second and third open
22 house meetings were held at the Travelodge in Bedford from 1PM to 3PM and 6PM to
23 8PM. At the meeting, attendees received a project factsheet, information on the PUC

1 process, and comment cards. The public information meetings provided an opportunity
2 for residents and other interested parties to review project information displays and
3 discuss the Project with Penelec and AECOM representatives. The factsheet contained a
4 brief statement on project need and benefits, a description of the siting process,
5 information about easements and permitting, and a preliminary project timeline. The
6 open houses consisted of several stations that identified the Project processes. Forty-five
7 people attended the Cairnbrook open house and fifty-four people attended the two
8 Bedford open houses. Comment cards were completed during the meetings. Comments
9 generally referred to concerns around specific line locations on individual properties,
10 local ecosystems, and endangered or threatened species populations. Several landowners
11 worked with the Routing Team to define better alignments across their properties.
12 Primary concerns about the project focused on areas around Shaffer Mountain Ridge and
13 along the Alternate Routes 1 and 3.

14 Once the alternative routes were narrowed to the Proposed Route, a PNDI request
15 was submitted to the USFWS, DCNR, PGC, and PFBC on April 1, 2015 requesting
16 information pertaining to the presence of any federally endangered, threatened, or rare
17 species and habitat along the proposed alignment. Due to a halt in the routing process,
18 Penelec has delayed the initial consultation letter to the PHMC until a final alignment is
19 negotiated. Results of the PNDI consultation are discussed in subsequent sections of this
20 testimony.

21
22 **III. ENVIRONMENTAL ASSESSMENT**
23

1 **Q. DID THE ROUTING TEAM EVALUATE THE IMPACTS OF THE**
2 **ALTERNATIVE ROUTES ON THE BUILT ENVIRONMENT?**

3 A. Yes. The Routing Team evaluated the potential impact of the six Alternative
4 Routes on existing residential, commercial and industrial development; land uses;
5 archaeological and historical areas; recreational and scenic resources; and terrain and
6 landscape. With the exception of the developed areas surrounding the Bedford and
7 Central City Substations, nearly the entire length of the Alternative Routes crossed
8 forested or agricultural areas. The Project is not anticipated to impact any scenic,
9 geologic or wilderness areas.

10 The closest airport is the Bedford County Airport, which is located just northeast
11 of the Bedford Substation along US 220. The Bedford County runway is 5,000 feet long
12 and is approximately 2,600 feet from Route 1 and 4,750 feet from the Bedford North
13 Substation and all of the other alternatives extending from this point. Therefore, Penelec
14 will likely need to file the appropriate documentation with both the Federal Aviation
15 Administration and the PennDOT Bureau of Aviation to ensure the proposed line will not
16 be a hazard to the airport's flight operations. No other smaller airports or heliports were
17 identified within 2 miles of the Study Area.

18 After analyzing and comparing the six Alternative Routes against potential
19 impacts on the built environment, Route 2 is preferred over other alternatives.
20 Approximately forty (40) percent of Route 2 can be constructed within an existing 115
21 kV ROW and it is the shortest, most direct route of all of the alternatives. Other options
22 would require a significantly longer distance of new ROW. Although Route 2 crosses
23 within 300 feet of more residences than other options, these residences are located within

1 300 feet of the existing 115 kV line or in the developed areas along the railroad corridor
2 paralleled through Central City. Therefore, Route 2 is expected to result in minimal
3 incremental impacts to land use, cultural resources and the existing viewshed.
4

5 **Q. DID THE ROUTING TEAM CONSIDER IMPACTS OF CONSTRUCTING THE**
6 **TRANSMISSION LINE ON EACH ALTERNATIVE ROUTE ON THE**
7 **NATURAL ENVIRONMENT?**

8 A. Yes. Natural environment impacts include potential impacts to vegetation and habitat,
9 surface waters, and conservation and recreation lands. Potential impacts are evaluated
10 based on publically available maps and data as well as consultation with federal and state
11 agencies.

12 All six Alternative Routes would extend across the forested slopes of the
13 Allegheny Front. One high quality stream would be crossed by several of the Alternative
14 Routes including Route 2. However, Route 2 would result in fewer stream and forest
15 impacts due to the generally direct route of this alternative. The length of wetland
16 crossings would be moderate in comparison to the other alternatives, but would involve
17 several emergent wetlands that would be spanned by the route.

18 Most of the vegetation crossed by the Alternative Routes consists of forest cover.
19 In these areas, a 100-foot-wide ROW will be cleared and maintained in accordance with
20 Penelec's Vegetation Management Program. Approximately seven miles of Route 2
21 would be constructed within an existing 100-foot-wide ROW that is presently cleared.
22 Therefore, only 10 miles of new ROW would need to be cleared to construct this option.

1 Based on a review of aerial imagery and field reviews, other options would require
2 significantly more forest clearing than Route 2.

3 The USFWS' response to Penelec's PNDI letter request for Route 2 indicated that
4 the Project is located within a known maternity and swarming area of a federally-listed
5 Indiana bat (*Myotis sodalis*) hibernacula and within the range for the northern long-eared
6 bat (*Myotis septentrionalis*). The USFWS recommends restricting tree cutting activities
7 from October 1 to March 31 to avoid potential impacts to these protected bat species.
8 Penelec is aware of these restrictions and will either adhere to them or submit an *Indiana*
9 *Bat Conservation Plan* to the USFWS that may involve the need for mitigation due to the
10 potential impacts to the habitat area.

11 DCNR noted that two plant species (mountain bellwort (*Uvularia pudica*) and
12 yellow-fringed orchid (*Platanthera ciliaris*)) may be located in the area. Botanical
13 surveys for these species will be conducted at the appropriate time of year for these two
14 plants.

15 The PFBC and PGC response indicated no adverse impact is anticipated to
16 threatened and endangered species and/or special concern species and habitat.

17 After analyzing and comparing the six routes against potential impacts to the
18 natural environment, the Routing Team concluded that Route 2 is preferred over the other
19 alternatives. Route 2 would result in significantly less forest clearing compared to other
20 options. Forest clearing can result in numerous impacts including forest fragmentation
21 and creation of new edge habitat, wetland function modification, soil erosion and
22 increased stormwater runoff. Route 2 would also minimize the number of new aerial
23 crossings of streams and the amount of 100-year floodplain crossed. Field wetland

1 delineations will be conducted for the Proposed Route and engineered access roads to
2 determine the exact location of any wetlands or waterways. Penelec anticipates that
3 project engineering can minimize wetland and stream impacts through spanning and
4 avoidance. Regardless, Penelec will obtain and adhere to all required state and federal
5 permits.

6
7 **IV. ROUTE SELECTION STUDY CONCLUSION**

8
9 **Q. DID THE ROUTING TEAM DECIDE WHICH ALTERNATIVE IS THE**
10 **PROPOSED ROUTE?**

11 A. Yes. Based on a quantitative and qualitative review of information obtained from GIS
12 data, field reconnaissance, agency consultation, and engineering and constructability
13 considerations for this Project, the Routing Team selected **Alternative Route 2** as the
14 Proposed Route. The Routing Team believes that the cumulative social, environmental,
15 and financial impacts associated with constructing Alternative Route 2 will be less than
16 any other Alternative Route. Specific reasons include the following:

- 17
- 18 • Route 2 is shorter and requires fewer angled structures compared to the other
19 Alternative Routes. Route 2 will also require significantly fewer acres of forest
clearing and minimizes the number of new stream crossings.
 - 20 • Penelec would use a significant portion of existing 115 kV ROW to build a new
21 double-circuit system. Using the existing right-of-way will greatly minimize the
22 amount of new easements required to build the project and would significantly

1 reduce the amount of vegetation clearance required, thereby reducing the overall
2 Project cost and environmental impact.

3 • While any route selected would result in changes to the existing viewshed, Route
4 2 would rebuild existing transmission infrastructure for a significant length, which
5 minimizes changes to the existing viewshed compared to constructing an all new
6 transmission line in areas without an existing transmission line.

7 • Route 2 would also be the least costly of the Alternative Routes. Penelec
8 evaluated the Alternative Routes from a cost perspective based on estimates from
9 siting, real estate, engineering, procurement, and construction.

10

11 **Q. DOES THIS CONCLUDE YOUR TESTIMONY AT THIS TIME?**

12 A. Yes, it does. I reserve the right to supplement my testimony as additional issues arise
13 during the course of this proceeding.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**APPLICATION OF PENNSYLVANIA :
ELECTRIC COMPANY FOR APPROVAL :
TO LOCATE AND CONSTRUCT THE :
BEDFORD NORTH-CENTRAL CITY :
WEST 115 KILOVOLT TRANSMISSION : Docket No.
LINE PROJECT IN CENTRAL CITY :
BOROUGH AND SHADE TOWNSHIP, :
SOMERSET COUNTY, AND NAPIER, :
EAST ST. CLAIR, AND BEDFORD :
TOWNSHIPS, BEDFORD COUNTY, :
PENNSYLVANIA :**

DIRECT TESTIMONY OF

LAWRENCE P. MATTEI

ON BEHALF OF

PENNSYLVANIA ELECTRIC COMPANY

STATEMENT NO. 4

**Re: The Design, Engineering, Construction,
Operation and Maintenance of the Project**

Dated: September 1, 2016

1 **I. INTRODUCTION AND PURPOSE OF TESTIMONY**

2

3 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

4

5 **A.** My name is Lawrence P. Mattei. My business address is FirstEnergy Service
6 Company, 800 Cabin Hill Drive, Greensburg, PA. 15601.

7

8 **Q. By whom are you employed and in what capacity?**

9

10 **A.** I am employed by FirstEnergy Service Company as a transmission design
11 engineer.

12

13 **Q. Please describe your educational background and professional experience.**

14

15 **A.** I am a 1980 graduate of the University of Pittsburgh with a Bachelor of Science
16 degree in Civil Engineering. I am a registered Professional Engineer in
17 Pennsylvania. After graduation from the University of Pittsburgh I worked for
18 the Municipal Authority of Westmoreland County, Pennsylvania, designing
19 public water supply projects. In 1981 I began employment with Allegheny Power
20 Service Corporation in the Surveys and Rights-of-Way Section. My primary
21 responsibilities included engineering support for right-of-way acquisition of
22 Company transmission lines. I also teamed with environmental specialists to
23 establish new transmission line routes and obtain approval of regulators at the
24 local, state, and federal levels. In 1995, I was assigned to the Allegheny Power's
25 Transmission Engineering Department. My responsibility was to design new
26 transmission lines as issued by Company planners and to re-design existing
27 transmission lines for planned upgrades. I also was responsible for civil

1 engineering design activities associated with new substations and the expansion of
2 existing substations. With the 2011 merger of Allegheny Energy, Inc., with
3 FirstEnergy Corp., I was assigned to the FirstEnergy Service Company
4 Transmission Design Department and keeping the same job responsibilities. In
5 July 2015 I was assigned to the Company's External Design Engineering
6 Department. My current responsibilities focus on the oversight of the Company's
7 external transmission engineering consultants.

8

9 **Q. What is the purpose of your testimony?**

10

11 **A.** The purpose of my testimony is to describe the design and construction
12 methodology of Pennsylvania Electric Company ("Penelec") for the proposed
13 Bedford North-Central City West 115 kV HV Transmission Line Project.
14 Penelec is a FirstEnergy company. I will also provide information on the
15 operations and maintenance of this line.

16

17

18 **Q. Briefly outline your testimony.**

19

20 **A.** My testimony will cover the following aspects of the proposed 115 kV line:

21

22 • Proposed transmission line configuration

23

24 • Right-of-way requirements

25

26 • Design criteria

27

28 • Construction activities

29

30 • Maintenance activities

31

32

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Q. Does your testimony address the filing requirements of 52 Pa. Code § 57.1 and §§ 57.1 – 57.77 concerning the siting and construction of high voltage (“HV”) transmission lines?

A. Yes. My direct testimony, together with the siting Application filed by Penelec provides information to respond to the requirements of 52 Pa. Code § 57.72(c)(6) (safety considerations to be incorporated into the design, construction and maintenance of the proposed HV line); (c)(13)(ii) (an engineering and design-based description of the proposed line); and (c)(13)(iii) (a simple drawing of a cross section of the proposed right-of-way of the HV line showing the placement of supporting structures at typical locations, with structure sizes, right-of-way widths, and the lateral distances between the conductors and the edge of the right-of-way indicated).

II. EXHIBITS

Q. Please identify and describe the exhibits that you will refer to in your testimony.

A. I am sponsoring exhibits 6A, 6B, 10A, 10B, 10C, 10D, 10E, 10F, 10G, 10H, 10I, 10J, 11A, 11B, 11C, and 20.

1 I will refer to the exhibits that accompanied Penelec's Application. The exhibits
2 were developed by me or under my supervision. Exhibits 6A and 6B show the
3 minor relocation of the Central City West – Statler Hill 115 kV Line at Central
4 City Substation. Exhibit Nos. 10A through Exhibit No. 10J to Penelec's
5 Application show the types of structures that will be used in the project. Exhibit
6 11A through 11C to the Application depict typical right-of-way widths for the
7 transmission line. Exhibit No. 20 is a copy of the Company's Tree Trimming and
8 Comprehensive Vegetation Management Plan.

9

10 **III. LINE CONFIGURATION**

11

12 **Q. Has a general description of the project been provided?**

13

14 **A.** Yes, a description of the proposed transmission line project has been provided in
15 Penelec's Application. Additionally, other Penelec witnesses will provide a
16 general description of the need for the line, the proposed route and other basic
17 information about this project. My discussion of the engineering, construction,
18 and maintenance of the project which follows is consistent with those
19 descriptions.

20

21

22 **Q. Please describe the general transmission line configuration planned for the**
23 **project.**

24

25 **A.** The project calls for a double circuit 115 kV Line to be constructed between
26 Bedford North Substation and Central City West Substation. The line length is

1 approximately 17.5 miles. Based on preliminary engineering the Project requires
2 installation of approximately 144 structures ranging from 50 feet to 145 feet in
3 height above ground level. The average span length is approximately 650 feet. It
4 will share a common right of way with the existing Bedford North-New Baltimore
5 115 kV Line on the westerly side of the line corridor for approximately 7.2 miles.
6 This project will also require that the existing Central City West-Statler Hill 115
7 kV Line be relocated where it enters Central City Substation. This relocation is
8 about 1,000 feet. The Bedford North-Central City West 115 kV Line will then
9 occupy the existing Central City West-Statler Hill 115 kV Line termination
10 structure at Central City Substation. The Central City West-Statler Hill 115 kV
11 Line will use an open termination at Central City West Substation. Reasons for
12 this will be further discussed below. Also, this line termination change is depicted
13 on exhibits 6A and 6B.

14 There are numerous structure designs under consideration to best fit topography,
15 land use, and constructability constraints for this project. As such, we anticipate
16 single and double pole structures using both wood and steel. Initially only one
17 circuit will be installed. The proposed transmission line conductors will be
18 installed on one side of the structure in a vertical configuration for all structures
19 except the substation termination structures which will be configured horizontally.
20 The other side of the structure will be used for future transmission line conductors
21 with similar geometry. Some structures are actually two independent single circuit
22 structures installed adjacent to each other for a double circuit configuration. In

1 these situations, only the Bedford North-Central City West 115 kV circuit will be
2 constructed. The other structure will be constructed when the second circuit is
3 needed. However, a section of this new line will rebuild the existing Bedford
4 North-New Baltimore 115 kV Line for about 7.2 miles. As such, both circuits will
5 be installed on this section of the line. Refer to Exhibit Nos. 10A through 10J of
6 Penelec's Application, which depict the various types of structures that will be
7 used on the project. Exhibit No. 10A shows a typical double circuit tangent wood
8 pole structure. This structure will be used on straight line sections. Exhibit 10B
9 shows a typical double circuit light angle wood pole structure. This structure
10 requires guying to stabilize unbalance loads due to line direction changes. Exhibit
11 10C shows a typical double circuit angle dead end wood pole structure. This
12 structure requires in-line guying to stabilize unbalance loads due to line direction
13 changes also. Exhibit 10D shows a typical double circuit steel tangent structure.
14 These structures could be used where wood poles are structurally inadequate to
15 support the line. Also, there are locations where the line route will overbuild
16 sections of Penelec's distribution lines. At these locations, the existing
17 distribution lines will be attached below the transmission line as needed. These
18 structures are typically direct imbedded into the ground or can be supported on
19 concrete foundations if soil conditions require it. Exhibit 10E shows a typical
20 double circuit steel dead end or tangent structure. The difference between the two
21 is primarily on the insulator assembly attachment to the pole. Dead end structures
22 are typically used where line direction changes occur and tangent structures are

1 typically used where there are no line angles. This structure will use concrete
2 foundations and are typical where structure loads are high and require increased
3 foundation support. Exhibit 10F shows another typical double circuit dead end
4 structure on a concrete foundation. This type of structure will be used on shorter
5 spans that could require distribution underbuild. As mentioned, there are some
6 sections of the proposed route where we will combine the existing distribution
7 lines with the Bedford North-Central City West 115 kV Line. This joint use
8 occupancy of transmission and distribution lines is in the Central City area where
9 it's advantageous to share existing right-of-way to minimize land use by this
10 proposed project. Exhibit 10G shows a typical substation termination structure.
11 These will only be used at the Bedford North Substation and Central City West
12 Substation. They will be inside the substation fences. Exhibit 10H shows a typical
13 single circuit angle dead end steel pole structure. This structure will be used to re-
14 route the existing Central City West-Statler Hill 115 kV Line in and around
15 Central City West Substation. It is used as direct embedded when the supporting
16 soil conditions warrant. Otherwise, it could be installed on concrete foundations.
17 As mentioned in the Siting Application and above, this existing line will move its
18 termination location to accommodate the Bedford North-Central City West 115
19 kV Line termination. This will keep the line exits at Central City Substation from
20 immediately crossing each other and increase reliability of both lines. Exhibit 10I
21 also shows a typical single circuit angle dead end structure. This structure will be
22 used to re-route the existing Central City West-Statler Hill 115 kV Line in and

1 around Central City West Substation. It will be used on concrete foundations
2 when the supporting soil conditions cannot support the structure. Exhibit 10J
3 shows a typical single circuit wood light angle structure with guying. This
4 structure will be used where wood poles are structurally adequate on the existing
5 Central City West-Statler Hill 115 kV Line. This structure could also be used
6 where the two circuits separate to enter the Bedford North Substation. As shown
7 on the exhibits, structure heights will vary between 50 feet and 145 feet above
8 ground level.

9

10 **Q. Do you anticipate the need for any other types of structures for the project?**

11

12 **A.** No. We do not anticipate the need for any other types of structures other than
13 those shown in Exhibit Nos. 10A through 10J to Penelec's Application. However,
14 if the situation arises where the wood pole structures shown on Exhibits 10A,
15 10B, 10C, and 10J are not structurally adequate we would use steel pole versions
16 of similar dimensions as the wood poles for needed strength requirements.

17

18

19 **Q. What width of right-of-way is planned for the project?**

20

21 **A.** As shown in Exhibits 11A, 11B, and 11C of the Application the project will be
22 constructed on varying right-of-way of 100 feet and 130 feet. However, if during
23 detailed design engineering, it becomes necessary to develop longer span lengths,
24 for example, to span environmentally sensitive areas, the Company would require
25 wider right-of-way to accommodate the greater side-to-side conductor movement
26 with longer span lengths. Additionally, in areas where the proposed line would

1 parallel, and be located just outside of a public road's right-of-way, a narrower
2 transmission line right-of-way can be used in combination with the road right-of-
3 way.

4
5 **Q Will the proposed transmission line overlap any existing transmission line**
6 **right-of-way?**

7
8 **A.** Yes. The proposed transmission line will use the centerline of the existing
9 Bedford North-New Baltimore 115 kV Line 115 kV transmission line for about
10 40 percent of its length. In this overlap section the existing right-of-way is 100
11 feet in width in some places and 120 feet in width in other places. These right-of-
12 way widths are shown on exhibits 11A and 11B. No new right-of-way is
13 anticipated for this section of the line.

14
15 **Q. Will the existing Bedford North-New Baltimore 115 kV transmission line**
16 **remain in service following the completion of the proposed project?**

17
18 **A.** Yes. The Bedford North-New Baltimore 115 kV line will be re-energized and
19 share the same structures as described above.

20
21 **Q. Will the supporting structures carry any wires other than transmission**
22 **conductors?**

23
24 **A.** Yes. The structures will have two static wires that will be located above the
25 transmission conductors. The purpose of the static wire is to protect the

1 conductors from lighting strikes. One of these static wires will also serve as
2 communications via fiber optics.

3
4 **Q. Does the project meet FirstEnergy’s existing engineering and design**
5 **standards?**

6
7 **A.** Yes, the structures depicted in Exhibits Nos. 10A through 10J of the Application
8 are based upon and meet FirstEnergy’s applicable existing engineering and design
9 standards for 115 kV transmission lines.

10
11 **IV. DESIGN CRITERIA**

12
13 **Q. Please describe the “vertical configuration” of the three conductor phases**
14 **shown on Exhibit Nos. 10A through 10J and explain why this configuration**
15 **was selected.**

16
17 **A.** The vertical configuration is FirstEnergy’s typical configuration for a 115 kV
18 double circuit transmission line. The configuration minimizes the width of the
19 right-of-way.

20
21 **Q. Please describe the voltage, temperature and other electrical parameters at**
22 **which the conductors will operate and how these parameters will conform to**
23 **the National Electric Safety Code (“NESC”).**

24

1 A. The 115 kV transmission line will be designed to operate at a maximum design
2 temperature of 212 degree Fahrenheit. The line will meet all requirements of the
3 current NESC under all operating conditions.

4
5 **Q. Please describe the minimum conductor-to-ground clearances under**
6 **maximum operating conditions the design will meet.**

7
8 A. The transmission line will be designed to meet or exceed the NESC minimum
9 requirements of 21 feet (rounded up to nearest foot) under all operating
10 conditions.

11
12 **Q. Please describe the type and size of conductor planned for the conductors**
13 **and shield wire.**

14
15 A. The three (3) conductors are 795 thousand circular mills (“kcmil”) 26/7 aluminum
16 conductor, steel reinforced (“ACSR”). The 26/7 designation indicates the
17 stranding of the conductor, with the 26 representing the outer 26 aluminum wires
18 and the 7 representing the inner 7 steel wires. The shield wires will be one 7#8
19 alumoweld and one fiber optic.

20
21 **Q. Please describe the relationship of the proposed right-of-way width to the**
22 **design and NESC requirements for the project.**

23

1 A. The right-of-way width was selected to provide necessary conductor clearances
2 when considering structure type, span length between supporting structures,
3 conductor motion, line voltage, and NESC defined weather conditions.

4

5

6

V. CONSTRUCTION ACTIVITIES

7

8

9

Q. Please describe, in general terms, the construction process.

10

11

A. The project will be constructed according to a well-defined procedure that utilizes
12 standard construction practices to perform all work safely and in compliance with
13 the Occupational Safety and Health Administration (“OSHA”) Rules and
14 Regulations, while keeping environmental impact to a minimum. Project
15 activities will include the installation and maintenance of soil erosion and
16 sedimentation control measures, temporary access route construction, right-of-
17 way clearing, foundation, structure and wire installations, and the rehabilitation of
18 all areas disturbed during construction.

19

20

21

Q. Will a construction project contractor and/or manager be utilized?

22

23

A. Penelec plans to construct the line with contractor construction labor and
24 supervision, with FirstEnergy Service Company personnel oversight.

25

26

27

**Q. How will Penelec oversee and monitor the construction cost and progress of
28 the project?**

28

29

1 A. Penelec uses the services of FirstEnergy Service Company, a FirstEnergy affiliate,
2 for oversight of engineering, construction, and other services. FirstEnergy
3 Service Company will assign a project manager to monitor and oversee the
4 project construction activities.

5
6 **Q. What is the estimated cost to site and construct the project?**

7
8 A. The cost of the project is currently estimated to be \$48 million.

9
10 **Q. When will the project be constructed?**

11
12 A. Pending approval for the Project from the Pennsylvania Public Utility
13 Commission, construction is scheduled to occur from February 2018 thru
14 December 2018.

15
16 **Q. What steps are planned for minimizing the effects of construction on areas
17 within and outside of the right-of-way, including such things as traffic and
18 other local community issues?**

19
20 A. Physical work on the Project will not begin until the necessary permits for work
21 have been issued. All work will be conducted in accordance with state, local, and
22 federal permits, property releases, and approved special conditions. Penelec will,
23 at all times, minimize to the greatest extent practical the impacts of construction
24 activities on local communities.

25
26
27
28

VI. RIGHT-OF-WAY CLEARING AND PREPARATION

1 Q. What methods will be used to clear and prepare the right-of-way for
2 construction?

3
4 A. The construction specifications adopted for the project are designed to keep
5 environmental impact to a minimum. In addition to the implementation of best
6 management practices for erosion control (“BMPs”), Penelec’s efforts to
7 minimize environmental impact during the right-of-way preparation phase of
8 construction will include the following:

9

10 1. A copy of the Soil Erosion and Sedimentation Control Plan, along with the
11 appropriate permit forms, will be submitted to the Pennsylvania
12 Department of Environmental Protection and, as necessary, the County
13 Conservation District for approval.

14

15 2. BMP for soil erosion measures and sedimentation control will be put in
16 place prior to any earth disturbance.

17

18 3. Construction access routes will be installed in accordance with the Soil
19 Erosion and Sedimentation Control Plan. Existing roads, private farm
20 lanes, private forest roads and other similar existing access will be utilized
21 to the extent practical. Where new access routes are needed for vegetation
22 removal and/or construction, it is preferred that the access remain for
23 future maintenance activities. Any new access roads that are to remain

1 will be stabilized by seeding and installation of water diversion measures.

2 Where it is necessary to remove new access roads after construction, the
3 roads will be re-graded to pre-construction contours and re-vegetated with
4 an appropriate seed mix.

5

6 4. Disturbed work areas will be re-vegetated in accordance with the approved
7 Soil Erosion and Sediment Control Plan.

8

9 5. Penelec will clear the corridor to the specific width in accordance with the
10 FirstEnergy Initial Clearing of Transmission Lines Specification and the
11 FirstEnergy Detailed Property and Provision List. Trees located outside
12 the ROW that are deemed Priority Trees shall be removed. Priority Trees
13 are defined as trees located adjacent to transmission corridors that are
14 dead, dying, diseased, structurally defective, leaning or significantly
15 encroaching, where the transmission conductor would be a target when a
16 tree fails and will fall or be within close proximity of the transmission
17 conductor to potentially flash-over, strike or grow into the conductor. In
18 order to remove trees and vegetation both on and off ROW, Penelec will
19 first obtain the necessary rights from the applicable property owners.

20

1 When required, Penelec's standard specifications will be modified and/or
2 amended for construction of the project to comply with all terms of the governing
3 permits required and applicable to construct the project.

4
5 **Q. What steps will be taken to upgrade, seed, or otherwise restore disturbed**
6 **right-of-way once construction is complete?**

7
8 **A.** After construction is completed, the transmission line right-of-way will be
9 restored to conditions as good as or better than what existed prior to construction.
10 Such work includes restoring drainage ditches, fencing, and field drainage tiles.
11 Non-cultivated areas that are disturbed by construction activities will be fertilized,
12 seeded, and mulched. Temporary soil erosion and sedimentation control
13 measures will be removed after vegetative cover has been established.

14
15 **Q. Please describe the steps that will be taken to control erosion and the siltation**
16 **of streams where the ground is disturbed during construction activities along**
17 **the right-of-way.**

18
19 **A.** FirstEnergy will follow all applicable guidelines from the Commonwealth of
20 Pennsylvania, Department of Environmental Protection Office of Water
21 Management's Erosion and Sediment Pollution Control Program Manual (Chapter
22 102).

23
24 **VII. RIGHT-OF-WAY MAINTENANCE**
25

1 **Q. Please describe the procedures that will be employed to maintain the right-**
2 **of-way free of incompatible vegetation following the completion of**
3 **construction and the commencement of operations.**

4
5 **A.** The approach that Penelec employs is the control or removal of all incompatible
6 vegetation that has the potential to interfere with the safe and efficient operation of the
7 transmission system. This is accomplished through either removal by mechanical means
8 or the application of herbicides. The goal is to promote a low growing plant community
9 of grasses, herbs, and low growing compatibles. Along the transmission corridor, where
10 the transmission conductor is a target, priority trees that are dead, dying, diseased,
11 structurally defective, leaning or significantly encroaching are identified and removed.
12 Work activities are performed under established cycles considering the inter-relations
13 between vegetation growth rates, vegetation control methods and inspection frequency.
14 These cycles have been developed based on consideration of vegetation conditions and
15 species, movement of line conductors under their rating and all rated electrical operating
16 conditions, as well as terrain, state regulatory requirements, easement restrictions and
17 environmental concerns.

18
19 **Q. Describe the general parameters under which Penelec will maintain the**
20 **project right-of-way?**

21
22 **A.** Penelec's methods used to manage and control vegetation include manual control
23 methods using hand-operated tools, mechanical control using aerial and equipment-
24 mounted saws, mowers or other devices, and various herbicide application techniques

1 such as, selective basal, stem foliage and cut stubble. Exhibit 20 provides additional
2 information on Penelec's vegetation management program.

3 Penelec will maintain the Project in accordance with best management practices
4 and the Company's Transmission Vegetation Management Program.

5 The objective of the Penelec transmission vegetation management program is to
6 ensure the continued and safe operation of transmission circuits through the
7 removal and control of all incompatible vegetation that has the potential to
8 interfere with the safe and efficient operation of the transmission system.

9 Penelec's vegetation management practices are designed to prevent vegetation
10 related outages by creating and sustaining a stable and compatible vegetated
11 community within and along the transmission corridor using integrated vegetation
12 management techniques. Penelec's overarching goal is to prevent all vegetation-
13 caused service interruptions at the lowest possible cost by removing potentially
14 threatening vegetation at the most advantageous time.

15
16

17 **Q. Will Penelec's vegetation control procedures observe specific legal or**
18 **regulatory standards?**

19

20 **A.** Yes. The vegetation management procedures described above are designed to
21 ensure that Penelec complies with all required federal, state, and local vegetation
22 management standards. For example, the North American Electric Reliability
23 Service Company ("NERC") Reliability Standard FAC-003-3 contains, the
24 following requirements among others:

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

- Standard R3 requires Penelec to have documented maintenance strategies or procedures or process or specifications it uses to prevent the encroachment of vegetation into the Minimum Vegetation Clearance Distances (MVCD) provided in FAC-003-3 Table 2.
- Standard R1 and R2 requires Penelec to manage vegetation to prevent encroachments into the MVCD. Penelec’s Transmission Vegetation Management Strategies and Procedures are designed to maintain a reliable electric transmission system by using a defense-in-depth strategy to manage vegetation located on and adjacent to transmission rights-of-way (ROW). The objective of these strategies and procedures is to ensure that vegetation with the potential to encroach into Penelec’s vegetation clearances is identified and mitigated and that vegetation clearances are achieved at the time of maintenance to prevent encroachments into the MVCD and to ensure safe and reliable operation of the electric transmission system.
- Standard R6 and R7 requires Penelec to perform and complete vegetation inspections. Maintenance inspections are scheduled annually for those corridors that are scheduled for vegetation maintenance based on their established vegetation management cycle. Aerial and/or associated ground inspections are scheduled on 100% of FirstEnergy applicable transmission

1 lines Aerial and/or ground inspections generally are performed at least once
2 per calendar year and with no more than 18 calendar months between
3 inspections on the same ROW

- 4
- 5 • Standard R7 requires Penelec to complete 100% of its annual vegetation work
6 plan of applicable lines to ensure no vegetation encroachments occur within
7 the MVCD. The purpose of creating and implementing the annual work plan
8 for vegetation management work is to ensure no vegetation encroachments
9 occur within the MVCD. The creation of the work plan involves scheduling
10 transmission corridors every year for vegetation management based on the
11 next cycle date. The work plan is flexible enough to adjust to changing
12 conditions, taking into consideration anticipated growth of vegetation, and all
13 other environmental factors that may impact the reliability of the transmission
14 system.

15
16
17 **Q. Please describe the expected right-of-way maintenance cycle for this project.**

18
19 **A.** The FirstEnergy transmission vegetation management program within the Penelec
20 service territory is currently on a five-year maintenance schedule for all
21 transmission voltages.

22
23 **Q. Does this conclude your direct testimony?**

24
25 **A.** Yes, it does. However, I would like to reserve the right to file such additional
26 testimony or exhibits as may be necessary or appropriate.