

Tori L. Giesler
(330) 315-9263
tgiesler@firstenergycorp.com

610-929-3601

January 26, 2017

RECEIVED

VIA UNITED PARCEL SERVICE

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

JAN 26 2017

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

**Re: Joint 3rd Quarter 2016 Reliability Report – Metropolitan Edison Company,
Pennsylvania Electric Company, Pennsylvania Power Company and West Penn
Power Company – Public and Proprietary Versions - ERRATA**


Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 57.195(d) and (e), enclosed for filing on behalf of Metropolitan Edison Company (“Met-Ed”), Pennsylvania Electric Company, Pennsylvania Power Company and West Penn Power Company (collectively, the “Companies”) is corrected page 6 for both the Joint 3rd Quarter 2016 Reliability Report – Public and Proprietary Versions (“Joint Reports”) which were originally filed on November 1, 2016.

While all numerical data reported in both Joint Reports was correct, it was discovered that Pennsylvania Power Company inadvertently erred in reporting six entries in the “Outage by Cause” table as “UG dig up” when, in fact, they should have been reported as “unknown” outages. The enclosed page 6 revises this information to correct for that error. Please date stamp the enclosed additional copy of this corrective letter and return it in the postage-prepaid envelope provided.

Please feel free to contact me if you have any questions or need additional information regarding this matter.

Sincerely,


Tori L. Giesler

Enclosures

- c: As Per Certificate of Service
D. Gill – Bureau of Technical Utility Services (via email and first class mail)
D. Searfoorce - Bureau of Technical Utility Services (via email and first class mail)
D. Washko – Bureau of Technical Utility Services (via email and first class mail)

Section 57.195(e)(5): A rolling 12-month breakdown and analysis of outage causes during the preceding quarter, including the number and percentage of service outages, the number of customers interrupted, and customer interruption minutes categorized by outage cause such as equipment failure, animal contact, tree related, and so forth. Proposed solutions to identified service problems shall be reported.

Outages by Cause

Outages by Cause – Penn Power

Outage by Cause				
3rd Quarter 2016 12-Month Rolling	Penn Power			
Cause	Customer Minutes	Number of Sustained Interruptions	Customers Affected	% Based on Number of Outages
Animal	1,630,438	555	16,417	17.47%
Trees off ROW - tree	5,161,177	489	27,733	15.39%
Bird	357,998	394	5,154	12.40%
Lightning	1,207,973	330	11,107	10.39%
Equipment failure	2,951,098	315	30,722	9.92%
Line failure	1,707,424	270	22,888	8.50%
Trees off ROW - limb	1,277,892	261	7,190	8.22%
Unknown	512,121	147	7,150	4.63%
Trees - sec/service	102,225	115	428	3.62%
Vehicle	1,384,895	83	12,374	2.61%
Forced outage	152,502	48	8,334	1.51%
Previous lightning	29,242	47	234	1.48%
Overload	61,210	27	1,022	0.85%
Human error - non-company	105,945	24	1,674	0.76%
UG dig-up	26,054	13	226	0.41%
Human error - company	26,335	11	427	0.35%
Trees off ROW - tree	23,236	11	145	0.35%
Ice	155,507	10	1,157	0.31%
Object contact with line	88,570	9	452	0.28%
Customer equipment	6,043	5	15	0.16%
Fire	342,018	5	1,882	0.16%
Other electric utility	24,522	3	201	0.09%
Vandalism	7,127	3	46	0.09%
Contamination	61	1	1	0.03%
Other utility - non electric	96	1	2	0.03%
Total	17,341,709	3,177	156,981	100.00%

RECEIVED

JAN 26 2017

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Joint 3rd Quarter 2016 Reliability Report – :
Metropolitan Edison Company, :
Pennsylvania Electric Company :
Pennsylvania Power Company and West :
Penn Power Company – Public and :
Proprietary Versions :**

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true and correct copy of the foregoing document upon the individuals listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

Service by first class mail, as follows:

John R. Evans
Office of Small Business Advocate
Suite 1102, Commerce Building
300 North Second Street
Harrisburg, PA 17101

Tanya McCloskey
Office of Consumer Advocate
555 Walnut Street – 5th Floor
Harrisburg, PA 17101-1923

Richard A. Kanaskie
Bureau of Investigation & Enforcement
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

Scott Rubin
Utility Workers Union of America
333 Oak Lane
Bloomsburg, PA 17815-2036

Service by electronic mail, as follows:

David Dulick, General Counsel
David.Dulick@ccsenergy.com

Rich Geosits, Manager, Power Delivery
Rich.Geosits@ccsenergy.com

Dated: January 26, 2017


Tori L. Giesler
Attorney No. 207742
FirstEnergy Service Company
2800 Pottsville Pike, P.O. Box 16001
Reading, Pennsylvania 19612-6001
(610) 921-6203
tgiesler@firstenergycorp.com

RECEIVED

JAN 26 2017

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

Counsel for Metropolitan Edison Company,
Pennsylvania Electric Company,
Pennsylvania Power Company and
West Penn Power Company



CMPC

To: CHIAVETA, R. PUC

Agency PUC

Floor:

External Carrier: UPS 1 DAY AIR

1/27/2017 9:59:00 AM



1ZAE14400157322914

1
unit
an
merical
sit
cument.
oz. or less.
light
ronic media
send cash


you.

1 000-742-5877

MAIL ROOM
(610) 921-6633
AE-1440
2800 POTTSVILLE PIKE
READING PA 19605-2459

LTR 1 OF 1

SHIP TO:
ROSEMARY CHIAVETTA, SECRETARY
PA PUBLIC UTILITY COMMISSION
2ND FLOOR
COMMONWEALTH KEYSTONE BUILDING
400 NORTH STREET
HARRISBURG PA 17120-0079



PA 171 9-20



UPS NEXT DAY AIR

TRACKING #: 1Z AE1 440 01 5732 2914

1



BILLING: P/P

REF 1:503003
REF 2:TORI GIESLER-REAP-37

US 18.0.34 LP2644 84.0A 01/2017

Apply shipping documents on this side.
Do not use this envelope for:
UPS Ground
UPS Standard
UPS 3 Day Select®
UPS Worldwide Expedited®



SEE NOTICE ON REVERSE regarding UPS Terms, and notice of limitation of liability. Where allowed by law, shipper authorizes UPS to act as forwarding agent for export control and customs purposes. If exported from the US, shipper certifies that the commodities, technology or software were exported from the US in accordance with the Export Administration Regulations. Diversion contrary to law is prohibited.

800 9 1116