


**KLH**  
**ENGINEERS, INC.**

5173 CAMPBELLS RUN ROAD  
PITTSBURGH, PA 15205

SUBJECT *MACH. ACT. 537 PROJECTS* ..... JOB NO. *220-33*  
*WHITE OAK LOW RISE 75.* ..... SHEET NO. *3* OF .....  
COMPUTED BY *K.A.H.* ..... DATE *12-20-01*



**KLH**  
**ENGINEERS, INC.**

5173 CAMPBELLS RUN ROAD  
PITTSBURGH, PA 15205

SUBJECT .....


JOB No. 220-33

.....

SHEET No. 4 OF .....

COMPUTED BY .....

DATE 12-20-07



REFER

KLH  
ENGINEERS, INC.

5173 CAMPBELLS RUN ROAD  
PITTSBURGH, PA 15205

SUBJECT LONG RUN INTERCEPTOR JOB NO. 220-27

P.S. SHEET NO.        OF       

COMPUTED BY K&H & RDH DATE 12-13-07

TOP OF INFLUENT LINE: 788.75  
INV. OF INFLUENT LINE: 776.30

LESS TO OPS. LEVEL 3'-00

773.0

Ops. Level

6

767.0

788.75

- 5.00

783.75

790

Static = ~~784~~ - 767 = 17'-0"

Static ~~20'~~  
23'

5 MGD - 3472 GPM @ 98.3 → 98.5.

2 PUMPS OPERATING - 1736 → 1740 GPM.

NEED 3 PUMPS @ 98.5 TDH @ 1740 GPM.



WOLR



Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/14/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:

Site:  
 Pump:

Model: 8417-4A  
 Type: 6000  
 Synch speed: 1200 rpm  
 Curve ID No.: 40063A  
 Specific Speeds:

Speed: 1160 rpm  
 Dia: 16.625 in  
 Impeller ID No.: Y-4012D  
 Ns: 1782  
 Nss: 5796  
 Suction: 8 in  
 Discharge: 8 in

**Search Criteria:**

Flow: 1740 US gpm

Head: 98.5 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---

Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC

Size: 75 hp  
 Speed: 1200  
 Frame: 405T

Sizing criteria: Max Power on Design Curve

**Pump Limits:**


Temperature: 150 °F  
 Pressure: 90 psi g  
 Sphere size: 4 in

Power: ---  
 Eye area: ---

--- Data Point ---  
 Flow: 1740 US gpm  
 Head: 98.5 ft  
 Eff: 77%  
 Power: 56.1 hp  
 NPSHr: 16.9 ft

--- Design Curve ---  
 Shutoff head: 136 ft  
 Shutoff dP: 58.8 psi  
 flow: ---  
 : 79% @ 2088 US gpm  
 NOL power:  
 66.9 hp @ 2573 US gpm

-- Max Curve --  
 Max power:  
 71.3 hp @ 2657 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
2088	1160	89.9	79	60.3	19.5
1740	1160	98.5	77	56.1	16.9
1392	1160	106	70	53	14.6
1044	1160	113	57	51.9	12.7
696	1160	120	43	50.2	10.8

Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/14/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 6153  
 Type: 9100  
 Synch speed: 1800 rpm  
 Curve ID No.: 3603  
 Specific Speeds:

Speed: 1750 rpm  
 Dia: 12.875 in  
 Impeller ID No.: Y-4739  
 Ns: ---  
 Nss: ---  
 Suction: ---  
 Discharge: 6 in

**Search Criteria:**

Flow: 1740 US gpm

Head: 98.5 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---

Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: YCC  
 Enclosure: TENV

Size: 75 hp  
 Speed: 1800  
 Frame: 320

Sizing criteria: Max Power on Design Curve

**Pump Limits:**

Temperature: 104 °F  
 Pressure: 150 psi g  
 Sphere size: 3 in

Power: ---  
 Eye area: ---

**--- Data Point ---**


Flow: 1740 US gpm  
 Head: 101 ft  
 Eff: 70.8%  
 Power: 62 hp  
 NPSHr: ---

**--- Design Curve ---**

Shutoff head: 177 ft  
 Shutoff dP: 76.5 psi  
 flow: ---  
 : 71.4% @ 1626 US gpm  
 NOL power:  
 62.3 hp @ 1894 US gpm

**--- Max Curve ---**

Max power:  
 103 hp @ 2395 US gpm



FOR TEMP. ABOVE 104 DEG. F (40 DEG C) REFER TO FACTORY FOR ASSISTANCE.

**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
2088	1750	78.4	66.1	62.2	---
1740	1750	101	70.8	62	---
1392	1750	120	70.4	59.4	---
1044	1750	136	66	54	---
696	1750	150	57.9	46.4	---

Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/14/2007



*VERT. SHUTT*

**Pump:**

Size: 6"5413  
 Type: 5400-NONCLOG  
 Synch speed: 1800 rpm  
 Curve: 130604C  
 Specific Speeds:  
 Dimensions:  
 Speed: 1780 rpm  
 Dia: 11.625 in  
 Impeller: T8C1C  
 Ns: 2614  
 Nss: 7567  
 Suction: 6 in  
 Discharge: 6 in

**Search Criteria:**

Flow: 1740 US gpm  
 Head: 98.5 ft  
 Fluid:  
 Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC  
 Sizing criteria: Max Power on Design Curve  
 Size: 75 hp  
 Speed: 1800  
 Frame: 365T

**Pump Limits:**

Temperature: 150 °F  
 Pressure: 85 psi g  
 Sphere size: 3 in  
 Power: ---  
 Eye area: ---

--- Data Point ---


Flow: 1740 US gpm  
 Head: 99 ft  
 Eff: 80%  
 Power: 54 hp  
 NPSHr: 22.2 ft

--- Design Curve ---

Shutoff head: 146 ft  
 Shutoff dP: 63.3 psi  
 Design flow: 500 US gpm  
 Efficiency: 81% @ 2029 US gpm  
 NOL power:  
 64.4 hp @ 3232 US gpm

--- Max Curve ---

Max power:  
 73.3 hp @ 3406 US gpm



Curve efficiencies are typical. For guaranteed values, contact Fairbanks Morse or your local distributor. Las eficiencias en curvas son típicas. Para valores garantizados contacte a Fairbanks Morse o a su distribuidor local.

**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
2088	1780	89.5	81	57.9	25
1740	1780	99	80	54	22.2
1392	1780	108	77	49.2	20.4
1044	1780	117	70	44.1	20
696	1780	126	56	39.5	20

Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/14/2007



**SUBMERSIBLE**

**Pump:**

Size: 6"5433M&W  
 Type: 5430-SOLIDS HANDLING  
 Synch speed: 1800 rpm  
 Curve: 330604C  
 Specific Speeds:  
 Dimensions:  
 Speed: 1770 rpm  
 Dia: 11.6875 in  
 Impeller: T6C1C  
 Ns: 2604  
 Nss: 7480  
 Suction: 8 in  
 Discharge: 6 in

**Search Criteria:**

Flow: 1740 US gpm Head: 98.5 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: --  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Consult Fairbanks Morse Pump, 60 Hz to select a motor for this pump.

**Pump Limits:**

Temperature: 104 °F  
 Pressure: 85 psi g  
 Sphere size: 3 in  
 Power: --  
 Eye area: --

--- Data Point ---


Flow: 1740 US gpm  
 Head: 99.5 ft  
 Eff: 80%  
 Power: 54.3 hp  
 NPSHr: 22.6 ft

--- Design Curve ---

Shutoff head: 146 ft  
 Shutoff dP: 63 psi  
 flow: 500 US gpm  
 η: 82% @ 2042 US gpm  
 NOL power:  
 64.7 hp @ 3080 US gpm

--- Max Curve ---

Max power:  
 71.9 hp @ 3200 US gpm



Curve efficiencies are typical. For guaranteed values, contact Fairbanks Morse or your local distributor. Las eficiencias en curvas son típicas. Para valores garantizados contacte a Fairbanks Morse o a su distribuidor local.

**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
2088	1770	90.1	81	58.3	25.3
1740	1770	99.5	80	54.3	22.6
1392	1770	108	77	49.4	20.8
1044	1770	117	70	44.3	20
696	1770	126	56	39.8	20



**Kevin Hoffman**

---

**From:** Mark Robinson [mrobinson@daman-superiorllc.net]  
**Sent:** Tuesday, December 18, 2007 2:00 PM  
**To:** Kevin Hoffman  
**Subject:** MACM

Kevin,

Various Yeomans selections for White Oak Long Run P.S.

Series 9235 dry-pit submersible M/N 6173SC with 100 hp motor.....\$26,968.00 (wt. 3,047#)  
Options; SS casing or impeller wear rings.....\$575.00 each  
Non-witnessed performance test.....\$1,118.00

Series 9100 submersible M/N 6173 with 100 hp motor.....\$20,339.00 (wt. 2197#)  
Options; SS casing or impeller wear rings.....\$460.00  
Non-witnessed performance test.....\$1,143.00

**This submersible pump is designed for Class 1 Group C&D (FM labeled.)**

4X4 EL rail system; base elbow, sealing flange assy., top guide bracket & intermediate guide bracket....\$1,010.00 (wt. 180#) **2" Rails not included.**

Series 6000 dry-pit vertical shaft M/N 6317SC-4A with 100 hp motor.....\$25,350.00 (wt. 2,980#)  
Options; mechanical seal.....\$1,019.00  
SS casing or impeller wear rings.....\$575.00  
Non-witnessed performance test.....\$1,131.00

Same pump but with Explosion Proof motor.....\$27,273.00 (wt. 3,588#)

16 FT of shafting with hardware for vertical dry-pit.....\$4,000.00

Please call should you need additional information or have any questions.

Merry Christmas to you and your family,  
Mark

No virus found in this outgoing message.

Checked by AVG Free Edition.

Version: 7.5.503 / Virus Database: 269.17.4/1188 - Release Date: 12/17/2007 2:13 PM

12/18/2007

 Live Search Maps



**MACM: West Shore Pump Station  
Side-by-Side Pump Comparison**

**Required Duty Point** 11,810 gpm at 96.5 feet TDH  
**Required Duty Point per Pump** 3,950 gpm at 97.5 feet TDH

Manufacturer (Model)	Flygt	Wilo - EMU	Yeomans Chicago	Yeomans Chicago
Type of Pump	Dry Pit Submersible	Dry Pit Submersible	Dry Pit Submersible	Verticle Shaft
Number of Pumps	4 Total -3 Operating	3 Total - 2 Operating	3 Total - 2 Operating	3 Total - 2 Operating
Model	NT 3306/705	FA 30.93D	No Option Avaialble	10522-6/5
Mfr. Curve No.	63-670		No Option Avaialble	3596
Impeller Type	N- Series	GGG50	No Option Avaialble	Y-4696
No. of Impeller Vanes	3	3	No Option Avaialble	????
Impeller Diameter, in. (mm)	16.9 (430)	16.7	No Option Avaialble	18
Max. Impeller Dia. in. (mm)	16.9 (430)	17.8	No Option Avaialble	22
Percentage of Max Impeller	100.0%	93.8%	No Option Avaialble	81.8%
Nearest Duty Point	3,999 gpm at 98.2 feet TDH	3,950 gpm at 96.5 feet TDH	No Option Avaialble	3,950 gpm at 98.2 feet TDH
Best Efficiency Point	5,575 gpm at 82.9 feet TDH	5,100 gpm at 81 feet TDH	No Option Avaialble	4,150 gpm at 97 feet TDH
Rated Horsepower <sup>2</sup>	150 HP	134 HP	No Option Avaialble	128 HP
Motor Horspower	150 HP	150 HP	>125 HP	150 HP
Pump Speed <sup>2</sup>	1185 rpm	1151 rpm	No Option Avaialble	1200 rpm
Pump Efficiency <sup>2</sup>	67.1%	80.3%	No Option Avaialble	77.0%
NPSHr	15.9	18.5	No Option Avaialble	16.5
Power Requirement	460 Volt, 3 Phase, 60 Hz	460 Volt, 3 Phase, 60 Hz	No Option Avaialble	460 Volt, 3 Phase, 60 Hz
Solids Capability	????	????	No Option Avaialble	5" diameter
Suction	14" diameter	12" diameter	No Option Avaialble	10" diameter
Discharge	12" diameter	12" diameter	No Option Avaialble	10" diameter
Front to Back Dimension (in)	41.375	42.5	No Option Avaialble	41
Base Width (in)	39	27.5625	No Option Avaialble	38
Height - Suction CL to Top (in)	93	82.6875	No Option Avaialble	66.1875
Weight, lb.	3530	2645.5	No Option Avaialble	3590
Estimate Budget Price <sup>3</sup>	\$62,383	\$48,740	No Option Avaialble	\$41,379

1. All series data is total for the pumping system as one entity.
2. At duty point.
3. From manufacturer representative quotes.

*Overall Selection:  
YEOMANS VERT SHAFT.  
DRY PIT SUB SELECTION  
WILCO EMU.*

PUMP SELECTION CALCULATION

Client / Job MACCM: West Shore Pump Station

Pipe Diameter	24 in		24 in		24 in
Length of Pipe	100 ft	Low	100 ft	High	100 ft
Friction Factor "C"	130		100		100
Pump Suction El.	715 ft		Pump Suction	725 ft	High
Pump Discharge El.	755 ft		Pump Discharge	755 ft	
Static Head	40 ft		Static Head	30 ft	
Flow Rate Incrementer	500 GPM				
Design Pump rate	17 MGD				
Design Pump rate	11806 GPM				
Velocity	8.37 ft/sec				
V <sup>2</sup> /2g	1.09 ft				
Friction Headloss	48.14 ft				
TDH Required	88.14 ft				

Flow Rate GPM	24			24			20			24			Total Dynamic Headloss
	Velocity ft/sec	V <sup>2</sup> / 2g ft	Friction Headloss ft	Velocity ft/sec	V <sup>2</sup> / 2g ft	Friction Headloss ft	Velocity ft/sec	V <sup>2</sup> / 2g ft	Friction Headloss ft	Velocity ft/sec	V <sup>2</sup> / 2g ft	Friction Headloss ft	
0	0	0	0	0	0	0	0	0	0	0	0	0	40.00
500	0.35	0.00	0.138745248	0.35	0.00	0.003948001	0.51	0.00	0.01917183	0.35	0.00	0	40.16
1000	0.71	0.01	0.500176875	0.71	0.01	0.014232549	1.02	0.02	0.069114481	0.71	0.01	0	40.58
1500	1.06	0.02	1.058991411	1.06	0.02	0.030133636	1.53	0.04	0.146331519	1.06	0.02	0	41.24
2000	1.42	0.03	1.803138559	1.42	0.03	0.051308367	2.04	0.06	0.249157831	1.42	0.03	0	42.10
2500	1.77	0.05	2.724661936	1.77	0.05	0.077530345	2.55	0.10	0.376494006	1.77	0.05	0	43.18
3000	2.13	0.07	3.817665997	2.13	0.07	0.108631812	3.06	0.15	0.527525395	2.13	0.07	0	44.45
3500	2.48	0.10	5.077494839	2.48	0.10	0.144480283	3.57	0.20	0.701608646	2.48	0.10	0	45.92
4000	2.84	0.12	6.500317841	2.84	0.12	0.184966759	4.08	0.26	0.898214444	2.84	0.12	0	47.58
4500	3.19	0.16	8.082891685	3.19	0.16	0.22999895	4.60	0.33	1.116894625	3.19	0.16	0	49.43
5000	3.55	0.20	9.822411322	3.55	0.20	0.279497038	5.11	0.40	1.357261589	3.55	0.20	0	51.46
5500	3.90	0.24	11.71641063	3.90	0.24	0.333390851	5.62	0.49	1.618974566	3.90	0.24	0	53.67
6000	4.26	0.28	13.76269298	4.26	0.28	0.391617883	6.13	0.58	1.901730026	4.26	0.28	0	56.06
6500	4.61	0.33	15.95928088	4.61	0.33	0.454121864	6.64	0.68	2.20525472	4.61	0.33	0	58.62
7000	4.96	0.38	18.30437829	4.96	0.38	0.520851688	7.15	0.79	2.529300468	4.96	0.38	0	61.35
7500	5.32	0.44	20.79634176	5.32	0.44	0.591760591	7.66	0.91	2.873640182	5.32	0.44	0	64.26
8000	5.67	0.50	23.43365785	5.67	0.50	0.666805507	8.17	1.04	3.238064731	5.67	0.50	0	67.34
8500	6.03	0.56	26.2149251	6.03	0.56	0.745946559	8.68	1.17	3.622380464	6.03	0.56	0	70.58
9000	6.38	0.63	29.13883948	6.38	0.63	0.829146639	9.19	1.31	4.02640719	6.38	0.63	0	73.99
9500	6.74	0.70	32.20418245	6.74	0.70	0.916371074	9.70	1.46	4.449976528	6.74	0.70	0	77.57
10000	7.09	0.78	35.40981099	7.09	0.78	1.00758734	10.21	1.62	4.892930538	7.09	0.78	0	81.31
10500	7.45	0.86	38.75464936	7.45	0.86	1.102764826	10.72	1.79	5.355120574	7.45	0.86	0	85.21
11000	7.80	0.94	42.237682	7.80	0.94	1.201874635	11.23	1.96	5.836406305	7.80	0.94	0	89.28
11500	8.16	1.03	45.85794755	8.16	1.03	1.304889411	11.74	2.14	6.336654891	8.16	1.03	0	93.50
11810	8.38	1.09	48.17102852	8.38	1.09	1.370708206	12.06	2.26	6.656276605	8.38	1.09	0	96.20
12000	8.51	1.12	49.61453367	8.51	1.12	1.411783193	12.25	2.33	6.855740265	8.51	1.12	0	97.88
12500	8.86	1.22	53.50657258	8.86	1.22	1.522531288	12.77	2.53	7.393542514	8.86	1.22	0	102.42
13000	9.22	1.32	57.53323712	9.22	1.32	1.63711016	13.28	2.74	7.949947345	9.22	1.32	0	107.12
13500	9.57	1.42	61.69373737	9.57	1.42	1.755497332	13.79	2.95	8.524845605	9.57	1.42	0	111.97
14000	9.93	1.53	65.98731761	9.93	1.53	1.8776713	14.30	3.17	9.118132869	9.93	1.53	0	116.98
14500	10.28	1.64	70.41325367	10.28	1.64	2.003611456	14.81	3.40	9.729709071	10.28	1.64	0	122.15
15000	10.64	1.76	74.97085053	10.64	1.76	2.133298025	15.32	3.64	10.35947817	10.64	1.76	0	127.46
15500	10.99	1.88	79.65944022	10.99	1.88	2.266712	15.83	3.89	11.00734787	10.99	1.88	0	132.93
16000	11.35	2.00	84.4783799	11.35	2.00	2.403835087	16.34	4.15	11.67322935	11.35	2.00	0	138.56
16500	11.70	2.13	89.42705017	11.70	2.13	2.544649663	16.85	4.41	12.357037	11.70	2.13	0	144.33
17000	12.06	2.26	94.50485349	12.06	2.26	2.689138724	17.36	4.68	13.05868828	12.06	2.26	0	150.25
17500	12.41	2.39	99.7112128	12.41	2.39	2.83728585	17.87	4.96	13.77810343	12.41	2.39	0	156.33
18000	12.77	2.53	105.0455703	12.77	2.53	2.989075168	18.38	5.25	14.51520537	12.77	2.53	0	162.55
18500	13.12	2.67	110.507386	13.12	2.67	3.144491316	18.89	5.54	15.26991951	13.12	2.67	0	168.92
19000	13.47	2.82	116.0961373	13.47	2.82	3.303519418	19.40	5.85	16.04217362	13.47	2.82	0	175.44
19500	13.83	2.97	121.8113172	13.83	2.97	3.466145051	19.91	6.16	16.83189764	13.83	2.97	0	182.11
20000	14.18	3.12	127.6524341	14.18	3.12	3.632354225	20.42	6.48	17.63902365	14.18	3.12	0	188.92
20500	14.54	3.28	133.6190106	14.54	3.28	3.802133355	20.94	6.81	18.46348566	14.54	3.28	0	195.88
21000	14.89	3.44	139.7105827	14.89	3.44	3.975466239	21.45	7.14	19.30521958	14.89	3.44	0	202.99
21500	15.25	3.61	145.9266993	15.25	3.61	4.152349044	21.96	7.49	20.16416308	15.25	3.61	0	210.24
22000	15.60	3.78	152.2669218	15.60	3.78	4.332780283	22.47	7.84	21.04025553	15.60	3.78	0	217.64
22500	15.96	3.95	158.7308227	15.96	3.95	4.516690796	22.98	8.20	21.93343788	15.96	3.95	0	225.18
23000	16.31	4.13	165.3179858	16.31	4.13	4.70412874	23.49	8.57	22.84365261	16.31	4.13	0	232.87
23500	16.67	4.31	172.0280054	16.67	4.31	4.895062569	24.00	8.94	23.77084366	16.67	4.31	0	240.69
24000	17.02	4.50	178.8604857	17.02	4.50	5.089481022	24.51	9.33	24.71495634	17.02	4.50	0	248.66
24500	17.38	4.69	185.8150406	17.38	4.69	5.287373112	25.02	9.72	25.6759373	17.38	4.69	0	256.78
25000	17.73	4.88	192.89129932	17.73	4.88	5.488728111	25.53	10.12	26.65373445	17.73	4.88	0	265.03
25500	18.08	5.08	200.088875	18.08	5.08	5.693353554	26.04	10.53	27.64829688	18.08	5.08	0	273.43
26000	18.44	5.28	207.4074263	18.44	5.28	5.901785158	26.55	10.95	28.65957489	18.44	5.28	0	281.97
26500	18.79	5.48	214.8465951	18.79	5.48	6.113466953	27.06	11.37	29.68751984	18.79	5.48	0	290.65
27000	19.15	5.69	222.4060374	19.15	5.69	6.328571131	27.57	11.81	30.73208418	19.15	5.69	0	299.47

Peak Instantaneous Flow 17 MGD 11805.6 gpm

Assume Maximum Detention Time in Wetwell 1 min

Q 11805.56  
t 2  
V 5902.778 gallons  
788.614 ft<sup>3</sup>

Effective Volume of Wet Well 11805.6 gallons  
Effective Volume of Wet Well 1577.23 ft<sup>3</sup>  
Number of Sections in Wetwell 2  
Effective Volume per Section 5902.78 gallons  
Effective Volume per Section 788.614 ft<sup>3</sup>

Check Detention times at other flows

	Q MGD	Q gpm	t(d) minutes
Low Flow	3.7	2569	2.297
Proposed Average Daily	10.037	6970	0.847

Dimensioning for Total and Effective Volume  
Enter Information in shaded areas


Client MACM  
Job West Shore Pump Station

Effective Volume Goal 788.6143 ft<sup>3</sup>

Slope 1 2

Base Dim	Depth ft	Frt to Bck Wall ft	Wall to Wall ft	Eff. Vol. ft <sup>3</sup>	Total Vol ft <sup>3</sup>	Elevation
	0	8.00	14.00	Submerge	0.00	719.5
	1	8.00	14.00	Submerge	67.00	720.5
	2	8.00	14.00	Submerge	134.00	721.5
	3	8.00	14.00	Submerge	201.00	722.5
0.5	3.5	8.50	15.00	Submerge	261.63	723
1	4	9.00	16.00	Submerge	332.00	723.5
1.17	4.17	9.17	16.34	Submerge	358.28	723.67
1.5	4.5	10.50	18.00		194.22 474.75	724
2	5	13.00	18.00		311.22 640.00	724.5
2.5	5.5	13.00	18.00		428.22 704.00	725
3	6	13.00	18.00		545.22 768.00	725.5
3.5	6.5	13.00	18.00		662.22 832.00	726
4	7	13.00	18.00		779.22 896.00	726.5
4.5	7.5	13.00	18.00		896.22 960.00	
3.83	8	13.00	18.00		1013.22 1024.00	
4.33	8.5	13.00	18.00		1130.22 1088.00	
4.83	9	13.00	18.00		1247.22 1152.00	
5.33	9.5	13.00	18.00		1364.22 1216.00	
5.83	10	13.00	18.00		2202.46 1280.00	
6.33	10.5	19.33	18.00		2437.9 1942.19	
6.83	11	19.83	18.00		3517.52 2084.17	
7.33	11.5	26.66	18.00		3898.4 2885.81	
7.83	12	27.66	18.00		5246.401 3119.28	
8.33	12.5	34.99	18.00		5799.721 4073.88	
8.83	13	36.49	18.00		7443.101 4412.33	
9.33	13.5	44.32	18.00		8195.861 5533.38	
9.83	14	46.32	18.00		4206.06 5990.32	

Pipe Diameter	Pipe Length	Inlet	Valves	Check Valve	90	45	Side of Tee	Run of Tee	Increaser	Outlet	Equivalent Length
2											0
4											0
6											0
8											0
10											0
12											0
14											0
16											0
18											0
20	30		1	1							176
22											0
24	5505				3.25						5709.75
30											0
36											0
42											0
48											0






February 4, 2008

**City of Mckeesport  
West Shore Pump Station**

Duperon Corporation Budgetary Proposal No. 4156



EQUIPMENT SUMMARY	
Model	Full Penetration, Fine Screen Model
1. Nominal Size	5 ft x 16 ft
2. Unit Length	15 ft
3. Dist. Between Scrapers	2 Link (21 in)
4. Bar Clear Opening	0.50 in
5. Bar Thickness	0.25 in
6. Bar Depth	0.75 in
7. Bar Screen Length	Approx. 5.75 ft
8. Container Height	Estimated 4 ft
9. Max. Flow Rate	17 MGD
10. Intake Channel Height	5 ft
11. Intake Channel Width	5 ft
12. Intake Channel Depth	TBD
13. Max. Liquid Level	TBD
14. Angle (From Vertical)	30 Degrees
15. Ceiling Height	Unknown
Drive Side (L/R)	Unknown
Material of Construction	304 SSSL

ACCESSORIES	
Channel Closeouts	YES
Enclosure/Cover	OPTIONAL
Debris Chute	NO
Controls Package	Range

SCREENINGS	
Gravity Feed or Pumped?	Unknown
Typical Debris?	Unknown





February 4, 2008

**City of McKeesport  
West Shore Pump Station  
Duperon Corporation Proposal No. 4156**

FLOW CALCULATIONS												
MAX. FLOW 17 MGD per channel	Slot (In)	Bar (In)	Intake Width (ft)	Req'd. Liquid Level (ft)	Approach Velocity (fps)	Slot Velocity (fps)	Head Loss		@ 25% Blockage		@ 50% Blockage	
							(ft)	(In)	(ft)	(In)	(ft)	(In)
		0.50	0.25	5.00	3.50	1.67	2.96	0.14	1.66	0.28	3.40	0.71

**NOTE:** These calculations are a rough estimation based upon the information available at this time in order to maintain approximately a 3 fps slot velocity for peak flow. Flow characteristics calculated for clean water and not derated for debris.

**NOTE:** Duperon strongly recommends a minimum of 1 ft water depth at all times the unit is in operation to get an optimal amount of screening area.

Company: K LH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 11/7/2007

Customer: **MACM**  
 Project: **WEST SHORE**  
 Location: **VERTICAL SHAFT**  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 10522-6 / 5  
 Type: 6000  
 Synch speed: 1200 rpm  
 Curve ID No.: 3596  
 Specific Speeds:  
 Dimensions:  
 Speed: 1160 rpm  
 Dia: 18 in  
 Impeller ID No.: Y-4696  
 Ns: 1817  
 Nss: 8097  
 Suction: 10 in  
 Discharge: 10 in

**Search Criteria:**

Flow: 3950 US gpm  
 Head: 96.5 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a


**Motor:**

Standard: NEMA  
 Enclosure: TEFC  
 Sizing criteria: Max Power on Design Curve  
 Size: 150 hp  
 Speed: 1200  
 Frame: 447T

**Pump Limits:**

Temperature: 150 °F  
 Pressure: 105 psi g  
 Sphere size: 5 in  
 Power: ---  
 Eye area: ---

--- Data Point ---	
Flow:	3950 US gpm
Head:	98.2 ft
Eff:	77%
Power:	128 hp
NPSHr:	16.5 ft
--- Design Curve ---	
Shutoff head:	154 ft
Shutoff dP:	66.6 psi
n flow:	---
:	77% @ 4072 US gpm
NOL power:	140 hp @ 5282 US gpm
--- Max Curve ---	
Max power:	316 hp @ 7456 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
4740	1160	84.6	74	135	20.3
3950	1160	98.2	77	128	16.5
3160	1160	110	73	119	13.1
2370	1160	120	67	108	9.88
1580	1160	131	58	91.6	6.88

Company: K LH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 11/7/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 10522-6 / 5  
 Type: 6000  
 Synch speed: 1200 rpm  
 Curve ID No.: 3596  
 Specific Speeds:  
 Dimensions:  
 Speed: 1160 rpm  
 Dia: 18 in  
 Impeller ID No.: Y-4696  
 Ns: 1817  
 Nss: 8097  
 Suction: 10 in  
 Discharge: 10 in

**Search Criteria:**

Flow: 3950 US gpm  
 Head: 96.5 ft  
 Fluid:  
 Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC  
 Sizing criteria: Max Power on Design Curve  
 Size: 150 hp  
 Speed: 1200  
 Frame: 447T

**Pump Limits:**

Temperature: 150 °F  
 Pressure: 105 psi g  
 Sphere size: 5 in  
 Power: ---  
 Eye area: ---

--- Data Point ---


Flow: 3950 US gpm  
 Head: 98.2 ft  
 Eff: 77%  
 Power: 128 hp  
 NPSHr: 16.5 ft

--- Design Curve ---

Shutoff head: 154 ft  
 Shutoff dP: 66.6 psi  
 in flow: ---  
 : 77% @ 4072 US gpm  
 NOL power:  
 140 hp @ 5282 US gpm

--- Max Curve ---


Max power:  
 316 hp @ 7456 US gpm



Use Bearing Frame #5 W/ Impeller Dia. Under 20"


**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
4740	1160	84.6	74	135	20.3
3950	1160	98.2	77	128	16.5
3160	1160	110	73	119	13.1
2370	1160	120	67	108	9.88
1580	1160	131	58	91.6	6.88




RELATIVE POSITION OF  
SUCTION AND DISCHARGE  
(AS VIEWED FROM THE MOTOR END)


LEFT HAND ROTATION



RIGHT HAND ROTATION



NOTE: DISCHARGE IN POSITION NO.1  
FURNISHED AS STANDARD.  
OTHER POSITIONS AVAILABLE  
FROM FACTORY WHEN SPECIFIED.



NOTES: 1. ALL DIMENSIONS ARE IN INCHES.  
2. WEIGHT IS IN POUNDS.

OUTLINE DWG # 102900

S.O. \_\_\_\_\_

JOB: \_\_\_\_\_

ISSUE	REVISION	DATE

LIST OF EQUIPMENT FURNISHED:

Model \_\_\_\_\_ Pump  
 Rated for \_\_\_\_\_ GPM at \_\_\_\_\_ Ft.DH.  
 \_\_\_\_\_ HP, \_\_\_\_\_ RPM, \_\_\_\_\_ Volts  
 \_\_\_\_\_ Phase, \_\_\_\_\_ Hz Vertical C-Face  
 Motor in \_\_\_\_\_ NEMA  
 enclosure complete with pedestal

ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_  
 ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_

- OPTIONAL ACCESSORIES:
- Anchor Bolts
  - Mechanical Seal
  - Bronze or S.S. Impeller
  - Bronze or S.S. Wear Rings
  - 416 S.S. Pump Shaft
  - Safety Guard

**TABLE OF DIMENSIONS**

✓	PUMP MODEL	DIS	SLC	A	E	G	K	X	Z	CP	U	KEY	V	VD	VS	VY	WEIGHT
	4317-4A/4BHT	4	8	30	13 3/4	5/8		13	10 3/4	61 7/8				27	13 3/4	14	1175
	4317-4A/4BHT	4	8	30	13 3/4	5/8		13	10 3/4	61 7/8				27	13 3/4	14	1175
	6315-4A/4BHT	6	8	24	10 3/4	1/2		16	11	60				26	16 7/8	14	1160
	6315-4A/4BHT	6	8	24	10 3/4	1/2		16	11	60				26	16 7/8	14	1160
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 3/4	62 1/4				28 3/8	17 3/4	15	1325
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 3/4	62 1/4				28 3/8	17 3/4	15	1325
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 3/4	62 1/4				28 3/8	17 3/4	15	1325
	8317-4A/4BHT	8	10	30	13 3/4	5/8	1/2	17	11 3/4	62 1/4	2 3/8	3/4 x 3/8 x 3	4 1/4	28 3/8	18 1/2	16	1325
	8417-4A	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8417-4A	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8515-4A	8	8	30	13 3/4	5/8		16 1/2	11 3/8	63 1/8				28 3/8	18	15	1420
	8515-4A	8	8	30	13 3/4	5/8		16 1/2	11 3/8	63 1/8				28 3/8	18	15	1420
	8518-4A/4B	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8518-4A/4B	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	10522-4B	10	10	38	16 1/2	1		22	17	75 3/8				39 1/4	21 1/4	18	3500
	10522-4B	10	10	38	16 1/2	1		22	17	75 3/8				39 1/4	21 1/4	18	3500
	10522-5/6	10	12	38	16 1/2	1		22	17	84	2 7/8	1/2 x 3/8 x 5	6 1/2	39 1/4	21 1/4	18	3590
	10522-5/6	10	12	38	16 1/2	1		22	17	84	2 7/8	1/2 x 3/8 x 5	6 1/2	39 1/4	21 1/4	18	3590
	12515-4A	12	12	38	16 1/2	1		15 1/2	12	69				33 1/4	22	20	1760
	12622-4B	12	12	38	16 1/2	1		24	18	76 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	40 3/8	25 1/4	20	4500
	12622-4B	12	12	38	16 1/2	1		24	18	76 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	40 3/8	25 1/4	20	4500
	12622-5/6	12	14	38	16 1/2	1		24	18	84 3/4	2 7/8	3/4 x 3/8 x 5	6 1/2	40 3/8	25 1/4	20	4600
	12622-5/6	12	14	38	16 1/2	1		24	18	84 3/4	2 7/8	3/4 x 3/8 x 5	6 1/2	40 3/8	25 1/4	20	4600
	12624-4B	12	12	38	16 1/2	1		24	18	76 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	40 3/8	25 1/4	20	4520
	12624-4B	12	12	38	16 1/2	1		24	18	76 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	40 3/8	25 1/4	20	4520
	12624-5/6	12	12	38	16 1/2	1	3/4	24	18	84 3/4	2 7/8	1/2 x 3/8 x 5	6 1/2	40 3/8	25 1/4	20	4620
	12624-5/6	12	12	38	16 1/2	1	3/4	24	18	84 3/4	2 7/8	1/2 x 3/8 x 5	6 1/2	40 3/8	25 1/4	20	4620
	14518-4B/4BHT	14	14	38	16 1/2	1		20	18	74	2 3/8	1/2 x 3/8 x 3	4 1/4	38 3/8	24 3/8	22	4600
	14518-4B/4BHT	14	14	38	16 1/2	1		20	18	74	2 3/8	1/2 x 3/8 x 3	4 1/4	38 3/8	24 3/8	22	4600
	14620-4B	14	14	38	16 1/2	1		20	18	77 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	41 3/8	26 1/8	22	4800
	14620-5	14	14	38	16 1/2	1		20	18	86 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	41 3/8	26 1/8	22	4800
	14620-4B	14	14	38	16 1/2	1		20	18	77 1/2	2 3/8	1/2 x 3/8 x 3	4 1/4	41 3/8	26 1/8	22	4820
	14620-5	14	14	38	16 1/2	1		20	18	86 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	41 3/8	26 1/8	22	4820
	16622-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	52 1/4	32 1/4	16 1/2	4900
	16622-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	52 1/4	32 1/4	16 1/2	4930
	18530-6B/6BHT	18	20	48	20	1 1/2		27	22	98 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	53 1/4	36 1/4	18	5600
	18624-5B/6B	18	20	43 1/2	20	1		27	19 1/2	97 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	52 1/4	32 1/4	16 1/2	4950
	18622-5B	18	18	43 1/2	20	1		22	19 1/2	100 1/2	2 3/8	1/2 x 3/8 x 5	6 1/2	54 1/4	33 1/4	16 1/2	4920
	20724-6B	20	20	43 1/2	20	1		22	24	98	2 3/8	1/2 x 3/8 x 5	6 1/2	52 1/4	42 1/4	18	5700



**SERIES 6250**

**VERTICAL LINE-SHAFT  
SOLIDS-HANDLING PUMPS**






TABLE OF DIMENSIONS

SHAFT SERIES	C	B	W	F	M	VV
27-31, 37	1 1/2	6 1/4	1	2 1/2	1 1/2	5
41	1 7/8	6 3/4	1 1/4	2 1/2	1 1/2	5 1/2
48	2 1/8	7 3/4	2 1/8	3	1 1/2	6 1/8
55-61	2 1/4	8 1/4	2 1/4	3 1/8	5/8	7
71	2 1/2	8 7/8	2 3/8	3 3/8	5/8	7 3/4
81	2 3/4	9 5/8	2 1/2	3 5/8	5/8	7 3/4
88	3 1/2	12	3 1/2	4 1/2	7/8	8
91	4	14	3 3/8	5 7/16	7/8	9

NOTES:  
 1) ALL DIMENSIONS ARE IN INCHES.  
 2) ALTERNATIVE SHAFT SERIES OR TYPES MAY BE REQUIRED DEPENDING ON THE SPECIFIC PUMP MODEL, OPERATING SPEED RANGE AND OTHER FACTORS. PLEASE REFER TO FACTORY FOR SELECTION, SIZING AND DESIGN ASSISTANCE



OUTLINE DWG # 109150

S.O. \_\_\_\_\_

JOB: \_\_\_\_\_

ISSUE	REVISION	DATE

LIST OF EQUIPMENT FURNISHED:

ITEM  STANDARD  SPECIAL TUBE

QTY: \_\_\_\_\_




SHAFTING CONSISTING OF:  
 1 SECTION "A" SHAFTING WITH SPLINED END  
 \_\_\_\_\_ SECTION "B" SHAFTING EACH WITH ONE (1) INTERMEDIATE BEARING

\_\_\_\_ HR. \_\_\_\_ RPM. \_\_\_\_ VOLTS. \_\_\_\_ PHASE. \_\_\_\_ HZ.

VERTICAL, C-FACE MOTOR IN \_\_\_\_\_

NEMA ENCLOSURE COMPLETE WITH PEDESTAL AND COUPLING.

OPTIONAL:  
 SAFETY GUARD



**Kevin Hoffman**

---

**From:** Mark Robinson [mrobinson@daman-superiorllc.net]  
**Sent:** Wednesday, November 14, 2007 4:01 PM  
**To:** Kevin Hoffman  
**Subject:** SPAM -MACM  
**Attachments:** mck3.pdf

Kevin,  
Pricing for the Vertical Shafted Yeomans pumps and a drawing & curve for the 10522 pump.

West Shore: 10522-6/5 with 150 hp, 1200 rpm, 460/3/60, TEFC motor.....\$33,649.00 (wt. 5075#)  
    Same but with Explosion Proof motor.....\$35,037.00 (wt. 5910#)

Adder Options: Mechanical Seal.....\$1,159.00  
                  SS Impeller or Case wear ring.....\$694.00 Each  
                  Non-Witnessed Performance Test..... \$1,877.00

Long Run: 6317LC-4BHT with 200 hp, 1800 rpm, 460/3/60, TEFC motor.....\$29,196.00 (wt. 2840#)  
    Same but with Explosion Proof motor.....\$30,048.00 (wt. 3575#)

Adder Options: Same as above.

Note: Adder for flexible shafting for all four pump stations (I assumed a 16 ft. length) and per each pump, including shafting, safety shields and hardware.....\$4,000.00 per pump.

Please contact me should you have any questions or require additional information.

Best regards,  
Mark

No virus found in this outgoing message.  
Checked by AVG Free Edition.  
Version: 7.5.503 / Virus Database: 269.15.31/1130 - Release Date: 11/14/2007 9:27 AM

Selection list: ---  
 Selection Criteria:  
 Flow: 3950 US gpm  
 Head: 96.5 ft  
 Tolerance: --- % of head

Catalog: 6000 Dry Pit Solids Handling 60Hz vers 2  
 Pump: 10522-6 / 5  
 Type: 6000  
 Synch speed: 1200 rpm  
 Speed: 1160 rpm  
 Dia: 18 in  
 Curve no.: 3596

Fluid: Water  
 Temperature: 60 °F  
 SG: 1  
 Viscosity: 1.105 cP  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

Specific Speeds  
 Ns: 1817                      Nss: 8097

Dimensions:  
 Suction: 10 in                  Discharge: 10 in

NPSHa: --- ft

Pump Limits:  
 Temperature: 150 °F  
 Pressure: 105 psi g  
 Sphere size: 5 in  
 Power: --- bhp

Advanced Criteria:  
 Preferred Operating Area: ---  
 Secondary Operating Point: ---  
 Max temperature: --- °F  
 Max suction pressure: --- psi g  
 Max sphere size: --- in  
 Max power: --- bhp  
 Max suction specific speed: --- (Nss)  
 Min trim: --- % of max diameter  
 Min head rise: --- % to shutoff

Motor: 150 hp  
 Speed: 1200  
 Frame: 447T  
 Standard: NEMA  
 Enclosure: TEFC  
 Sizing criteria: Max Power on Design Curve

Curve Corrections: none

--- Data Point ---


Flow: 3950 US gpm  
 Head: 98.2 ft  
 Eff: 77%  
 Power: 127 bhp  
 NPSHr: 16.5 ft

--- Design Curve ---

Shutoff Head: 154 ft  
 Shutoff dP: 66.6 psi  
 Min Flow: --- US gpm  
 BEP: 77% eff  
     @ 4072 US gpm  
 NOL Pwr: 139 bhp  
     @ 5289 US gpm

--- Max Curve ---

Max Pwr: 315 bhp  
     @ 7456 US gpm



Pump note: USE BEARING FRAME #5 W/ IMPELLER DIA. UNDER 20"

Selection list: —

Catalog: 6000 Dry Pit Solids Handling 60Hz vers 2  
Pump: 10522-6 / 5


Performance Evaluation:

Flow US gpm	Speed rpm	Head ft	Pump %eff	Power bhp	NPSHr ft	Motor %eff	Motor kW	Hrs/yr	Cost /kWh
4740	1160	84.5	74	135	20.3				
3950	1160	98.2	77	127	16.5				
3160	1160	110	73	119	13.1				
2370	1160	121	67	108	9.87				
1580	1160	131	54	97.4	7.48				






**SERIES 6250**  
**VERTICAL LINE-SHAFT**  
**SOLIDS-HANDLING PUMPS**




RELATIVE POSITION OF  
 SUCTION AND DISCHARGE  
 (AS VIEWED FROM THE MOTOR END)

LEFT HAND ROTATION



RIGHT HAND ROTATION



NOTE: DISCHARGE IN POSITION NO.1  
 FURNISHED AS STANDARD.  
 OTHER POSITIONS AVAILABLE  
 FROM FACTORY WHEN SPECIFIED.

OUTLINE DWG # 102900

S.O.

JOB:

ISSUE REVISION DATE


LIST OF EQUIPMENT FURNISHED:

Model \_\_\_\_\_ Pump  
 Rated for \_\_\_\_\_ GPM at \_\_\_\_\_ FLTDH.  
 \_\_\_\_\_ HP, \_\_\_\_\_ RPM, \_\_\_\_\_ Volts  
 \_\_\_\_\_ Phase, \_\_\_\_\_ Hz Vertical C-Face  
 Motor in \_\_\_\_\_ NEMA  
 enclosure complete with pedestal

ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_  
 ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_

OPTIONAL ACCESSORIES:

- Anchor Bolts
- Mechanical Seal
- Bronze or S.S. Impeller
- Bronze or S.S. Wear Rings
- 416 S.S. Pump Shaft
- Safety Guard



NOTES: 1. ALL DIMENSIONS ARE IN INCHES.  
 2. WEIGHT IS IN POUNDS.


TABLE OF DIMENSIONS

✓ PUMP MODEL	DIS	SUC	A	E	G	K	X	Z	CP	U	KEY	V	VD	VS	W	WEIGHT
4317-4A/4BHT	4	B	30	13 1/2	5/8		13	10 1/2	61 7/8				27	13 1/2	14	1175
4317-4A/4BHT	4	B	30	13 1/2	5/8		13	10 1/2	61 7/8				27	13 1/2	14	1175
6315-4A/4BHT	6	B	24	10 1/2	1/2		16	11	60				26	16 1/2	14	1160
6315-4A/4BHT	6	B	24	10 1/2	1/2		16	11	60				26	16 1/2	14	1160
6317-4A/4BHT	6	B	30	13 1/2	5/8		17	11 3/4	62 1/2				28 3/8	17 1/2	15	1325
6317-4A/4BHT	6	B	30	13 1/2	5/8		17	11 3/4	62 1/2				28 3/8	17 1/2	15	1325
8317-4A/4BHT	8	B	30	13 1/2	5/8	1/2	17	11 3/4	62 1/2				28 3/8	17 1/2	15	1325
8317-4A/4BHT	8	B	30	13 1/2	5/8	1/2	17	11 3/4	62 1/2				28 3/8	17 1/2	15	1325
8417-4A	8	B	30	13 1/2	5/8		18	13	63 1/8		2 1/2 x 3/8 x 3	4 1/2	28 1/2	18	15	1520
8417-4A	8	B	30	13 1/2	5/8		18	13	63 1/8		2 1/2 x 3/8 x 3	4 1/2	28 1/2	18	15	1520
8515-4A	8	B	30	13 1/2	5/8		16 1/2	11 1/8	63 1/2				28 1/2	18	15	1420
8515-4A	8	B	30	13 1/2	5/8		16 1/2	11 1/8	63 1/2				28 1/2	18	15	1420
8518-4A/4B	8	B	30	13 1/2	5/8		18	13	63 1/2				28 3/8	18	15	1520
8518-4A/4B	8	B	30	13 1/2	5/8		18	13	63 1/2				28 3/8	18	15	1520
10522-4B	10	B	38	16 1/2	1		22	17	75 1/2				39 1/2	21 1/2	18	3500
10522-4B	10	B	38	16 1/2	1		22	17	75 1/2				39 1/2	21 1/2	18	3500
10522-5/6	10	B	38	16 1/2	1		22	17	84	2 1/2	1/2 x 5/8 x 5	6 1/2	39 1/2	21 1/2	18	3590
10522-5/6	10	B	38	16 1/2	1		22	17	84	2 1/2	1/2 x 5/8 x 5	6 1/2	39 1/2	21 1/2	18	3590
12515-4A	12	B	38	16 1/2	1		15 1/2	12	69				33 1/2	22	20	1760
12622-4B	12	B	38	16 1/2	1		24	18	76 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	40 1/8	25 1/2	20	4500
12622-4B	12	B	38	16 1/2	1		24	18	76 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	40 1/8	25 1/2	20	4500
12622-5/6	12	B	38	16 1/2	1		24	18	84 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	40 1/8	25 1/2	22	4600
12622-5/6	12	B	38	16 1/2	1		24	18	84 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	40 1/8	25 1/2	22	4600
12624-4B	12	B	38	16 1/2	1		24	18	76 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	40 1/8	25 1/2	20	4520
12624-4B	12	B	38	16 1/2	1		24	18	76 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	40 1/8	25 1/2	20	4520
12624-5/6	12	B	38	16 1/2	1		24	18	84 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	40 1/8	25 1/2	22	4620
12624-5/6	12	B	38	16 1/2	1		24	18	84 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	40 1/8	25 1/2	22	4620
14518-4B/4BHT	14	B	38	16 1/2	1		20	18	74	2 1/2	1/2 x 5/8 x 3	4 1/2	38 1/2	24 1/2	22	4680
14518-4B/4BHT	14	B	38	16 1/2	1		20	18	74	2 1/2	1/2 x 5/8 x 3	4 1/2	38 1/2	24 1/2	22	4680
14620-4B	14	B	38	16 1/2	1		20	18	77 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	41 1/2	26 1/2	22	4800
14620-5	14	B	38	16 1/2	1		20	18	86 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	41 1/2	26 1/2	22	4800
16620-4B	16	B	38	16 1/2	1		22	18	77 1/2	2 1/2	1/2 x 5/8 x 3	4 1/2	41 1/2	26 1/2	22	4820
16620-5	16	B	38	16 1/2	1		22	18	86 1/2	2 1/2	1/2 x 5/8 x 5	6 1/2	41 1/2	26 1/2	22	4820
16622-5B/6B	16	B	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4900
16622-5B/6B	16	B	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4900
18530-6B/6BHT	18	B	48	20	1 1/2		27	22	98 1/2	2 1/2			6 1/2	53 1/2	36 1/2	5600
18530-6B/6BHT	18	B	48	20	1 1/2		27	22	98 1/2	2 1/2			6 1/2	53 1/2	36 1/2	5600
18624-5B/6B	18	B	43 1/2	20	1		27	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4950
18624-5B/6B	18	B	43 1/2	20	1		27	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4950
18622-5B	18	B	43 1/2	20	1		22	19 1/2	100 1/2	2 1/2			6 1/2	54 1/2	33 1/2	4920
18622-5B	18	B	43 1/2	20	1		22	19 1/2	100 1/2	2 1/2			6 1/2	54 1/2	33 1/2	4920
20724-6B	20	B	43 1/2	20	1		22	24	98 1/2	2 1/2			6 1/2	52 1/2	42 1/2	5700
20724-6B	20	B	43 1/2	20	1		22	24	98 1/2	2 1/2			6 1/2	52 1/2	42 1/2	5700



**SERIES 6250**  
**VERTICAL LINE-SHAFT**  
**SOLIDS-HANDLING PUMPS**

CHANNEL MOUNTED GUIDE BEARING  
 -STANDARD-



MOTOR FRAMES

182TC THRU 445TC (FOR FRAMES ABOVE  
 445TC OR "P" MOUNTING CONSULT FACTORY)





TABLE OF DIMENSIONS

SHAFT SERIES	C	B	W	F	M	VV
27-31, 37	1 7/8	6 1/4	1 3/8	2 3/8	1 1/2	5
41	1 7/8	6 3/4	1 3/4	2 1/2	1 1/2	5 1/2
48	2 1/8	7	2	3	1 1/2	6 1/8
55-61	2 1/4	8 1/4	2 1/4	3 1/8	1 3/4	7
71	2 1/2	8 7/8	2 1/2	3 3/8	1 3/4	7 3/4
81	2 3/4	9	2 3/4	3 5/8	1 3/4	7 3/4
88	3 1/2	12	3 1/2	4 1/2	2 7/8	8 5/8
91	4	14	3 3/4	5 7/16	3 1/8	9

NOTE: ALL DIMENSIONS ARE IN INCHES.

MOTOR FRAMES  
 143TC THRU 145TC




OUTLINE DWG # 109150

S.O. \_\_\_\_\_  
 JOB: \_\_\_\_\_  
 ISSUE REVISION DATE


LIST OF EQUIPMENT FURNISHED:

- ITEM  STANDARD  SPECIAL TUBE \_\_\_\_\_  
 (QTY) SHAFING CONSISTING OF:  
 1 SECTION "A" SHAFING WITH SPLINED END  
 \_\_\_\_\_ SECTION "B" SHAFING EACH WITH ONE (1) INTERMEDIATE BEARING  
 \_\_\_\_\_ HP \_\_\_\_\_ RPM \_\_\_\_\_ VOLTS \_\_\_\_\_ PHASE \_\_\_\_\_ HZ  
 \_\_\_\_\_ VERTICAL C-FACE MOTOR IN \_\_\_\_\_  
 \_\_\_\_\_ NEMA ENCLOSURE COMPLETE WITH PEDESTAL  
 AND COUPLING  
 OPTIONAL:  
 SAFETY GUARD


SINGLE  
 SHAFING LENGTH



DOUBLE  
 SHAFING LENGTH



TRIPLE  
 SHAFING LENGTH





D



**APPENDIX D**

---

**WWTP CALCULATIONS AND  
CATALOG CUTS**

EXPAND WWTP:

GIVEN:

① EXISTING CAPACITY - HYDRAULIC - 11.5 MGD  
 ORGANIC - 19,950 #/D (203 mg/L)  
 TSS - 23,690 #/D (247 mg/L)

② EXISTING LOADINGS\* - AVE Q - 11.0 MGD  
 #/DAY FROM (1/07-8/07) MAX DAY - 22.0 MGD  
 MIN DAY - 6.4 MGD

ALL LOADS  
INCLUDE  
INTERNAL  
WWTP  
RECYCLE

BOD AVE DAY - 114 mg/L  
 BOD MAX MONTH - 176.2 mg/L  
 BOD MAX DAY - 277 mg/L (7/07)

TSS AVE DAY - 102 mg/L  
 TSS MAX DAY - 310 mg/L (7/07)  
 TSS MAX MONTH - 137.5 mg/L

③ PROPOSED WWTP LOADINGS - HYDRAULIC -  
 AVE DAY Q - 12.0 MGD  
 MAX DAY - 42.5 MGD - FROM 537

ORGANIC - 19,950 #/D (200 mg/L)  
 TSS - 23,690 #/D (237 mg/L)  
 NH<sub>3</sub>-N - 2,302 #/D (23 mg/L)  
 TN - 3,703 #/D (37 mg/L)

④ EFFLUENT GOALS

BOD - 10 mg/L  
 TSS - 10 mg/L  
 TN - 5 mg/L  
 NH<sub>3</sub>-N - 1 mg/L

ASSUMPTIONS

- 1) DEFAULT KINETIC VALUES UNLESS OTHERWISE INDICATED
- 2) WW TEMP 15° C SUMMER 10° C WINTER

### SPLIT TREATMENT SCHEME:

- ALL Q THROUGH NEW HEADWORKS CONSISTING OF SCREENS, GRIT REMOVAL & RAW SEWAGE PUMP STATION.
- FLOW FROM PUMPS WILL BE SPLIT IN A CONTROLLED Q-PACED SPLITTER BOX → SOME PERCENTAGE (APPROX  $\frac{1}{2}Q$ ) WILL BE PROCESSED BY THE EXISTING WWTTP AND THE REMAINDER TREATED BY NEW SBR'S.
- ALL AVE DAY Q UP TO THE PEAK LESS CAPACITY OF EXIST CCT WILL BE DISINFECTED BY UV AND DISCHARGED TO RIVER.

→ ASSUME NO BOD OR TSS REMOVAL IN HEADWORKS

- REFERENCE SBR DESIGN SPREADSHEET OUTPUT FOR NEW PROCESS CALCULATIONS
- REFERENCE FLOW & MASS BALANCE SHEETS FOR OVERALL DESIGN

GOAL TOTAL N = 5 mg/L

IF WWTP IS SPLIT & SBR FUNCTIONS FOR BNR

THEN SBR MUST ACHIEVE TN OF:

$$(6 \text{ MGD})(7.8) + (6 \text{ MGD})TN_{\text{SBR}} = (12 \text{ MGD})(5 \text{ mg/L})$$

$$TN = 2.2 \text{ mg/L } TN_{\text{SBR}}$$

$$TKN = 1.12 \text{ mg/L } (51\%)$$

$$NH_3-N = 0.88 \text{ mg/L } (40.3\%)$$

$$NO_x = 1.08 \text{ mg/L } (49\%)$$

THE SBR IS BEING DESIGNED FOR TN = 5 mg/L & NH<sub>3</sub>-N = 1 mg/L



∴ SBR WILL NOT OBTAIN LOW ENOUGH CONCENTRATIONS TO BLEND W/ EXISTING WWTP Q TO MEET TN GOAL = 5 mg/L

IF TP = 1 mg/L

$$(6 \text{ MGD})(1.62) + (6 \text{ MGD})(TP_{\text{SBR}}) = 12 \text{ MGD}(1 \text{ mg/L})$$

$$TP = 0.38 \text{ mg/L } TP_{\text{SBR}}$$

THIS IS PRETTY MUCH IMPOSSIBLE TO ACHIEVE AS TYPICALLY BIO P REMOVAL STOPS AT 1 mg/L.

MUST LEAVE BACK DOOR TO REMOVE PHOSPHORUS !!!

CONSIDER HAVING SBR REACH 1 mg/L & UTILIZE EXISTING BASINS CONVERTING TO S-STAGE BNR OR 3-STAGE A<sup>2</sup>/O PHOREDOX PROCESS

MACM ACTUAL DATA

Date	Flow	Effluent					Influent						
		NH3-N	TKN	Free Org N	Nox	TN	TP	NH3-N	TKN	Free Org N	Nox	TN	TP
9/20/2007		4.76	6.1	1.34	6.34	12.44	1.65						
9/24/2007		4.11	4.7	0.59	2.3	7	<0.1						
10/1/2007		1.14	2.7	1.56	6.28	8.98	2.16						
10/8/2007		2.55	4.5	1.95	0.38	4.88	2.6	11.6	15.2	3.6	0.07	15.27	3.6
10/15/2007		2.86	4.4	1.54	6.23	10.63	1.45	14.1	5.3		0.06		4.4
10/22/2007		4.6	4.7	0.1	2.85	7.55	2.15	15.2	23.7	8.5	0.14	23.84	3.7

Average	3.34	4.52	1.18	4.06	8.58		13.63	14.73	6.05	0.09	19.56	3.90
Percentage	38.9%	52.6%	13.8%	47.4%	100.0%		69.7%	75.3%	30.9%	0.5%	100.0%	
TKN:NH3-N Ratio		1.35						1.08				
Max	4.76	6.10	1.95	6.34	12.44	2.60	11.60	15.20	3.60	0.07	15.27	3.60
Percentage	38.3%	49%	15.7%	51.0%	100.0%		76.0%	99.5%	23.6%	0.5%	100.0%	
TKN:NH3-N Ratio		1.28						1.31				




# MACM: BNR FOR EXIST PROCESS

## MLE - DN ZONE

Enter following Influent Data

Flow	8 MGD
BOD	114 mg/L
NH3-N	14 mg/L
TKN:NH3	1.08 Ratio
TKN:NOx	163.6 Ratio
TN:NH3-N	0.69 Ratio
COD:BOD	2 Ratio



Enter the following Effluent

BOD	15 mg/L
NH3-N	1 mg/L
TN	166.8 #/D

Enter the following Operating Parameters

MLSS	3500
Volatile Fraction	0.75
Is there Primary Clarifiers?	No
Volume of Aeration	371,420 ft <sup>3</sup>

TKN	15.12 mg/L
NOx	0.092420538 mg/L
NH3-N	115.092 #/D
TN	2.50 mg/L
Residual NOx	1.50 mg/L
MLVSS	2625 mg/L
Volume in Aeration	2778221.6 gal
Soluble Influent TKN	10.962 mg/L
Remaining to be Nitrified	8.46 mg/L
qN	0.028
MLVSS in DN	20163.73714 #
MLVSS in Aeration	60822.21638 #

Volume DN	921,034 gallons
Detention Time	2.8 hours
Percentage of Volume	33%

lb. NO3 Equivalent	100.08 #
Effluent COD	1401.12 #
DN BOD Removal	700.56 #
DN BOD Removal	11 mg/L
DN Effluent BOD	104 mg/L

Vol Req'd for BOD Removal 1,840,000.00 gallons

Total Volume Required	2,761,034 gallons
Total Volume Required	369,122 ft <sup>3</sup>

**RATIONALE DESIGN FOR ACTIVATED SLUDGE SYSTEMS**

**Client**                   MACM  
**Project**                 Existing Unit Process WWTP

**Given Information**

Max Day Q	8 MGD	Entered Value	
BOD <sub>in</sub>	6905.5 #/d	BOD influent to aeration basins	
BOD <sub>in</sub>	104 mg/L	Unit Conversion	Includes 5% load for recycle
BOD <sub>eff</sub>	15 mg/L	BOD (soluble) effluent from aeration basins	
NH3-N <sub>in</sub>	522.8 #/d	NH3-N influent to aeration basins	Includes 15% load for recycle
NH3-N <sub>in</sub>	7.835185185 mg/L	TKN based on 60% as NH3-N	
NH3-N <sub>eff</sub>	1 mg/L	NH3-N effluent from aeration basins	
TKN <sub>in</sub>	8.5 mg/L		
MinWW Temp.	50 deg F	Entered Value	
MinWW Temp.	10 deg C	Unit Conversion	
Vant-Hoff Factor	1.135	Temperature Correction Value	
Rxtr DO	3 mg/L	Entered Value for Minimu DO in Rxtr	
pH	7 units	Entered Value	
MLSS	3500 mg/L	Entered Target Value	
f	0.75	Entered Value for Ratio of Active Cells in MLVSS	
MLVSS	2625 mg/L	Calculated MLVSS from Volatile Fraction	
μ <sub>m</sub>	0.5 d <sup>-1</sup>	Max. Specific Growth Rate (Typical value unless otherwise noted)	
K <sub>s</sub>	1.4 mg/L	Typical value unless otherwise noted	
Y <sub>n</sub>	0.2 mg VSS/mg	Synthesis Rate for Nitrifiers (Typical value unless otherwise noted)	
Y	0.5 mg VSS/mg BOD	Synthesis Rate for BOD (Typical value unless otherwise noted)	
k <sub>dn</sub> @ 15 deg C	0.07 d <sup>-1</sup>	Endogenous Resp. Rate for Nit @ 15 deg. C (Typical value unless otherwise noted)	
k <sub>dn</sub>	0.037	Temperature Correction	
k <sub>d</sub> @ 15 deg C	0.08 d <sup>-1</sup> BOD	Endogenous Resp. Rate for BOD @ 15 deg. C (Typical value unless otherwise noted)	
k <sub>d</sub>	0.029	Temperature Correction	
K <sub>n</sub>	0.22 mg/L	Calculated nitrification rate constant	
SF	2	Safetey Factor	

**Application of Model:**

BOD Removed	5904.7 # BOD removed
NH3-N Removed	456.0 # NH3-N removed
f <sub>n</sub>	0.030
μ'(m)	0.18 d <sup>-1</sup>
k'	0.9 d <sup>-1</sup>
θ <sub>c</sub> <sup>M</sup>	6.99 days
θ <sub>c</sub>	13.98 days
U(NH3-N)	0.54 d <sup>-1</sup>
Predicted N <sub>e</sub>	0.33 mg/L
U	0.2 # BOD removed/# MLVSS * d
θ (BOD)	0.23 days      5.52 hours
θ(NH3-N)	0.21 days      5.04 hours

<b>Governing θ</b>	<b>0.23 days</b>	<b>5.52 hours</b>
<b>Volume Required</b>	<b>1,840,000 gallons</b>	<b>245,989 ft<sup>3</sup></b>

Calculated F:M                   0.17 d<sup>-1</sup>      BOD (mg/L) / [MLVSS (mg/L)\*HRT]

MACM WWTP Expansion  
 Existing Unit Processes  
 WAS Production Estimate by Aerobic Treatment

Enter design parameters and assumptions in highlighted cells  
 Influent Conditions (Assuming balanced recycle loads)

Flow	8 MGD	
Influent Effluent BOD	104 mg/L	7606 lb./day
Primary Effluent TSS	102 mg/L	6805 lb./day
VSS fraction of TSS	75%	
Non-Deg fraction of V	20%	
Tank Volume	1,840,000 MG	

Activated Sludge Process

Actual F:M Ratio	0.17	
Min Required MLSS	59,654.9 #/D	3,887 mg/L
Volatile Fraction of M	75%	
MLVSS	44,741.2 #/D	2,916 mg/L
Water Temperature	50 deg F	10 deg C
f(d)	0.46	
k(d) (active cell basis)	0.07	
Y Yield Constant	0.55 /d	
Effluent BOD Soluble	7.5 mg/L	497 lb./day
Effluent TSS	10 mg/L	663 lb./day
BOD Design Efficiency	92.8%	
TSS Design Efficiency	90.2%	
Substrate Utilization, $\mu$	0.16	

Waste Activated Sludge

		VSS	ISS	TSS
Influent Solids, lb./day				
Inert				1701
Non-Deg VSS		1021		
Synthesized Cells				
Y*BOD(in-out)	3908.08			
f(d)*k(d)*MLVSS	1,440.67			
Deg. Fractic	77%		1569	
Non-Deg Fr	23%	898.8584		
Organic	69%		620	
New Cells Inorganic	31%			279
<b>Total</b>		<b>3210</b>	<b>1980</b>	<b>5189</b>
Percentage		0.62	0.38	

<b>Effluent Loss</b>	<b>413</b>	<b>255</b>	<b>667</b>
----------------------	------------	------------	------------

<b>Waste Activated Sludge</b>	<b>2797</b>	<b>1725</b>	<b>4522</b>
-------------------------------	-------------	-------------	-------------

WAS Concentration	10017 mg/L	10000 mg/L
	54,131 gpd	54,223 gpd

MCRT (waste)	13.19 days
MCRT (check w/ U)	10.33 days

CHEMICAL DOSING OF SECONDARY TANKS FOR  
PHOSPHORUS REMOVAL

$$\text{CHEM DOSE} = \text{CDE} (TP - TP_e) \times (\text{SF})$$

ALUM DOSE BASED ON % P REMOVED

% Remov.	CDE
< 85	13 mg/L
85 ≤ R ≤ 95	16 mg/L
> 95%	22 mg/L

$$\% \text{ Removed} = \frac{4-1}{4} = 75\% \Rightarrow 13 \text{ mg/L}$$

$$13 \text{ mg/L} (4-1) \times (\text{SF}) = 39 \times \text{SF}$$

SF → ROUND TO NEAREST 5 mg/L INTERVAL

ASSUME 40 mg/L

ESTIMATE ALUM REQUIRED

$$\text{ALUM} = 40 \text{ mg/L} \times 8 \text{ MGD} \times 8.34 = 2,668 \text{ \# / d}$$

INCREASE IN SLUDGE

$$P_{\text{sludge}} = \frac{Q \times \text{CD} \times 0.091 \times 4 \times 8.34}{1 \times 10^6}$$

$$P_{\text{sludge}} = \frac{9,000,000 \times 40 \times 0.091 \times 4 \times 8.34}{1 \times 10^6} = 97 \text{ \# / d}$$

$$V_{\text{PS}} = P_{\text{sludge}} \times \text{SVI}$$

$$V_{\text{PS}} = 97 \text{ \# / d} \times 71.2 = 69,167 \text{ FT}^3 / \text{BAYIN}$$

W 25% TOTAL VOL FOR SEC CLARIFIERS. FOR ALUM SLUDGE ONLY!!! → TOTAL = 4522 + 971 = 5493 #/d × 71.2 = 391,101

TOTAL VOL = 273,178 FT<sup>3</sup> !! TOO MUCH VOL!!

MUST HAVE 100% P REMOVAL!

- SINCE EXPECTED BIO P & CHEM PRECIP IS NOT LIKELY TO ACHIEVE POTENTIAL EFFLUENT LIMITS LOOK AT OTHER PROCESS TO REMOVE P.

- SINCE ALL EXISTING AERATION BASINS WILL BE UTILIZED TO ACHIEVE POTENTIAL TN LIMITS OPTIONS ARE LIMITED.

OPTIONS AVAILABLE FOR "SEPARATE" STAGE P REMOVAL INCLUDE THE PHO STRIP PROCESS & TERTIARY FILTRATION

FIRST LOOK AT PHO STRIP

EXISTING ORIGINAL CCT WILL NOT BE UTILIZED IN TREATMENT SCHEME CAN IT BE USED FOR PHOSPHORUS SIDE STREAM?

SEE TABLE 11-25 FROM METCALF & EDDY ATTACHED.

THE MLE PROCESS DESIGNED APPEARS TO MEET THE FOLLOWING CRITERIA

CRITERIA	PROCESS	DESIGN
F/M	0.1-0.5	0.17
$\theta_c$	10-30 d	14 days
MLSS	600-5000 g/L	3500 g/L
HRT		
ANEROBIC	8-12 hr	?
AEROBIC	4-10 hr	5.5 hr
RAS % INF	20-50%	?
INTERNAL RECYCLE % INF	10-20%	?

USING INTERNAL RECYCLE AS STRIPPER UNDERFLOW & ANEROBIC

HRT AS BASIS — IS EXISTING CCT A VIABLE OPTION?

INFLUENT Q = 8 MGD.

10% Q = 0.8 MGD

20% Q = 1.6 MGD

HRT<sub>max</sub> = 12 hr

HRT<sub>min</sub> = 8 hr

10% Q @ HRT<sub>max</sub> = 0.8 MGD x 12 hr (12/24) = 0.4 MGD.

10% Q @ HRT<sub>min</sub> = 0.8 MGD x 8 hr (8/24) = 0.267 MGD.

20% Q @ HRT<sub>max</sub> = 1.6 x 12/24 = 0.8 MGD

20% Q @ HRT<sub>min</sub> = 1.6 x 8/24 = 0.534 MGD.

EXIST VOL =

SIDE WATER DEPTH = 6'-0" FT  
2 CHANNELS AT 8' WIDE PER PASS x 5 PASSES AT 30'-0"  
& 1 PASS AT 23.5' PER CHANNEL

VOL/CHANNEL = 6 x 8 x [(5 x 30) + 23.5] = 8328 FT<sup>3</sup>

TOTAL VOL = 16,565 FT<sup>3</sup> = 124,600 GAL.

→ JUST SHORT FOR LOW Q & MIN HRT

IF USED COULD PROBABLY EXPECT SOME REMOVAL

BUT STILL NOT ENOUGH on ITS OWN. COULD

POSSIBLY BE UTILIZED TO OFFSET CHEM ADDITION

IF USE BOTH METHODS. !!!

POTENTIAL BIO P REMOVAL

$$TP_{BE} = TP_i - (Y + BO_{D2} \times TP_{fMLVSS})$$

$$TP_{BE} = TP_{BIO\ EFFLUENT}$$

$$TP_i = TP_{INFLUENT} = 4\text{ mg/L}$$

$$TP_{fMLVSS} = \% TP\ in\ Biomass = 0.04\ (\text{Assumed})$$

$$TP_{BE} = 4 - (0.5 \times (104 - 15) \times 0.04)$$

$$TP_{BE} = 2.22\text{ mg/L}$$

THIS IS SLIGHTLY ABOVE PUBLISHED INFO FOR CONSERVATIVE PROSTRIP DESIGN (15) HOWEVER w/ INSUFFICIENT VOL. THIS COULD BE VIABLE → FURTHERMORE THIS REPRESENTS A 45% REMOVAL EXISTING PROCESS REMOVAL IS DOCUMENTED THROUGH SAMPLING AT APPROX ~ 35%

CHEMICAL ADDITION w/ PROSTRIP:

$$Chem\ Dose = C_D \times (TP - TP_{BE}) \times SF$$

$$\% \text{ Removal} = \frac{2.2 - 1}{2.2} = \sim 55\% \quad C_D = 13 \text{ SEE pg. 6 OF CALC}$$

$$13 \times (2.2 - 1) \times SF = 15.6\ SF$$

ADD SF TO 20% FOR NEARLY HIGHER 5% L DISE.

$$Alum = 20\% \times 8\text{ MGD} \times 8.34 = 1334\ \#/\text{D}$$

$$P_2 \text{ Sludge} = \text{SHOULD BE } \frac{1}{2} \text{ ALSO.} \\ = 485.7\ \#/\text{D} \\ + 4522.\ \#/\text{D} \text{ BOO SLUDGE.}$$

← CUTS ALUM DISE 1/2 FROM ASSUMPTION NO BIO P OCCURS

5007 x 71.2 = 356,459 → STILL HIGH. WILL HAVE TO WASTE AT RAPID RATE!!


MOVING SLUDGE IN & OUT TO ACCOMMODATE STORAGE

SL IN CLARIFIERS WILL BE HIGH → HOWEVER

MLE REQUIRES SLUDGE BE MOVED AT 100-200% Q<sub>FORWARD</sub>

∴ 5010 #/D AT SAY 10,000 mg/L

= 60,071 gpd → 41.7 gpm



$Q_i = 8,000,000 \text{ GPD}$

$Q_e = Q_i - Q_w$

$Q_w = Q_{wB} + Q_{wP}$

$Q_{wB} = 54,223 \text{ gpd}$

$Q_{wP} = 5,824 \text{ gpd}$

$C_e = 15$

$C_i = 104$

$C_w = C_r = 10,000$

$MLSS = 3500$

MASS BALANCE ON AERATION BASIN

$Q_i C_i + Q_r C_r = Q_m C_m$

$Q_i C_i + Q_r C_w = Q_i C_m + Q_r C_m$

SOLVE FOR Q<sub>r</sub>

$Q_r (C_w - C_r C_m) = Q_i C_m - Q_i C_i$

$Q_r (10,000) - Q_r (3500) = (8)(3500) - 8(104)$

$Q_r = 4.2 \text{ MGD}$

$\Rightarrow Q_r / Q_i = 0.53\%$

$Q_p = 0.1 \times Q_i =$

$0.1 \times 8 = 0.8 \text{ MGD}$

$Q_r + Q_{wP} + Q_{wB} = 4.2 + 0.054 + 0.005$

$Q_{TOTAL W/R} = 4.23 \text{ MGD} = 2944 \text{ gpm}$



AT THIS RATE 2944 gpm.

$$\frac{60,057 \text{ gal}}{2944 \text{ gpm}} = 20 \text{ min IN STORAGE.}$$



→ AT LOW SVI SHOULD NOT BE STORAGE ISSUE.

∴ BNR FOR TN & TP IS POSSIBLE

DO NOT CONSTRUCT UNTIL ACTUAL PERMIT  
LIMITS ARE KNOWN !!!



*our solutions are simple*



***FlexRake™***

***Trashracks & Trashrakes***


# The Duperon FlexRake™

## BENEFITS

- Affordable
- Reduces Operating/Maintenance Costs
- Eliminates Underwater Maintenance
- Increases Productivity
- Easily Installed, Available Fully Assembled
- Reduces Risk for Worker Injury
- Easily Adapted to Changing Site and Debris Conditions
- Customized to New and Existing Sites and Barscreens

## FEATURES

- Simple Mechanical Device
- Automatic, Continuous Cleaning
- Rakes Coarse to Fine Screens
- Energy Efficient
- Lifting Capacity to 1000 lbs
- Multiple Scrapers Rake Entire Screen
- All Non-corrosive Parts Underwater
- No Frame or Underwater Sprockets, Bearings or Shafts
- Flexible for Larger Debris (drums, tires...)




# THE FLEXRAKE™ MODELS

Model	STANDARD (Coarse Screen)	FULL PENETRATION	FINE SCREEN	SINGLE STRAND
<b>Applications</b>	Water Treatment, Stormwater Pumpstations, Industrial Intakes, Hydroelectric	Water Treatment, Wastewater, Pulp/Paper Mills, Food Processing, Industrial Intakes or where debris wrapping or accumulation on barscreens is a problem	Water Treatment, Food Processing, Fish Screening, Industrial Processing	Water Treatment, Wastewater, Food Processing, Fish Screening, Industrial Processing
<b>Screen Size</b>	2 - 12 feet wide Max. 40-50 feet long (without modifications)	1 - 12 feet wide Max. 40-50 feet long (without modifications)	1 - 12 feet wide Max. 40-50 feet long (without modifications)	1-2 feet wide Max. 40-50 feet long (without modifications)
<b>Scraper Configuration (see below)</b>	Serrated	Full penetration	Straight Edge, 45 degree bevel (optional brush)	Straight Edge, 45 degree bevel, or Full Penetration, or Serrated (depending upon bar opening)
<b>Bar Opening</b>	1 - 12 inches	1/4 - 2 inches	.060 - .25 inches (smaller openings available - consult factory)	.060 - 4 inches (smaller openings available - consult factory)
<b>Purchase Options</b>	<b>For Retrofit with existing barscreens:</b> <ul style="list-style-type: none"> <li>• Rake Only</li> <li>• Rake Mounting</li> <li>• Barscreen Accessories: return guides, chain slides, strippers, etc.</li> <li>• Scraper Accessories: brushes, etc.</li> </ul> <b>For new barscreens:</b> <ul style="list-style-type: none"> <li>• FlexRake™ fully assembled on barscreen (including accessories)</li> <li>• Just place, anchor and wire.</li> </ul>	FlexRake™ fully assembled on barscreen	FlexRake™ fully assembled on barscreen Back cleaning device available	FlexRake™ fully assembled on barscreen

## ALL MODELS

<b>Power Requirements Available</b>	110/230 volt, single phase 230/460 volt, three phase Solar
<b>Installation</b>	Installed, Adapted, Maintained and Removed from the deck in most cases
<b>Controls</b>	Custom and Standard Packages are available.
<b>Drive</b>	Standard is 1/8hp electric integral gearmotor. DC, Explosion Proof and other Special Duty motors are available
<b>Screen Materials</b>	A36 Steel, coated with Duperon Standard Coating or 304 Stainless Steel (other options available).
<b>Screen Orientation</b>	Horizontal to vertical



**our solutions are simple**



**BUDGET PROPOSAL SUMMARY  
PISTA® GRIT REMOVAL**

**1.0 GENERAL DESCRIPTION**

Four Model 12.0A PISTA® Grit Chamber mechanisms, each suitable for installation in a concrete structure. Each PISTA® shall be complete with the following: drive motor, spur gear final drive head, air bell, propeller, drive tube, top mounted grit pump, grit concentrator, dewatering screw, conveyor, and automatic NEMA 4 electrical and vacuum priming controls. Fluidizer vanes and Flow Control Baffles also included.

**2.0 PISTA® GRIT REMOVAL EQUIPMENT**

The flow in each removal chamber shall travel between the inlet and outlet a minimum of 360 degrees, providing maximum travel of the liquid for effective grit removal. It shall handle all flows equal to or less than a peak flow of 12.0 MGD each.

The *standard* dimensions of the Model 12.0A PISTA® are as follows:

Upper Chamber Diameter .....	12'-0"
Upper Chamber Depth.....	6'-8"
Lower Chamber Diameter (minimum).....	5'-0"
Lower Chamber Depth (minimum).....	6'-8"
Inlet & Outlet Channel Widths.....	3'-0"

**3.0 CORROSION PROTECTION**

All fabricated steel components shall be commercial blasted and prime coated by the Manufacturer with one 3-mil DFT coat of Tnemec 66-1211 prior to shipment. All motors and gearboxes shall be furnished with the original manufacturer's coating. Final touch up and finish painting is the responsibility of the purchasing contractor.

**4.0 ITEMS NOT INCLUDED**

- Field assembly/erection or installation
- Interconnecting piping, wiring and conduit
- Field paint, painting, and final surface preparation
- Lubricants
- Anchorage, anchor bolts
- Field testing, if required
- Grouting
- All concrete work

**5.0 DELIVERY, TERMS, BUDGET PRICING**

Submittal drawings and other technical engineering details are expected to be complete in 4-6 weeks after receipt of a purchase order. Once Smith & Loveless receives approved drawings, manufacturing would take 12-14 weeks.

**Payment Terms** -To be determined



**Budget Price List (FOB, Factory) – Offer Valid for 60 days.**

Four Model 12.0A for concrete tank .....	\$500,000.00
Freight, startup and training .....	Included
Turbo Grit Pumps .....	Included
Grit Concentrators (qty 4) .....	Included
Dewatering Screw Conveyors (qty 4) .....	Included
Controls .....	Included

See a Complete PISTA Grit Removal System Installation Photo below



67B198/A


### PISTA® GRIT REMOVAL SYSTEM MULTIPLE LAYOUT

FOR	DATE	ALLOWABLE TOLERANCES
	R.D.R.H.M.	FINISHES
	L.P.A.	
	APPROVED BY:	DESIGNED BY:
	S.E.M.	
	SCALE:	
	NTS	
BY	DATE	BY
REV. NO.	DATE	BY
REV. A		
NO. 67B198		
SALES 67B198A		
PRICE 1=64,000		



SMITH & LOVELESS, INC.  
THE DESIGN AND DETAIL OF THIS DRAWING IS THE PROPERTY OF SMITH & LOVELESS, INC. AND IS NOT TO BE USED EXCEPT IN CONNECTION WITH OUR WORK. DESIGN AND INVENTION RIGHTS ARE RESERVED. PATENTS ARE IN FORCE UNLESS OTHERWISE NOTED.

- NOTES:
1. CONSULT FACTORY FOR DIMENSIONS FOR A PARTICULAR MODEL.
  2. COPYRIGHT (C) 1988, 2007 SMITH & LOVELESS, INC.



# ENGINEERING DATA



Smith &  
Loveless, Inc.

14040 W. Santa Fe Trail Dr.  
Lenexa, Kansas 66215

Water & Wastewater  
Treatment Systems  
Pista® Grit Chamber  
Outline Drawings  
Page 27  
April, 1991

PISTA® GRIT REMOVAL SYSTEM W/ CONCRETE TANK MODEL NUMBER	DIA. A	DIM. B	DIM. C	DIM. D	DIM. E	DIA. F	SEE NOTE 1.		DIA. H	DIM. J	# MAX. K	SEE NOTE 1.		H.P. M	DIA. N
							G <sub>1</sub>	G <sub>2</sub>				L <sub>1</sub>	L <sub>2</sub>		
1.0	6'-0"	2'-0"	1'-0"	3'-8"	5'-0"	3'-0"	1'-0"	1'-0"	1'-0"	21'-0"	4'-1"	1'-5"	1'-8"	3/4	3'-6"
2.5	7'-0"	2'-6"	1'-3"	3'-8"	5'-0"	3'-0"	1'-3"	1'-0"	1'-0"	22'-0"	4'-1"	1'-11"	2'-2"	3/4	3'-6"
4.0	8'-0"	3'-0"	1'-6"	4'-0"	5'-0"	3'-0"	1'-4"	1'-0"	1'-0"	23'-0"	4'-1"	2'-2"	2'-4"	3/4	3'-6"
7.0	10'-0"	4'-0"	2'-0"	4'-9"	5'-6"	5'-0"	1'-6"	1'-0"	1'-0"	25'-0"	4'-1"	2'-6"	2'-6"	1	5'-6"
12.0	12'-0"	5'-0"	2'-6"	5'-0"	6'-8"	5'-0"	1'-11"	1'-9"	1'-6"	29'-6"	6'-1"	3'-1"	3'-1"	1	5'-6"
20.0	16'-0"	7'-0"	3'-6"	5'-6"	6'-10"	5'-0"	2'-2"	2'-0"	1'-6"	40'-6"	6'-1"	3'-6"	3'-6"	2	5'-6"
30.0	18'-0"	8'-0"	4'-0"	6'-6"	7'-0"	5'-0"	2'-8"	2'-3"	1'-6"	46'-0"	6'-1"	4'-3"	4'-3"	2	5'-6"
50.0	20'-0"	9'-0"	4'-6"	7'-0"	8'-0"	5'-0"	3'-9"	3'-5"	1'-6"	51'-6"	6'-1"	5'-10"	5'-10"	2	5'-6"
70.0	24'-0"	11'-0"	5'-6"	7'-0"	8'-0"	6'-0"	3'-9"	3'-9"	1'-6"	62'-6"	6'-1"	5'-11"	5'-11"	2	6'-6"
PISTA® GRIT REMOVAL SYSTEM W/ CONCRETE TANK MODEL NUMBER	DIM. P	DIM. S													
1.0	2'-0"	15'-0"													
2.5	2'-6"	15'-0"													
4.0	3'-0"	15'-0"													
7.0	4'-0"	15'-0"													
12.0	5'-0"	17'-6"													
20.0	6'-0"	24'-6"													
30.0	7'-0"	28'-0"													
50.0	9'-0"	31'-6"													
70.0	10'-0"	38'-6"													

- NOTES:**
- Dimensions G and L on Drawings 67D132, 67D135, and 67D138 Change According to the Type of System Required:  
Dim's. G<sub>1</sub> and L<sub>1</sub> are used for the Free Flow Flume.  
Dim's. G<sub>2</sub> and L<sub>2</sub> are used for the Parshall Flume, Size Shown on Drawing 67D130.
  - Max. K Dimension is not Applicable for the Turbo Pump Pista®.

67C117

SMITH & LOVELESS, INC. 1991

THIS DRAWING IS THE PROPERTY OF SMITH & LOVELESS, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

DATE	12/21	BY	R. DIEHM	2/80
REVISED	5/8/91	BY	E.A.M.	6/80
DATE	7/5/91	BY	S.M.	6/80
DATE	11/15/91	BY	NONE	
DATE	11/15/91	BY	N80-1	9

PISTA® GRIT REMOVAL SYSTEM  
WITH CONCRETE TANK  
DIMENSIONAL CHART


SMITH & LOVELESS, INC.

67C117





**MACM: Influent Raw Sewage Pump Station System Curve**



Pump Selections

Peak Flow 50 MGD

Pump Orientation

	Option 1			Option 2			Option 3			Option 3a		
	No. Pumps	3	2 Total	3	2 Total	50	3	3 Total	60	3	3 Total	80
Flow, MGD	36	14	50	30	20	50	30	30	60	30	30	60
Per Pump Flow, MGD	18	7	50	15	10	50	8.8	8.8	44	8.8	8.8	44
Flow, gpm	12500	4861.11		10416.67	6944.444		6111.111	6111.111		6111.111	6111.111	
Flow, ft <sup>3</sup> /s	27.85	10.83		23.21	15.47		13.61	13.61		13.61	13.61	

Desired Suction Velocity 3 fps

	Option 1		Option 2		Option 3		Option 3a	
Suction Ax, ft2	9.28	3.61	7.74	5.16	4.54	4.54	4.54	4.54
Diameter, ft	3.44	2.14	3.14	2.56	2.40	2.40	2.40	2.40
Diameter, in	41.25	25.73	37.66	30.75	28.84	28.84	28.84	28.84
Actual Diameter Used	38.75	25	38.75	32	27.5	27.5	24	24
If Bell, Nominal Pipe	30	18	30	24	20	20	24	24
Actual Diameter Used	3.23	2.08	3.23	2.67	2.29	2.29	2.00	2.00
Actual Suction Ax	8.19	3.41	8.19	5.59	4.12	4.12	3.14	3.14
Actual Suction Vel.	3.40	3.18	2.83	2.77	3.30	3.30	4.33	4.33
Velocity in Suction								
Suction Ax	4.91	1.77	4.91	3.14	2.18	2.18	3.14	3.14
Suction Vel	5.67	6.13	4.73	4.92	6.24	6.24	4.33	4.33

Check Low Flow Velocities

	Option 1		Option 2		Option 3		Option 3a	
No. Pumps	3	2 Total	3	2 Total	3	3 Total	3	3 Total
Flow, MGD	25.2	9.8	21	14				
Per Pump Flow, MGD	12.6	4.9	10.5	7	4.5	5.5	4.5	5.5
Flow, gpm	8750	3402.78	7291.667	4861.111	3125	3819.444	3125	3819.444
Flow, ft <sup>3</sup> /s	19.49	7.58	16.24	10.83	6.96	8.51	6.96	8.51
Actual Diameter Used	38.75	25	38.75	32	27.5	27.5	24	24
If Bell, Nominal Pipe	30	18	30	24	20	20	24	24
Actual Diameter Used	3.23	2.08	3.23	2.67	2.29	2.29	2.00	2.00
Actual Suction Ax	8.19	3.41	8.19	5.59	4.12	4.12	3.14	3.14
Actual Suction Vel.	2.38	2.22	1.98	1.94	1.89	2.06	2.22	2.71
Velocity in Suction								
Suction Ax	4.91	1.77	4.91	3.14	2.18	2.18	3.14	3.14
Suction Vel	3.97	4.29	3.31	3.45	3.19	3.90	2.22	2.71

Selection Option 3

Reasons: Intake velocity at peak near 3 fps, at low >2 fps  
Suction Velocities between approx. 4-6 fps low to peak

	D1	D2
D, ft	2.29	2.29
Dist From Wall, xD	0.75	1.71875
Dist CL to CL, xD	2	3.4375

	2	1
No. Wetwell Sections	2	1
No. of Suctions	2	1
Bottom W of Wet Well	10.3125	
Rounded Bottom W	10	

**MACM: Raw Sewage Pump Station at WWTP  
Side-by-Side Pump Comparison**

**Required Duty Point**                      30555 gpm at 92.5 feet TDH  
**Required Duty Point per Pump**        6111 gpm at 92.5 feet TDH


Manufacturer (Model)	Flygt	Yeomans Chicago
Type of Pump	Dry Pit Submersible	Verticle Shaft
Number of Pumps	4 Total - 3 Operating	4 Total - 3 Operating
Model	NT 3356-735	12624-6
Mfr. Curve No.	63-670	3596
Impeller Type	N Serires	Y-5090
No. of Impeller Vanes	3	????
Impeller Diameter, in. (mm)	17.5 (445)	23.125
Max. Impeller Dia. in. (mm)	17.5 (445)	24
Percentage of Max Impeller	100.0%	96.4%
Nearest Duty Point	6,120 gpm at 93.1 feet TDH	6,111 gpm at 93.5 feet TDH
Best Efficiency Point	7,150 gpm at 84.1 feet TDH	6,550 gpm at 90 feet TDH
Rated Horsepower <sup>2</sup>	215 HP	181 HP
Motor Horspower	250 HP	250 HP
Pump Speed <sup>2</sup>	1185	875
Pump Efficiency <sup>2</sup>	80.2%	80.0%
NPSHr		10.9
Power Requirement	460 Volt, 3 Phase, 60 Hz	460 Volt, 3 Phase, 60 Hz
Solids Capability	????	6" diameter
Suction	14" diameter	12" diameter
Discharge	14" diameter	12" diameter
Front to Back Dimension (in)	42.125	43
Base Width (in)	37.5	38
Height - Suction CL to Top (in)	105.5	69.5
Weight, lb.	4,410	4,620
Estimate Budget Price <sup>3</sup>	\$82,560	\$49,200

1. All series data is total for the pumping system as one entity.
2. At duty point.
3. From manufacturer representative quotes.


REPLACED EXISTING PUMPS FOR HEAD & Q AT EXIST WWTTP PUMP STA.



**SERIES 6250**  
VERTICAL LINE-SHAFT SOLIDS-HANDLING PUMPS



RELATIVE POSITION OF SUCTION AND DISCHARGE (AS VIEWED FROM THE MOTOR END)



NOTE: DISCHARGE IN POSITION NO 1 FURNISHED AS STANDARD. OTHER POSITIONS AVAILABLE FROM FACTORY WHEN SPECIFIED.


OUTLINE DWG # 102900  
S.O.  
JOB:

ISSUE	REVISION	DATE

LIST OF EQUIPMENT FURNISHED:  
 Model \_\_\_\_\_ Pump  
 Rated for \_\_\_\_\_ GPM at \_\_\_\_\_ Ft.TDH.  
 \_\_\_\_\_ HP, \_\_\_\_\_ RPM, \_\_\_\_\_ Volts  
 \_\_\_\_\_ Phase, \_\_\_\_\_ Hz Vertical C-Face  
 Motor in \_\_\_\_\_ NEMA enclosure complete with pedestal

ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_  
 ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_

- OPTIONAL ACCESSORIES:
- Anchor Bolts
  - Mechanical Seal
  - Bronze or S.S. Impeller
  - Bronze or S.S. Wear Rings
  - 416 S.S. Pump Shaft
  - Safety Guard



NOTES: 1. ALL DIMENSIONS ARE IN INCHES.  
2. WEIGHT IS IN POUNDS

TABLE OF DIMENSIONS

✓	PUMP MODEL	DIS	SUC	A	E	G	K	X	Z	CP	U	KEY	V	VD	VS	VY	WEIGHT
	4317-4A/4BHT	4	8	30	13 3/4	5/8		13	10 3/4	61 1/2				27	13 1/2	14	1175
	4317-4A/4BHT	4	8	30	13 3/4	5/8		13	10 3/4	61 1/2				27	13 1/2	14	1175
	6315-4A/4BHT	6	8	24	10 1/4	1/2		16	11	60				26	16 7/8	14	1160
	6315-4A/4BHT	6	8	24	10 1/4	1/2		16	11	60				26	16 7/8	14	1160
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 3/4	62 1/4				28 3/8	17 1/2	15	1325
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 3/4	62 1/4				28 3/8	17 1/2	15	1325
	8317-4A/4BHT	8	8	30	13 3/4	5/8	1/2	17	11 3/4	62 1/4	2 3/8	5/8 x 3/8 x 3	4 1/4	28 3/8	18 1/2	16	1325
	8317-4A/4BHT	8	8	30	13 3/4	5/8	1/2	17	11 3/4	62 1/4	2 3/8	5/8 x 3/8 x 3	4 1/4	28 3/8	18 1/2	16	1325
	8417-4A	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8417-4A	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8515-4A	8	8	30	13 3/4	5/8		16 1/2	11 9/16	63 1/8				28 3/8	18	15	1420
	8515-4A	8	8	30	13 3/4	5/8		16 1/2	11 9/16	63 1/8				28 3/8	18	15	1420
	8518-4A/4B	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	8518-4A/4B	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/8	18	15	1520
	10522-4B	10	10	38	16 1/2	1		22	17	75 1/8				39 1/2	21 1/8	18	3500
	10522-4B	10	10	38	16 1/2	1		22	17	75 1/8				39 1/2	21 1/8	18	3500
	10522-5/6	10	10	38	16 1/2	1		22	17	84	2 7/8	1/2 x 3/4 x 5	6 1/4	39 1/2	21 1/8	18	3590
	10522-5/6	10	10	38	16 1/2	1		22	17	84	2 7/8	1/2 x 3/4 x 5	6 1/4	39 1/2	21 1/8	18	3590
	12515-4A	12	12	38	16 1/2	1		15 1/2	12	69				33 1/2	22	20	1760
	12622-4B	12	12	38	16 1/2	1		24	18	76 1/8	2 1/2	5/8 x 3/4 x 3	4 1/4	40	25 1/8	20	4500
	12622-4B	12	12	38	16 1/2	1		24	18	76 1/8	2 1/2	5/8 x 3/4 x 3	4 1/4	40	25 1/8	20	4500
	12622-5/6	12	12	38	16 1/2	1		24	18	84 1/4	2 7/8	3/4 x 5/8 x 5	6 1/4	40	25 1/8	22	4600
	12622-5/6	12	12	38	16 1/2	1		24	18	84 1/4	2 7/8	3/4 x 5/8 x 5	6 1/4	40	25 1/8	22	4600
	12624-4B	12	12	38	16 1/2	1		24	18	76 1/8	2 1/2	5/8 x 3/4 x 3	4 1/4	40	25 1/8	20	4520
	12624-4B	12	12	38	16 1/2	1		24	18	76 1/8	2 1/2	5/8 x 3/4 x 3	4 1/4	40	25 1/8	20	4520
	12624-5/6	12	12	38	16 1/2	1	3/4	24	18	84 3/4	2 7/8	1/2 x 3/4 x 5	6 1/4	40	25 1/8	20	4620
	12624-5/6	12	12	38	16 1/2	1	3/4	24	18	84 3/4	2 7/8	1/2 x 3/4 x 5	6 1/4	40	25 1/8	20	4620
	14518-4B/4BHT	14	14	38	16 1/2	1		20	18	74	2 1/2	5/8 x 3/4 x 3	4 1/4	38 1/8	24 1/8	22	4600
	14518-4B/4BHT	14	14	38	16 1/2	1		20	18	74	2 1/2	5/8 x 3/4 x 3	4 1/4	38 1/8	24 1/8	22	4600
	14620-4B	14	14	38	16 1/2	1		20	18	77 1/2	2 1/2	5/8 x 3/4 x 3	4 1/4	41 1/8	26 1/8	22	4800
	14620-5	14	14	38	16 1/2	1		20	18	86 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	41 1/8	26 1/8	22	4800
	16620-4B	16	14	38	16 1/2	1		22	18	77 1/2	2 1/2	5/8 x 3/4 x 3	4 1/4	41 1/8	26 1/8	22	4820
	16620-5	16	14	38	16 1/2	1		22	18	86 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	41 1/8	26 1/8	22	4820
	16622-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	52 1/8	32 1/8	16 1/2	4900
	16624-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	52 1/8	32 1/8	16 1/2	4930
	18530-6B/6BHT	18	20	48	20	1 1/2		27	22	98 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	53 1/8	36 1/8	18	5600
	18624-5B/6B	18	20	43 1/2	20	1		27	19 1/2	97 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	52 1/8	32 1/8	16 1/2	4950
	18624-5B/6B	18	20	43 1/2	20	1		27	19 1/2	97 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	52 1/8	32 1/8	16 1/2	4950
	1862-5B	18	18	43 1/2	20	1		22	19 1/2	100 1/2	2 1/2	3/4 x 5/8 x 5	6 1/4	54 1/8	33 1/8	16 1/2	4920
	20724-6B	20	20	43 1/2	20	1		22	24	98	2 1/2	3/4 x 5/8 x 5	6 1/4	52 1/8	42 1/8	18	5700

**Kevin Hoffman**

---

**From:** Mark Robinson [mrobinson@daman-superiorllc.net]  
**Sent:** Monday, December 03, 2007 10:56 AM  
**To:** Kevin Hoffman  
**Subject:** MACM

Kevin,

Yeomans pricing, the curve you viewed is accurate. Revised condition of 6111 gpm @ 93' tdh.

12624-6, Series 6250 vertical shafted pump with 250 hp, 900 rpm, 460/3/60, TEFC motor.....\$49,200.00

Same pump but with Explosion Proof motor.....\$54,120.00

Mark

No virus found in this outgoing message.

Checked by AVG Free Edition.

Version: 7.5.503 / Virus Database: 269.16.13/1165 - Release Date: 12/2/2007 8:34 PM

COST/PUMP = 49,200

20% FOR VFD DUTY = 9,840

PERFORMANCE TEST = 2,158.00

SHAFT = 4,000.00

---

TOTAL = \$65,200

Company: K LH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/3/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 12624-6  
 Type: 6000  
 Synch speed: 900 rpm  
 Curve ID No.: 40169  
 Specific Speeds:

Dimensions:

Speed: ~~875~~ rpm  
 Dia: 23.125 in  
 Impeller ID No.: Y-5090  
 Ns: 2192  
 Nss: 11150  
 Suction: 12 in  
 Discharge: 12 in

**Search Criteria:**

Flow: 6111 US gpm Head: 93 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---

Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC

Size: 250 hp  
 Speed: 900  
 Frame: 449T

Sizing criteria: Max Power on Design Curve

**Pump Limits:**


Temperature: 150 °F  
 Pressure: ---  
 Sphere size: 6 in

Power: ---  
 Eye area: ---

--- Data Point ---  
 Flow: 6111 US gpm  
 Head: 93.5 ft  
 Eff: 80%  
 Power: 181 hp  
 NPSHr: 10.9 ft

--- Design Curve ---  
 Shutoff head: 138 ft  
 Shutoff dP: 59.8 psi  
 "n flow: ---  
 : 80% @ 6555 US gpm  
 NOL power:  
 212 hp @ 9911 US gpm

--- Max Curve ---  
 Max power:  
 264 hp @ 10870 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
7333	875	82	79	192	14.6
6111	875	93.5	80	181	10.9
4889	875	103	76	168	8.46
3667	875	110	67	152	6.55
2444	875	117	54	134	4.69

Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 12/3/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 12624-6  
 Type: 6000  
 Synch speed: 900 rpm  
 Curve ID No.: 40169  
 Specific Speeds:

Dimensions:

Speed: 875 rpm  
 Dia: 23.125 in  
 Impeller ID No.: Y-5090  
 Ns: 2192  
 Nss: 11150  
 Suction: 12 in  
 Discharge: 12 in

**Search Criteria:**

Flow: 6111 US gpm

Head: 93 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---

Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC

Size: 250 hp  
 Speed: 900  
 Frame: 449T

Sizing criteria: Max Power on Design Curve

**Pump Limits:**

Temperature: 150 °F  
 Pressure: ---  
 Sphere size: 6 in


Power: ---  
 Eye area: ---

--- Data Point ---  
 Flow: 6111 US gpm  
 Head: 93.5 ft  
 Eff: 80%  
 Power: 181 hp  
 NPSHr: 10.9 ft

--- Design Curve ---  
 Shutoff head: 138 ft  
 Shutoff dP: 59.8 psi  
 Min flow: ---  
 ∴ 80% @ 6555 US gpm

NOL power:  
 212 hp @ 9911 US gpm

--- Max Curve ---  
 Max power:  
 264 hp @ 10870 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
7333	875	82	79	192	14.6
6111	875	93.5	80	181	10.9
4889	875	103	76	168	8.46
3667	875	110	67	152	6.55
2444	875	117	54	134	4.69



Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 11/28/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pump:**

Model: 12624-6  
 Type: 6000  
 Synch speed: 900 rpm  
 Curve ID No.: 40169  
 Specific Speeds:  
 Dimensions:  
 Speed: 875 rpm  
 Dia: 23.125 in  
 Impeller ID No.: Y-5090  
 Ns: 2192  
 Nss: 11150  
 Suction: 12 in  
 Discharge: 12 in

**Search Criteria:**

Flow: 6111 US gpm  
 Head: 92.5 ft  
 Fluid:  
 Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Pump Limits:**

Temperature: 150 °F  
 Pressure: ---  
 Sphere size: 6 in  
 Power: ---  
 Eye area: ---


**Motor:**

Standard: NEMA  
 Enclosure: TEFC  
 Sizing criteria: Max Power on Design Curve  
 Size: 250 hp  
 Speed: 900  
 Frame: 449T

--- Data Point ---  
 Flow: 6111 US gpm  
 Head: 93.5 ft  
 Eff: 80%  
 Power: 181 hp  
 NPSHr: 10.9 ft

--- Design Curve ---  
 Shutoff head: 138 ft  
 Shutoff dP: 59.8 psi  
 Min flow: ---  
 : 80% @ 6555 US gpm  
 NOL power:  
 212 hp @ 9911 US gpm

--- Max Curve ---  
 Max power:  
 264 hp @ 10870 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
7333	875	82	79	192	14.6
6111	875	93.5	80	181	10.9
4889	875	103	76	168	8.46
3667	875	110	67	152	6.55
2444	875	117	54	134	4.69

Company: KLH Engineers, Inc.  
 Name: Kevin Hoffman  
 Date: 11/28/2007

Customer:  
 Project:  
 Location:  
 Quote #:  
 Item ID / Tag #:  
 Qty. of Pumps:



**Pumps:**

Model: 12624-6  
 Type: 6000  
 Synch speed: 900 rpm  
 Curve ID No.: 40169  
 Specific Speeds:  
 Dimensions:

Speed: 875 rpm  
 Dia: 23.125 in  
 Impeller ID No.: Y-5090  
 Ns: 2192  
 Nss: 11150  
 Suction: 12 in  
 Discharge: 12 in

**Search Criteria:**

Flow: 6111 US gpm

Head: 92.5 ft

**Fluid:**

Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: ---

Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a

**Motor:**

Standard: NEMA  
 Enclosure: TEFC

Size: 250 hp  
 Speed: 900  
 Frame: 449T

Sizing criteria: Max Power on Design Curve

**Pump Limits:**


Temperature: 150 °F  
 Pressure: ---  
 Sphere size: 6 in

Power: ---  
 Eye area: ---

**--- Data Point ---**  
 Flow: 6111 US gpm  
 Head: 93.5 ft  
 Eff: 80%  
 Power: 181 hp  
 NPSHr: 10.9 ft

**--- Design Curve ---**  
 Shutoff head: 138 ft  
 Shutoff dP: 59.8 psi  
 100% flow: ---  
 80% @ 6555 US gpm  
 NOL power: 212 hp @ 9911 US gpm

**-- Max Curve --**  
 Max power: 264 hp @ 10870 US gpm




**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Efficiency %	Power hp	NPSHr ft
7333	875	82	79	192	14.6
6111	875	93.5	80	181	10.9
4889	875	103	76	168	8.46
3667	875	110	67	152	6.55
2444	875	117	54	134	4.69




**SERIES 6250**  
**VERTICAL LINE-SHAFT**  
**SOLIDS-HANDLING PUMPS**




RELATIVE POSITION OF  
 SUCTION AND DISCHARGE  
 (AS VIEWED FROM THE MOTOR END)

LEFT HAND ROTATION



RIGHT HAND ROTATION



NOTE: DISCHARGE IN POSITION NO.1  
 FURNISHED AS STANDARD.  
 OTHER POSITIONS AVAILABLE  
 FROM FACTORY WHEN SPECIFIED.


OUTLINE DWG # 102900

S.O.  
 JOB:

ISSUE	REVISION	DATE

LIST OF EQUIPMENT FURNISHED:  
 Model \_\_\_\_\_ Pump  
 Rated for \_\_\_\_\_ GPM at \_\_\_\_\_ Ft.TDH.  
 \_\_\_\_\_ HP, \_\_\_\_\_ RPM, \_\_\_\_\_ Volts  
 \_\_\_\_\_ Phase, \_\_\_\_\_ Hz Vertical C-Face  
 Motor in \_\_\_\_\_ NEMA  
 enclosure complete with pedestal  
 ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_  
 ROTATION \_\_\_\_\_ POSITION # \_\_\_\_\_

- OPTIONAL ACCESSORIES:
- Anchor Bolts
  - Mechanical Seal
  - Bronze or S.S. Impeller
  - Bronze or S.S. Wear Rings
  - 416 S.S. Pump Shaft
  - Safety Guard



NOTES: 1. ALL DIMENSIONS ARE IN INCHES.  
 2. WEIGHT IS IN POUNDS.

TABLE OF DIMENSIONS

✓	PUMP MODEL	DIS	SUC	A	E	G	K	X	Z	CP	U	KEY	V	VD	VS	VY	WEIGHT
	4317-4A/4BHT	4	8	30	13 1/2	5/8		13	10 3/4	61 1/2				27	13 1/2	14	1175
	6315-4A/4BHT	6	6	24	10 1/2	1/2		16	11	60				26	16 1/2	14	1160
	6317-4A/4BHT	6	8	30	13 3/4	5/8		17	11 1/4	62 1/2			28 3/8	17 1/2	15	1325	
	8317-4A/4BHT	8	8	30	13 3/4	5/8	1/2	17	11 3/4	62 1/2	2 3/8	5/8 x 3/8 x 3	4 1/2	28 3/8	18 1/2	16	1325
	8417-4A	8	8	30	13 3/4	5/8		18	13	63 1/8				28 3/4	18	15	1520
	8515-4A	8	8	30	13 1/2	5/8		16 1/2	11 3/8	63 1/8				28 3/4	18	15	1420
	8515-4A	8	10	30	13 1/2	5/8		18	13	63 1/8				28 3/4	18	15	1520
	8518-4A/4B	8	8	30	13 1/4	5/8		18	13	63 1/8				28 3/4	18	15	1520
	8518-4A/4B	8	10	30	13 1/4	5/8		18	13	63 1/8				28 3/4	18	15	1520
	10522-4B	10	10	38	16 1/2	1		22	17	75 3/4				39 1/2	21 1/2	18	3500
	10522-4B	10	12	38	16 1/2	1		22	17	75 3/4				39 1/2	22 1/2	20	3590
	10522-5/6	10	10	38	16 1/2	1		22	17	84	2 1/2	3/4 x 3/8 x 5	6 1/2	39 1/2	21 1/2	18	3590
	10522-5/6	10	12	38	16 1/2	1		22	17	84	2 1/2	3/4 x 3/8 x 5	6 1/2	39 1/2	22 1/2	20	3590
	12515-4A	12	12	38	16 1/2	1		15 1/2	12	69				33 3/4	22	20	1760
	12622-4B	12	12	38	16 1/2	1		24	18	76 1/2	2 3/8	5/8 x 3/8 x 3	4 1/2	40 1/8	25 1/8	22	4500
	12622-4B	12	14	38	16 1/2	1		24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4600
	12622-5/6	12	12	38	16 1/2	1		24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4600
	12622-5/6	12	14	38	16 1/2	1		24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4600
	12624-4B	12	12	38	16 1/2	1	3/4	24	18	76 1/2	2 3/8	5/8 x 3/8 x 3	4 1/2	40 1/8	25 1/8	22	4520
	12624-4B	12	14	38	16 1/2	1	3/4	24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4620
	12624-5/6	12	12	38	16 1/2	1	3/4	24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4620
	12624-5/6	12	14	38	16 1/2	1	3/4	24	18	84 3/4	2 1/2	3/4 x 3/8 x 5	6 1/2	40 1/8	25 1/8	22	4620
	14518-4B/4BHT	14	14	38	16 1/2	1		20	18	74	2 3/8	5/8 x 3/8 x 3	4 1/2	38 1/2	24 3/8	22	4600
	14518-4B/4BHT	14	16	38	16 1/2	1		20	18	74	2 3/8	5/8 x 3/8 x 3	4 1/2	38 1/2	25 1/8	15	4600
	14620-4B	14	14	38	16 1/2	1		20	18	77 1/2	2 1/2	3/4 x 3/8 x 3	4 1/2	41 1/2	26 1/8	22	4800
	14620-5	14	14	38	16 1/2	1		20	18	86 1/2	2 1/2	3/4 x 3/8 x 5	6 1/2	41 1/2	26 1/8	22	4800
	16620-4B	16	14	38	16 1/2	1		22	18	77 1/2	2 1/2	3/4 x 3/8 x 3	4 1/2	41 1/2	26 1/8	22	4820
	16620-5	16	14	38	16 1/2	1		22	18	86 1/2	2 1/2	3/4 x 3/8 x 3	4 1/2	41 1/2	26 1/8	22	4820
	16622-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4900
	16624-5B/6B	16	18	43 1/2	20	1		22	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4930
	18530-6B/6BHT	18	20	48	20	1 1/2		27	22	98 1/2	2 1/2	3/4 x 3/8 x 5		6 1/2	53 1/2	36 1/2	5600
	18624-5B/6B	18	20	43 1/2	20	1		27	19 1/2	97 1/2	2 1/2			6 1/2	52 1/2	32 1/2	4950
	18622-5B	18	18	43 1/2	20	1	1	22	19 1/2	100 1/2	2 1/2			6 1/2	54 1/2	33 1/2	4920
	20724-6B	20	20	43 1/2	20	1		22	24	98	2 1/2			6 1/2	52 1/2	42 1/2	5700



# PERFORMANCE CURVE

PRODUCT  
**NT 3356 /735**

TYPE

DATE  
**2008-03-05**



PROJECT

CURVE NO  
**63-670**

ISSUE  
**2**

	1/1-LOAD	3/4-LOAD	1/2-LOAD		
POWER FACTOR	0.83	0.79	0.69	RATED POWER .....	215 hp
EFFICIENCY	93.5 %	93.5 %	93.0 %	STARTING CURRENT ...	1555 A
MOTOR DATA	---	---	---	RATED CURRENT ...	260 A
COMMENTS	INLET/OUTLET			RATED SPEED .....	1185 rpm
	14/ 14 inch			TOT.MOM.OF INERTIA ...	3.3 kgm2
	IMP. THROUGHLET			NO. OF BLADES	3
	---				

IMPELLER DIAMETER <b>445 mm</b>			
MOTOR #	STATOR	REV	
<b>43-44-6BC</b>	<b>01D</b>	<b>13</b>	
FREQ.	PHASES	VOLTAGE	POLES
<b>60 Hz</b>	<b>3</b>	<b>460 V</b>	<b>6</b>
GEARTYPE		RATIO	
---		---	



FLYPS3.1.5.8 (20060531)

NPSH<sub>re</sub> = NPSH<sub>3%</sub> + min. operational margin  
Performance with clear water and ambient temp 40 C



**HI B Curve**



Box 478 ♦ 1799 Plank Rd. ♦ Carrolltown, PA 15722-0478  
Telephone 814/344-6591 ♦ Fax 814/344-8020

November 16, 2007

KLH Engineering, Inc.  
5173 Campbell Run Road  
Pittsburgh, PA 15205  
Phone# 412-494-0510  
Fax# 412-494-0426  
Attn: Mr. Kevin Hoffman

**Page 1 of 1**

Proposal No.: MP1107-1947JF

We are pleased to quote the following equipment MACM Project:

**Item 1: *Raw Sewage Pumps - Duty Point Each Pump: 6,945 GPM @ 105' TDH***

- Six (6) Flygt Submersible Dry Pit Wastewater Pumps, Model CT3312/765, 670 Impeller Code with 475 mm impeller, 3-60-460 Volt, 280 HP Motor. Includes 12" discharge, 40' of power cable, FLS, and prepared for MAS unit. Package complete with 14" X 16" suction elbow and stand. Price includes start up.

**Total Price for Pumps: \$495,360.00**

**\*Explosion Proof Adder per pump would be \$4,532.00 each.**

Terms: Subject to credit approval  
F.O.B. Shipping Point  
Freight: Prepaid and Allowed  
Delivery: 16-18 Weeks after approved submittals  
Pricing: Firm for acceptance within thirty days from date of quotation.

Should you require any additional information, or if we may be of further assistance please do not hesitate to contact us.

Sincerely,

Joseph M. Felix, Inside Sales  
Mike Presutti, Sales Manager Cell # 412-841-9324  
**Ram Industrial Services, Inc.**



# PERFORMANCE CURVE

PRODUCT  
NT 3312 /765

TYPE


DATE  
2007-11-16

PROJECT  
MACM - Raw Sewage Pumps


CURVE NO  
63-670

ISSUE  
2

POWER FACTOR	1/1-LOAD 0.80	3/4-LOAD 0.75	1/2-LOAD 0.63	RATED POWER .....	280	hp
EFFICIENCY	94.0 %	94.0 %	93.0 %	STARTING CURRENT ...	2230	A
MOTOR DATA	---	---	---	RATED CURRENT ...	345	A
COMMENTS	INLET/OUTLET		RATED SPEED .....	1185	rpm	IMPELLER DIAMETER
	14/ 12 inch		TOT.MOM.OF	4.5	kgm2	490 mm
	IMP. THROUGHLET		INERTIA ...	---	---	MOTOR #
	---		NO. OF	3	---	43-56-6BC
			BLADES	3		STATOR
						01D
						REV
						13
						FREQ.
						60 Hz
						PHASES
						3
						VOLTAGE
						460 V
						POLES
						6
						GEARTYPE
						---
						RATIO
						---



DUTY-POINT	FLOW[USgpm]	HEAD[ft]	POWER [hp]	EFF. [%]	NPSHre[ft]
B.E.P.	6470	123	263 (247)	77.1 (81.9)	20.2



FLYPS3.1.5.9 (20060531)

NPSHre = NPSH3% + min. operational margin  
Performance with clear water and ambient temp 40 °C



## HI B Curve




# VFD-Analysis - Performance



Project: MACM - Raw Sewage Pumps

Created by:: JOE



Pump: N 3312 63-670

**PRODUCT DATA**

Imp. diam.: 475 mm

Rtd. pwr.: 280 hp

Vanes: 3

Throughlet: 0 inch

Connection: Single

VFD connection: 1-VFD pump

No of pumps: 1

Frequency: 60 Hz

Flow: 7038.7 USgpm

Head: 105.5 ft

Pwr cons.: 188.5 kW

Overall eff: 74.4 %

Spec. energy: 445.4 kWh/Mg

Flygt






# VFD-Analysis - Performance



Project: MACM - Raw Sewage Pumps

Created by:: JOE



Pump: N 3312 63-670

**PRODUCT DATA**

Imp. diam.: 475 mm

Rtd. pwr.: 280 hp

Vanes: 3

Throughlet: 0 inch

Connection: Single

VFD connection: 1-VFD pump

No of pumps: 1

Frequency: 49 Hz

Flow: 5001.0 USgpm

Head: 77.5 ft

Pwr cons.: 105.0 kW

Overall eff: 69.7 %

Spec. energy: 349.3 kWh/Mg

Flygt








# VFD-Analysis - Performance



Project: MACM - Raw Sewage Pumps

Created by:: JOE



Pump: N 3312 63-670

**PRODUCT DATA**

Imp. diam.: 475 mm

Rtd. pwr.: 280 hp

Vanes: 3

Throughlet: 0 Inch

Connection: Single

VFD connection: 1-VFD pump

No of pumps: 1

Frequency: 39 Hz

Flow: 2748.5 USgpm

Head: 57.6 ft

Pwr cons.: 50.6 kW

Overall eff: 59.0 %





Spec. energy: 306.3 kWh/Mg

Flygt



NOTE:  
 PUMP CAN BE ROTATED ABOUT ITS CENTERLINE  
 TO 16 POSITIONS RELATIVE TO THE INLET ELBOW.  
 INCREMENTS ARE 22.5°.

\*DIMENSION TO INLET ELBOW FLANGE.



Weight (lbs)		
Pump	Stand	Inlet Elbow
4410	335	445
Drawn by KA	Checked by	Date 050630
Scale 1:40		Reg no 5399
6444500		2

Autocad Drawing  
 Denomination  
 Dimensional drwg  
 CT,NT 3312 765/775  
 Ø16" / Ø12"





**PRODUCT: NT 3312 / 765**

Product picture

Curves  Enlarge

Available Impeller diam: 475 mm



Performance  NPSHr  Shaft Power

**Pump Data**

Curve id: 63-670 Impeller: 670 Poles: 6 - pole Motor: 43-56-6BC Frequency: 60 Hz

**Motor Data**

Rated output power Hp (kW)	Ø	Nominal voltage (V)	Full load current (A)	Locked rotor current (A)	Locked rotor kVA	Locked rotor code letter kVA/HP	Poles/rpm
280 (209)	3	460	345	2230	1775	H	6/1185
Pump motor Hp	Efficiency			Power factor			
	100% load	75% load	50% load	100% load	75% load	50% load	
	280	94	94	93	0.8	0.75	0.63

**Cable Data**

HP	Cables	Volts	Max. length (Ft)	Cable size/Nominal OD.	Conductors (In one cable)	Type	Part number
280	2	460	420	4 G 70 1.85"-(47mm)	(3) 70 mm <sup>2</sup> (PWR) (1) 70 mm <sup>2</sup> (GND)	STD	942067
	Pilot cable			S12 X 1.5 30.0 mm (1.18")	(12) 1.5 (CTRL)		94 08 94

**Available Outlet and Inlet Sizes**

Outlet Drilled Flange	12"
Inlet Drilled Flange	16"

*Engineered for life*



# PERFORMANCE CURVE

PRODUCT  
**NT 3312 /765**

TYPE

DATE  
**2007-11-16**

PROJECT  
**MACM - Raw Sewage Pumps**

CURVE NO  
**63-670**



ISSUE  
**2**

	1/1-LOAD	3/4-LOAD	1/2-LOAD
POWER FACTOR	0.80	0.75	0.63
EFFICIENCY	94.0 %	94.0 %	93.0 %
MOTOR DATA	---	---	---

RATED POWER .....	280	hp
STARTING CURRENT ...	2230	A
RATED CURRENT ...	345	A
RATED SPEED .....	1185	rpm
TOT.MOM.OF INERTIA ...	4.5	kgm2
NO. OF BLADES	3	

IMPELLER DIAMETER <b>475 mm</b>		
MOTOR #	STATOR	REV
<b>43-56-6BC</b>	<b>01D</b>	<b>13</b>
FREQ.	PHASES	VOLTAGE
<b>60 Hz</b>	<b>3</b>	<b>460 V</b>
GEARTYPE		RATIO
---		---

COMMENTS	INLET/OUTLET
	14/ 12 inch
	IMP. THROUGHLET
	---



FLYPS3.1.5.9 (20060531)

NPSHre = NPSH3% + min. operational margin  
Performance with clear water and ambient temp 40 °C



## HI B Curve


**KLH**  
**ENGINEERS, INC.**

5173 CAMPBELLS RUN ROAD  
 PITTSBURGH, PA 15205

SUBJECT MACM JOB No. 220-33

SALTER BOX SHEET No. 1 OF 1

COMPUTED BY KDH DATE 1-15-08



**SBR Design Sheet (up to 4 Basins)**

**REQUIRED DATA (Enter requested information in shaded cell.)**

Client (Job No.)	MACM	
Design Period	20	Years
Low Ave Day	4	MGD
Ave Day Flow (Q):	6	MGD
Intermediate Wet Weather Q	12	MGD
Peak Day Flow (Q):	24.00	MGD
Influent Parameters:	mg/L	#/D
BOD	115	3836.4
TSS (mg/L)	102	3402.7
NH3-N (mg/L)	25	1251.0
Effluent BOD Soluble	15	mg/L
Effluent TSS	15	mg/L
Effluent NH3-N	1	mg/L
No. SBR Tanks	4	Tanks
Normal Total Cycle Time	4.8	hours
Normal Q Cycles per Tank	5	Cycles
Normal Decant time	72	minutes
Storm Total Cycle Time	3.6	hours
Storm Q Cycles per Tank	6.666666667	Cycles
Storm Decant time	54	minutes
Storm Total Cycle Time	2	hours
Storm Q Cycles per Tank	12	Cycles
Extreme Storm Decant time	60	minutes
<b><u>Physical/Biological Wastewater Characteristics (Assuming balanced recycle loads)</u></b>		
F:M Ratio	0.035	
Desired MLSS (mg/L)	4843	mg/L
VSS fraction of TSS	75%	
Non-Deg fraction of VSS	25%	
Water Temperature deg. F; deg. C	50	10
f(d)	0.46	
k(d) (active cell basis)	0.12	
N(s), Sludge Nitrogen Content	0.09	
Y, Yield Constant	0.6	/d
Desired SVI	150	ml/g
Desired SVI	2.4	ft <sup>3</sup> /lb.

*Formula or Reasoning*

Entered Design Period  
 Entered Flow  
 Entered Flow  
 Entered Flow  
 Calculated Peak = Ave Day Q \* Peak Factor  
 Entered Concetration; Calculated Mass = C(mg/L)\*Q(MGD)\*8.34  
 Entered Concetration; Calculated Mass = C(mg/L)\*Q(MGD)\*8.34  
 Entered Concetration; Calculated Mass = C(mg/L)\*Q(MGD)\*8.34  
 Entered Concetration  
 Entered Concetration  
 Entered Concetration  
 Entered Number of Tanks  
 Entered Time  
 24 hours per day / Entered cycle time  
 Entered Decant Time  
 Entered Time  
 Entered Number of Cycles  
 Entered Decant Time  
 Entered Time  
 Entered Number of Cycles  
 Entered Decant Time  
 Changed value consistent with ABJ NDN Design  
 Changed value consistent with ABJ NDN Design  
 Assumed Default Value  
 Assumed Default Value  
 Entered Temperature in deg. F; Conversion from deg. F to Deg. C  
 Assumed Default Value from published kinetic factors  
 Assumed Default Value from published kinetic factors  
 Assumed Default Value from published kinetic factors  
 Assumed Default Value from published kinetic factors  
 Assumed Default Value  
 Conversion of units

REPRESENTS CONFIRMATION  
 OF ABJNDN DESIGN  
 FROM T. KUNZ - 11-7-07

**LOW WATER LEVEL CALCULATION**

BOD Loading per Basin	959.1	#/D
Required MLVSS for BOD Removal	27,402.9	#/D
Required MLSS for BOD Removal	36,537.14	#/D
Nitrogen Loading	232.69	#/D
Minimum Required MLSS for Nitrification	25,854.00	#/D
Governing Required MLSS	36,537.14	#/D
Minimum Required MLSS	2,920.63	mg/L
SBR Sludge Volume	65,766.9	ft <sup>3</sup> /basin
SBR Sludge Volume	491,970.26	gal / basin

**DECANT CALCULATIONS**

Normal SBR Conditions

High Water Volume Normal Conditions	30,080.21	ft <sup>3</sup>
Storm Decant Rate per Tank	4,513.89	GPM
<b>Storm Decant Rate per Tank</b>	<b>6.50</b>	<b>MGD</b>

Storm SBR Conditions

High Water Volume Storm Conditions Per Tank	45,120.32	ft <sup>3</sup>
Storm Decant Rate per Tank	8,333.33	GPM
<b>Storm Decant Rate per Tank</b>	<b>12.00</b>	<b>MGD</b>

Extreme Storm SBR Conditions

Extreme Storm Decant Volume per Tank	33,422.46	ft <sup>3</sup>
Extreme Storm Decant Volume per Tank	8,333.33	GPM
<b>Extreme Storm Decant Rate per Tank</b>	<b>12.00</b>	<b>MGD</b>

Total Decanter Length	45	ft
Decanters per Basin	2	
Decanter Length (each)	22.5	

**BASIN SIZING**

Basin Working Volume	99,189.32	ft <sup>3</sup>
Top Water Level	15	ft
LWL Buffer Zone	3	ft
Basin Area	8265.78	ft <sup>2</sup>
Sludge Depth	7.96	ft
Low Water Level	10.96	ft
Decant Depth	4.04	ft
High Water Level Check	Continued with Design	
Length:Width Ratio (to 1)	1.5	
<b>Basin Width</b>	<b>73.0</b>	<b>ft</b>
<b>Basin Length</b>	<b>111.00</b>	<b>ft</b>
Maximum Average Flow Depth	13.38	ft
Hydraulic Retention Time	0.83	days
Hydraulic Retention Time	19.86	hrs
MLVSS at Low Water Level	4,847.5	mg/L
MLSS at Low Water Level	6,463.3	mg/L
MLVSS at High Water Level	3,540.8	mg/L
MLSS at High Water Level	4,721.0	mg/L

*Formula or Reasoning*

Calculated Mass = C(mg/L)\*Q(MGD)\*8.34  
 BOD Loading / F:M Ratio  
 Required MLVSS / Percent Volatile  
 Nit(in) -Nit(out) - [(BOD(in)-BOD(out)\*Y\*N(s)\*Q (mgd) \* 8.34  
 Nitrogen Loading \* 1e3 /Nitrification Rate \* Aeration Time \* VSS fraction of TSS  
 Internal Program Check for Recommended Values  
 Conversion from #/D to mg/L (divide by Q(MGD)\*8.34)  
 Governing Required MLSS \*SVI  
 Conversion to gallons fom ft<sup>3</sup> (multiply ft<sup>3</sup> by 7.48)

*Formula or Reasoning*

Ave Day Flow per Basin \* [(hr/cycle)-Decant time(hr)] / [24 \* 7.48]  
 [High Water Volume Normal Conditions \* 7.48 / Decant Time] + [Wet Weather Flow per Basin / 1440]  
 Conversion from GPM to MGD

Peak Day Flow per Basin \* [(hr/cycle)-Decant time(hr)] / [24 \* 7.48]  
 [High Water Volume Storm Conditions \* 7.48 / Decant Time] + [Peak Day Flow per Basin / 1440]  
 Conversion from GPM to MGD

Peak Day Flow / (Number Tanks \* Extreme Storm Cycles per Tank)  
 Conversion from gallons to ft<sup>3</sup> (divide gallons by 7.48)  
 Extreme Storm Decant Volume / Extreme Decant Time

Conditional Value Based Upon Calculated Decanter Length  
 Total Decanter Length / Decanters per Basin

*Formula or Reasoning*

High Water Volume Storm Conditions + SBR Sludge Volume  
 Assumed Value / Program Default  
 Assumed Value / Program Default  
 Basin Working Volume / (Top Water Level - Buffer Zone)  
 SBR Low Water Level Vol. / Basin Area  
 Sludge Depth + LWL Buffer Zone  
 High Water Volume Storm Conditions  
 Internal Program Check  
 Assumed Value  
 [Basin Area / L:W Ratio]^(0.5)  
 Length:Width Ratio (to 1) \* Width  
 Low Water Level Depth + [Flow per Basin \* (Cycle Time (min) - Decant Time)] / Basin Area \* 7.48 \* 1440  
 Basin Area \* Maximum Average Flow Depth \* 7.48 / Flow per Basin  
 Hydraulic Retention Time in days \* 24 hr/D  
 Required MLVSS for BOD Removal / (Basin Area \* Low Water Level Depth \* 62.4/1e6)  
 Required MLVSS for BOD Removal / (Basin Area \* High Water Level Depth \* 62.4/1e6)  
 Required MLSS for BOD Removal / (Basin Area \* Low Water Level Depth \* 62.4/1e6)  
 Required MLSS for BOD Removal / (Basin Area \* High Water Level Depth \* 62.4/1e6)

**ACTIVATED SLUDGE BIOLOGICAL CALCULATIONS**

*Waste Sludge Calculation (All values are in #/D unless otherwise noted)*

	Volatile SS	Inert SS	Total SS
Influent Suspended Solids, lb/day	3402.7		
Inert Fraction	25%	851	
Non-Degradable VSS Fraction	25%	638	
Synthesized Cells			
BOD Reduction	2001.60		
MLVSS Reduction	1,512.64		
Degradable Synthesized Cell Fraction	77%		
Non-Degrad. Synthesized Cell Fraction	23%		
Degradable Synthesized Cells		29	
Non-Degradable Synthesized Cells	460.37		
Non-Degradable Organic Cell Fraction	75%		
Non-Degradable Inorganic Cell Fraction	25%		
Non-Degradable Organic Cells		345	
Non-Degradable Inorganic Cells		115	
<b>Total Waste Sludge in #/D</b>	<b>1012</b>	<b>966</b>	<b>1978</b>
Percentage of Total Sludge	51%	49%	
Effluent Loss in #/D	384	367	751
<b>Waste Activated Sludge Production</b>	<b>628</b>	<b>599</b>	<b>1227</b>

Solids Retention Time	55.43 days
Sludge Wasted per # BOD	1.28
Is Sludge Wasted per # BOD > 0.5 ?	Yes. Continue with Design
Waste Sludge Concentration	<u>8,000 mg/L</u>
Sludge Flow from SBR	18,391.1 gpd
Sludge Flow per Tank	3.19 gpm

Will Nit/Denit occur naturally?	Possible
Assuming Provisions for Complete Nitrification, Minimum Alkalinity Req'd.	278.5 mg/L as CaCO3
Potential Denit. Alkalinity Recovery	89.25 mg/L as CaCO3
Chemical Addition with Denit	189.25 mg/L as CaCO3
CaCO3 in 50% NaOH Solution	8.20 # CaCO3 / gal NaOH
Maximum Chemical Addition Dosage	1699.53 gpd 50% NaOH
Maximum Chemical Addition Dosage	1.18 gpm 50% NaOH
Reduced Chemical Addition Dosage	1154.89 gpd 50% NaOH
Reduced Chemical Addition Dosage	0.80 gpm 50% NaOH

*Formula or Reasoning*

Influent Solids \* Inert Fraction  
 Influent Solids \* VSS Fraction \* Non-Degradable VSS Fraction  
 Yield Coeff. \* Influent BOD Mass \* Eff. BOD Mass  
 Decay fraction \* Decay Coeff. \* MLVSS Mass  
 Assumed Default Value  
 Assumed Default Value  
 [BOD Reduction \* Degradable Fraction] - MLVSS Reduction  
 BOD Reduction \* Non-Degradable Fraction  
 Assumed Default Value  
 Assumed Default Value  
 Non-Degradable Synthesized Cells \* Non-Degradable Organic Cell Fraction  
 Non-Degradable Synthesized Cells \* Non-Degradable inorganic Cell Fraction  
 Sum of SS Category  
 SS Category / Total SS  
 Calculated Effluent Mass = C(mg/L)\*Q(MGD)\*8.34 8 Percentage of Total Sludge  
 Total Waste Sludge in #/D - Effluent Loss in #/D

Minimum Required MLSS / Waste Activated Sludge Production  
 Waste Activated Sludge Production / Influent BOD Mass  
 Internal Program Check for Recommended Values  
 Assumed Default Value  
 Waste Activated Sludge Production / Waste Sludge Concentration \* 8.34 \* 1e6  
 Sludge Flow / Number of Tanks \* 1440 min/d

If the Solids Retention Time > 15, then natural Nitrification is Possible  
 60 mg/L CaCO3 + (7.14 \* NH-N3 Concentration)  
 50% \* (7.14 \* NH-N3 Concentration)  
 Nitrification, Minimum Alkalinity Req'd. - Potential Denit. Alkalinity Recovery  
 Chemical Property Default Value  
 [Nitrification, Minimum Alkalinity Req'd. \* 8.34 \* Ave Day Q] / CaCO3 in 50% NaOH Solution  
 Conversion from gpd to gpm (by dividing by 1440)  
 [Chemical Addition with Denit. \* 8.34 \* Ave Day Q] / CaCO3 in 50% NaOH Solution  
 Conversion from gpd to gpm (by dividing by 1440)



**PROCESS AIR CALCULATIONS**

#O2/#BOD	1.1
#O2/#NH4-N	4.6
AOR	9,974.64 #O2/day
Bubble Diffuser Type (Fine or Coarse)	Fine
AOR/SOR	0.33
Assumed OTE	2% / ft
SOR	20.99 #O2/min
Diffusers to Floor Distance	1 ft
Submergence	14.0 ft
OTE	0.28
Theoretical 1-SCFM	0.0173 #O2/min
Calculated 1-SCFM	0.0048 #O2/min
SCFM Required	4,333.78 scfm
Water Depth Pressure	6.07 psig
Piping Loss	0.75 psig
Total Pressure Required	6.82 psig
Blower Efficiency	70%
Required BHP	162.11 BHP
Specified Total BHP	170 BHP
Number of Operating Blowers	3
HP Each	60 BHP

Assumed Default Value  
 Assumed Default Value  
 (#O2/#BOD \* #/D BOD) + (#O2/#NH4-N \* #/D NH4-N)  
 Entered Diffuser Type  
 Conditional Default for Diffuser Type  
 Conditional Default for Diffuser Type  
 AOR / (AOR/SOR) \* 1440  
 Entered Distance  
 High Water Level Depth - Diffuser to Floor Distance  
 Submergence \* Assumed OTE  
 Assumed Default Value  
 OTE \* Theoretical 1-SCFM  
 [SOR / Calculated 1-SCFM] + 0.5 scfm  
 Submergence / Specific Gravity of Water  
 Entered Piping Loss  
 Water Depth Pressure + Piping Loss  
 Assumed Default Value  
 [(SCFM Required \* 0.23) \* ((14.7 + Total Pressure)/14.7)^(0.283-1)] / Blower Efficiency  
 Rounded Value  
 Entered Number of Operating Blowers  
 Specified Total BHP per Number of Operating Blowers

**DESIGN CALCULATIONS**  
 BOD Removal Nitrification and De-Nitrification Process

McKeesport, PA  
 Sanitaire Project Number 17501-05a

**Design Parameters**

**A. Influent Conditions**

Average Dry Weather Flow	4.0 MGD
Peak Dry Weather Flow	6.0 MGD
Peak Wet Weather Flow	24.0 MGD
BOD <sub>5</sub> (20°C)	115 mg/l
Suspended Solids	102 mg/l
TKN	38 mg/l
Phosphorus	5 mg/l
Alkalinity (Minimum Requirement)	185 mg/l
Waste Water Temperature	50 - 68 °F
Ambient Air Temperature	20 - 90 °F
Site Elevation	750 ft

**B. Effluent Conditions**

BOD <sub>5</sub> (20°C)	15 mg/l
Suspended Solids	15 mg/l
NH <sub>3</sub> -N	1 mg/l
Total Nitrogen	5 mg/l
Total Phosphorous	1 mg/l

**C. ICEAS™ Process Design Criteria**

F / M	0.035 BOD <sub>5</sub> / MLSS / day
SVI (after 30 minutes settling)	150 ml/g
Number of ICEAS Basins	4
Top Water Level	15 ft

CYCLE	AIR-OFF	AIR-ON	SETTLE	DECANT	TOTAL
Normal	48 min	120 min	48 min	72 min	4.8 hour
Intermediate	36 min	90 min	36 min	54 min	3.6 hour
Storm	0 min	30 min	30 min	60 min	2 hour

**BOD Load**

$$BOD_L = \frac{Q \times BOD_{in} \times 8.34}{1E+06}$$

where  $BOD_L$  = BOD Load (lb/day)  
 $Q$  = Average Dry Weather Flow per basin (gal/day)  
 $BOD_{in}$  = Influent BOD concentration (mg/l)  
 $1.E+06$  = conversion (l/mg)  
 $8.34$  = conversion (lb/gal)

$$BOD_L = \frac{1,000,000 \times 115 \times 8.34}{1E+06}$$

$BOD_L = 959 \text{ lb/day/basin}$
------------------------------------

**Mass of Biomass for BOD Removal**

$$M_{bod} = \frac{BOD_L}{F/M}$$

where  $M_{bod}$  = Mass of Biomass for BOD Removal (lb/day/basin)  
 $F/M$  = Food to Microorganism ratio ( $\text{day}^{-1}$ )

$$M_{bod} = \frac{959}{0.035}$$

$M_{bod} = 27,403 \text{ lb/basin}$
-------------------------------------

**Nitrogen Load**

$$\Delta N = \frac{[(NH_{3in} - NH_{3out}) - ((BOD_{in} - BOD_{out}) \times Y \times N_s)] \times Q \times 8.34}{1E+06}$$

where  $\Delta N$  = Net Nitrogen Load (lb/day/basin)  
 $NH_{3in}$  = Influent Ammonia Concentration (mg/l)  
 $NH_{3out}$  = Effluent Ammonia required (mg/l)  
 $BOD_{out}$  = Effluent BOD required (mg/l)  
 $Y$  = Sludge Yield (MLSS / BOD removed)  
 $N_s$  = Sludge Nitrogen content (N / sludge)

$$\Delta N = \frac{[(38 - 1) - ((115 - 15) \times 0.75 \times 0.07)] \times 1,000,000 \times 8.34}{1E+06}$$

$\Delta N = 264.80 \text{ lb/day/basin}$
--

**Mass of Biomass Required for Nitrification**

$$M_{nit} = \frac{\Delta N \times 10^3}{K \times T_a \times 0.7}$$

where  $M_{nit}$  = Mass of Biomass for Nitrification (lb/day/basin)  
 $10^3$  = conversion (mg/g)  
 $K$  = Nitrification Rate (mg  $NH_3$  -N/g MLVSS/hr)  
 $T_a$  = Time of Aeration (hr/day)  
 $0.7$  = Fraction of MLSS which is volatile

$$M_{nit} = \frac{264.80 \times 10^3}{1.5 \times 10 \times 0.7}$$

$M_{nit} = 25,219 \text{ lb/day/basin}$
---

**Design Mass of Biomass**

The Design Mass of Biomass is the larger of the BOD Removal Mass and the Nitrification Mass:

$$M_{\text{bod}} = 27,403 \text{ lb/day/basin}$$

$$M_{\text{nit}} = 25,219 \text{ lb/day/basin}$$

$M_{\text{bio}} = 27,403 \text{ lb/day/basin}$
--

**Volume of Biomass**

$$V_{\text{bio}} = M_{\text{bio}} \times \text{SVI}$$

where  $V_{\text{bio}}$  = Volume of Biomass (ft<sup>3</sup>/basin)  
 $M_{\text{bio}}$  = Mass of Biomass (lb/day/basin)  
 $\text{SVI}$  = Sludge Volume Index (ft<sup>3</sup>/lb)

$$V_{\text{bio}} = 27,403 \times 2.4$$

$V_{\text{bio}} = 65,767 \text{ ft}^3/\text{basin}$
---

**Maximum Volume Above Bottom Water Level**

**Peak Dry Weather Flow:**

$$V_{bwld} = \frac{PDWF \times (NCT - NDT)}{24 \times 7.48}$$

where  $V_{bwld}$  = Maximum Volume Above BWL at Peak Dry Weather Flow (ft<sup>3</sup>/basin)  
 PDWF = Peak Dry Weather Flow (gal/day)  
 NCT = Normal Cycle Time (hr/cycle)  
 NDT = Decant Time (hr/cycle)  
 7.48 = conversion (gal/ft<sup>3</sup>)

$$V_{bwld} = \frac{1,200,000 \times (4.80 - 1.2)}{24 \times 7.48}$$

$V_{bwld} = 30,080 \text{ ft}^3/\text{basin}$
---

**Peak Wet Weather Flow:**

$$V_{bwls} = \frac{PWWF \times (SCT - SDT)}{24 \times 7.48}$$

where  $V_{bwls}$  = Maximum Volume Above BWL at Peak Wet Weather (Storm) Flow (ft<sup>3</sup>/basin)  
 PWWF = Peak Wet Weather Flow (gal/day)  
 SCT = Storm Cycle Time (hr/cycle)  
 SDT = Storm Decant Time (hr/cycle)  
 7.48 = conversion (gal/ft<sup>3</sup>)

$$V_{bwls} = \frac{6,000,000 \times (2.0 - 1)}{24 \times 7.48}$$

$V_{bwls} = 33,422 \text{ ft}^3/\text{basin}$
---

$MVAB = 33,422 \text{ ft}^3/\text{basin}$
---

---

**Decant Rates**

**Peak Dry Weather Flow:**

$$\text{NDR} = \frac{\text{MVAB} \times 7.48}{\text{NDT}} + \frac{\text{PDWF}}{1,440}$$

where    NDR = Normal Decant Rate (gal/min)  
           NDT = Normal Decant Time (min/cycle)

$$\text{NDR} = \frac{33,422 \times 7.48}{60} + \frac{1,200,000}{1,440}$$

NDR = 4,514 gal/min
---------------------

**Peak Wet Weather Flow:**

$$\text{PDR} = \frac{\text{MVAB} \times 7.48}{\text{SDT}} + \frac{\text{PWWF}}{1,440}$$

where    PDR = Peak Decant Rate (gal/min)  
           SDT = Storm Decant Time (min/cycle)

$$\text{PDR} = \frac{33,422 \times 7.48}{60} + \frac{6,000,000}{1,440}$$

PDR = 8,333 gal/min
---------------------

---

**Decanter Sizing**

**Average Dry Weather Flow:**

$$DL_a = \frac{NDR}{\text{Weir Loading Rate} \times 7.48}$$

where  $DL_a$  = Decanter Length for Average Dry Weather Flow (ft)  
 20 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

$$DL_a = \frac{4,514}{20 \times 7.48}$$

$DL_a = 30.17 \text{ ft}$
---------------------------

**Peak Wet Weather Flow:**

$$DL_p = \frac{PDR}{\text{Weir Loading Rate} \times 7.48}$$

where  $DL_p$  = Decanter Length for Peak Wet Weather (Storm) Flow (ft)  
 25 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

$$DL_p = \frac{8,333}{25 \times 7.48}$$

$DL_p = 44.56 \text{ ft}$
---------------------------

<b>Design Decanter Length = 60.0 ft</b>
---



**Basin Working Volume**

$$BWV = MVAB + V_{bio} + V_c$$

where MVAB = Maximum Volume Above BWL (ft<sup>3</sup>/basin)  
 V<sub>bio</sub> = Volume of Biomass (ft<sup>3</sup>/basin)  
 V<sub>c</sub> = Volume of chemical sludge due to Phosphorus removal (ft<sup>3</sup>/basin [See end of calculation] ).  
 Please refer to phosphorus removal calculation.

$$BWV = 33,422 + 65,767 + 146$$

BWV = 99,335 ft <sup>3</sup>
------------------------------

**Basin Area**

$$BA = \frac{BWV}{TWL - BZ}$$

where BA = Basin Area (ft<sup>2</sup>)  
 TWL = Top Water Level (ft)  
 BZ = Buffer Zone (ft) - Safety Factor

$$BA = \frac{99,335}{15.0 - 3.0}$$

BA = 8,278 ft <sup>2</sup>
----------------------------

**Sludge Depth**

$$SD = \frac{V_{bio}}{BA}$$

where SD = Sludge Depth (ft)

$$SD = \frac{65,767}{8,278}$$

SD = 7.94 ft
--------------

Decanter Draw Down

$$DD = \frac{MVAB}{BA}$$

where DD = Draw Down (ft)  
MVAB = Maximum Volume Above BWL (ft<sup>3</sup>)

$$DD = \frac{33,422}{8,278}$$

DD = 4.04 ft
--------------

Bottom Water Level

$$BWL = SD + BZ + \frac{Vc}{BA}$$

where BWL = Bottom Water Level (ft)

$$BWL = 7.94 + 3.00 + \frac{145.72}{8,278}$$

BWL = 10.96 ft
----------------

Top Water Level

$$TWL = BWL + DD$$

where TWL = Top Water Level (ft)

$$TWL = 10.96 + 4.04$$

TWL = 15.00 ft
----------------

**Hydraulic Retention Time**

$$\text{HRT} = \frac{\text{BA} \times \text{MAFD} \times 7.48}{Q}$$

where HRT = Hydraulic Retention Time (days)  
 BA = Basin Area (ft<sup>2</sup>)  
 MAFD = Maximum Average Flow Depth (ft)

$$\text{MAFD} = \frac{Q \times ((\text{CT} \times 60) - \text{DT})}{\text{BA} \times 60 \times 24 \times 7.48} + \text{BWL}$$

$$\text{MAFD} = \frac{1,000,000 \times ((4.8 \times 60) - 72)}{8,278 \times 60 \times 24 \times 7.48} + 10.96$$

$$\text{MAFD} = 13.38$$

$$\text{HRT} = \frac{8,278 \times 13.38 \times 7.48}{1,000,000}$$

HRT = 0.83 days
-----------------

**MLSS Concentration at Bottom Water Level**

$$\text{MLSS} = \frac{\text{Mbio} \times 1\text{E}+06}{\text{BWL} \times (\text{BA} - \text{CA}) \times 62.42}$$

where MLSS = Mixed Liquor Suspended Solids concentration at Bottom Water Level (mg/l)  
 Mbio = Mass of Biomass (lb/basin)  
 62.42 / 1E+06 = conversion (lb/mg x l/ft<sup>3</sup>)  
 CA = Area Increment due to chemical sludge (ft<sup>2</sup>/basin)

$$\text{MLSS} = \frac{27,403 \times 1\text{E}+06}{10.96 \times (8278 - 9.71) \times 62.42}$$

MLSS = 4,843 mg/l
-------------------

**Mass of Sludge Produced**

$$\Delta M = \frac{Q \times (\text{BOD}_{in} - \text{BOD}_{out}) \times Y_{obs} \times 8.34}{1E+06}$$

where  $\Delta M$  = Mass of Sludge Produced (lb/day/basin)  
 $Y_{obs}$  = Observed Sludge Yield (MLSS / BOD<sub>removed</sub>)

$$\Delta M = \frac{1,000,000 \times (115 - 15) \times 0.75 \times 8.34}{1E+06}$$

$\Delta M = 626 \text{ lb/day/basin}$
---------------------------------------

**Volume of Sludge Produced**

$$V_{ws} = \frac{\Delta M}{SF_{ws} \times 8.34} + \frac{CS_{sludge}}{SF_{ws} \times 8.34}$$

where  $V_{ws}$  = Volume of Waste Sludge (gal/day/basin)  
 $SF_{ws}$  = Solids Fraction in Waste Sludge  
 8.34 = density (lb/gal)  
 $CS_{sludge}$  = Mass of chemical sludge produced (lb/day/basin) Please refer to phosphorus removal calculation.

$$V_{ws} = \frac{626 + 60.72}{0.0085 \times 8.34}$$

$V_{ws} = 9,680 \text{ gal/day/basin}$
--

**Mean Cell Residence Time**

$$MCRT = \frac{M_{bio}}{\Delta M + ((Q - V_{ws}) \times S_{sout} \times 8.34 / 1E+06)}$$

where  $M_{bio}$  = Mass of Biomass (lb/basin)  
 $S_{sout}$  = Suspended Solids in Effluent (mg/l)  
 $8.34E-06$  = conversion (lb/mg x l/gal)

$$MCRT = \frac{27,403}{626 + ((1,000,000 - 9,680) \times 15 \times 8.34 / 1E+06)}$$

MCRT = 36.57 days
-------------------

**Waste Sludge Pump Capacity**

$$WSP = \frac{V_{ws} \times CT}{24 \times SPT}$$

where  $WSP$  = Waste Sludge Pump Capacity(gal/min)  
 $SPT$  = Sludge Pumping Time (min/cycle)

$$WSP = \frac{9,680 \times 4.8}{24 \times 20}$$

WSP = 97 gal/min
------------------

**Biological Phosphorus Removal**

$$TPb = TPi - [ (Y_{obs} \times BODr) \times TPps ]$$

where  
 TPb = Concentration of the Total Phosphorus in the Effluent after biological removal, mg/l  
 TPi = Concentration of the Total Phosphorus in the Influent, mg/l  
 Y<sub>obs</sub> = Observed Yield Factor, (lb of MLSS/lb of BOD Removed)  
 BODr = Biochemical Oxygen Demand Removed, mg/l  
 TPps = Percent of Total Phosphorus in Biomass

$$TPb = 5.0 - [ (0.75 \times 100) \times 0.04 ]$$

TPb = 2.0 mg/l
----------------

**Chemical Dosing**

$$CD = CDt \times (TPb - TETP) \times (1 + SF)$$

where  
 CDt = Theoretical Chemical Dosage (mg/l)  
 SF = Safety Factor for Chemical Dosing (%)  
 TETP = Required Phosphorus concentration in effluent (mg/l)

Alum Dosage Based on percentage removal (PR) of Phosphorus:

PR	CDt
PR < 85	13 mg/l
85 ≤ PR ≤ 95	16 mg/l
PR > 95	22 mg/l

$$PR = \left[ \frac{(TPb - TETP)}{TPe} \right] \times 100$$

$$PR = \left[ \frac{(2.0 - 1.0)}{2.0} \right] \times 100$$

PR = 50%

CDt = 13 mg/l

CD = 13 x (2.0 - 1.0) x #####

... Rounded to the Nearest 5 mg/l

CD = 20 mg/l
--------------

**Mass of Chemical Sludge**

$$CS_{\text{Sludge}} = \frac{Q \times CD \times 0.091 \times 4 \times 8.34}{1E+06}$$

where  $CS_{\text{Sludge}}$  = Mass of Chemical Sludge Produced per basin (lb/day/basin)  
 0.091 = Fraction of Alum reacting with Phosphorus  
 4 = Mass of Precipitate formed per Mass of Alum

$$CS_{\text{Sludge}} = \frac{1,000,000 \times 20 \times 0.091 \times 4 \times 8.34}{1E+06}$$

$CS_{\text{Sludge}} = 60.7 \text{ lb/day}$
--

**Volume of Chemical Sludge**

$$V_{\text{cs}} = CS_{\text{Sludge}} \times SVI$$

where  $V_{\text{cs}}$  = Volume of Chemical Sludge (ft<sup>3</sup>/basin)  
 $CS_{\text{Sludge}}$  = Mass of Chemical Sludge (lb/day/basin)  
 SVI = Sludge Volume Index (ft<sup>3</sup>/lb)

$$V_{\text{cs}} = 61 \times 2.4$$

$V_{\text{cs}} = 146 \text{ ft}^3/\text{basin}$
---

**AIR CALCULATIONS**  
 BOD Removal Nitrification and Denitrification Process

McKeesport, PA  
 ABJ Project Number 17501-05a

---

$$AOR1 = A \times \frac{Q \times BOD_{in}}{1E+06} \times 8.34$$

where

- AOR1 = Actual Oxygen Required for BOD oxidation (lb/day/basin)
- A = O<sub>2</sub> / BOD
- Q = average flow (gal/day/basin)
- BOD<sub>in</sub> = influent BOD received (mg/l)
- 1E+06 = conversion (g x mg)
- 8.34 = conversion (lb x gal)

$$A = AT - DNC$$

where

- AT = Total O<sub>2</sub>/BOD required for carbonaceous treatment
- DNC = Denitrification Credit (O<sub>2</sub>/BOD)

$$AT = 1.20 \text{ O}_2/\text{BOD}$$

Denitrification Credit

$$DNC = \frac{2.9 \times DN \times \Delta N}{BOD_L}$$

where

- DNC = Denitrification credit (O<sub>2</sub>/BOD)
- DN = Fraction of nitrate denitrified
- ΔN = Net Nitrogen Load (lb/day/basin)
- BOD<sub>L</sub> = BOD Load (lb/day/basin)



$$\Delta N = \frac{[(NH_3in - NH_3out) - ((BODin - BODout) \times Y_{obs} \times N_s)] \times Q \times 8.34}{1E+06}$$

where  
 NH<sub>3</sub>in = influent ammonia concentration (mg/l)  
 NH<sub>3</sub>out = effluent ammonia required (mg/l)  
 Y<sub>obs</sub> = Observed sludge Yield (MLSS / BOD removed)  
 N<sub>s</sub> = Sludge Nitrogen content (N / sludge)  
 BODout = effluent BOD (mg/l)

$$\Delta N = \frac{[(38 - 1) - ((115 - 15) \times 0.75 \times 0.07)] \times 1,000,000 \times 8.34}{1E+06}$$

$\Delta N =$	264.80 lb/day/basin
--------------	---------------------

$$DNC = \frac{2.9 \times 0.9 \times 264.80}{959.1}$$

DNC = 0.00 O<sub>2</sub>/BOD **No denitrification credit taken.**

$$A = AT - DNC$$

$$A = 1.20 - 0.00$$

$A =$	1.20 O <sub>2</sub> /BOD
-------	--------------------------

$$AOR1 = 1.2 \times \left[ \frac{1,000,000 \times 115 \times 8.34}{1E+06} \right]$$

$AOR1 =$	1,151 lb/day/basin
----------	--------------------

$$AOR2 = 4.6 \times \Delta N$$

where AOR2 = Actual Oxygen Requirement for NH<sub>3</sub> oxidation (lb/day/basin)

$$AOR2 = 4.6 \times 264.80$$

$AOR2 =$	1,218 lb/day/basin
----------	--------------------

$$AOR = AOR1 + AOR2$$

$$AOR = 1,151 + 1,218$$

AOR = 2,369 lb/day/basin
--------------------------

$$SOR = \frac{AOR}{AOR/SOR}$$

$$AOR/SOR = \frac{\alpha \times \theta^{(T_{site}-20)} \times (\beta \times C^*_{sat20} \times P_{site}/P_{std} * C_{surfT}/C_{surf20} - D.O.)}{C^*_{sat20}}$$

- where
- alpha = alpha factor
  - theta = temperature coefficient
  - Tsite = water temperature (°C)
  - beta = beta factor
  - Psite = Site Atmospheric Pressure
  - Pstd = standard atmospheric pressure (1 atm)
  - C\*<sub>sat20</sub> = dissolved oxygen solubility at standard conditions (mg/l)
  - C<sub>surfT</sub> = dissolved oxygen solubility at site water temperature (mg/l)
  - C<sub>surf20</sub> = dissolved oxygen solubility at 20°C (mg/l)
  - D.O. = residual dissolved oxygen concentration (mg/l)

$$AOR/SOR = \frac{0.65 \times 1.024^{(20-20)} \times (0.95 \times 10.15 \times 14.34/14.7 \times 9.07/9.07 - 2.0)}{10.15}$$

AOR/SOR = 0.4744
------------------

$$SOR = \frac{2,369}{0.4744}$$

SOR = 4,994 lb/day/basin
--------------------------

**Aeration Depth**

**Average Aeration Depth:**

$$AADad = \frac{ADWF \times [(NCT \times 60) - (NDT + NST)]}{2 \times 1440 \times 7.48 \times BA} + BWL$$

- where
- MADpd = Maximum Aeration Depth at Average Dry Weather Flow (ft)
  - ADWF = Average Dry Weather Flow (gpd/basin)
  - NCT = Normal Cycle Time (hr)
  - NDT = Normal Decant Time (min)
  - NST = Normal Settling Time (min)
  - BA = Basin Area (ft<sup>2</sup>)
  - 1440 = conversion (min/day)
  - 7.48 = conversion (gal/ft<sup>3</sup>)

$$MADad = \frac{1,000,000 \times [(4.8 \times 60) - (48 + 72)]}{2 \times 1440 \times 7.48 \times 8,278} + 10.96$$

AADad =	11.90 ft
---------	----------

**Maximum Aeration Depth:**

$$MADpw = \frac{PWWF \times [(SCT \times 60) - (SDT + SST)]}{1440 \times 7.48 \times BA} + BWL$$

- where
- MADpw = Maximum Aeration Depth at Peak Wet Weather Flow (ft)
  - PWWF = Peak Wet Weather Flow (gpd/basin)
  - SCT = Storm Cycle Time (hr)
  - SDT = Storm Decant Time (min)
  - SST = Storm Settling Time (min)

$$MADpw = \frac{6,000,000 \times [(2 \times 60) - (30 + 60)]}{1440 \times 7.48 \times 8,278} + 10.96$$

MADpw =	12.98 ft
---------	----------

MAD = 13.79 ft
----------------

**Air Flow Requirement**

$$\text{Process Air} = \frac{\text{SOR} \times 10,000}{\rho \times \text{SOTE} \times \text{TA} \times \text{Opw} \times 60}$$

where Process Air = Process air flow requirement (SCFM)  
 rho = air density (lb/ft<sup>3</sup>)  
 SOTE = Standard Oxygen Transfer Efficiency @ Submergence of 10.9 ft  
 TA = Time of Aeration (hr/day)  
 Opw = fraction of Oxygen in air by Weight  
 10,000 = conversion (100% \* 100%)  
 60 = Conversion (min/hr)

$$\text{Process Air} = \frac{4,994 \times 10,000}{0.075 \times 23.2\% \times 10 \times 23.2\% \times 60}$$

Process Air=	2,066 SCFM
--------------	------------

$$\text{Mixing Air} = 0.125 \times \text{BA}$$

where Mixing Air = Mixing air flow requirement (standard SCFM)  
 0.125 scfm/ft<sup>2</sup> = recommended air flow per unit area of basin

$$\text{Mixing Air} = 0.125 \times 8,278$$

Mixing Air =	1,035 SCFM
--------------	------------

**Blower Unit Capacity**

The Blower Unit Capacity (BUC) is the larger of the process air requirement and the mixing air requirement:

Process Air = 2,066 SCFM

Mixing Air = 1,035 SCFM

Use 2 blowers per basin...

BUC =	1,033 SCFM
-------	------------

---

**Blower Pressure**

$$\text{PSIG} = (\text{MAD} \times 0.432) + \text{HL}$$

where PSIG = blower pressure (PSIG)  
0.432 = water density (PSI/ft)  
HL = Head Loss safety factor (PSIG)

$$\text{PSIG} = (13.79 \times 0.432) + 1$$

Rounded to the next tenth of a psig...

PSIG = 7.00 PSIG
------------------

# ICEAS<sup>®</sup>


## Advanced SBR Technology

### ABJ

## Cost-Effective Wastewater Treatment

Sanitaire has provided the wastewater treatment industry with innovative and cost-effective treatment technologies for over 35 years. This tradition continues with the ABJ Intermittent Cycle Extended Aeration (ICEAS) process, which is an advance sequencing batch reactor (SBR) technology for municipal and industrial wastewater treatment.

The conventional SBR, a variant of the activated sludge process, operates on the fill and draw principle. Fill, react, settle, decant and idle phases occur sequentially on a cyclic basis. In the conventional SBR configuration, flow is diverted from the basin during settling and decanting and requires two or more basins or an influent equalization tank to receive flow when settling and decanting. Sanitaire can provide a conventional SBR but recommends the superior flexibility of the ICEAS design, which does not require any flow diversion.



## The ICEAS Process

The advanced ABJ ICEAS process is a fully automated and simple to operate biological treatment system that:




- Operates as a time-based control system allowing continuous inflow of wastewater during all phases of the cycle.
- Responds to flow and load variations.
- Can achieve processes of biological oxidation, nitrification, denitrification, phosphorus removal and liquid/solids separation continuously in a single basin.
- Easily expands and produces a high quality effluent.
- Provides two treatment zones (pre-react and main-react) separated by a non-hydrostatic baffle wall.
- Utilizes the pre-react zone as a biological selector for enhancing the growth of desirable organisms.
- Offers flexibility for meeting specific application needs with custom engineered process cycles.

## The ICEAS Cycle

**React** – Periods of aeration and/or mixing are applied to achieve the desired biological treatment.

**Settle** – Aeration and/or mixing are discontinued allowing solids to settle to the bottom of the basin leaving a layer of clear, treated water at the top.

**Decant** – The clear, treated water is removed by an automated, time-controlled decant mechanism.



# ICEAS Features

## Continuous Inflow

- Provides equal loading and flow to all basins, simplifying operation and process control.
- Can be designed to accommodate up to six times average daily flow.
- Results in smaller basin size and less equipment, reducing construction and O&M costs.
- Eliminates primary and secondary clarifiers and return sludge pumps.
- Enables single-basin operation for maintenance and low flow conditions.

## Decanter Design

- High quality workmanship and advanced engineering provide a long-lasting decanter.
- Rugged, corrosion resistant stainless steel construction.
- Decants from the top down withdrawing only the uppermost clear water from the basin preventing disruption of the settling solids.
- Uses a proprietary scum exclusion float to prevent the carryover of floating material with the treated effluent.
- Flow over the decanter weir is visible from the basin walkway providing a check of effluent quality.
- Actuator operates via a VFD providing a constant rate of effluent discharge to downstream facilities.
- Parked above top water level during react and settling phases serving as an emergency overflow device in the event of extreme storm conditions or power failure.
- Actuator drive mounted outside of basin at walkway level for easy maintenance.

## Energy Efficient Aeration Systems

- State-of-the-art aeration systems have been applied worldwide in activated sludge and biological nutrient removal applications. SANITAIRE diffusers provide high oxygen transfer efficiency, require minimal maintenance and are time proven for their durability in wastewater treatment processes.
- Fine Bubble Membrane aeration systems include advanced membrane material specifically engineered for domestic and industrial applications providing resistance to material property changes. The time-proven piping system accommodates thermal expansion and contraction and prevents air leakage, pipe separation and distributor rollover.
- Coarse Bubble aeration systems provide efficient wide band aeration and mixing with minimal maintenance. Stainless steel material provides corrosion resistance and structural integrity and is fully passivated after fabrication. (Available in fixed header and removable header options).

# Municipal and Industrial Wastewater Treatment


The ABJ ICEAS process provides high quality effluent for both municipal and industrial wastewater treatment facilities. Typical industrial applications include waste from meat processing, beverage, pharmaceutical, food processing, pulp and paper and chemical plants.



Typical ABJ ICEAS process



Effluent sampling



Effluent treatment

## ICEAS-NDN PROCESS: BIOLOGICAL NUTRIENT REMOVAL (BNR)

Designed for the Removal of:

- BOD
- TSS
- Ammonia
- Total Nitrogen
- Total Phosphorous

Typically Used for:


- Municipal Wastewater
- Industrial Wastewater

Biological nutrient removal is accomplished in the ICEAS-NDN process by incorporating alternating phases of oxic-anoxic/anaerobic (air on-air off) conditions in the cycle as shown in Figure 13. The ICEAS basin is sized to ensure complete nitrification, denitrification and to maximize the total biological phosphorus removal.

Typical normal and storm cycles using 2 basins for the ICEAS-NDN process are shown in Figure 14 and 15. The aerobic phases promote BOD removal, nitrification and phosphorus uptake. The anoxic/anaerobic (air off) phases promote denitrification and phosphorus release. Nitrification rates and sludge age requirements for the nitrification process are calculated based on the temperature range and pH of the influent wastewater.

The degree of denitrification and phosphorus removal achieved by the ICEAS-NDN process is dependant on the influent BOD/TN and BOD/TP ratios. The typical blower control for the ICEAS-NDN process involves a D.O. control system with blower output control.


Figure 13






Normal Cycle Operational Sequence of ICEAS-NDN Process

Figure 14



Storm Cycle Operational Sequence of the ICEAS-NDN Process


Figure 15



The cycle charts for the ICEAS-NDN process operating in normal and storm cycles using four basins are shown in Figures 16 and 17.


Normal Cycle Operational Sequence for the ICEAS-NDN Process

Figure 16



Storm Cycle Operational Sequence of the ICEAS-NDN Process

Figure 17



# SIEMENS

**SCOPE OF SUPPLY**  
**Ultraviolet "UV" Disinfection**

**November 16, 2007**  
**Proposal # 2772001**

**PROJECT NAME:** McKeesport, OH WWTP  
**RECOMMENDED SYSTEM:** HE-40-A300-AW-6 Train # 2 (24 MGD)  
**ORIENTATION:** Vertical  
**LAMP TECHNOLOGY:** Low-pressure high intensity "AMALGAM"  
**AUTHORIZED REPRESENTATIVE:** Rick Bible  
 BissNuss, Inc.  
 2600 Boyce Plaza Rd.  
 Pittsburgh, PA 15241  
 (412) 221-1200

**DESIGN OVERVIEW- Train # 2- 24 MGD:**

Water type	Wastewater
Flow rate (Peak)	24 MGD
Flow rate (Average)	7.5 MGD
Flow rate (Minimum)	SBR Decant
Transmission @ 254 nm	65% (assumed)
Total suspended solids TSS	<10 mg/liter (design)
Biological oxygen demand	<10 mg/liter (design)
Temperature	50 F
Influent (per 100 ml sample)	N/A
Discharge permit	200/100 ml (summer)
Discharge permit	2000/100 ml (winter)
UV Dosage <sup>1</sup>	>30,000

System type	Vertical Open Channel
UV monitoring system	Yes
Lamp type	High intensity
Module material	Stainless Steel
Electrical enclosure	NEMA 4x
Running time meter	Yes
Individual lamp indicators	Yes
Flow pacing	<del>No</del>
Auto quartz cleaning system	Yes
Power Distribution Center	Remote NEMA 4x
Level Control	Finger Weir
Redundancy	TBD

*Rick & Adam  
 Conf. Call  
 12/13/07  
 ← YES*



- *LEAST EXPENSIVE*
- EASIEST TO OP*
- BIGGEST FOOTPRINT*
- *NOTE 12 STATIC*
- 40 LAMP/ MOD.*
- 10/ MOD.*
- *4-20 mA FROM DECA-TER*

*Adam - 201-760-0364*



## OVERVIEW

The vertical design will allow for energy and lamp conservation by flow pacing. A flow signal will be used to turn modules on and off. This provides the most economical way to control the system.

This UV disinfection system is designed to provide maximum dosage using low-pressure high intensity "AMALGAM" output technology at peak flow at end of lamp life. System has been designed based on calculations as outlined in the EPA design manual.

System is to be installed in pre-poured concrete channels. All supports will be provided. Anchorages will be provided by others and should be stainless steel.

## SCOPE

TYPE	Vertical
CHANNEL TYPE	Poured Concrete
NUMBER CHANNELS	1
MODULES PER CHANNEL	6
LAMPS PER MODULE	40
TOTAL LAMPS PER CHANNEL	240
TOTAL LAMPS PER PROJECT	240
LEVEL CONTROL	Fixed Finger Weir

Modules will hold lamps in a vertical position in a channel. An automatic air driven cleaning system will be provided. This will lower maintenance costs as well as improve system performance. System requires an air compressor. Compressor will be rated at 60 to 90 psi. If plant air exists, then it can be incorporated.

The Modules will be connected to a Power Distribution Center (PDC) through watertight cables. The plant electrician will bring protected power to the PDC.

Each module will contain and display through a window kit located in the top of the module: the UV monitoring system, L.E.D. lamp on/off indicators, elapsed running time meter, on/off switch, electronic ballasts and other electrical controls.

All materials exposed to the effluent will be stainless steel and quartz. All other materials exposed to UV light will be stainless steel, GE type 214 quartz, Teflon, Viton, EPDM and EPR.

### MAINTENANCE

In order to insure proper disinfection, the system needs to be maintained. Each UV system has lamps that are protected by quartz sleeves. Since the lamps produce heat and since the effluent has solids, the quartz sleeves can become fouled. This necessitates a cleaning regime that will be determined by plant operating conditions.

#### *Automatic Cleaning*

To automate the cleaning process, an air driven cleaning system has been incorporated. The system is operated using plant compressed air or via a dedicated air compressor. An air-driven piston will push the quartz wiping system over the arc length of the UV lamp. The cleaning system is comprised of a stainless steel fitting housing an EPDM ring. The "quick-stroke" approach prevents build-up and also prevents dragging of material over the sleeve.



Dirty Quartz Sleeves



Cleaned Quartz Sleeves

## ELECTRICAL PER MODULE

Power consumption per system:	14 kW
Voltage:	230 volt single phase
Hertz:	50/60
Amp draw:	70

## SYSTEM CONTROLS AND DISPLAYS

UV monitors:	One (1) per module
Lamp indicators:	Forty (40) per module
Running time meter:	One (1) per module
Flow pacing system	One (1) per module
Main PLC:	Allen Bradley Micrologix 1100

## UV LAMPS

Lamp watts:	320
UV watts @ 254 nm:	110
Quantity per module:	40
Lamp spacing:	4.0"
Lamp life:	12,000 hours
Lamp treatment:	Internal coating
Arrangement:	Staggered

## QUARTZ SLEEVES

Material:	Pure fused quartz
Seals:	Viton
Transmission:	94%
Type:	GE TYPE 214
Style:	Open on one end

## SPARE PARTS

While the system has been designed to be maintained on a regular schedule and undergo component replacement on a yearly basis, Siemens recommends having spare parts on site for unforeseen occurrences.

10 %	UV Lamps	(16)
10 set	Quartz sleeves	(10)
10 set	O-rings	(10)
10 set	Wiper rings	(10)

## WARRANTY

All metal and structural components will be guaranteed for a period of five (5) years. All electrical components will be guaranteed for a period of one (1) year. Lamps have a pro-rated warranty of one (1) year.

**ESTIMATED SHIPMENT**

Submittals 6-8 weeks after order  
Equipment Delivery 12-14 weeks after approval

**DELIVERABLES:**

Six (6) UV Modules (240 total lamps)  
Six (6) Bracketing systems  
Six (6) Automatic cleaning systems  
Six (6) Ultraviolet monitoring systems  
One (1) Power Distribution Center  
One (1) System Control Center (Allen Bradley PLC)  
One (1) Air compressor  
One (1) Wireway  
One (1) Weir sized for peak of 24 MGD  
One (1) Set of spare parts  
One (1) Hoist  
One (1) Crating  
One (1) Shipping  
One (1) Start up

**PRICING**

Total Price, FOB Shipping Points..... **\$ 370,000**

Siemens Water Technologies

John Rutledge  
Technical Sales Manager- UV

SIEMENS WATER TECHNOLOGIES HYDRAULIC ANALYSIS

MCKEESPORT, PA WWTP

SYSTEM: VE-40-A300-3X2-AW

VE-40-A300-3X2-AW	Open Channel Vertical System
Peak Flow Rate:	24 MGD
Number of Channels:	1
Number of Modules per channel	6

1a) Determine open area of the channel:

Channel dims:  
Width = 90.0"  
Depth = 60.5"

Open area of channel: 90.0 in X 60.5 in = **5445 in<sup>2</sup>**

1b) Determine area of UV equipment:

Area of support legs = 1.5 in X 60.5 in X 6 = **544.5 in<sup>2</sup>** ✓  
Area of wiper blades = .50 in 25.25 X 6 = **75.0 in<sup>2</sup>** 75.75  
Area of wiper rods = 20 X .5 X 6 = **60 in<sup>2</sup>** ✓  
Area of air cylinder = 2 in by 24.0 in X 3 = **144 in<sup>2</sup>** ✓  
Area of quartz sleeves = .985 X 21 X 60.5 = **1245 in<sup>2</sup>** 1251.5

1c) Determine net open channel flow area:

$$5445 \text{ in}^2 + \overset{75.75}{75.0} + 60.0 \text{ in}^2 + 144.0 \text{ in}^2 + \overset{1251.5}{1245} \text{ in}^2 = \overset{2075.25}{2068} \text{ in}^2$$

$$5445 \text{ in}^2 - \overset{2075.25}{2068} \text{ in}^2 = \overset{3369.75}{3377} \text{ in}^2 / 1550 \text{ m}^2/\text{in}^2 = 2.1 \text{ m}^2$$

2075.25 = 3369.75 → 3369 in<sup>2</sup> = 23.4 SFT.



2) Determine the maximum velocity in the channel at 24.0 MGD

$$V_{\text{channel}} = \frac{(\text{Q}) \text{ Total Flow Rate}}{(\# \text{ of channels}) (A_{\text{channel}})(1000\text{L}/\text{m}^3)(60\text{s}/\text{min})}$$

$$V_{\text{channel}} = \frac{63,083 \text{ l}/\text{min}}{(2.1)(1000\text{L}/\text{m}^3)(60\text{s}/\text{min})}$$





$$V_{\text{channel}} = .500 \text{ m/s}$$

3) Determine the headloss in the channel for 24 MGD:

$$H_{\text{channel}} = \frac{1.8 V^2}{2g}$$

$$H_{\text{channel}} = \frac{1.8 (.500^2 (1000\text{mm}/\text{m})) \times 2 (\# \text{ modules})}{2(9.81)} = 45.87 \text{ mm}$$

$$H_{\text{channel}} = 45.87 \text{ mm} = 1.8 \text{ in total headloss at 24 MGD}$$



QTY.	PART NUMBER	DESCRIPTION
1	1	CHANNEL - UV EQUIPMENT
1	2	LAVA 4000 EQUIPMENT
1	3	WEIR DAM PLATE
20	4	FINGER WEIR
1	5	WIRING TROUGH
2	6	ENCLOSURE
1	7	V LEVEL WATER SENSOR
1	8	AINING TANK
1	9	AIR COMPRESSOR

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES AND INCLUDE THICKNESS OF COATINGS  
TOLERANCES ON ALL SURFACES  
1-PLACE DECIMALS ± .030 1/8"  
2-PLACE DECIMALS ± .015 1/16"  
3-PLACE DECIMALS ± .005  
FRACTIONS ± 1/64"  
ANGLES ± .1°  
DIMENSIONING AND TOLERANCING IN ACCORDANCE WITH ANSI Y14.3M

DESIGNER: S. MARTIN  
CHECKER:  
ENGINEER:  
MANAGER:

DATE: 12/28/07

TITLE: BARRIER - VE-40-A300-3X2-AW: UV EQUIPMENT DETAIL

CLIENT:

**SIEMENS**  
Wabtec Technologies  
Attendale New Jersey  
201-750-0364

- GOALS: 1) DESIGN AEROBIC DIGESTERS FOR MACM WWTW  
2) DETERMINE IF PRIMARY CLARIFIER HAS SUFFICIENT VOL FOR THIS CAPACITY. IF NOT, IF BASIN DEPTH IS INCREASED CAN BASIN FUNCTION AS DIGESTER

GIVEN:

SLUDGE FLOW FROM EXISTING PROCESS: 4522 #/D = 91,200 @ 1% (90,000 m<sup>3</sup>/L)  
SLUDGE FLOW FROM SBR PROCESS: 1227 #/D = 18,391 @ 0.8% (80,000 L)

TOTAL WASTE TO DIGESTER  
#/D = 5750 #/D  
GPD = 72,600 gpd = 9705 CF/D  
CONCENTRATION: 9,500 m<sup>3</sup>/L (0.95%)  
TEMP = 10°C MIN = 50°F

GOAL TO THICKEN TO 1.8% BY VOLATILE SOLIDS REDUCTION  
ACHIEVE 40% VOLATILE SOLIDS REDUCTION  
3425 #/D OR 60% VOLATILE MATTER

$$V = \frac{Q_c (X_i + Y S_i)}{X (k_d P_v + 1/SRT)}$$

WHERE  $Q_c$ : SLUDGE FLOW CF/D  
 $X_i = 9,500$  m<sup>3</sup>/L  
 $X = 18,000$  m<sup>3</sup>/L  
 $Y = 0$   
 $S_i = 0$  } B/C NO PRIMARY SLUDGE  
 $k_d = 0.02$  - SEE FIG 3.1 FROM WEF MOP FD-9 1985  
 $P_v = 0.6$  - % VOLATILE  
 $SRT = 48.0$  DAYS - REF FIG 3.2 WEF MOP FD-9 1985  
WHERE 40% VSRED = 480 RT.°C

$$VOL = \frac{9,705 (9,500 + 0)}{18,000 (0.02(0.6) + 1/48)} = 156,002 \text{ FT}^3$$

$$= 1,166,980 \text{ GAL}$$

$$HRT = \frac{1,166,980 \text{ GAL}}{72,600 \text{ GPD}} = 16 \text{ DAYS} \quad \checkmark \text{ w/ TYP DESIGN VALUES}$$


(12-18 DAYS)

PRIMARY CLARIFIER & FLOC TANK VOL.

PRIMARY CLARIFIERS = 125 x 29 x 9.5' x 4 = 137,750 # SWD.  
FLOCCULATION TANKS = 28 x 29 x 11.33' x 4 = 36,800 # SWD.  
174,550 FT<sup>3</sup>

$$V_{PC/FT} > V_{DIG,REQ'D}$$

$$\rightarrow \text{AVE DEPTH} = \frac{156,002}{174,550} \approx 0.89 = 8.5 \text{ FT}$$




**FIGURE 3.2. Volatile solids reduction as a function of digester liquid temperature and digester sludge age.**

The data presented in Figure 3.2 can be used to compute a required sludge age given a desired level of volatile suspended solids reduction and an assumed operating temperature. The required digester volume is then determined by:

$$V = \frac{Q(X_i + YS_i)}{X(K_d P_v + 1/SRT)} \quad (8)$$

where

the deterioration in the aerobic digestion process. This has been attributed to the theory that classical biological kinetics do not apply at temperatures in excess of 35 to 40°C.



**FIGURE 3.1. Reaction rate  $K_d$  versus aerobic digester liquid temperatures.**

AIR REQUIREMENTS.

TOTAL MASS WASTED = 5,750 #/d

To ACHIEVE 40% VS REDUCTION IN WINTER (10°C ASSUMED TEMP)  
SRT-TEMP = 480 ⇒ SRT = 48 DAYS SEE FIG 3.2 MAP9

IN SUMMER - ASSUME T = 20°C AT 480 DAYS  
TEMP SRT = 960 = VS% REDUCTION OF 45%

TOTAL MASS VSS = 2797 + 628 = 3425 #/d

MASS REDUCTION

WINTER = 3425 x 0.4 = 1370 #/d

SUMMER = 3425 x 0.45 = 1541.25 #/d

O<sub>2</sub> REQUIRED.

WINTER 1370 x 2.3 = 3151 #O<sub>2</sub>/d

SUMMER 1541.25 x 2.3 = 3545 #O<sub>2</sub>/d ← GOVERNS.

AIR REQUIRED.

$\frac{3545 \text{ #O}_2/\text{d}}{(0.075)(0.232)} = 203,735 \text{ FT}^3/\text{d}$

ASSUME 10% OTE.

$\frac{203,735}{(0.1)(1440)} = 1415 \text{ CFM}$

CHECK FOR MIXING:

1415 CFM ÷ 156,000 FT<sup>3</sup> = 9.07 CFM/1000 CF

DEP REQUIRE'S MIN 30 CFM/1000 CF

∴ MIXING DEFICIENT.

SO DESIGN AIR FOR MIXING

174.55 x 30 CFM = 5,236.5 CFM

CHECK H<sub>2</sub>O FOR CHEMICAL PRECIP SLUDGE ASSOCIATED  
w/ PHOSPHORUS REMOVAL.

$$\begin{aligned} \#/\text{D WASTED} &= 5007 + 1227 = 6234 \\ \text{GPD} &= 78682 = 10520 \text{ CF/D.} \\ \text{CONCENTRATION} &= 9500 \text{ mg/L} \\ \text{TEMP} &= 10^\circ \text{C} \end{aligned}$$

$$H = \frac{10,520 (9500 + 0)}{18000 (0.02)(.6) + (1/48)} = 169,103. \text{ FT}^3$$

$$H_{PC/H} > V_{DIGREQ.} \quad \checkmark \text{ O.K.}$$

NEED 5,236.5 CFM FOR MIXING

MAX DEPTH - 11.33 FT.

ASSUME LOSSES THRU:

DIFFUSERS - 1.5 FT  
 LATERALS - 0.5 FT.

2 FT.

STATIC 11.33 FT

SUBTOTAL - 13.33 FT = 5.77 psig

PIPING LOSSES

	CFM	LOSS
MAIN - 16" GALV.	5240	0.052 / 100 FT.
10"	2620	0.18 / 100 FT
8"	2620	0.52 / 100 FT
6"	2620	2.3 / 100 FT

MAIN

16" → 216' x 0.052/100 = 0.11 FT  
 10" → 60' x 0.18/100 = 0.11 FT. } 0.22 FT. = 0.1 psig.

16" = 70' 1" YB. + 20' 1" BLO + 3'-80"

5.8  
 + 1 psig OVERPRESSURE  
6.8

ASSUME 2 UNITS @ 8 psig  
 5240



# Friction Loss Chart

This chart may be used to compute friction losses in a piping system. For example, determine the friction loss incurred when 70 CFM flows through a 2" pipe, 50' long.


**Step 1:** Intersect 70 CFM and the sloping line for 2" pipe as shown.

**Step 2:** Drop a vertical from this point of intersection and read the loss/100' of line, in this case, .60Hg/100'.

**Step 3:** Multiply the loss/100' of line by the length of run/100'.  
The loss for 50', then is

$$.60 \left( \frac{\text{length of run}}{100'} \right) = .60 \left( \frac{50'}{100'} \right) = 0.30'' \text{ Hg.}$$

**Also:** Velocity in the line may be read from the negatively sloping lines on the graph. Here, to get 70 CFM through a 2" line, the air must travel at a velocity of approximately 3000 FPM.





## Environmental Dynamics Inc.

5601 Paris Road Columbia, MO 65202-9399  
TELEPHONE (573) 474-9456 FAX (573) 474-6988

January 7, 2008

Mr. Dennis Telleck  
Learco Equipment Co.  
1373 McLaughlin Run Road  
Pittsburg, PA 15241

RE: MACM WWTP - McKeesport, PA  
Aerobic Digester Basins upgrade  
EDI FlexAir™ and MaxAir™ Aeration-Mixing System

Dear Dennis:

Environmental Dynamics Inc. (EDI) appreciates receiving the design request for the upgrade of eight digesters at the MACM WWTP, located in McKeesport, PA. EDI has a tremendous amount of experience in the aeration field and I think you will find the proposed system to be economically feasible and attractive in your application. A preliminary process review and aeration system design has been prepared for your review.

### Process Review:

EDI understands that at this facility, there are 4 pre-aeration basins and 4 primary clarifiers to be converted into aerobic digesters. EDI is proposing two options using flexible membrane and PVC wide band coarse bubble diffusers for this project. This equipment will result in excellent process performance, adequately sized aeration capacity, superior mixing, and optimized power consumption.

Each pre-aeration basin has dimensions of 28 feet x 29 feet x 11.33 feet SWD and each clarifier has dimensions of 125 feet x 29 feet x 9.5 feet SWD.

The following design option was provided:

Airflow = 5,240 scfm (8 basins)

Traditional aerobic digester mixing parameters require the aeration system to be capable of producing 30 SCFM per 1000 cubic feet of basin volume with the largest blower out of service. This design parameter closely follows the "Ten State Standards" which were written around coarse bubble diffusers when the tanks were basically in the 8-10 ft SWD range. However, based upon almost 20 years of experience, EDI has determined that using flexible membrane diffusers at an airflow rate of 0.25 scfm per square foot of floor area will provide proper mixing conditions with sludge suspended solids content less than 3.5% and with the diffusers in a grid configuration.

EDI has analyzed the oxygen requirements of the system to provide adequate MLVSS reduction. The airflow required for VSS reduction is less than the required mixing airflows. EDI recommends supplying a maximum of 30 scfm per 1000 cubic feet of basin volume to provide a

completely mixed environment at peak conditions, this meets the given airflow of 5,240 scfm, distributed with 1,104 scfm going to the pre-aeration basins and 4,132 scfm to the clarifiers.

It is also proposed that the average design condition and recommended operating condition be based upon 0.25 scfm per square foot for the flexible membrane system, this corresponds to an airflow of 812 scfm for the pre-aeration basins and 3,625 scfm for the clarifiers.

#### Diffuser Selection and System Design:

EDI recommends the FlexAir™ Magnum diffuser for the digester basin. This diffuser offers high oxygen transfer capabilities with the added advantage of maximum fouling or clogging resistance for minimum maintenance. We have extensive field experience with these diffusers and have numerous field installations demonstrating the excellent mechanical and process performance capabilities of the diffusers. We have also presented a design using the EDI MaxAir™ coarse bubble diffusers for the proposed digester

The FlexAir and MaxAir diffusers offered on this project employ several unique features that offer a high degree of mechanical integrity for the Client and ease of installation for the Contractor. Specifically, the following features are provided:

- Employs standard PVC piping for ease of handling and installation. Piping components are provided with flanged joints at all field connections. Piping sections are prefabricated at the factory and are shipped in maximum allowable lengths. Prefabricated header sections include factory drilled diffuser outlet ports.
- Provision of PVC piping and patented Spectrum™ diffuser mounting system provides a high degree of mechanical integrity. The mounting system offered will withstand 4,800 in-lbs of applied load with no mechanical failure. This mechanical integrity is superior to all competing tube and disc mounting systems offered in the industry.
- Factory assembled diffuser assemblies are provided with diffuser units and Spectrum mounting bracket. The only installation required is to clamp the assembly on the air header piping.
- The physical size of the FlexAir and MaxAir diffuser assembly and the high degree of preassembly provided minimizes the installation requirements for these systems.

The airflow and corresponding number of diffusers per basin, are shown below, also a generic layout for each option is attached.

DIFFUSER SYSTEM OPTION	DIGESTER BASIN					
	PRE-AERATION (28' x28' x11.33')			CLARIFIER (125' x28' x9.5')		
	AIRFLOW (SCFM)	# OF DIFFUSERS	AIR PER DIFFUSER (SCFM)	AIRFLOW (SCFM)	# OF DIFFUSERS	AIR PER DIFFUSER (SCFM)
Flex Air - Magnum 84P (flexible membrane)	peak: 276 ave: 203	24 units (12 assemblies)	peak: 11.5 ave: 8.46	peak: 1033 ave: 907	100 units (50 assemblies)	peak: 10.33 ave: 9.07
PVC MaxAir Simplex	276	18 units	15.33	1033	72 units	15.33

The FlexAir™ Model 84P diffuser assembly employs two Magnum tubes per assembly mounted in a duplex arrangement with the patented Spectrum™ Saddle Mount Assembly. Please note that using the Magnum Diffuser system, the airflow per tube for peak can be reduced to the average use, this will allow considerable energy cost savings.

The PVC MaxAir™ Simplex diffuser employs one MaxAir™ tube, mounted with the patented Spectrum™ Saddle Mount Assembly. Details and specifications of all diffusers are enclosed for your reference.

Budget Costs:

The budget cost for this application is \$98,150 USD for the FlexAir™ option and \$ 102,990 USD for the MaxAir™ system, total for the 8 basins. These prices include all in-basin aeration components starting at the top of the stainless steel drop pipe. An allocation for freight and field service is also included in these prices.

Mr. Telleck, thank you for your interest in our products. Please contact EDI for any additional information regarding our products or the design developed for this application.

Sincerely,

*Carolina Ausmus*  
 Carolina Ausmus  
 Application Engineer

Attachments:  
 System and Diffuser Details



5601 Paris Road  
Columbia, MO 65202  
Phone: 573-474-9456  
Fax: 573-474-6988

# Preliminary Project Drawing

**Requested by :** Sales  
**Title:** McKeesport, PA (digester upgrade)  
**Requested Due Date:** \_\_\_\_\_

**Submitted Date:** January 7, 2008  
**Submitted by:** Carolina Ausmus  
**Project Number:** (if applicable) N/A

**Drawing Type:**

Mktg.  Lab  Proposal  Submittal  Final Con.  Fabrication  R&D  Re-Work  Revision  Production  Misc.

**Technical Reference:**

**Diffuser Type:** PVC MaxAir Simplex Diffuser Assembly

**Number of Diffusers:** 18

**Submergence Depth:** 10.33

**Liquid Depth:** 11.33

**Basin Length:** 28

**Basin Width:** 29

**Basin Diameter:** \_\_\_\_\_

**No. of Basins:** 4


**Diffuser Spacing:** 3.11

**Drop Size:** 4

**No. of Laterals:** 2

**Lateral Size:** 4

**Special Comments:** \_\_\_\_\_



**Disclaimer:** Generic Image Only - Final Proposal/Submittal Drawing(s) may differ from generic sales image.




5601 Paris Road  
Columbia, MO 65202  
Phone: 573-474-9456  
Fax: 573-474-6988

# Preliminary Project Drawing


**Requested by :** Sales  
**Title:** McKeesport, PA (algester upgrade)  
**Requested Due Date:** \_\_\_\_\_  
**Submitted Date:** January 7, 2008  
**Submitted by:** Carolina Ausmus  
**Project Number:** (if applicable) N/A

**Drawing Type:**  
 Mktg.  Lab  Proposal  Submittal  Final Con.  Fabrication  R&D  Re-Work  Revision  Production  Misc.

**Technical Reference:**  
**Diffuser Type:** PVC MaxAir Simplex Diffuser Assembly  
**Number of Diffusers:** 72  
**Submergence Depth:** 8.5  
**Liquid Depth:** 9.5  
**Basin Length:** 125      **Basin Width:** 29  
**Basin Diameter:** \_\_\_\_\_      **No. of Basins:** 4  
**Diffuser Spacing:** 3.47      **Drop Size:** 8  
**No. of Laterals:** 2      **Lateral Size:** 6  
**Special Comments:** \_\_\_\_\_




**Disclaimer:** Generic Image Only - Final Proposal/Submittal Drawing(s) may differ from generic sales image.



NOTES:  
 BOTTOM SADDLE ASSEMBLY FACTORY  
 ASSEMBLED AND CONTAINS:  
 BOTTOM OF SPECTRUM™ SADDLE  
 O-RING SEAL  
 HEAVY WALL PVC BODY  
 THREADED ENDCAP

<b>MAXAIR SIMPLEX DIFFUSER ASSEMBLY</b>		ENG. BY:	DWG. BY:
TYPICAL INSTALLATION DETAIL		REV	DATE
DATE:	SCALE:	DWG NO:	
9-7-95	N.T.S.	7764	

	<b>ENVIRONMENTAL DYNAMICS INC.</b> 5801 PARIS ROAD COLUMBIA, MISSOURI 65202 PHONE: 573-474-9458 FAX: 573-474-8988 WWW.WASTEWATER.COM
---	---



5601 Paris Road  
Columbia, MO 65202  
Phone: 573-474-9456  
Fax: 573-474-6988

# Preliminary Project Drawing


Requested by : Sales  
Title: McKeesport, PA (dlaester upgrade)  
Requested Due Date: \_\_\_\_\_  
Submitted Date: January 7, 2008  
Submitted by: Carolina Ausmus  
Project Number: (if applicable) N/A

**Drawing Type:**

Mktg.  Lab  Proposal  Submittal  Final Con.  Fabrication  R&D  Re-Work  Revision  Production  Misc.

**Technical Reference:**

Diffuser Type: FlexAir® 84P Magnum Assembly  
Number of Diffusers: 24  
Submergence Depth: 10.33  
Liquid Depth: 11.33  
Special Comments: \_\_\_\_\_  
Basin Length: 28  
Basin Width: 29  
Basin Diameter: \_\_\_\_\_  
No. of Basins: 4  
Diffuser Spacing: 4.67  
Drop Size: 4  
No. of Laterals: 2  
Lateral Size: 4



Disclaimer: Generic Image Only - Final Proposal/Submittal Drawing(s) may differ from generic sales image.





5601 Paris Road  
Columbia, MO 65202  
Phone: 573-474-9456  
Fax: 573-474-6988

# Preliminary Project Drawing


**Requested by :** Sales  
**Title:** McKeesport, PA (dlaester upgrade)  
**Requested Due Date:** \_\_\_\_\_  
**Submitted Date:** January 7, 2008  
**Submitted by:** Carolina Ausmus  
**Project Number:** (if applicable) N/A

**Drawing Type:**


Mktg.  Lab  Proposal  Submittal  Final Con.  Fabrication  R&D  Re-Work  Revision  Production  Misc.

**Technical Reference:**

<b>Diffuser Type:</b>	<u>FlexAir® B4P Magnum Assembly</u>	<b>Basin Length:</b>	<u>125</u>	<b>Basin Width:</b>	<u>29</u>
<b>Number of Diffusers:</b>	<u>100</u>	<b>Basin Diameter:</b>	_____	<b>No. of Basins:</b>	<u>4</u>
<b>Submergence Depth:</b>	<u>8.5</u>	<b>Diffuser Spacing:</b>	<u>5</u>	<b>Drop Size:</b>	<u>8</u>
<b>Liquid Depth:</b>	<u>9.5</u>	<b>No. of Laterals:</b>	<u>2</u>	<b>Lateral Size:</b>	<u>6</u>
<b>Special Comments:</b>	_____				



**Disclaimer:** Generic Image Only - Final Proposal/Submittal Drawing(s) may differ from generic sales image.



NOTES:


A ACTIVE PERFORATED AREA= 732IN<sup>2</sup> (0.47m<sup>2</sup>)  
 NORMAL AIRFLOW RANGE= 6-40 scfm (10-68m<sup>3</sup>/h)  
 PEAK AIRFLOW CAPACITY+ 68 scfm (116m<sup>3</sup>/h)

ENVIRONMENTAL DYNAMICS INC.  
 5601 PARIS ROAD  
 COLUMBIA, MISSOURI 65202  
 PHONE: 673-474-0458  
 FAX: 673-474-8988  
 WWW.WASTEWATER.COM

FLEXAIR MAGNUM 84P DIFFUSER ASSEMBLY		
WITH SPECTRUM SDM CENTERLINE SADDLE		
SALES DRAWING		
DRAWN BY: M. BROOKS	CHECKED:	ENG: B. FROEBEL
DATE: 06/24/04	REV LEVEL: A	REV DATE: 03/17/06
SCALE: N.T.S.	PAGE NO. 1 OF 1	DRAWING NO. 21375

**KLH**  
**ENGINEERS, INC.**  
5173 CAMPBELL RUN ROAD  
PITTSBURGH, PA 15205

SUBJECT MACM. Act 237 Project JOB No. 220-33  
WWT. ETC. DIVERSIFIED FLOWEC. PANS SHEET No. 1 OF .....  
COMPUTED BY EDH DATE 1-16-07





*We Are The Original Manufacturer*





# The Universal Difference

## *The Right People*

In the last 25 years we've learned that selling blower packages involves more than a firm handshake and a trusting smile. Effectively sell custom engineered products requires people who understand the process from start to finish. That's why our sales team is comprised of people who are highly technical and have a firm grasp of the engineering, manufacturing and service aspects of the business.

## *Engineered Around You*

We pride ourselves on engineering the right blower system for each customer. Doing so requires that we maintain our own CAD-based engineering department with multiple engineers on staff dedicated to blower system design. Our team of professionals evaluates each job on an individual basis so you're never forced to settle for anything less than the best.

## *Manufactured to Fit*

Universal Blower Pac believes that the only way to guarantee quality is to establish complete control of product creation. That is why, in addition to engineering, we also manufacture all of our blower packages. This allows sales, engineering, and manufacturing to work together in meeting your expectations.

## *Service that Keeps You Running*

Down-time can put your commitments in jeopardy. Universal Blower Pac understands the implications that go along with service issues, which is why we employ service technicians with decades of experience in solving problems of application, installation, maintenance, etc. You can count on us, before, during and after the sale.





## *Warranties for your Piece of Mind*

As with any capital investment, you want to be sure the product you buy is going to last. We supply a one point warranty and service to solve all possible problems and issues. In addition, we maintain authorized reps for local service. Extended warranties are available for properly designed and maintained packages at little extra cost. You'll rest easy knowing the blower package you purchased will be around for the long haul.

# Diverse Products *for a* Changing Market

At Universal Blower Pac we know in order to serve our clients we must remain flexible. For each application our blower packages must adapt to fit unique needs. That's why we've developed products to address the varying needs of the customers we serve. From affordable, compact units to the most powerful package, we will work to find the solution that best fits your goals.

- **Highly custom packages** meeting detailed specifications to pre-engineered units that will have you up and running in no time.
- **Innovative designs** for competitive pricing due to mass production and cost control, with in-house manufacturing.
- **Specialized packages** designed to serve specific industries.
- **Acoustical solutions** with dependable results offering variable performance levels and pricing depending on customer requirements.
- **Electrical interface control systems** – from simple monitoring to complex feedback variable frequency drives with programmable controls.



Talk to us and learn what it means to be “*taken care of*”

From inception, we'll work together to define your needs. Then, we'll custom design and manufacture a blower package that fits you.

**Universal Blower Pac - *The Original Manufacturer***

440 Park 32 West Drive | Noblesville, IN 46062-9252 | PH 317-773-7256 | FX 317-776-5086  
website: [www.universalblowerpac.com](http://www.universalblowerpac.com) | email: [sales@universalblowerpac.com](mailto:sales@universalblowerpac.com)



January 10, 2008

Project: MACM


Customer: BissNuss, Inc.

Option 1: Two UBP Aerobic Digester Blower Packages





**Notes:**

- This proposal is for two Universal Blower Pac packages utilizing 11CDL31 Cycloblowers and 300 HP NEMA frame motors.
- The attached drawing is from a similar project. This configuration can be modified to meet dimensional constraints or other customer needs.
- This blower uses a helical screw to move air versus a standard straight-lobed impeller. It gradually releases air through its discharge port resulting in a balanced compression cycle with little noise and pulsation. Its volumetric efficiency is also much better than a straight lobed machine at high pressure resulting in significant power savings.
- The blower and motor will be connected through use of a drive coupling. This eliminates lateral loading on the blower and motor shafts that shortens bearing life. It also eliminates v-belt maintenance and the 3-5% power transfer losses normally incurred with a v-belt drive.
- The unit's speed and flow are controlled with a variable frequency drive. We can achieve turndown to around 2000 SCFM.
- The unit will operate without an enclosure at an estimated noise level of 91 dBA at 1m in a free field. A partial Acousti-Pac enclosure will lower the noise level to 81 dBA.
- Specifications and CAD drawings are available.

ITEM NO.	ITEM NUMBER	DESCRIPTION	QTY.
1	U... +2	Grade I, Inlet Silencer w/ oversized 14" flanges	1
2	14" 8 F-F	14" Single oich flex joint	1
3	11CDL27	CYCLO BLOWER	1
4	ECP440BT-4	250 HP, PE, IEP-C, 1800 RPM Motor w/ NC 1-stats and 120V space heaters	1
5	10901	Stainless 110 Drive coupling	1
6	CG970738	Coupling guard	1
7	8070738	A700 Blower / Motor base w/ motor rail	1
8	12" 8 F-F	12" Flanged flex joint, 8" F-F w/ acoustical wrap	1
9	DRS-12	Grade I Discharge Silencer w/ lagging	1
10	12"	12" Pipe spool	1
11	8"	Weighted Pressure Relief Valve	1
12	ES5-E238C	TEXA 4 terminal temperature switch w/ 1/2" x 4" Stainless steel thermowell	1
13	J6-222	J6-222, 0-20 PSI Pressure Switch	1
14	130025-B10	3" 50-300 F temperature gauge w/ stainless steel thermowell	1
15	P9081G	4-1/2" Pressure Gauge Assembly	1
16	J6-136	J6-136, 0-50" WC Vacuum Switch	1
17	2030-LT	4-1/2" 0-30" WC Vacuum gauge w/ bracket	1
18	PMC-BETA 440	Electronic Vibration switch	1
19	EO70738	ENCLOSURE W/ FAN	1



REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED
	A	DRAWING CREATED	10/30/2007	JH



**PACKAGE PERFORMANCE:**

DESIGN PRESSURE: 10 PSIG  
 DESIGN AIRFLOW: 4250 ICFM  
 BLOWER SPEED: 1796 RPM  
 PRV SET POINT: 11 PSIG  
 PRESS. SW. SET POINT: 11 PSIG  
 TEMP. SW. SET POINT: 350 °F  
 VAC. SW. SET POINT: 20" WC  
 APPROX. WEIGHT: 10346 LBS

**NOTE:**

1. INSTALL AND OPERATE ACCORDING TO O&M MANUAL.
2. SOME ITEMS, USUALLY SILENCERS, MAY BE DISASSEMBLED FOR SHIPMENT. REASSEMBLY MAY BE REQUIRED.

UNLESS OTHERWISE SPECIFIED	UNIT	SCALE	DATE	REVISIONS
DESIGNED BY: [Signature]	INCHES	1:1	10/30/07	
CHECKED BY: [Signature]				
APPROVED BY: [Signature]				
<b>UNIVERSAL</b>				TITLE: 11CDL27 / 250 HP / A700
SHEET NO: 070738				SCALE: 1:1 (WEIGHT)
SHEET 1 OF 2				





CycloBlower Pressure Model 11CDL31

Price:

[Click to enter price](#)

Project Specifications

Corrected Values	Original Units	English Units	Metric Units
Barometer	500 ALTI-FT	14.426 PSIA	0.995 bar a
Elevation	500 ALTI-FT	500 ALTI-FT	152 alti-m
Inlet Pressure	0 In HGV	0 PSIG	0 bar g
Inlet Temp.	100 °F	100 °F	38 °C
Inlet Flow	5240 SCFM	5967.84 ICFM	10139 m³/h
Dis. Flow	4534 CFM	4534 CFM	7703 m³/h
Dis. Pressure	8 PSIG	8 PSIG	0.552 bar g
Rel. Humidity	90 %	90 %	90 %
Delta Pressure	8 PSI	8 PSI	0.552 bar

Measured Values	Plot Units	English Units	Metric Units
Blower Speed	2055 RPM	2055 RPM	2055 RPM
% of Max Speed	93 %	93 %	93 %
Blower Power**	263 HP	263 HP	196.1 kw
Efficiency	67.1 %	67.1 %	67.1 %
Discharge Temp.	201 °F	201 °F	94 °C
Estimated Noise	91 db	91 db	91 db

\*\*Drive losses not included

Physical:	
Weight	3560 lbs.
Main Diameter	18.111 in.




Performance:	
Max Delta P	20.1 PSI
Min Delta P	0 PSI
Max Temp	350 °F
Max speed	2200 rpm
Min speed	0 rpm
Max Case Pressure	35 PSIG

Gas Parameters	English Units	Metric Units
Molecular Weight	28.32 lbm/lbmol	28.32 kg/kgmol
R Value	54.57 ft.lbf/lbm.R	0.3 kJ/kg.K
Density	0.068 lbm/ft³	1.089 kg/m³
Sp. Heat @ Const. P	0.25 BTU/lbm.R	1.04 kJ/kg.K
Ratio of Sp. Heats	1.39	1.39
Saturated Vapor Pres.	0.9487 PSIA	0.065 bar a
Partial Pres. of Gas	13.5726 PSIA	0.938 bar a
Partial Pres. of Vapor	0.8538 PSIA	0.0585 bar a
Reference Pressure	14.696 PSIA	0.995 bar a
Reference Temperature	68 °F	0 °C
Reference Rel. Humid.	38 %	0 %

Gas mix: % by volume  
Air 100 %

Performance Information - Cyclo Blower Pressure Model 11CDL31

Temperature Rise





January 10, 2008

Project: MACM

Customer: BissNuss, Inc.

Option 2: Three UBP Aerobic Digester Blower Packages

Notes:


- This proposal is for three Universal Blower Pac packages utilizing 624-HF blowers and 150 HP NEMA frame motors.
- The attached drawing is from a similar project. This configuration can be modified to meet dimensional constraints or other customer needs.
- This blower uses a twisted helical lobe to move air versus a standard straight-lobed impeller. It gradually releases air through its discharge port resulting in a balanced compression cycle with little noise and pulsation.
- The blower and motor will be connected through use of a drive coupling. This eliminates lateral loading on the blower and motor shafts that shortens bearing life. It also eliminates v-belt maintenance and the 3-5% power transfer losses normally incurred with a v-belt drive.
- The unit's speed and flow are controlled with a variable frequency drive. We can achieve turndown to around 500 SCFM.
- The unit will operate without an enclosure at an estimated noise level of 97 dBA at 1m in a free field. A partial Acousti-Pac enclosure will lower the noise level to 87 dBA. An Attenu-Pac full enclosure will lower the noise level to 77 dBA.
- Specifications and CAD drawings are available.

ITEM NO.	DESCRIPTION	DATE	APPROVED
1	REVISION		
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			

UNIVERSAL	SCALE: 1/16" = 1"	SHEET 1 OF 2
06123A	6024 / 125 HP / A500	
06123A		

Package Performance

Design Airflow: 1650 SCFM  
 Blower Speed: 2139 RPM  
 PRV Set Point: 10 PSIG  
 Vacuum Sw. Set Pt: 15" WC  
 Pressure Sw. Set Pt: 10 PSIG  
 Temperature Sw. Set Pt: 300 F  
 Approx. Package Wt: 4200 LBS  
 Approx. Enclosure Wt: 650 LBS



ITEM NO.	NUMBER	DESCRIPTION	QTY.
1		Fiber restriction indicator	1
2		Filter w/ paper element	1
3		Grade 1 (4x) Silencer	1
4		1/2" (1) Bottom discharge	1
5		1/2" (1) Motor w/ fan	1
6		Drive coupling	1
7		Coupling Guard	1
8		1/2" (1) Blower / Motor base w/ motor coil	1
9		1/2" (1) Flange	1
10		Grade 1 Discharge Silencer	1
11		4-1/2" Pressure Gauge Assembly	1
12		2" (1) Motor Mounting Flange w/ 4-1/2" (1) Motor	1
13		2000 gauge, coarse	1
14		1750 Differential Pressure Switch	1
15		1/2" (1) 0-20 PSI Pressure Switch	1
16		NEPAK 2X High Efficiency Filter	1
17		ATTENU-PAC FULL ENCLOSURE W/ FAN	1

NOTE:





1. INSTALL AND OPERATE ACCORDING TO OEM MANUAL

2. SOME ITEMS, USUALLY SILENCERS, MAY BE DISASSEMBLED FOR SHIPMENT. REASSEMBLY MAY BE REQUIRED.

**Specifications:**

1. Material of construction: 1/8" Aluminum
2. Enclosure and vent boxes lined w/ 2" acoustical foam
3. Qty (4) hinged doors (2 front, 2 back)
4. Qty (8) 1/2 turn compression latches (2 per door)
5. Qty (1) Exhaust fan

REVISIONS				
LOH#	REV	DESCRIPTION	DATE	APPROVED
		See Sheet		



UNIVERSAL SYSTEMS	DATE	2	2	UNIVERSAL SYSTEMS, INC.
DESIGNED AND DRAWN BY	DATE			UNIVERSAL SYSTEMS, INC.
CHECKED BY	DATE			UNIVERSAL SYSTEMS, INC.
APPROVED BY	DATE			UNIVERSAL SYSTEMS, INC.
TITLE	6024 / 125 HP / A500			
SEE DWG. NO.	06123A			
SCALE	1-1/4" = 1'-0"			SHEET 2 OF 2

HeliFlow HF Series Model 624

Price:  
[Click to enter price](#)

Project Specifications

Corrected Values	Original Units	English Units	Metric Units
Barometer	500 ALTI-FT	14.426 PSIA	0.995 bar a
Elevation	500 ALTI-FT	500 ALTI-FT	152 alti-m
Inlet Pressure	0 In HG	0 PSIG	0 bar g
Inlet Temp.	100 °F	100 °F	38 °C
Inlet Flow	2620 SCFM	2983.92 ICFM	5070 m³/h
Dis. Flow	2316 CFM	2316 CFM	3935 m³/h
Dis. Pressure	8 PSIG	8 PSIG	0.552 bar g
Rel. Humidity	90 %	90 %	90 %
Delta Pressure	8 PSI	8 PSI	0.552 bar

Measured Values	Plot Units	English Units	Metric Units
Blower Speed	3248 RPM	3248 RPM	3248 RPM
% of Max Speed	98 %	98 %	98 %
Blower Power**	121.4 HP	121.4 HP	90.5 kw
Efficiency	72.7 %	72.7 %	72.7 %
Discharge Temp.	216 °F	216 °F	102 °C
Estimated Noise	97 db	97 db	97 db

\*\*Drive losses not included

Physical:	
Weight	N/A lbs.
Gear Diameter	6.5 in.
Case Length	24.00 in.
Port Size	10 in.
WR <sup>2</sup>	N/A lb-ft <sup>2</sup>
Configuration	Horizontal




Performance:	
Max Delta P	12 PSI
Max Temp	350 °F
Max speed	3300 rpm
Min speed	882 rpm
Max Case Pressure	25 PSIG
Max Delta T	250 °F
Max T	350 °F

Gas Parameters	English Units	Metric Units
Molecular Weight	28.32 lbm/lbmol	28.32 kg/kmol
R Value	54.57 ft.lbf/lbm.R	0.3 kJ/kg.K
Density	0.068 lbm/ft <sup>3</sup>	1.089 kg/m <sup>3</sup>
Sp. Heat @ Const. P	0.25 BTU/lbm.R	1.04 kJ/kg.K
Ratio of Sp. Heats	1.39	1.39
Saturated Vapor Pres.	0.9487 PSIA	0.065 bar a
Partial Pres. of Gas	13.5726 PSIA	0.936 bar a
Partial Pres. of Vapor	0.8538 PSIA	0.0585 bar a
Reference Pressure	14.696 PSIA	0.995 bar a
Reference Temperature	68 °F	0 °C
Reference Rel. Humid.	36 %	0 %


Gas mix: % by volume  
 Air 100 %

Performance Information - HellFlow HF Series Model 624

Temperature Rise









E



**APPENDIX E**

---

**HYDRAULIC PROFILE  
CALCULATIONS**




To New WWTP

Description

		Loss						Elevation					
		4.5	7.5	12	15.5	24	44	4.5	7.5	12	15.5	24	44
Flow in MGD		3125	5208	8333	10264	16667	30556						
Flow in gpm		6.96	11.60	18.56	23.98	37.13	68.07						
Flow in cfs													
Starting Elevation	Normal Pool							740.34	740.34	740.34	740.34	740.34	740.34
Invert of Flume		724.45	724.45	724.45	724.45	724.45	724.45						
Submergence at Flood - Static Loss		15.89	15.89	15.89	15.89	15.89	15.89						
Open Channel Loss		729	729	729	729	729	729						
Invert Elevation		11.34	11.34	11.34	11.34	11.34	11.34						
Depth		30.68	30.68	30.68	30.68	30.68	30.68						
Wetted Perimeter		90.71	90.71	90.71	90.71	90.71	90.71						
Area		2.96	2.96	2.96	2.96	2.96	2.96						
Hydraulic Radius		0.08	0.13	0.20	0.26	0.41	0.76						
Velocity ft/s		4.07E-09	1.3E-08	3.32E-08	5.54E-08	1.33E-07	4.46E-07						
Length		4.9E-07	1.36E-06	3.48E-06	5.82E-06	1.39E-05	4.89E-05						
Actual Loss		Negligible	Negligible	Negligible	Negligible	Negligible	Negligible						
Water Level In Effluent Flume								740.34	740.34	740.34	740.34	740.34	740.34
Calculated Recommended Static over weir		0.24	0.33	0.45	0.54	0.72	N/A						
Actual Static Drop over weir		0.72	0.72	0.72	0.72	0.72							
Effluent Weir	No. Weirs	1	1	1	1	1	1						
Weir Loss		51.63	51.63	51.63	51.63	51.63	51.63						
UV Channel Downstream Elevation								741.18	741.22	741.28	741.33	741.42	741.05
Open Channel Loss		729.75	729.75	729.75	729.75	729.75	729.75						
Invert Elevation		Negligible	Negligible	Negligible	Negligible	Negligible	Negligible						
Actual Loss thru Liv Area (ft <sup>2</sup> )		0.2975	0.495833	0.783333	1.024722	1.586567	2.808869						
Loss No. Module In Pass		0.004946	0.013743	0.035183	0.058899	0.14073							
UV Channel Upstream/Stilling Well Elevation								741.18	741.24	741.32	741.39	741.56	
Pipe Loss		1167	1167	1167	1167	1167	1167						
Exit Loss		0.02	0.04	0.11	0.18	0.43	N/A						
Pipe Friction Loss		0.09	0.24	0.62	1.04	2.50							
Orifice		0.02	0.06	0.16	0.27	0.64	N/A						
Total Loss		0.13	0.35	0.89	1.49	3.57							
SBR Effluent Box								741.31	741.59	742.21	742.87	745.12	
SBR Decanter Loss													
SBR Low Water Level													746.62
SBR High Water Level													781.62
SBR Splitter Box													
Pipe Loss		151	151	151	151	151	151						
Exit Loss		0.00	0.01	0.03	0.06	0.14	N/A						
Pipe Friction Loss		0.01	0.01	0.04	0.06	0.15							
Orifice		0.01	0.02	0.05	0.08	0.20	N/A						
Total Loss		0.02	0.05	0.12	0.20	0.49							
Effluent SBR Splitter Box Level								751.84	751.67	751.75	751.83	752.11	
Calculated Recommended Static over weir		0.44	0.62	0.85	1.01	1.35	N/A						
Actual Static Drop over weir		1.81	1.78	1.79	1.62	1.33							
Splitter Box Weir	No. Weirs	4	4	4	4	4	4						
Weir Loss		5	5	5	5	5	5						
Flow Control Box								753.67	753.76	753.88	753.96	754.13	
Pipe Loss		236	236	236	236	236	236						
Exit Loss		0.24	0.67				N/A						
Pipe Friction Loss		0.54	1.51										
Orifice		0.02	0.06	0.16	0.27	0.64	N/A						
Total Loss		0.81	2.24	0.70	1.17	2.81							
Influent Flow Control Box Level								754.93	756.36	756.55			
Calculated Recommended Static over weir		0.34	0.48	0.65	0.77	1.03	1.55						
Actual Static Drop over weir		5.82	4.39	3.50	3.03	1.39	1.39						
Flow Control Box Weir	No. Weirs	1	1	1	1	1	1						
Weir Loss		30	30	30	30	30	30						
Pipe Loss		736	736	736	736	736	736						
Exit Loss		0.01	0.02	0.06	0.09	0.21	0.71						
Pipe Friction Loss		0.01	0.02	0.06	0.09	0.22	0.74						
Orifice		0.00	0.00	0.00	0.01	0.02	0.07						
Total Loss		0.02	0.04	0.11	0.19	0.45	1.51						
								780.94	781.05	781.19	781.32	781.72	783.04






REPRINTED FROM THE MUNICIPAL AUTHORITY OF THE CITY OF MCKEESPORT ACT 537 SEWAGE FACILITIES PLAN (NOVEMBER 2006)







**PLAN KEY**

NEW STRUCTURE	
MODIFIED STRUCTURE	
BUILDING RENOVATIONS	
NEW ASPHALT PAVING	
NEW CONCRETE PAVING	
PROPERTY LINE	
NEW FENCE	
APPROXIMATE RIVER BANK	

**PROPOSED SITE PLAN**  
SCALE: 1" = 40'

Scale:	As Shown
Date:	March 2008
Drawn By:	DMB
Checked By:	KCH
Approved By:	SMG
Sheet No.:	5 OF 6
Plate No.:	4 - 4

**MUNICIPAL AUTHORITY OF THE CITY OF MCKEESPORT  
ALLEGHENY COUNTY, PENNSYLVANIA  
WASTEWATER TREATMENT PLANT  
PROPOSED PROPERTY AND SITE PLAN**

**KLH  
ENGINEERS, INC.**

5173 CAMPBELL BLVD. ROAD  
PITTSBURGH, PA 15206-3310  
PHONE: 412-484-0310  
FAX: 412-484-0326  
info@klhinc.com

Revisions	Date