



17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
717-731-1970 Main
717-731-1985 Main Fax
www.postschell.com

Christopher T. Wright

cwright@postschell.com
717-612-6013 Direct
717-731-1985 Direct Fax
File #: 166392

November 27, 2017

VIA HAND DELIVERY

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

RECEIVED
2017 NOV 27 AM 9:39
PA PUC
SECRETARY'S BUREAU
FRONT DESK

**Re: Letter of Notification of PPL Electric Utilities Corporation, Filed Pursuant to 52 Pa. Code Chapter 57 Subchapter G, for Approval to Rebuild the Existing Breinigsville-Alburtis 500 kV Transmission Line in Lehigh County, Pennsylvania
Docket No. A-2017-**

Dear Secretary Chiavetta:

Enclosed for filing is the Letter of Notification of PPL Electric Utilities Corporation in the above-referenced proceeding. A CD containing a copy of the Letter of Notification and Attachments in Support of the Letter of Notification is also enclosed.

As indicated on the Certificate of Service, copies of the Letter of Notification are being served by certified mail, return receipt requested upon the involved governmental agencies, municipalities and property owners.

Subject to Commission approval, construction is scheduled to begin in May 2018 to support an in-service date of March 2019.

If you have any questions concerning this matter, please contact me at the address or telephone numbers provided above.

Rosemary Chiavetta, Secretary
November 27, 2017
Page 2

Respectfully submitted,



Christopher T. Wright

CTW/jl
Enclosures

cc: Certificate of Service
Office of Consumer Advocate
Office of Small Business Advocate
Bureau of Investigation & Enforcement
Robert F. Young
Paul T. Diskin
Yasmin Snowberger
Kimberly Hafner

RECEIVED
2017 NOV 27 AM 9:39
PA PUC
SECRETARY'S BUREAU
FRONT DESK

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Letter of Notification of PPL Electric :
Utilities Corporation, Filed Pursuant to :
52 Pa. Code Chapter 57 Subchapter G, : Docket No. A-2017-_____
for Approval to Rebuild the Existing :
Breinigsville-Alburtis 500 kV :
Transmission Line in Lehigh County, :
Pennsylvania :

LETTER OF NOTIFICATION

TO THE PENNSYLVANIA PUBLIC UTILITY COMMISSION:

PPL Electric Utilities Corporation ("PPL Electric") hereby files, pursuant to 52 Pa. Code § 57.72(d), this Letter of Notification to request approval from the Pennsylvania Public Utility Commission ("Commission") to rebuild the existing single circuit Breinigsville-Alburtis 500 kV Transmission Line to a double-circuit configuration (the "Project"). The Breinigsville-Alburtis 500 kV Transmission Line extends approximately 6 miles from the existing Breinigsville 500-138-69 kV Substation in Upper Macungie Township, Lehigh County, to the existing Alburtis 500-230 kV Substation in Lower Macungie Township, Lehigh County. As explained below, the Project is required to improve reliability and operational performance, reduce the potential for and duration of outages, and increase system operability in Lehigh County. Subject to the Commission's approval, construction is scheduled to begin in May 2018 to support the in-service date of March 2019. In support thereof, PPL Electric states as follows:

RECEIVED
2017 NOV 27 AM 9:39
PA PUC
SECRETARY'S BUREAU
FRONT DESK

I. INTRODUCTION

1. This Letter of Notification is filed by PPL Electric, a public utility that provides electric distribution, transmission, and provider of last resort services in Pennsylvania subject to the regulatory jurisdiction of the Commission.

2. PPL Electric's address is PPL Electric Utilities Corporation, Two North Ninth Street, Allentown, Pennsylvania 18101.

3. PPL Electric's attorneys are:

Kimberly A. Klock (ID #89716)
Amy E. Hirakis (ID # 310094)
PPL Services Corporation
Two North Ninth Street
Allentown, PA 18101
Voice: 610-774-4254
Fax: 215-587-1444
E-mail: kklock@pplweb.com

David B. MacGregor (I.D. # 28804)
Christopher T. Wright (I.D. # 203412)
Post & Schell, P.C.
17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
Voice: 717-731-1970
Fax: 717-731-1985
E-mail: dmacgregor@postschell.com
E-mail: cwright@postschell.com

PPL Electric's attorneys are authorized to receive all notices and communications regarding this Letter of Notification.

4. PPL Electric furnishes electric service to approximately 1.4 million customers throughout its certificated service territory, which includes all or portions of twenty-nine counties and encompasses approximately 10,000 square miles in eastern and central Pennsylvania. PPL Electric is a "public utility" and an "electric distribution company" as defined in Sections 102 and 2803 of the Pennsylvania Public Utility Code, 66 Pa.C.S. §§ 102, 2803.

5. PPL Electric owns approximately 5,000 miles of transmission lines operating at 69 kV (kilovolts) or higher, approximately 375 substations with a capacity of 10 MVA (megavolt amperes) or more, and approximately 43,000 miles of distribution lines operating at less than 69 kV.

6. This Letter of Notification includes the following accompanying attachments:

- Attachment 1 Necessity Statement.
- Attachment 2 Design & Engineering Description.
- Attachment 3 Description of Right-of-Way.
- Attachment 4 PPL Electric Design Criteria and Safety Practices.

7. This Letter of Notification and accompanying Attachments, which are incorporated herein by reference, contain all the information required by 52 Pa. Code § 57.72(d)(4).

II. THE PROJECT

A. NEED FOR THE PROJECT

1. Existing System

8. The existing Wescosville 500-138-69 kV Substation serves customers in parts of Lehigh County, Pennsylvania. The Wescosville 500-138-69 kV Substation is currently supplied by a single 500 kV tap off the existing single-circuit Susquehanna-Wescosville 500 kV Transmission Line.

9. The Susquehanna-Wescosville 500 kV Transmission Line extends from the Susquehanna 500-230 kV Substation¹ to the tap point with the Wescosville 500-138-69 kV Substation. From the tap point, the 500 kV line continues to the Breinigsville 500-138-69 kV Substation (this segment is referred to as the Wescosville-Breinigsville 500 kV Transmission Line).

¹ The Susquehanna 500-230 kV Substation is also interconnected with the Susquehanna-Lackawanna 500 kV Transmission Line, which is part of PPL Electric's Susquehanna-Roseland 500 kV Transmission Line.

10. The Breinigsville 500-138-69 kV Substation is also interconnected with the existing single-circuit Breinigsville-Alburtis 500 kV Transmission Line that extends approximately 6 miles from the Breinigsville 500-138-69 kV Substation located in Upper Macungie Township, Lehigh County, to the existing Alburtis 500-230 kV Substation in Lower Macungie Township, Lehigh County.

11. A description, aerial map, and one-line diagram of the existing system are provided in the Necessity Statement included as Attachment 1 to this Letter of Notification.

2. Need for the Project

12. PPL Electric's system planning studies have determined that the loss of the Susquehanna-Lackawanna 500 kV Transmission Line followed by the loss of the Susquehanna-Wescosville 500 kV Transmission Line, an N-1-1 contingency, creates an unacceptable voltage drop and low voltage on the 138 kV and 69 kV transmission lines supplied by the Wescosville 500-138-69 kV Substation and the Breinigsville 500-138-69 kV Substation.

13. In addition, the 500 kV yard at the Wescosville 500-138-69 kV Substation is directly tapped off the Susquehanna-Wescosville 500 kV Transmission Line. The Susquehanna-Wescosville 500 kV Transmission Line is approximately 67 miles long, which puts the line at high risk of exposure to faults. A fault on the Susquehanna-Wescosville 500 kV Transmission Line would trip the 500-138 kV transformer, which is the single 500 kV source for the Wescosville 500-138-69 kV Substation. Additionally, a fault on the Susquehanna-Wescosville 500 kV Transmission Line would remove one of the 500 kV source to the Breinigsville 500-138-69 kV Substation.

14. The need for the proposed Project is further explained in Attachment 1 to this Letter of Notification.

B. THE PROPOSED PROJECT

15. To resolve the low voltage and voltage drop concerns on the 138 kV and 69 kV systems caused by the N-1-1 contingency described above, PPL Electric proposes to build a more reliable double bus double breaker 500 kV yard at the Wescosville 500-138-69 kV Substation² and to rebuild the existing single-circuit Breinigsville-Alburtis 500 kV Transmission Line to a double-circuit configuration.

16. The proposed Project will extend approximately 6 miles from the existing Breinigsville 500-138-69 kV Substation in Upper Macungie Township, Lehigh County, to the existing Alburtis 500-230 kV Substation in Lower Macungie Township, Lehigh County. Upon completion, the 500 kV circuit from Breinigsville 500-138-69 kV Substation to the Alburtis 500-230 kV Substation will be renamed to the Breinigsville-Alburtis #1 & #2 500 kV Transmission Line.

17. The rebuild Project will use a combination of conductor and ground wire types due to audible noise constraints and the varying fiber path taken along the circuit. The double-circuit double bundle design between the Alburtis 500-230 kV Substation and Structure 1 and between the Breinigsville 500-138-69 kV Substation and Structure 27 will utilize six (6) conductors that make up three (3) double bundle phases and two (2) overhead ground wires per circuit. The double-circuit triple bundle design between Structure 1 and Structure 27 will utilize nine (9) conductors that make up three (3) triple bundle phases and one (1) optical ground wire per circuit. A description of the conductor and ground wire types used for the proposed Project is provided in Attachment 2 to this Letter of Notification.

² The 500-138 kV transformer will be rearranged and will no longer be directly tapped from the Susquehanna-Wescosville 500 kV Transmission Line. The Susquehanna-Wescosville 500 kV Transmission Line will be terminated into the new 500 kV yard as the Susquehanna-Wescosville and Wescosville-Breinigsville 500 kV Transmission Lines. As a result, the 500-138 kV transformer will still remain in service after the loss of the Susquehanna-Wescosville 500 kV Transmission Line.

18. To rebuild the existing single-circuit Breinigsville-Alburtis 500 kV Transmission Line to a double-circuit configuration, PPL Electric will: (i) replace 21 existing H-frame structures with 21 new H-frame structures; (ii) replace 2 H-frame structures with new two-pole structures; (iii) install 2 new H-frame structures at the Breinigsville 500-138-69 kV Substation; (iv) replace 3 two-pole structures with 3 new two-pole structures; and (v) replace 1 monopole at the Alburtis 500-230 kV Substation with a new two-pole structure. In total, the Project will require the replacement of 23 existing structures within the right-of-way, and the replacement of 4 existing structures and the installation of 2 new structures on PPL Electric's substation properties as further described in Section IV below.

19. A detailed map of the proposed the proposed Project, including the structure locations, is provided in Figure 3-1 to Attachment 3, and an engineering description is provided in Attachment 2.

20. The proposed Project will resolve the low voltage and unacceptable voltage drop issues at the Breinigsville 500-138-69 kV Substation as further explained in Attachment 1 to this Letter of Notification. The proposed Project also will provide a third 500 kV source to the Breinigsville 500-138-69 kV Substation, which will avoid any interruptions in service during maintenance of or outages on the 500 kV transmission lines.

21. The proposed Project has been presented at the PJM Mid-Atlantic Sub-Regional RTEP stakeholder meeting on April 9, 2015 and has been approved as supplemental project s0864 in the PJM RTEP.

22. The total estimated cost of the proposed Project is approximately \$33 million.³

³ The estimated cost for the proposed Project is an order-of-magnitude estimate developed using averages of recent costs for similar projects and without an in-depth analysis of filed investigation. The estimated cost is subject to change as the constructability of the Project, sequence of construction, and other factors that may affect cost are identified and analyzed as the Project progresses.

23. Upon Commission approval, the Project has a scheduled construction start date of May 2018 to support the in-service date of March 2019.

III. HEALTH AND SAFETY

24. The proposed Project will not create any unreasonable risk of danger to the public health or safety.

25. The Project will be designed, constructed, operated, and maintained in a manner that meets or surpasses all applicable National Electrical Safety Code (“NESC”) minimum standards and all applicable legal requirements. Descriptions PPL Electric’s design criteria and safety practices are provided in Attachment 4 to this Letter of Notification.

26. Consistent with its Magnetic Field Management Program, the proposed Project will utilize structures that have a ground clearance that is three feet higher than NESC standards. In addition, upon completion of the project, the Breinigsville-Alburtis 500 kV Transmission Line will be double-circuit lines that will be reverse phased. This measure will further reduce the potential for exposure to magnetic fields. A description of PPL Electric’s Magnetic Field Management Program is provided in Attachment 2 to this Letter of Notification.

IV. DESCRIPTION OF THE RIGHT-OF-WAY

27. The entire Project will be constructed entirely within the existing Breinigsville-Alburtis 500 kV Transmission Line rights-of-way and on PPL Electric’s property for the Breinigsville 500-138-69 kV and Alburtis 500-230 kV Substations.

28. The Breinigsville-Alburtis 500 kV Transmission Line extends approximately 6 miles from the existing Breinigsville 500-138-69 kV Substation in Upper Macungie Township, Lehigh County, to the existing Alburtis 500-230 kV Substation in Lower Macungie Township, Lehigh County. From the Breinigsville Substation, the line travels in a southwesterly direction

through agricultural fields before turning sharply to the southeast and proceeding primarily across agricultural fields and adjacent to forested lands, but also extending through several residential areas before reaching the Alburdis Substation. A description of the existing right-of-way is provided in Attachment 3.

29. Two new and four replacement structures will be located entirely on the PPL Electric-owned properties for the Breinigsville 500-138-69 kV Substation or Alburdis 500-230 kV Substation. The remaining 23 replacement structures will be located in close proximity to and have heights similar to the existing structures as explained in Attachment 2 and as shown in Figure 3-1 to Attachment 3.

30. As explained in Attachment 3 to this Letter of Notification, land use and environmental impacts are anticipated to be minimal due to the fact that the Project will be constructed entirely within the existing right-of-way for the Breinigsville-Alburdis 500 kV Transmission Line and on PPL Electric's substation properties. Where practical, PPL Electric will use previously established access roads for construction to further reduce interference with existing land uses.

31. The Project area previously has been cleared of vegetation. As a result, limited vegetation management will be required for this project. In areas where vegetation management is required to complete the project, PPL Electric will apply its "*Specifications for Transmission Vegetation Management LA-79827*" to mitigate any impacts.

32. No communication towers, pipelines, or other utilities will be affected by the proposed Project.

33. PPL Electric does not anticipate any interference with airport operations because of the distance from the Project area, the presence of existing electrical facilities in the Project

area, and the new/replacement tower structures will be similar height to the existing facilities. However, PPL Electric will file any required documentation with the Federal Aviation Administration and the Pennsylvania Department of Transportation, Bureau of Aviation.

34. The Project area contains no state lands, national parks, state parks, or local parks.

35. The existing Breinigsville-Alburtis 500 kV Transmission Line currently traverses one farm preserved through the Lehigh County Farmland Preservation Program. No new or replacement structures will be installed on this preserved farmland.

36. The Project will not traverse or affect any unique geological, scenic, or natural areas.

37. The Project will not affect any recreational areas or natural landmarks.

38. PPL Electric will coordinate with the Pennsylvania Historical and Museum Commission ("PHMC") regarding any potential impacts the proposed Project may have on cultural and archaeological resources.

39. The existing Breinigsville-Alburtis 500 kV Transmission Line currently crosses four waterways. These streams currently are spanned by the existing single-circuit Breinigsville-Alburtis 500 kV Transmission Line and will be spanned by the proposed second 500 kV circuit (three conductor wires). No permanent impacts to these streams are anticipated.

40. The existing Breinigsville-Alburtis 500 kV Transmission Line right-of-way crosses several wetland systems. PPL Electric will avoid impacts to wetlands and streams where possible by aerially spanning these features.

41. The existing Breinigsville-Alburtis 500 kV Transmission Line currently spans a 100-year floodplain. No new or replacement structures will be installed in the 100-year floodplain.

42. PPL Electric will obtain permits and other authorizations from the County Conservation District, Pennsylvania Department of Environmental Protection and the United States Army Corps of Engineers, as needed, and will comply with all of the terms and conditions placed on those permits or authorizations.

43. PPL Electric will acquire any required soil erosion and sedimentation control permits and will comply with any conditions placed on those permits.

44. PPL Electric has consulted with state and federal agencies to obtain information regarding endangered and threatened species in close proximity to the Project. The Pennsylvania Department of Conservation and Natural Resources responded that there was no known impact to species under their jurisdiction, and no further review by their agency was required.

45. The Pennsylvania Game Commission noted that species or resources of concern may be located in the vicinity of the Project, but determined that no impact is likely and no further coordination is necessary.

46. The Pennsylvania Fish and Boat Commission noted the potential for the State-threatened Eastern Spadefoot Toad (*Scaphiopus holbrookii*) within the Project area. PPL Electric has conducted the required habitat survey and will coordinate with Pennsylvania Fish and Boat Commission to incorporate acceptable avoidance measures into the Project.

47. The U.S. Fish and Wildlife Service noted that the proposed Project is located within the known range of the federally threatened Bog Turtle (*Clemmys muhlenbergii*). Based on PPL Electric's habitat assessment of the wetlands within the Project area, the U.S. Fish and Wildlife Service determined that a qualified biologist will need to be on-site during work that is being conducted within 300-feet of the identified potential habitat areas.

48. PPL Electric will continue to consult with the jurisdictional agencies regarding potential impacts to protected species. PPL Electric will obtain all approvals and permits necessary for the construction of the Project, and will comply with any conditions placed on those permits.

V. NOTICE

49. PPL Electric has provided information regarding the Project to representatives of Upper and Lower Macungie Townships, and Lehigh County. These entities have not objected to the proposed Project.

50. Copies of this Letter of Notification will be served on the governmental agencies, municipalities, and other public entities agencies in accordance with 52 Pa. Code § 57.72(d)(3).

51. Copies of this Letter of Notification will be served on the owners of land subject to the right-of-way and easement in accordance with 52 Pa. Code § 57.72(d)(3).

VI. LETTER OF NOTIFICATION

52. PPL Electric is proceeding by means of a Letter of Notification, instead of a full Application, pursuant to the Commission's regulations at 52 Pa. Code § 57.72(d)(1)(i).

53. The proposed Project will be located entirely within the existing Breinigsville-Alburtis 500 kV Transmission Line right-of-way and on PPL Electric-owned substation property. No additional right-of-way is required for this Project.

54. The Project will require two new and four replacement structures that will be located entirely on the PPL Electric-owned properties for the Breinigsville 500-138-69 kV Substation or Alburtis 500-230 kV Substation. The Project also will require 23 replacement structures will be located in close proximity to and have heights similar to the existing structures as explained in Attachment 2 and as shown in Figure 3-1 to Attachment 3.

55. Based on the foregoing, PPL Electric submits that the proposed Project will not substantially alter the existing Breinigsville-Alburtis 500 kV Transmission Line right-of-way and, therefore, qualifies as a Letter of Notification.


56. This Letter of Notification is filed on the date set forth below. As provided in 52 Pa. Code § 57.72(d)(5), the Commission will review and, by order, approve or disapprove this Letter of Notification. If the Commission approves this Letter of Notification, the proposed Project will be constructed as proposed herein without the formal application process set forth at 52 Pa. Code §§ 57.71, *et seq.*

VII. CONCLUSION

WHEREFORE, PPL Electric Utilities Corporation respectfully requests Pennsylvania Public Utility Commission approval to install the second, 6-mile 500 kV circuit to the existing Breinigsville-Alburtis 500 kV Transmission Line in Upper and Lower Macungie Townships, Lehigh County, Pennsylvania, as explained above and in the Attachments hereto.

Respectfully submitted,

Kimberly A. Klock (ID #89716)
PPL Services Corporation
Two North Ninth Street
Allentown, PA 18101
Voice: 610-774-4254
Fax: 215-587-1444
E-mail: kklock@pplweb.com


David B. MacGregor (I.D. # 28804)
Christopher T. Wright (I.D. # 203412)
Post & Schell, P.C.
17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
Voice: 717-731-1970
Fax: 717-731-1985
E-mail: dmacgregor@postschell.com
E-mail: cwright@postschell.com

Date: November 27, 2017

Attorneys for PPL Electric Utilities Corporation

VERIFICATION

I, STEPHANIE R. RAYMOND, being the VICE PRESIDENT-TRANSMISSION AND SUBSTATIONS at PPL Electric Utilities Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: 11/16/17

Stephanie R. Raymond

RECEIVED

2017 NOV 27 AM 9:39

PA PUC
SECRETARY'S BUREAU
FRONT DESK

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing **Letter of Notification** has been served upon the following persons, in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

VIA CERTIFIED MAIL RETURN RECEIPT REQUESTED

PA Department of Environmental Protection
PO Box 2063
Market Street State Office Building
Harrisburg, PA 17105-2063
Attn: Office of Field Operations

U.S. Army Corps of Engineers
Philadelphia District
Regulatory Branch
Wanamaker Building, 100 Penn Square East
Philadelphia, PA 19107-3390

PA Department of Transportation
Commonwealth Keystone Building
400 North Street, 9th Floor
Harrisburg, PA 17120
Attn: Jason Sharp, Acting Chief Counsel

U.S. Fish and Wildlife Services
Pennsylvania Field Office
110 Radnor Road, Suite 101
State College, PA 16801
Attn: Lora Lattanzi

PA Historical and Museum Commission
Bureau for Historic Preservation
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120-0053
Attn: Mr. Douglas C. McLearn, Chief

Lehigh County Conservation District
4184 Dorney Park Road
Allentown, PA 18104

Lehigh County Planning Commission
961 Marcon Boulevard - Suite 310
Allentown, PA 18109

PA Department of Conservation
and Natural Resources
Rachel Carson State Office Building
PO Box 8767
400 Market Street
Harrisburg, PA 17105-8767
Attn: Rebecca Bowen

Lower Macungie Township
Board of Commissioners
3400 Brookside Road
Macungie, PA 18062
Attn: Douglas Brown

PA Game Commission
2001 Elmerton Avenue
Harrisburg, Pennsylvania 17110-9797
Attn: Olivia Mowery

Lower Macungie Township
Planning Commission
3400 Brookside Road
Macungie, PA 18062
Attn: Maury Robert

PA Fish and Boat Commission
450 Robinson Lane
Bellefonte, PA 16823-9620
Attn: Christopher A. Urban

Upper Macungie Township
Board of Commissioners
8330 Schantz Road
Breinigsville, PA 18031
Attn: James Brunell

Upper Macungie Township
Planning Commission
8330 Schantz Road
Breinigsville, PA 18031
Attn: Charles E. Deprill

Alburtis Rod & Gun Club
C-O Fred Beitler
PO Box 333
Alburtis, PA 18011-0333

Barry C. Arndt
335 Parkside Drive
Macungie, PA 18062-1009

Daniel J. & Deborah A. Bailey
937 Orange Tip Way
Breinigsville, PA 18031

Roger E. Bauer
8635 Mountain Road
Alburtis, PA 18011-9326

Paul S. Bilous
Stephanie Schlofer
8540 Oak Hollow Lane
Macungie, PA 18062

Dennis J. & Linda L. Bundra
1811 Amanda Drive
Breinigsville, PA 18031-1102

Christopher P. Burns
8351 S. Ridge Drive
Macungie, PA 18062

Adam F. & Caroline J Carbone
1189 Bramble Drive
Breinigsville, PA 18031

Randy L. Dalrymple
Hind M. Vanic
1485 Buck Hill Lane
Breinigsville, PA 18031

Danweber Land Trust
Charles Danweber & J. Danweber Trustee
3650 Schoeneck Road
Macungie, PA 18062-9637

Ryan M. & Annamay E. Daumer
1355 Buck Hill Lane
Breinigsville, PA 18031

Brian & Erika De Angelis
1147 Bramble Drive
Breinigsville, PA 18031

Brian J. & Lynn R. Donohue
8510 S Ridge Drive
Macungie, PA 18062-9142

Dennis W. Dorney
9590 Viceroy Lane
Breinigsville, PA 18031

Scott E. & Christina L. Dotter
1119 Bramble Drive
Breinigsville, PA 18031

Carl D. & Lois G. Dries
8607 Hensingersville Road
Macungie, PA 18062-9069

L. John & Barbara J. Finady
8675 Mountain Road
Alburtis, PA 18011-9326

Amy M. & Alan W. Heckman
1217 Bramble Drive
Breinigsville, PA 18031

Thomas S. & Elizabeth E. Hemphill
8950 Hemphill Road
Alburtis, PA 18011-9305

Gregory M. & Danielle Holland
8554 S Ridge Drive
Macungie, PA 18062

Philip C. & Dorothy A. Horlacher
1814 Amanda Drive
Breinigsville, PA 18031-9751

Daniel E. Hunsicker
2731 Hilltop Road
Mertztown, PA 19539-9401

Benjamin M. & Erin J. Jacobs
1161 Bramble Drive
Breinigsville, PA 18031-7700

Lori A. King
941 Orange Tip Way
Breinigsville, PA 18031

Bruce K. Klotz
1810 Amanda Drive
Breinigsville, PA 18031-1101

Carl R. Koch, Jr.
8413 Mountain Road
Macungie, PA 18062

John F. & Kimberly A. Krafczyk
945 Orange Tip Way
Breinigsville, PA 18031

Landston Equities LLC
3150 Coffeetown Road
Orefield, PA 18069

Lehigh County Authority
PO Box 3348
Allentown, PA 18106-0348

Lehigh Grains Inc.
3150 Coffeetown Road
Orefield, PA 18069-2511

Liberty Property Limited Partnership
ATTN: Accounts Payable Dept.
500 Chesterfield Parkway
Malvern, PA 19355

Steven W. Lutz, Jr
8427 S Ridge Drive
Macungie, PA 18062-9143

Dipen V Meghpara
P. Bharat-Patel
1395 Buck Hill Lane
Breinigsville, PA 18031

Christopher H. Michels
8972 Hemphill Road
Alburtis, PA 18011-9305

George D. & Rhonda J. Moore
933 Orange Tip Way
Breinigsville, PA 18031

Gustavo & Patricia Murillo
1465 Buck Hill Lane
Breinigsville, PA 18031

Joseph R. & Laurie J. Neusch
1203 Bramble Drive
Breinigsville, PA 18031

Jeffery L. & Melanie Oswald
3740 Gun Club Road
Alburtis, PA 18011-9556

Ronald C. & Catherine P. Paff
9353 Newtown Road
Breinigsville, PA 18031-1810

Ajaybhai A. & Hinaben A. Patel
1415 Buck Hill Lane
Breinigsville, PA 18031

Pennsylvania Power & Light Co.
PPL - Real Estate Taxes (GENN2)
2 North Ninth Street
Allentown, PA 18101

Pennsylvania Lines LLC
C-O Norfolk Southern Railway Company
110 Franklin Rd SE
Roanoke, VA 24042-0028

PPL Electric Utilities Corporation
2 North Ninth Street
Allentown, PA 18101

Ramesh & Veena Raghav
1092 Bramble Drive
Breinigsville, PA 18031

Eric & Rosalba Richburg
9600 Viceroy Lane
Breinigsville, PA 18031

Lorna M. Rizos
9418 Lisa Lane
Breinigsville, PA 18031-1132

Donald T. & Marian E. Rohrbach
8388 Hensingersville Road
Alburtis, PA 18011-9302

Runquist A E & S A Runquist Family Trust
1245 Bramble Drive
Breinigsville, PA 18031

Isadore Russell
9520 Monarch Lane
Breinigsville, PA 18031

Tiamiyu O. & Bola A. Salau
1133 Bramble Drive
Breinigsville, PA 18031

Jessica T. & Fahed I. Sallit
1819 Amanda Drive
Breinigsville, PA 18031

Robert J. Sarmir
1823 Amanda Drive
Breinigsville, PA 18031-1101

Nicholas Sauchelli
Jill F. Goldman
1818 Amanda Drive
Breinigsville, PA 18031

Sandra A. Shellhammer
1815 Amanda Drive
Breinigsville, PA 18031-1102

David J. Simmons, Sr.
8519 Oak Hollow Lane
Macungie, PA 18062-9149

John, Jr. & Patricia Ann Skrip
9850 Newtown Road
Breinigsville, PA 18031-1808

Evan M. & Donna J. Slotter
8576 Hensingersville Road
Macungie, PA 18062-9068

Zainab Soonasra, et al.
1175 Bramble Drive
Breinigsville, PA 18031

David P. & Patience L. Spess
8581 Hensingersville Road
Macungie, PA 18062-9066

Jane Z. Taintor Revocable Trust
PO Box 841
Emmaus, PA 18049-0841

Alex J. & Jennifer Taverez
1405 Buck Hill Lane
Breinigsville, PA 18031

Kate Tercha
2048 Tercha Road
Fogelsville, PA 18051-2029

Trexler Field HOA, Inc.
5930 Hamilton Blvd.
Allentown, PA 18106-9654

Trexler Field Twin Home Project LLC
5930 Hamilton Blvd.
Allentown, PA 18106-9654

David P. & Lynn J. Turoscy
1375 Buck Hill Lane
Breinigsville, PA 18031

Upper Macungie Twp.
8330 Schantz Road
Breinigsville, PA 18031-1510

Donald J. & Elizabeth A. Vaughn
8467 Oak Hollow Lane
Macungie, PA 18062-9149

Arturo & Danielle M. Villarreal
1315 Buck Hill Lane
Breinigsville, PA 18031

Joseph E. & Brooke N. Voda
1231 Bramble Drive
Breinigsville, PA 18031

Isaac J. & Rebekah Westdorp
9580 Viceroy Lane
Breinigsville, PA 18031-2105


Steven L. Wetzel
17 Wetzel Road
Macungie, PA 18062-2023

Edward C., Jr & Cindy Wigfield
8487 S Ridge Drive
Macungie, PA 18062-9100

Michael P. Zeigler
Jesse E. Stahl
1435 Buck Hill Lane
Breinigsville, PA 18031

Daniel & Shimara Zica
1335 Buck Hill Lane
Breinigsville, PA 18031

Date: November 27, 2017



Christopher T. Wright

RECEIVED
2017 NOV 27 AM 9:39
PA PUC
SECRETARY'S BUREAU
FRONT DESK