



An Exelon Company

Richard G. Webster, Jr.
Vice President
Regulatory Policy & Strategy
PECO
2301 Market Street
515
Philadelphia, PA 19103

Telephone 215.841.5777
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

June 8, 2018

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Second Floor
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-00991220
Request for Major Event Exclusion (March 02, 2018 - March 10, 2018) – Replacement
Filing**

Dear Secretary Chiavetta:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes.

PECO Energy Company previously made this filing on April 12, 2018. The filing and Service Outage Report were not sent under separate cover letters. This letter transmits for filing with the Commission a replacement filing. The enclosed report contains the Request for Major Exclusion. The major event occurred **March 02, 2018 through March 10, 2018** and was caused by heavy winds and snow. The combination caused damage to aerial and underground electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Webster", followed by a horizontal line.

cc: K. Monaghan, Bureau of Audits
P. Diskin, Bureau of Technical Utility Services
J. McKain (PECO)

Enclosures

mec

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
RELIABILITY REPORTING PURPOSES TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
P O BOX 3265
HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy Company
Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:
Rich Cornforth Director of Engineering
(Name) *(Title)*

3. Telephone number: 215-841-5843
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 603,697
Total number of customers in service territory: 1,635,159

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
Delaware County	1,085
Chester County	599
Montgomery County	960
Bucks County	542
Philadelphia	428
York County	42

- (c) Reason for interruption or outage, including weather data where applicable:

High winds and heavy snow caused damage to PECO's electric distribution system resulting in over 603,697 service interruptions.

Forecast issued on Thursday 03/01/2018 @ at 14:18

A VERY LARGE STORM IS EXPECTED TO DEVELOP OVER THE ATLANTIC. AS A RESULT, WINDS WILL INCREASE DRAMATICALLY FRIDAY FROM THE NORTH AND CONTINUE FRIDAY NIGHT. WINDS WILL THEN DIMINISH GRADUALLY INTO SATURDAY. WINDS ARE EXPECTED TO GUST 40 TO 50 MPH BY LATE IN THE DAY FRIDAY. THESE WINDS WOULD CONTINUE FRIDAY EVENING.

Forecast issued on Friday 03/02/2018 @14:46

VERY STRONG LOW PRESSURE OFF THE MID-ATLANTIC COAST TODAY AND THAT WILL CONTINUE TO RESULT IN VERY STRONG WINDS FOR THE TERRITORY, WITH FREQUENT GUSTS 45-50 MPH AND SOME PEAK GUSTS TO 55 MPH POSSIBLE. THAT LOW PRESSURE WILL LINGER OFF THE COAST INTO THE WEEKEND, SO WINDS WILL DIMINISH ONLY GRADUALLY. SNOW THIS AFTERNOON WILL DECREASE THIS EVENING AND END TONIGHT. HIGH PRESSURE BUILDS IN LATE SUNDAY INTO TUESDAY.

- (d) The number of utility workers and others assigned specifically to the repair work:
4,315
-

- (e) The date and time of the first notification of a service interruption: 03/02/2018 at 06:59

- (f) The actual time that service was restored to the last affected customer: 03/10/2018 at 14:18
-

Remarks: All PECO employees supported emergency response efforts in conjunction with crews from PECO's Exelon sister utility ComEd, located in Illinois; as well as utilities from Texas, Louisiana, Mississippi, Georgia, Arkansas, Florida, Michigan, Ohio, Illinois, Delaware, Maryland, and the Carolinas assisted in PECO's restoration effort
