

Richard G. Webster, Jr.
Vice President
Regulatory Policy & Strategy

PECO
2301 Market Street
S15
Philadelphia, PA 19103

Telephone 215.841.5777
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

June 8, 2018

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Second Floor
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-00991220
Request for Major Event Exclusion (March 07, 2018 - March 11, 2018) –
Replacement Filing**

Dear Secretary Chiavetta:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes.

PECO Energy Company previously made this filing on April 12, 2018. The filing and Service Outage Report were not sent under separate cover letters. This letter transmits for filing with the Commission a replacement filing. The enclosed report contains the Request for Major Exclusion. The major event occurred **March 07, 2018 through March 11, 2018** and was caused by heavy winds and snow. The combination caused damage to aerial and underground electric facilities.

If you have questions regarding this matter, please call me at 215-841-5777.

Sincerely,



cc: K. Monaghan, Bureau of Audits
P. Diskin, Bureau of Technical Utility Services
J. McKain (PECO)

Enclosures

mec

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
RELIABILITY REPORTING PURPOSES TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
P O BOX 3265
HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy Company
Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:
Rich Cornforth Director of Engineering
(Name) *(Title)*

3. Telephone number: 215-841-5843
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 191,272
Total number of customers in service territory: 1,635,159

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
Delaware County	292
Chester County	158
Montgomery County	407
Bucks County	869
Philadelphia	167
York County	10

(c) Reason for interruption or outage, including weather data where applicable:

High winds and heavy snow caused damage to PECO's electric distribution system resulting in over 191,272 service interruptions.

Forecast issued on Tuesday 03/06/2018 @ at 15:06

CONDITIONS WILL REMAIN DRY FOR TODAY, BUT AN APPROACHING STORM SYSTEM WILL BRING A PERIOD OF RAIN MIXED WITH SNOW LATER THIS EVENING AND INTO WEDNESDAY. PRECIPITATION WILL THEN TURN OVER TO ALL SNOW LATE WEDNESDAY AND DIMINISH INTO WEDNESDAY EVENING. AS SUCH, TOTAL SNOWFALL ACCUMULATION COULD RANGE FROM 2-3 INCHES, WITH LOCALLY HIGHER AMOUNTS POSSIBLE FOR ISOLATED SPOTS. WINDS WILL ALSO INCREASE WEDNESDAY EVENING AS THE SYSTEM MOVES NORTHWARD. GUSTS 30 TO 32 MPH EXPECTED.

Forecast issued on Wednesday 03/07/2018 @06:58

PERIODS OF SNOW TODAY, MIXED WITH A LITTLE RAIN THIS MORNING. SNOW WILL BE MODERATE TO HEAVY IN THE AFTERNOON INTO THE EARLY EVENING. HEAVY, WET SNOW WILL GATHER ON TREES/POWER LINES WHILE WINDS INCREASE MID-DAY/EARLY AFTERNOON. WIND AND SNOW DIMINISH LATER THIS EVENING

(d) The number of utility workers and others assigned specifically to the repair work:
4,315

(e) The date and time of the first notification of a service interruption: 03/07/2018 at 04:48

(f) The actual time that service was restored to the last affected customer: 03/11/2018 at 09:45

Remarks: All PECO employees supported emergency response efforts in conjunction with crews from PECO's Exelon sister utility ComEd, located in Illinois; as well as utilities from Texas, Louisiana, Mississippi, Georgia, Arkansas, Florida, Michigan, Ohio, Illinois, Delaware, Maryland, and the Carolinas assisted in PECO's restoration effort
