

8 Process Water Use.

The information in this question is restricted to Process wastewater discharged to the sewer (Question 5, Item c and Question 6, Item a). Note that Item e is the water used by the process and Items h and i are the wastewater discharge volumes. If some process water is contained in the product, or is evaporated, there will be a lower discharge volume than water use volume. Processes A, B, and C are the processes indicated by the SIC codes in Question B.2. If the various process discharges cannot be identified easily in this way, provide a description of each process listed in Question 8 on a separate sheet. You should also indicate these process discharges on the schematic provided for Question 7.

Section E-Wastewater Information

This section focuses on wastewater that is discharged, either to the sewer system or to the environment. Other water losses such as evaporation or incorporation in a product are tabulated in the previous section and are not included in this Section.

1 Wastewater Discharges.

Provide estimates of the wastewater discharged to the sewer in the left column, and to any other points (such as direct discharges of cooling water to a stream) in the right column, for each water use. Information for Process wastewater (processes A, B, and C) should agree with the discharge information in Section D, Question 8. Note that most direct discharges to the environment require an NPDES discharge permit issued by the Pennsylvania DEP. If you have such a permit report the permit number in the space provided.

The total discharge to the sanitary sewer reported in the left column should equal the total reported in Question 6, Item a. The total discharged to other points should equal the total reported in Question 6, Item b.

3 Categorical Pretreatment Standards.

If you checked any of the boxes in Question B.3, your facility might be subject to National Categorical Pretreatment Standards. These standards are found at 40 CFR Sections 404 through 472. If you are not sure if a Categorical Pretreatment Standard applies to your facility, check the appropriate box and Pennsylvania-American Water Company will assist you in making that determination.

Section F-Sewer Information

These questions are self-explanatory.

Section G-Wastewater Pretreatment

Wastewater pretreatment includes any steps taken to change the nature of the wastewater that is discharged to the sewer system. Grease traps, sedimentation basins, pH control, and other such treatment should be reported as well as more elaborate treatment processes that you may employ.

Section H-Characteristics of Discharges

1 *Inventory of Chemicals.*

The extensive list of chemicals in Question 1 is included to allow a comprehensive evaluation of the wastewater characteristics. To complete this table efficiently, you may rely on general sources of information readily available to you. These include MSD sheets for materials used in the facility, label information, and manufacturer's literature. Please try to report comprehensively. There are five possible responses for each chemical. Their meanings are discussed below.

- **No Response.** If no response is provided for a particular chemical (no box is checked), the response is interpreted to be that, after reasonable inquiry, you have no information about the chemical. You are required to make a reasonable inquiry and a no response in this section will imply that you have investigated this chemical and have been unable to determine if it is present or not. Pennsylvania-American Water Company may require wastewater testing for confirmation purposes for those chemicals for which no response is provided.
- **Known Present.** If the substance is known to be in use at your facility, AND if it was detected in an analysis of your wastewater, then check this box.
- **Suspected Present.** If the substance is known to be present in raw materials, is produced in the facility, or is otherwise known to be normally present at the facility, but no testing has been done to see if it is in the wastewater, then check this box.
- **Non-D.** If you have analyzed your wastewater discharge for a substance and it has not been detected, check this box. This might apply even if the substance is known to be used in the facility but there is no reason to believe that it might be in the wastewater AND testing has confirmed this.
- **Suspected Not Present.** If, based on a review of available information, you do not believe a particular chemical is used at your facility, you should check the box under Suspected Not Present. Checking this box implies a higher degree of investigation than checking no box at all.

6 *Hazardous Waste Reporting.*

All industrial dischargers that discharge hazardous waste to domestic sewers are required by federal regulations (40 CFR 403.12(p)) to report the nature and volume of these discharges to EPA. Note that the discharge of hazardous wastes to domestic sewers is not prohibited. Reporting such discharges is not normally an admission of any illegal activity, but failure to report when required may result in imposition of penalties by EPA.

Note that if you do discharge hazardous wastes to the sewer system, you are required to report the information indicated and to provide the statement that appears on in Section H. You must have in place a program of the nature described in that statement.

Because this section of the questionnaire has to do with federal regulations, errors or false statements made in answering the questions may subject you to penalties by EPA or DEP. You may wish to retain the services of an environmental consultant to advise you as to your rights and responsibilities under these regulations.

Section I-Non-Discharged Wastes

This section provides information about any wastes that are NOT disposed to the sewer system. This information is important in assessing the potential for spills and leaks, and may be used to verify that wastes are properly disposed of. If no wastes other than normal office and cafeteria trash are generated on site, indicate so in Question 1 of this section and proceed to Section J of the questionnaire. If such wastes are generated, provide information about their nature and volume and how they are disposed of in the remainder of this section.

Section J-Certification

Whether you have completed the entire form or have only completed portions of the form as provided by these instructions, you must certify that the information provided is correct. The Authorized Representative reported in Section A, Question 4 must sign this certification.

Please note that there may be penalties for providing false information. Review the information that is included in the form before signing it and sending it to Pennsylvania-American Water Company.

Also note the requirement to correct any errors or changes in information provided if changes occur (or an error is discovered) in the future.

PENNSYLVANIA-AMERICAN WATER COMPANY
COATESVILLE WASTEWATER TREATMENT PLANT

For Official Use:

INDUSTRIAL WASTEWATER DISCHARGE QUESTIONNAIRE

INSTRUCTIONS: Instructions for completing this form are attached. Please refer to the instructions before completing.
The completed and signed questionnaire should be mailed to:
Pennsylvania-American Water Company, c/o Terrance McKim, 100 Cheshire Court, Suite 104, Coatesville, PA 19320
Requests for confidential treatment of information provided herein shall be governed by
procedures specified in 40 CFR Part 2.

SECTION A - GENERAL INFORMATION

1. Company Name: _____

2. Mailing Address: _____
Municipality: _____

3. Facility Address: (If different from mailing address) _____
(If more than one facility discharges, see Instructions.)

4. Name of Authorized Representative: _____
(See instructions for definition of Authorized Representative. Attach delegation statement if necessary.)
Title _____ Telephone No.: () _____

5. Alternative person to contact concerning information provided on this form:
Name and Title: _____
Telephone No.: () _____

6. Describe activities conducted at this facility (in general). _____

7. Does this facility discharge OR HAVE THE POTENTIAL TO DISCHARGE any wastewater OTHER THAN from restrooms and cafeterias?
(Before answering this question, please refer to the Instructions for this question.)

- Yes If the answer to this question is "Yes", continue to question 8.
- No If the answer to this question is "No", you may skip to **Section I** on page 10.
You must also sign the certification statement in Section J on the last page of this form.

8. a. If this facility discharges ONLY non-contact cooling water, check here:
- b. If you answered question 7 "Yes" ONLY because of a Potential to Discharge, through floor drains or because of potential leaks or spills, check here:

If you checked either box in Question 8, see Instructions for how to complete this questionnaire.

If you answered Question 7 "Yes" AND you did NOT check one of the boxes in Question 8, continue on to Section B.

SECTION B - PRODUCT OR SERVICE INFORMATION

1. Briefly describe the manufacturing, production, or service activities your firm conducts. Indicate which activities produce industrial waste: (Attach additional sheets if necessary.) For a definition of "industrial waste" see instructions for **Section B**.

2. Indicate applicable Standard Industrial Classification (SIC) Code(s) for each process at your facility (If more than one applies, list in descending order of importance.)

a. _____ b. _____ c. _____

3. If your facility manufactures any of the products or employs any of the manufacturing processes listed below, AND any of these processes generate wastewater or waste sludge, place a check mark beside the appropriate activity (check all that apply).

- | | | |
|---|---|---|
| <input type="checkbox"/> Aluminum Forming | <input type="checkbox"/> Gum & Wood Chemicals | <input type="checkbox"/> Phosphating or Chromating |
| <input type="checkbox"/> Anodizing/coloring | <input type="checkbox"/> Inorganic Chemicals | <input type="checkbox"/> Plastic & Synthetic Materials Mfr. |
| <input type="checkbox"/> Battery Manufacturing | <input type="checkbox"/> Iron & Steel Manufacturing | <input type="checkbox"/> Plastics Molding/Forming |
| <input type="checkbox"/> Coil Coating | <input type="checkbox"/> Leather Tanning and Finishing | <input type="checkbox"/> Porcelain Enameling |
| <input type="checkbox"/> Copper Forming | <input type="checkbox"/> Metal Molding and Casting | <input type="checkbox"/> Printed Circuit Board Mfg. |
| <input type="checkbox"/> Dairy Products Processing | <input type="checkbox"/> Nonferrous Metals | <input type="checkbox"/> Pulp & Paper Products |
| <input type="checkbox"/> Electric & Electronic Components | <input type="checkbox"/> Organic Chemicals Mfg. | <input type="checkbox"/> Rubber Products |
| <input type="checkbox"/> Electroplating | <input type="checkbox"/> Paint & Ink Formulating | <input type="checkbox"/> Slaughtering/Packing/Rendering |
| <input type="checkbox"/> Explosives Manufacturing | <input type="checkbox"/> Paving & Roofing Materials | <input type="checkbox"/> Soap & Detergents Mfg. |
| <input type="checkbox"/> Fertilizer Products | <input type="checkbox"/> Pesticides Manufacturing | <input type="checkbox"/> Steam Electric Power Generation |
| <input type="checkbox"/> Food/Edible Products Processing | <input type="checkbox"/> Pesticides Formulating/Packaging | <input type="checkbox"/> Textile Mills |
| <input type="checkbox"/> Ferroalloy Manufacturing | <input type="checkbox"/> Petroleum Refining | <input type="checkbox"/> Timber Products Processing |
| <input type="checkbox"/> Glass Manufacturing | <input type="checkbox"/> Pharmaceutical Manufacturing | <input type="checkbox"/> Waste Treatment or Disposal |

4. List all materials, including industrial process chemicals, chemical additives and catalysts, water treatment chemicals, and cleaning agents (other than household type) stored or used at this facility. Appendix A of the instructions illustrates an example of such a list. (Attach additional sheets if necessary.)

MATERIAL	QUANTITY (indicate units)	USE
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Company Name: _____

SECTION C - FACILITY OPERATIONAL CHARACTERISTICS

1. Shift Information:
- a. Number of shifts per work day: 1 2 3
- b. Work days: Monday Tuesday Wednesday Thursday
 Friday Saturday Sunday
- c. Number of employees per shift: 1 st _____ 2 nd _____ 3 rd _____
- d. Shift start times: 1 st _____ 2 nd _____ 3 rd _____
- e. Shift end times: 1 st _____ 2 nd _____ 3 rd _____
2. Is operation subject to seasonal variation: Yes No
 If "Yes", indicate: Months of peak operation _____
 Maximum wastewater flow (gallons per day) _____
3. Does operation shutdown for vacation, maintenance, or other reasons? Yes No
 If "Yes", indicate period when shutdown occurs: _____
4. Are any process changes or expansions planned during the next three years that would alter wastewater volumes or characteristics? Consider both production processes, and air or water pollution control processes.
 Yes No (If yes, attach a separate sheet to this form describing the nature of the planned changes or expansions and their effects on the wastewater volume and characteristics.)
5. Are any materials recovery/reuse or water reclamation systems in use or planned?
 Yes No (If yes, attach a separate sheet to this form describing the recovery or recycling process.)
6. Has a Preparedness, Prevention and Contingency (PPC) Plan been prepared for the facility?
 Yes No **If "Yes", please attach a copy to this questionnaire.**

SECTION D - WATER USAGE

1. Water Sources: (Check as many as are applicable.)
 Private Well; Surface Water; Water Utility (Specify): _____
2. Name on the water bill: _____
3. Water Service Account Number(s): (1) _____ (2) _____
4. If water is supplied by landlord, give name and address:
 Name: _____
 Street: _____
 City: _____ Zip Code: _____

SECTION D - WATER USAGE (Cont'd)

Company Name: _____

5. List estimated average water usage on premises: (see instructions for definitions)

<u>TYPE</u>	<u>ESTIMATED AVG WATER USAGE</u> (gallons per day)	<u>TYPE</u>	<u>ESTIMATED AVG WATER USAGE</u> (gallons per day)
a. Cooling Water ...	_____	e. Equipment Washdown ...	_____
b. Boiler Feed	_____	f. Lawn Watering	_____
c. Process	_____	g. Other (Specify): _____	_____
d. Sanitary	_____		_____
		h. TOTAL of a. through g.	_____

6. List average volume wastewater discharge and other water losses:

	<u>ESTIMATED AVERAGE VOLUME</u> (gallons per day)		<u>ESTIMATED AVERAGE VOLUME</u> (gallons per day)
a. Municipal Sewer	_____	e. Evaporation	_____
b. Watercourse, Storm Drain ...	_____	f. Contained in Product ...	_____
c. Waste Haulers	_____	g. Other (Specify): _____	_____
d. Septic Tank	_____	h. TOTAL of a. through g..	_____
		<i>(Should equal TOTAL in item 5 above)</i>	

7. Attach a schematic water and wastewater flow diagram, and show all possible sources of water and wastewater flow, including overflows. The diagram should include a water balance so that all water sources and discharges are accounted for. The schematic should also identify the industrial process steps. An example of a flow diagram is attached to the instructions as Appendix B.

8. List average water usage for each process at the facility and resultant average wastewater discharge. Processes A, B, C are the same as those in Section B.2. (Attach additional sheets if necessary.)

	<u>PROCESS A</u>	<u>PROCESS B</u>	<u>PROCESS C</u>
a. Process Description	_____	_____	_____
c. Is Process	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous
d. If batch, number per day	_____	_____	_____
e. Average water use (gal/day) ...	_____	_____	_____
f. Is wastewater discharge	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous	<input type="checkbox"/> Batch <input type="checkbox"/> Continuous
g. If batch, number per day	_____	_____	_____
h. Average wastewater discharge (gal/day)	_____	_____	_____
i. Peak wastewater discharge (gal/day) ..	_____	_____	_____

Company Name: _____

SECTION D - WATER USAGE (Cont'd)

9. Describe any water treatment or conditioning processes utilized:

SECTION E - WASTEWATER INFORMATION

1. Please indicate the quantities of wastewater discharged from the processes indicated below. (Refer to **SECTION D** Items 6.a, 6.b and 8.) "Direct discharge" means directly to the environment, such as to a storm sewer or stream. For direct discharges, provide any State NPDES Permit number obtained for the discharge.

PROCESS	DISCHARGE TO SEWER (gallons/day)	DIRECT DISCHARGE (gallons/day)
A.	_____	_____
B.	_____	_____
C.	_____	_____
Sanitary Wastes	_____	_____
Boiler Blowdown	_____	_____
Cooling Water, contact	_____	_____
Cooling Water, non-contact	_____	_____
Plant and equipment washdown	_____	_____
Air Pollution Control Liquid Waste	_____	_____
Stormwater runoff to sanitary sewer	_____	xxxxxxxxxxxx
Other (Specify): _____	_____	_____
TOTALS		
(Should equal SECTION D)	Totals: _____	_____
	Part 6.a	Part 6.b

* NPDES Permit Number for direct discharges.....

2. Does your facility have floor drains which tie into the sanitary sewer system?
 Yes No

If "Yes", please attach a description of the areas that are served by the floor drains. Indicate whether chemicals, oils, or other substances are normally or occasionally present in each area. Also describe the measures in place to prevent accidental spills or leaks from entering the sewer system.

Company Name: _____

SECTION E - WASTEWATER INFORMATION (Cont'd)

3. Is the facility subject to EPA Categorical Pretreatment Standards? Yes No Don't Know
 (Facilities checking any of the items listed in **SECTION B** Part 3 might be a Categorical Industry, see Instructions.)

If "Yes", indicate which standards apply. _____

If "Yes," does the discharge currently comply with these standards? _____

SECTION F - SEWER INFORMATION

1. Attach a scaled drawing, if available, or sketch of your plant site showing the location of all sewers. Assign a sequential reference number to each building sewer (lateral) starting with No. 1. Also show location of possible sampling points for process wastewater itemized in **SECTION D** Part 8. For reference and field orientation, buildings, streets, and other prominent physical structures should be indicated on the drawing.
2. By reference number, list size, descriptive location and flow of each sewer shown in item F-1. (If more than 3, attach additional information on another sheet.)

REFERENCE NUMBER	SEWER SIZE (inches)	DESCRIPTIVE LOCATION OF SEWER CONNECTION OR DISCHARGE POINT	TYPE OF WASTE	AVERAGE FLOW (gallons/day)
1.	_____	_____	_____	_____
2.	_____	_____	_____	_____
3.	_____	_____	_____	_____

3. Is Industrial waste segregated from or combined with sanitary wastes when discharged to the sewer system?
 Segregated Combined
 If combined, with which wastes? _____

4. Is the industrial wastewater discharge to the sewer system continuously metered?
 Yes No

If "Yes", please describe the metering facilities. _____

SECTION G - WASTEWATER PRETREATMENT

1. Is any form of wastewater pretreatment practiced at this facility?
(Includes pH adjustment, filtering, precipitation, grease or silt traps, etc.) Yes No
2. Is any form of pretreatment planned for this facility within the next three years? Yes No
3. Please furnish a process flow diagram for each existing or planned pretreatment system. Include a brief description of the facilities, process equipment, by-products produced, by-product disposal method, concentrations, waste and byproduct volumes, design and operating conditions.

SECTION H - CHARACTERISTICS OF DISCHARGES

1. For each of the following, if it is used in your manufacturing or service activity, or generated as a product, by-product or waste, check whether it is KNOWN or SUSPECTED to be present in your wastewater discharge. If it is used in your facility but NOT discharged, check whether this has been confirmed by laboratory tests (NON-D) or not (Suspected Not Present). Not checking any box serves as your assertion that you have been unable to determine, after reasonable inquiry, if the substance is present at this facility. See instructions for more details. Please note that some compounds are known by other names (i.e. trichloromethane = chloroform).

CHEMICAL	KNOWN	SUSPECTED	SUSPECTED		CHEMICAL	KNOWN	SUSPECTED	SUSPECTED	
	PRESENT	PRESENT	NON-D	NOT PRESENT		PRESENT	PRESENT	NON-D	NOT PRESENT
I. METALS & INORGANICS					III. MONOCYCLIC AROMATICS				
Aluminum	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Antimony	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, chloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Arsenic	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, 1,2-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Asbestos	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, 1,3-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Beryllium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, 1,4-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cadmium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, 1,2,4-trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Chromium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, hexachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Copper	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, ethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cyanide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzene, nitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lead	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Toluene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mercury	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Toluene, 2,4-dinitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Molybdenum	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Toluene, 2,6-dinitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Nickel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	IV. PCBs				
Selenium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1016	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Silver	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1221	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Thallium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1232	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Zinc	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1242	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
II. PHENOLS & CRESOLS					PCB-1248	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol(s)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1254	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 2-chloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PCB-1260	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 2,4-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	V. ETHERS (E)				
Phenol, 2,4,6-trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E, bis chloromethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, pentachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E, bis 2-chloroethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 2-nitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E, bis 2-chloroisopropyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 4-nitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E, 2-chloroethyl vinyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 2,4-dinitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E, 4-bromophenyl phenyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phenol, 2,4-dimethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Bis 2-chloroethoxy methane	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
m-Cresol, p-chloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
o-Cresol, 4,6-dinitro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					

SECTION H - CHARACTERISTICS OF DISCHARGES (Cont'd)

CHEMICAL	SUSPECTED			SUSPECTED NOT PRESENT	CHEMICAL	SUSPECTED			SUSPECTED NOT PRESENT
	KNOWN PRESENT	SUSPECTED PRESENT	NON-D			KNOWN PRESENT	SUSPECTED PRESENT	NON-D	
VI. NITROSAMINES					IX. POLYCYCLIC AROMATICS				
Nitrosamine, dimethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Acenaphthene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Nitrosamine, diphenyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Acenaphthylene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Nitrosamine, di-n-propyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Anthracene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Benzidine	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzo (a) anthracene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Benzidine, 3,3-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzo (b) fluoranthene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hydrazine, 1,2-diphenyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzo (k) fluoranthene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Acrylonitrile	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benzo (ghi) perylene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
VII. HALOGENATED ALIPHATICS					Benzo (a) pyrene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, bromo-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-Chloronaphthalene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, chloro-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Chrysene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, dichloro-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Dibenzo (a,n,) anthracene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, chlorodibromo	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fluoranthene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, dichlorobromo	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fluorene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, tribromo	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Indeno (1,2,3-cd) pyrene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Naphthalene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, tetrachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Phenanthrene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, trichlorofluoro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pyrene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Methane, dichlorodifluoro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	X. PESTICIDES				
Ethane, 1,1-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Acrolein	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethane, 1,2-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Aldrin	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethane, 1,1,1-trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	BHC (Alpha)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethane, 1,1,2-trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	BHC (Beta)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethane, 1,1,2,1-tetrachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	BHC (Gamma) or Lindane	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethane, hexachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	BHC (Delta)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethene, chloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Chlordane	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethene, 1,1-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DDD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethene, trans-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DDE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethene, trichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DDT	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ethene, tetrachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Dieldrin	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Propane, 1-2, dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Endosulfan (Alpha)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Propene, 2,4-dichloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Endosulfan (Beta)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Butadiene, hexachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Endosulfan Sulfate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cyclopentadiene, hexachloro	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Endrin	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
VII. PHTHALATE ESTERS					Endrin Aldehyde	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, di-c-methyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Heptachlor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, di-n-ethyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Heptachlor epoxide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, di-n-butyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Isophorone	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, di-n-octyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	TCDD (or Dioxin)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, d (2-ethylhexyl)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Toxaphene	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Phthalate, butyl benzyl	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					

SECTION H - CHARACTERISTICS OF DISCHARGES (Cont'd)

- 2. Does your company keep a continuous record of wastewater pH? Yes No
- 3. Does your company measure and record wastewater discharge volume? Yes No
- 4. Is there a sampling manhole on the industrial waste discharge line or any other wastewater discharge line into the sanitary sewer? Yes No

If "Yes", please indicate its location. _____

5. HAZARDOUS WASTE REPORTING

a. Does your facility discharge to the sewer any wastes which, if otherwise disposed of, would be classified as Hazardous Wastes under 40 CFR Part 261? Yes No

If "No", continue to **Section I - Non-Discharged Wastes** on Page 10.

b. Please provide the following information on these wastes:

Name of Waste	EPA Hazardous Waste Number	Type of Discharge (Batch, Continuous)	Quantity Discharged (Kilograms per Month)
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Mark any of the above-listed wastes that are classified as Acute hazardous wastes under 40 CFR sec. 261.30(d) or sec. 261.33(e) with an "A"

c. For each waste listed above as discharged in quantities greater than 100 kilograms per month, provide on a separate sheet the following: identify all hazardous constituents; estimate mass and concentration discharged in the wastewater during the most recent month; estimate mass and concentration expected to be discharged during the next twelve months.

d. If hazardous wastes are discharged to the sewer, the following statement must be signed by a corporate official, partner, proprietor, director, or other responsible person:

"I certify that the industry named in this document has in place a program which is designed to reduce the volume and/or toxicity of the discharged wastes to the extent that it is economically practical."

(Signature)

(Name) Please print

NOTE: This information is subject to verification by inspection

Company Name: _____

SECTION I - NON-DISCHARGED WASTES

1. Are any wastes, by-products or sludges received or generated and not disposed in the sewer system? (Other than normal office and cafeteria trash.) Yes No

If "No": skip the remainder of **SECTION I** and sign the certification in **SECTION J**

If "Yes": these materials may best be described and quantified as (check all that apply):

	ESTIMATED QUANTITY PER YEAR (Indicate Units)		ESTIMATED QUANTITY PER YEAR (Indicate Units)
<input type="checkbox"/> Waste Solvent	_____	<input type="checkbox"/> Paints	_____
<input type="checkbox"/> Waste Product	_____	<input type="checkbox"/> Acids and Alkalies	_____
<input type="checkbox"/> Oil	_____	<input type="checkbox"/> Plating Wastes	_____
<input type="checkbox"/> Grease	_____	<input type="checkbox"/> Pesticides	_____
<input type="checkbox"/> Pretreatment Sludge ...	_____	<input type="checkbox"/> Other (Specify):	_____
<input type="checkbox"/> Inks/Dyes	_____	_____	_____
<input type="checkbox"/> Thinner	_____	_____	_____
<input type="checkbox"/> Heavy Metals	_____	_____	_____
<input type="checkbox"/> Organic Compounds	_____	_____	_____

2. Describe method of storing these wastes, including storage locations, size and type of containers, and methods for containing leaks and spills.

3. Does your company remove any of the above itemized wastes from the facility?
 (Do not answer "yes" if a contract hauler removes these wastes. See Question 6 on page 11.)

Yes No

Describe: _____

4. Are any of the above itemized wastes placed with trash for disposal?

Yes No

Describe: _____

5. Does your company practice on-site disposal for any of the above itemized wastes?

Yes No

Describe: _____

SECTION I - NON-DISCHARGED WASTES (Cont'd)

Company Name: _____

6. If an outside firm removes any of the above checked wastes, state the name(s) and address(es) of all haulers.

1. _____

_____ zip code: _____

2. _____

_____ zip code: _____

Permit No. (if applicable): _____

Permit No. (if applicable): _____

7. Does your facility require any Resource Conservation and Recovery Act permits?
If "Yes", please specify: _____

Yes No

EPA Generator Number: _____

SECTION J - CERTIFICATION
(By the Authorized Representative named in **SECTION A** Part 4.)

I have personally examined and am familiar with the information submitted in this document and attachments. Based upon my inquiry of those individuals immediately responsible for obtaining information reported herein, I believe that the submitted information is true, accurate and complete. I understand that there may be penalties, including the possibility of criminal prosecution, for providing false information.

Date

Signature of Official

(Seal if applicable)


NOTICE:

If at any time the industrial user determines that the information in this questionnaire is inaccurate or incomplete, or has become inaccurate or incomplete because of changes that have occurred, it is a duty of the industrial user to contact Pennsylvania-American Waste Company and provide the necessary corrections. Failure to provide correct information may constitute a violation of local, State, or federal laws or regulations and may result in the imposition of civil or criminal penalties.

APPENDIX A - EXAMPLE OF A RAW MATERIAL INVENTORY

RAW MATERIAL	FREQUENCY AND AMOUNT USED	USE
Nickel Sulfate	75 GPD	Nickel Source in Plating Tank 1 and 4
Boric Acid	50 GPD	Cleaning Solution in Acid Clean Tank (Ni Line)
Sodium Hypophosphate	10 GPD	Nickel Reducing Agent in Plating Tank 1
Citric Acid	25 GPD	Ni Chelating Agent in Plating Tank 1
Formaldehyde	40 GPD	Cu Reducing Agent in Plating Tank 2
Benzene	5 GPD	Cleaning Agent/Lab Solvent
Carbon Tetrachloride	5 GPD	Cleaning Solution (55 Gal Drums in Work Area)
Chloroform	Lab Quantities	Lab Solvent/Rinse Baths #2 & 8
Ethyl Benzene	Lab Quantities	Lab Solvent
Acetaldehyde	20 GPD	Cu Reducing Agent in Plating Tank 3
Sodium Cyanide	80 GPD	Cyanide "Strike" Source in Plating Tank 2
Chromic Acid	100 GPD	Chrome Source in Plating Tank 5
Copper Sulfate	100 GPD	Copper Sources in Plating Tank 3
Potassium Cyanide	40 GPD	Cyanide "Strike" Source in Plating Tank 2
Trichloroethylene	20 GPD	Degreaser in Rinse Tanks 4, 5, 10 & 11
Acetone	Lab Quantities	Lab Solvent
Acetic Acid	20 GPD	Acid Cleaning Tank (Ni Line) & Dip Tank (Cu, Cr Line)
Sulfuric Acid	20 GPD	pH Adjustment in Neutralization Tank & Cyanide Destruction - TRMT Tank
Sodium Hydroxide	20 GPD	Alkaline Clean Tank 1 & 2 and Treatment Tanks 1 & 2 (pH Adjustment)
Bromo Benzene	Lab Quantities	Lab Reagent
Iron Sulfate	70 lbs/day	Coagulant and Intreatment Tanks 1 & 2
Coagulant Aid	150 lbs/day	Aid in Coagulation & Precipitation in Treatment Tanks 1 & 2
Fluorene	5 GPD	Cleaning Agent Prior to Plating Tanks
<p>Contains: Activated Silica Potassium Permanganate (Oxidant) Diethyl Pthalate</p>		

Appendix B
 Example of a Water Flow Diagram



APPENDIX D

**SANITARY SEWER SYSTEM CAPACITY EVALUATION: PUMP STATION
DRAWDOWN TESTS**

**COATESVILLE WASTEWATER TREATMENT PLANT
PA AMERICAN WATER COMPANY**

TABLE OF CONTENTS

Drawdown Test Purpose & Description

Parquesburg

West Sadsbury

Quebecor

Sandy Hill

Millview

Branford #1

Strasburg Hunt Short Drive

Robin's Cove (Stone Creek) #2

Brinton #1

Brinton #2

Robin's Cove (Stone Creek) #1

Branford #2

Strasburg Hunt Windy Hill Drive

Drawdown Test Summary

Appendix A

Flowrate Calculations

Drawdown Test Purpose & Description

Thirteen individual pump stations were tested over a period of three days to determine flowrates through the pumps. Using the calculated flowrates at the pump stations, their contribution to the Coatesville Wastewater Treatment Plant can be determined.

To begin the drawdown tests, the dimension of each wet well was measured. Through the use of a water level indicator, the distance from top of wet well to top of the water was measured. Each test then consisted of running the pumps for a measurable time (either one or two minutes). The difference in the vertical distance to the water was then calculated. From these measurements, flowrates through the pumps can be expressed in cubic feet per minute, gallons per minute, and million gallons per day.

Parkesburg Pump Station

Pump station consists of three (3) Cornell 4NHTA Redi-Prime pumps equipped with 40 horsepower motors, operating in alternating fashion. The three parallel-aligned pumps are each rated for an unknown flowrate and against an unknown Total Dynamic Head (TDH). Documentation shows pumps were originally installed with 25 horsepower motors rated for 850 gallons-per-minute (gpm) against 110' TDH.

The control room contained instrumentation displaying water level in wet well. The wet well was allowed to fill to a water level above 50 inches. Drawing down the water from to a water level of 24 inches was performed for each test. The test of pump one revealed a flowrate of 1,197 gpm. The test of pump two revealed a flowrate of 1,155 gpm. The test of pump three revealed a flowrate of 1,197 gpm. The average observed flowrate was 1,183 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 1,419 gpm. The test of pumps one, two, and three operating simultaneously revealed a flowrate of 1,472 gpm.

Pumps appear to be operating at a rated capacity of 1200 gpm. Wet well, dry well, and piping appear to be in excellent condition.

West Sadsbury Pump Station

Pump station consists of two (2) Flygt 3153HT submersible pumps equipped with 18 horsepower motors, operating in alternating fashion. The two parallel-aligned pumps are each rated for 126 gpm against 130' TDH.

Pumps operated for two minutes during each test. The test of pump one revealed a flowrate of 95 gpm. The test of pump two revealed a flowrate of 96 gpm. The average

observed flowrate was 96 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 104 gpm.

Both pumps are operating below their rated capacity. Wet well, piping, and valves appear to be in fair condition.

Quebecor Pump Station

Pump station consists of two (2) Fairbanks Morse 3-D5433MTK submersible pumps, operating in alternating fashion. The two parallel-aligned pumps are each rated for an unknown flowrate against an unknown TDH.

Pumps operated for two minutes during each test. The test of pump one revealed a flowrate of 261 gpm. The test of pump two revealed a flowrate of 70 gpm. The average observed flowrate was 165 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 78 gpm.

Wet well, piping, and valves appear to be in fair condition. The reason for the large flowrate difference between the two pumps is not known.

Sandy Hill Pump Station

Pump station consists of two (2) Fairbanks Morse submersible pumps, operating in alternating fashion. The two parallel-aligned pumps are each rated for an unknown flowrate against an unknown TDH.

Pump number one was operated for two minutes during its test. The test revealed a flowrate of 222 gpm. Pump number two was operated for one minute during its test. The test revealed a flowrate of 250 gpm. The average observed flowrate was 236 gpm. Testing both pumps simultaneously was not performed due to large length of time needed to adequately fill wet well.

Wet well, piping, and valves are in fair condition.

Millview Pump Station

Pump station consists of two (2) Fairbanks Morse 5435 MV submersible pumps equipped with 40 horsepower motors. The two parallel-aligned pumps are each rated for 350 gpm against 65' TDH, operating in alternating fashion.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 190 gpm. The test of pump two revealed a flowrate of 162 gpm. The

average observed flowrate was 176 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 198 gpm.

Both pumps appear to be operating well below their rated capacity. Wet well needs to be cleaned of debris near pumps. The debris is the likely culprit for the poor pump performance.

Branford Village #1 Pump Station

Pump station consists of two (2) Smith and Loveless submersible pumps equipped with 30 horsepower motors. The two parallel-aligned pumps are each rated for 483 gpm against 127' TDH, operating in alternating fashion.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 307 gpm. The test of pump two revealed a flowrate of 374 gpm. The average observed flowrate was 340 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 411 gpm.

Both pumps appear to be operating well below rated capacity. Wet well and valves are in good condition. Piping inside pump station shows slight signs of rusting.

Strasburg Hunt Short Drive Pump Station

Pump station consists of two (2) Hydromatic SPGA 200M2-2 submersible pumps each equipped with 2 horsepower motors, operating in alternating fashion. The two parallel-aligned pumps are each rated for an unknown flowrate against an unknown TDH.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 40 gpm. The test of pump two revealed a flowrate of 46 gpm. The average observed flowrate was 43 gpm. The test of pumps one and two operating simultaneously revealed a flowrate of 80 gpm.

Wet well is in fair condition while piping shows signs of rusting. No valve vault present.

Robin's Cove (Stone Creek) #2 Pump Station

Pump station consists of two (2) Barnes 4XSE-EHA submersible non-clog pumps equipped with 60 horsepower motors. The two parallel-aligned pumps are each rated for 550 gpm against 217' TDH, operating in alternating fashion.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 627 gpm. The test of pump two revealed a flowrate of 621 gpm. The

average observed flowrate was 624 gpm. Testing both pumps simultaneously was not performed due to length of time needed to adequately fill wet well.

Pumps are operating above rated capacity. Wet well, piping, and valves are in excellent condition.

Brinton Station #1 Pump Station

Pump station consists of two (2) Hydromatic submersible pumps equipped with 7.5 horsepower motors. The two parallel-aligned pumps are each rated for 87 gpm against 118' TDH, operating in alternating fashion. During time of test, the second pump was out of service.

Pump one was operated for one minute during the test. The test of pump one revealed a flowrate of 89 gpm.

Pump one is operating at rated capacity. Wet well and valves are in excellent condition. Piping inside wet well shows signs of rusting.

Brinton Station #2 Pump Station

Pump station consists of two (2) Hydromatic submersible pumps equipped with 2 horsepower motors. The two parallel-aligned pumps are each rated for 27 gpm against 39' TDH, operating in alternating fashion. During time of test, the second pump was out of service.

Pump one was operated for one minute during the test. The test of pump one revealed a flowrate of 25 gpm.

Pump one is operating at rated capacity. Wet well is in fair condition while piping shows signs of rusting. No valve vault present.

Robin's Cove (Stone Creek) #1 Pump Station

Pump station consists of two (2) Barnes XSGV submersible grinder pumps equipped with 5 horsepower motors. The two parallel-aligned pumps are each rated for 55 gpm against 119' TDH, operating in alternating fashion.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 61 gpm. The test of pump two revealed a flowrate of 61 gpm. The average observed flowrate was 61 gpm. Testing both pumps simultaneously was not performed due to length of time needed to adequately fill wet well.

Pumps are operating slightly above rated capacity. Wet well and valves are in excellent condition. Piping inside wet well shows slight signs of rusting.

Branford Village #2 Pump Station

Pump station consists of two (2) Fairbanks Morse 5435MV submersible pumps equipped with 25 horsepower motors. The two parallel-aligned pumps are each rated for 156 gpm against 118' TDH, operating in alternating fashion.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 237 gpm. The test of pump two revealed a flowrate of 229 gpm. The average observed flowrate was 233 gpm. Testing both pumps simultaneously was not performed due to length of time needed to adequately fill wet well.

Pumps are operating above rated capacity. Wet well and valves are in fair condition. Piping inside wet well shows signs of rusting.

Strasburg Hunt Windy Hill Pump Station

Pump station consists of two (2) submersible non-clog pumps equipped with 5 horsepower motors, operating in alternating fashion. The two parallel-aligned pumps are each rated for an unknown flowrate against an unknown TDH.

Pumps were operated for one minute during each test. The test of pump one revealed a flowrate of 48 gpm. The test of pump two revealed a flowrate of 54 gpm. The average observed flowrate was 51 gpm. Testing both pumps simultaneously was not performed due to length of time needed to adequately fill wet well.

Wet well and piping are in fair condition. No valve vault present.

Drawdown Test Summary

Pump Station	Pump 1	Pump 2	Pump 3	Design Point	Pump 1 & 2	Pump 1, 2, & 3
Parkesburg	1,197 gpm (1.72 mgd)	1,155 gpm (1.66 mgd)	1,197 gpm (1.72 mgd)	Unknown	1,419 gpm (2.04 mgd)	1,472 gpm (2.12 mgd)

Pump Station	Pump 1	Pump 2	Design Point	Pump 1 & 2
West Sadsbury Commons	97 gpm (0.140 mgd)	100 gpm (0.143 mgd)	130 gpm (0.187 mgd)	108 gpm (0.155 mgd)
Quebecor	263 gpm (0.379 mgd)	70 gpm (0.100 mgd)	Unknown	79 gpm (0.114 mgd)
Sandy Hill	226 gpm (0.325 mgd)	267 gpm (0.384 mgd)	Unknown	Insufficient Flow
Millview	190 gpm (0.274 mgd)	165 gpm (0.238 mgd)	350 gpm (0.504 mgd)	205 gpm (0.295 mgd)
Branford Village #1	312 gpm (0.449 mgd)	380 gpm (0.547 mgd)	483 gpm (0.700 mgd)	417 gpm (0.601 mgd)
Strasburg Hunt Short Drive	40 gpm (0.058 mgd)	46 gpm (0.067 mgd)	Unknown	87 gpm (0.125 mgd)
Robin's Cove #2	669 gpm (0.964 mgd)	632 gpm (0.910 mgd)	550 gpm (0.792 mgd)	Insufficient Flow
Branford Village #2	237 gpm (0.341 mgd)	229 gpm (0.330 mgd)	156 gpm (0.225 mgd)	Insufficient Flow
Strasburg Hunt Windy Hill	48 gpm (0.070 mgd)	54 gpm (0.078 mgd)	Unknown	Insufficient Flow
Robin's Cove #1	61 gpm (0.088 mgd)	61 gpm (0.088 mgd)	55 gpm (0.079 mgd)	Insufficient Flow
Brinton Station #1	89 gpm (0.128 mgd)	Out Of Order	87 gpm (0.125 mgd)	N/A
Brinton Station #2	25 gpm (0.037 mgd)	Out Of Order	27 gpm (0.039 mgd)	N/A

Coatesville I & I Study

Parkesburg Pump Station

Date Inspected: 6/15/06
Location: Borough Line Road
Pumps: 3 aligned in parallel located in dry well (850 GPM @ 110' TDH)
Model: Cornell, 4NHTA-VC16
Motor: 40 hp Marathon Electric, 1775 RPM
Suction pipe: 6" diameter
Discharge pipe: 4" diameter
Force main: 10" diameter
Square Foot of wet well: 20.9' x 7.6' = 158.84

Pump 1 Test:

Height to water level before test (ft): 51
Height to water level after test (ft): 24
Total test time (min): 2.23
Observed flowrate (cfm): 160.03
Observed flowrate (gpm): 1196.99
Observed flowrate (mgd): 1.724

Pump 2 Test:

Wet well water level before test (ft): 52
Wet well water level after test (ft): 24
Total test time (min): 2.40
Observed flowrate (cfm): 154.43
Observed flowrate (gpm): 1155.12
Observed flowrate (mgd): 1.663

Pump 3 Test:

Height to water level before test (ft): 50
Height to water level after test (ft): 24
Total test time (min): 2.15
Observed flowrate (cfm): 160.07
Observed flowrate (gpm): 1197.33
Observed flowrate (mgd): 1.724

Pump 1 & 2 Test:

Height to water level before test (ft): 50
Height to water level after test (ft): 23
Total test time (min): 1.88
Observed flowrate (cfm): 189.76
Observed flowrate (gpm): 1419.44
Observed flowrate (mgd): 2.044

Pump 1 & 2 & 3 Test:

Height to water level before test (ft): 52
Height to water level after test (ft): 24
Total test time (min): 1.88
Observed flowrate (cfm): 196.79
Observed flowrate (gpm): 1472.01
Observed flowrate (mgd): 2.120

Flow Summary:

Average of normal operation observed flowrate (gpm): 1183.15

Coatesville I & I Study

West Sadsbury Commons Pump Station

Date Inspected: 9/6/06
Location: Octorara Trail
Pumps: 2 Flygt submersible pumps (130 gpm @ 126' TDH)
Model: 3153HT
Motor: 18 hp
Suction pipe: 4" diameter
Discharge pipe: 4" diameter
Force main: 4" diameter
Square Foot of wet well: 6' x 6' = 36

Pump 1 Test:

Height to water level before test (ft):	12.85
Height to water level after test (ft):	13.57
Total test time (min):	2.00
Observed flowrate (cfm):	12.96
Observed flowrate (gpm):	96.94
Observed flowrate (mgd):	0.140

Pump 2 Test:

Height to water level before test (ft):	13.57
Height to water level after test (ft):	14.31
Total test time (min):	2.00
Observed flowrate (cfm):	13.32
Observed flowrate (gpm):	99.63
Observed flowrate (mgd):	0.143

Pump 1 & 2 Test:

Height to water level before test (ft):	13.58
Height to water level after test (ft):	14.38
Total test time (min):	2.00
Observed flowrate (cfm):	14.40
Observed flowrate (gpm):	107.71
Observed flowrate (mgd):	0.155

Flow Summary:

Average of normal operation observed flowrate (gpm):	98.2872
--	----------------

Coatesville I & I Study

Quebecor Pump Station

Date Inspected: 9/6/06
Location: Lower Valley Road
Pumps: 2 Fairbanks Morse submersibles
Model: D5433MTK
Motor: 10 HP
Suction pipe: 4" diameter
Discharge pipe: 4" diameter
Force main: 4" diameter
Wet well: 8' diameter; area = 50.26548

Pump 1 Test:

Height to water level before test (ft):	15.7
Height to water level after test (ft):	17.1
Total test time (min):	2.00
Observed flowrate (cfm):	35.19
Observed flowrate (gpm):	263.19
Observed flowrate (mgd):	0.379

Pump 2 Test:

Height to water level before test (ft):	17.1
Height to water level after test (ft):	17.47
Total test time (min):	2.00
Observed flowrate (cfm):	9.30
Observed flowrate (gpm):	69.56
Observed flowrate (mgd):	0.100

Pump 1 & 2 Test:

Height to water level before test (ft):	16.37
Height to water level after test (in):	16.79
Total test time (min):	2.00
Observed flowrate (cfm):	10.56
Observed flowrate (gpm):	78.96
Observed flowrate (mgd):	0.114

Flow Summary:

Average of normal operation observed flowrate (gpm):	166.3737
--	-----------------

Coatesville I & I Study

Sandy Hill Pump Station

Date Inspected: 9/6/06
Location: Sandy Way
Pumps: 2 Fairbanks Morse
Model: D5433MT
Motor:
Suction pipe: 4" diameter
Discharge pipe: 4" diameter
Force main: 6" diameter
Wet well: 8' diameter; area = 50.26548

Pump 1 Test:

Height to water level before test (ft):	15.05
Height to water level after test (ft):	16.25
Total test time (min):	2.00
Observed flowrate (cfm):	30.16
Observed flowrate (gpm):	225.59
Observed flowrate (mgd):	0.325

Pump 2 Test:

Height to water level before test (ft):	15.4
Height to water level after test (ft):	16.11
Total test time (min):	1.00
Observed flowrate (cfm):	35.69
Observed flowrate (gpm):	266.95
Observed flowrate (mgd):	0.384

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):	
Height to water level after test (ft):	
Total test time (min):	
Observed flowrate (cfm):	
Observed flowrate (gpm):	
Observed flowrate (mgd):	

Flow Summary:

Average of normal operation observed flowrate (gpm):	246.2707
--	-----------------

Coatesville I & I Study

Millview Pump Station

Date Inspected: 9/6/06
Location: Victoria Drive
Pumps: 2 Fairbanks Morse (350 gpm @ 65' TDH)
Model: 5435 MV
Motor: 40 hp
Suction pipe: 4" diameter
Discharge pipe: 4" diameter
Force main: 6" diameter
Wet well: 6' diameter; area = 28.27433

Pump 1 Test:

Height to water level before test (ft):	14.8
Height to water level after test (ft):	15.7
Total test time (min):	1.00
Observed flowrate (cfm):	25.45
Observed flowrate (gpm):	190.34
Observed flowrate (mgd):	0.274

Pump 2 Test:

Height to water level before test (ft):	15.72
Height to water level after test (ft):	16.5
Total test time (min):	1.00
Observed flowrate (cfm):	22.05
Observed flowrate (gpm):	164.96
Observed flowrate (mgd):	0.238

Pump 1 & 2 Test:

Height to water level before test (ft):	15.45
Height to water level after test (ft):	16.42
Total test time (min):	1.00
Observed flowrate (cfm):	27.43
Observed flowrate (gpm):	205.15
Observed flowrate (mgd):	0.295

Flow Summary:

Average of normal operation observed flowrate (gpm):	177.65
--	--------

Coatesville I & I Study

Branford Village #1 Pump Station

Date Inspected: 9/7/06
Location: Hydrangea Road
Pumps: 2 Smith & Loveless (483 gpm @ 127' TDH)
Model: 4B3B or 4C3B or 4D3B
Motor: 30 HP
Suction pipe: 4" diameter
Discharge pipe: 4" diameter
Force main: 8" diameter
Wet well: 8' diameter; area = 50.26548

Pump 1 Test:

Height to water level before test (ft):	15.19
Height to water level after test (ft):	16.02
Total test time (min):	1.00
Observed flowrate (cfm):	41.72
Observed flowrate (gpm):	312.07
Observed flowrate (mgd):	0.449

Pump 2 Test:

Height to water level before test (ft):	16.05
Height to water level after test (ft):	17.06
Total test time (min):	1.00
Observed flowrate (cfm):	50.77
Observed flowrate (gpm):	379.75
Observed flowrate (mgd):	0.547

Pump 1 & 2 Test:

Height to water level before test (ft):	17.03
Height to water level after test (ft):	18.14
Total test time (min):	1.00
Observed flowrate (cfm):	55.79
Observed flowrate (gpm):	417.34
Observed flowrate (mgd):	0.601

Flow Summary:

Average of normal operation observed flowrate (gpm):	345.91
--	---------------

Coatesville I & I Study

Strasburg Hunt Short Drive Pump Station

Date Inspected: 9/7/06

Location: Short Drive

Pumps: 2 Aurora submersibles

Model: SPGA200M2-2

Motor: 2 HP, 3450 RPM

Suction pipe: 2" diameter

Discharge pipe: 2" diameter

Force main: 2" diameter

Wet well: 6' diameter; area = 28.27433

Pump 1 Test:

Height to water level before test (ft):	9.96
Height to water level after test (ft):	10.15
Total test time (min):	1.00
Observed flowrate (cfm):	5.37
Observed flowrate (gpm):	40.18
Observed flowrate (mgd):	0.058

Pump 2 Test:

Height to water level before test (ft):	10.15
Height to water level after test (ft):	10.37
Total test time (min):	1.00
Observed flowrate (cfm):	6.22
Observed flowrate (gpm):	46.53
Observed flowrate (mgd):	0.067

Pump 1 & 2 Test:

Height to water level before test (ft):	10.37
Height to water level after test (ft):	10.78
Total test time (min):	1.00
Observed flowrate (cfm):	11.59
Observed flowrate (gpm):	86.71
Observed flowrate (mgd):	0.125

Flow Summary:

Average of normal operation observed flowrate (gpm):	43.36
--	-------

Coatesville I & I Study

Stone Creek (Robin's Cove) #2 Pump Station

Date Inspected: 9/7/06
Location: Goosetown Road
Pumps: 2 Barnes submersible non-clog (550 gpm @ 217' TDH)
Model: 4XSE60044EHA
Motor: 60 HP
Suction pipe: 6" diameter
Discharge pipe: 6" diameter
Force main: 8" diameter
Wet well: 8' diameter; area = 50.26548

Pump 1 Test:

Height to water level before test (ft):	17.00
Height to water level after test (ft):	18.78
Total test time (min):	1.00
Observed flowrate (cfm):	89.47
Observed flowrate (gpm):	669.25
Observed flowrate (mgd):	0.964

Pump 2 Test:

Height to water level before test (ft):	18.80
Height to water level after test (ft):	20.48
Total test time (min):	1.00
Observed flowrate (cfm):	84.45
Observed flowrate (gpm):	631.66
Observed flowrate (mgd):	0.910

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):	
Height to water level after test (ft):	
Total test time (min):	
Observed flowrate (cfm):	
Observed flowrate (gpm):	
Observed flowrate (mgd):	

Flow Summary:

Average of normal operation observed flowrate (gpm):	650.46
--	---------------

Coatesville I & I Study

Brinton Station #1 Pump Station

Date Inspected: 9/20/06

Location: East Fallowfield Township

Pumps: 2 Hydromatic Submersible (87 gpm @ 118' TDH)

Model: G2HX750ED

Motor: 7.5 HP

Suction pipe: 4" diameter

Discharge pipe: 4" diameter

Force main: 4" diameter

Wet well: 6' diameter; area = 28.27433

Pump 1 Test:

Height to water level before test (ft): 8.95

Height to water level after test (ft): 9.37

Total test time (min): 1.00

Observed flowrate (cfm): 11.88

Observed flowrate (gpm): 88.83

Observed flowrate (mgd): 0.128

Pump 2 Test: NOT AVAILABLE

Height to water level before test (ft):

Height to water level after test (ft):

Total test time (min):

Observed flowrate (cfm):

Observed flowrate (gpm):

Observed flowrate (mgd):

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):

Height to water level after test (ft):

Total test time (min):

Observed flowrate (cfm):

Observed flowrate (gpm):

Observed flowrate (mgd):

Flow Summary:

Average of normal operation observed flowrate (gpm): **88.83**

Coatesville I & I Study

Brinton Station #2 Pump Station

Date Inspected: 9/20/06
Location: John Stevens Drive
Pumps: 2 Hydromatic Submersible (27 gpm @ 39' TDH)
Model: G1LX200CD
Motor: 2 HP
Suction pipe: 2" diameter
Discharge pipe: 2" diameter
Force main: 2" diameter
Wet well: 6' diameter; area = 28.27433

Pump 1 Test:

Height to water level before test (ft):	10.44
Height to water level after test (ft):	10.56
Total test time (min):	1.00
Observed flowrate (cfm):	3.39
Observed flowrate (gpm):	25.38
Observed flowrate (mgd):	0.037

Pump 2 Test: NOT AVAILABLE

Height to water level before test (ft):
Height to water level after test (ft):
Total test time (min):
Observed flowrate (cfm):
Observed flowrate (gpm):
Observed flowrate (mgd):

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):
Height to water level after test (ft):
Total test time (min):
Observed flowrate (cfm):
Observed flowrate (gpm):
Observed flowrate (mgd):

Flow Summary:

Average of normal operation observed flowrate (gpm): **25.38**

Coatesville I & I Study

Stone Creek (Robin's Cove) #1 Pump Station

Date Inspected: 9/20/06
Location: Caln Road
Pumps: 2 Barnes submersible grinders (55 gpm @ 119' TDH)
Model: XSGV
Motor: 5 HP
Suction pipe: 2" diameter
Discharge pipe: 2" diameter
Force main: 2.5" diameter
Square Foot of wet well: 6' diameter = 28.27433

Pump 1 Test:

Height to water level before test (ft): 6.47
Height to water level after test (ft): 6.76
Total test time (min): 1.00
Observed flowrate (cfm): 8.20
Observed flowrate (gpm): 61.33
Observed flowrate (mgd): 0.088

Pump 2 Test:

Height to water level before test (ft): 6.76
Height to water level after test (ft): 7.05
Total test time (min): 1.00
Observed flowrate (cfm): 8.20
Observed flowrate (gpm): 61.33
Observed flowrate (mgd): 0.088

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):
Height to water level after test (ft):
Total test time (min):
Observed flowrate (cfm):
Observed flowrate (gpm):
Observed flowrate (mgd):

Flow Summary:

Average of normal operation observed flowrate (gpm): **61.33**

Coatesville I & I Study

Branford Village #2 Pump Station

Date Inspected: 9/20/06

Location: Buck Run Road

Pumps: 2 Smith & Loveless submersible pumps (156 gpm @ 118' TDH)

Model: 5435 MV

Motor: 25 HP

Suction pipe: 4" diameter

Discharge pipe: 4" diameter

Force main: 4" diameter

Wet well: 8' diameter; area = 50.26548

Pump 1 Test:

Height to water level before test (ft):	9.88
Height to water level after test (ft):	10.51
Total test time (min):	1.00
Observed flowrate (cfm):	31.67
Observed flowrate (gpm):	236.87
Observed flowrate (mgd):	0.341

Pump 2 Test:

Height to water level before test (ft):	10.51
Height to water level after test (ft):	11.12
Total test time (min):	1.00
Observed flowrate (cfm):	30.66
Observed flowrate (gpm):	229.35
Observed flowrate (mgd):	0.330

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):

Height to water level after test (ft):

Total test time (min):

Observed flowrate (cfm):

Observed flowrate (gpm):

Observed flowrate (mgd):

Flow Summary:

Average of normal operation observed flowrate (gpm): 233.11

Coatesville I & I Study

Strasburg Hunt Windy Hill Pump Station

Date Inspected: 9/20/06

Location: Windy Hill Road

Pumps: 2 Hydromatic submersible pumps

Model: SPGH500M2-2

Motor: 5 HP

Suction pipe: 2" diameter

Discharge pipe: 2" diameter

Force main: 2" diameter

Wet well: 5' diameter; area = 19.63495

Pump 1 Test:

Height to water level before test (ft):	7.61
Height to water level after test (ft):	7.94
Total test time (min):	1.00
Observed flowrate (cfm):	6.48
Observed flowrate (gpm):	48.47
Observed flowrate (mgd):	0.070

Pump 2 Test:

Height to water level before test (ft):	7.94
Height to water level after test (ft):	8.31
Total test time (min):	1.00
Observed flowrate (cfm):	7.26
Observed flowrate (gpm):	54.34
Observed flowrate (mgd):	0.078

Pump 1 & 2 Test: NOT AVAILABLE

Height to water level before test (ft):

Height to water level after test (ft):

Total test time (min):

Observed flowrate (cfm):

Observed flowrate (gpm):

Observed flowrate (mgd):

Flow Summary:

Average of normal operation observed flowrate (gpm): **51.40**

APPENDIX E

CALN TOWNSHIP

**(SEE FULL REPORT SUBMITTED SEPARATELY BY
TOWNSHIP)**

CITY OF COATESVILLE

(NO RESPONSE)

EAST FALLOWFIELD TOWNSHIP

PENNSYLVANIA-AMERICAN WATER COMPANY
 COATESVILLE DISTRICT
 2007 WASTELOAD MANAGEMENT REPORT SURVEY

Municipality: East Fallowfield Township

Information furnished by:

Date: March 14, 2006

Municipality/Engineering Company: Herbert E. MacCombie Jr., P.E.
 Consulting Eng'rs & Surveyors, Inc.

Name: James W. MacCombie, P.E., P.L.S.

Address: P.O. Box 116
Broomall, Pa 19008

Phone: 610-356-9550 Fax: 610-356-5032

~~1. Total Present Number of EDU's connected to PAWC system:~~

Residential	
Commercial	
Industrial	

~~2. Total EDU's connected to PAWC system during 2007:~~

Residential	
Commercial	
Industrial	

3. Projections for future additional EDU's to be connected to PAWC system. These projections should reflect what is actually anticipated to be constructed and placed in service:

Year	Residential	Commercial	Industrial	Total EDU's
2008	72			72
2009	73			73
2010	129			129
2011	107			107
2012	41			41
Beyond 2012	200			200
Total	622			622

~~4. Sewer extensions constructed during 2007 that contribute flows to PAWC system:~~

Project/Development Name	Length & Diameter of Sewer Completed	Length & Diameter of Sewer Remaining	Total EDU's Completed	Total EDU's Remaining

5. Proposed projects which shall require sewer extensions that will contribute flows to PAWC system but are not yet constructed:

Project Name	Length & Diameter of Sewer Proposed	Total EDU's Proposed	Start of Construction (Year)
Martin Property-Ridgecrest		72	2009
Scott Farm		75	2009
Harkins Farm		21	2009
Bonsall Farms		19	2009
Cardinal Drive		77	2003

~~6. Please provide discussion of the following:~~

~~a) Sewer System Flow Monitoring:~~

~~_____

_____~~

~~b) Sewer System Maintenance:~~

~~_____

_____~~

~~c) Sewer System I&I Program:~~

~~_____

_____~~

7. Please provide discussion of the condition of your sewer system:

a) Portions where conveyance capacity is being exceeded or will be exceeded in the next 5 years:

b) Proposed projects to increase conveyance capacity, i.e., repair, rehabilitation, new construction:

8. Please provide data and discussion of your sewage flow:

Basin/Gravity Point or Flow Meter Point or Pump Station Name	Agreement/ or Retard Capacity (gpm)	2005 Average Daily Flow (gpm)*	2007 Projected Average Daily Flow (gpm)*	2011 Projected Average Daily Flow (gpm)*

* Based on Average Annual Flow

a) Other discussion or information:

9. Please provide a discussion of the industrial waste discharged into your sewer system:

a) Date of adoption of the ordinance or regulation governing industrial waste discharges to your system:

b) Discussion of program for the surveillance and monitoring of the industrial waste discharges into your sewer system:

c) Discussion of specific problems in your sewer system, known or suspected to be caused by industrial waste discharges within the past 5 years:

HIGHLAND TOWNSHIP
(NO RESPONSE)
(ONE CUSTOMER ONLY)

PARKESBURG BOROUGH



March 13, 2008

Mr. Wayne G. Reed
Pennsylvania American Water Company
100 Cheshire Court, Suite 104
Coatesville, PA 19320

RE: Borough of Parkesburg
Chapter 94 Update
ARRO # 6946.11

Dear Ted:

We have reviewed the questionnaire and requested information for the 2007 Chapter 94 Report for Pennsylvania American Water.

On behalf of the Borough of Parkesburg, the following information is provided:

- Narrative to the current Capacity Needs Analysis
- Chart of Estimated Future Additional Sanitary Sewage Flows

If you have any questions, please contact me at 717-560-2788.

Sincerely,

Phillip W. Brath

PWB:kmd

Enclosures

The ARRO Group, Inc.

ARRO Consulting, Inc.

*ARRO Environmental
Services, Inc.*

270 Granite Run Drive

Lancaster, PA 17601-6804

717.569.7021

Fax: 717.560.0577

info@thearrogroup.com

www.thearrogroup.com

BOROUGH OF PARKESBURG

CHAPTER 94 UPDATE

March 2008

Engineer's Project No. 06946.11

ARRO Consulting, Inc.
270 Granite Run Drive
Lancaster, PA 17601

Projections for future additional EDU's to be connected to the PAWC system:

Year	Residential	Commercial	Industrial	Total EDU's
2008	100	4	0	104
2009	238	10	0	248
2010	159	5	1	165
2011	125	4	0	129
2012	161	4	0	165
Beyond 2013	1538	65	2	1605

= 811
2416

For the purposes of updating the Chapter 94 Report under preparation by the Pennsylvania American Water Company, the Borough of Parkesburg has updated the "capacity needs analysis". This "capacity needs analysis" consists of the estimation of future additional sanitary sewage flows. The area of analysis was limited to the service area within the municipal limits of the Borough of Parkesburg. The original analysis was conducted during May and June 2006, based on data available at the time and has been updated for current projects before the Borough as of February 2008.

The Borough of Parkesburg is one of ten tributary municipalities served by the sewage facilities of the Pennsylvania American Water Company's Coatesville region. Pennsylvania American Water Company owns, operates, and maintains the collection system within the Borough.

Based on the analysis, the future additional sanitary sewage flows are a function of the following:

- Land use.
- Volume of waste discharge.

Regarding land use, the following factors were evaluated as part of this analysis:

- Development of existing vacant land feasible for development, including infill properties, all in accordance with Borough land planning policies.
- Redevelopment of certain properties in accordance with Borough initiatives, including the Borough's Revitalization Plan of 2003 and the Borough's Zoning Ordinances of 2005.

The Chester County Planning Commission's land use policy, known as "Landscapes", has designated the Borough of Parkesburg as an urbanized area. As an urbanized area, development within the Borough will target high densities in a manner that will permit the preservation of open space and agricultural lands in the surrounding communities of the county.

Water conservation measures as well as the control of inflow and infiltration will influence the actual flows and volumes of wastewater. Pennsylvania American Water Company is responsible for implementing the inflow and infiltration programs within the

Borough. The individual practice of water conservation continues to be encouraged by both the Borough of Parkesburg and Pennsylvania American Water Company. The following volumes of waste discharge have been generally used for this analysis.

- 150 gallons per day (gpd) per equivalent dwelling unit (EDU) for residential senior housing.
- 225 gpd per EDU for conventional residential housing.
- 0.1 gpd per square foot of building area for commercial establishments, excluding restaurant facilities, with a conversion of 262 gpd per EDU.
- 2.0 gpd per square foot of kitchen and dining areas for restaurant facilities, with a conversion of 262 gpd per EDU.

Based on the analysis, the timelines associated with the future additional sanitary sewage flows are a function of the following:

- Real estate demand and the related costs of financing.
- Borough revitalization efforts.
- Planning and construction capabilities of property owners.

The timelines provided herein are order-of-magnitude opinions subject to overall demographic tendencies, mass transit utilization, and the growth of western Chester County.

As part of this "capacity needs analysis", fifty planning areas within the Borough were defined. These planning areas are delineated on the "Map of Planning Areas" available with previous submissions.

The future additional sanitary sewage flows have been summarized in tabulation form, itemized for each of the fifty planning areas. This tabulation is an attachment to this narrative.

In general, existing units within all planning areas are connected to the collection system of the Pennsylvania American Water Company. An exception to this is the Woods Lane-Featherwood Drive area of the Borough, where lot sizes are typically one acre or greater in size and served by individual on-site sewer systems. Also, sections of Hamilton Street have some existing properties with on-site systems. In the Woods Lane-Featherwood Drive planning area, as well as the Hamilton Street properties, there have been no known incidences of malfunctioning systems reported to the Borough within the past ten years.

The Borough's ordinances require that all future developments and re-developments connect to public sewer. The only exception to this is within the R-1A Zoning District, the Woods Lane-Featherwood Drive planning area, where new detached residential dwelling units on minimum 80,000 square foot lots are permitted to utilize on-site systems.

The information provided in this "capacity needs analysis" is not intended to revise or supersede any provisions of previous agreements between the Borough of Parkesburg and the Pennsylvania American Water Company (formerly the City of Coatesville Authority).

SADSBURY TOWNSHIP

**PENNSYLVANIA-AMERICAN WATER COMPANY
COATESVILLE DISTRICT
2007 WASTELOAD MANAGEMENT REPORT SURVEY**

Municipality: Sadsbury Township

Information furnished by:

Date: 3/4/08

Herbert E. MacCombie Jr., P.E.

Municipality/Engineering Company: Consulting Eng's & Surveyors, Inc.

Name: James W. MacCombie, P.E., P.L.S.

Address: P.O. Box 118
Broomall, Pa. 19008

Phone: 610-356-9550 Fax: 610-356-5032

1. Total Present Number of EDU's connected to PAWC system:

Residential	834
Commercial	89
Industrial	0

2. Total EDU's connected to PAWC system during 2007:

Residential	39
Commercial	0
Industrial	0

3. Projections for future additional EDU's to be connected to PAWC system. These projections should reflect what is actually anticipated to be constructed and placed in service:

Year	Residential	Commercial	Industrial	Total EDU's
2008	108	20	2	130
2009	100	20	2	122
2010	100	20	2	122
2011	100	20	2	122
2012	100	20	2	122
Beyond 2012	360	440	-	800
Total	868	540	10	1418

4. Sewer extensions constructed during 2007 that contribute flows to PAWC system:

Project/Development Name	Length & Diameter of Sewer Completed	Length & Diameter of Sewer Remaining	Total EDU's Connected	Total EDU's Remaining
None				

5. Proposed projects which shall require sewer extensions that will contribute flows to PAWC system but are not yet constructed:

Project Name	Length & Diameter of Sewer Proposed	Total EDU's Proposed	Start of Construction (Year)
Sadsbury Phase IV West	7000 L.F. 8"	80	2008
End			

6. Please provide discussion of the following:

a) Sewer System Flow Monitoring:

P & B Maintenance Company of Essington Pa. is currently under contract with Sadsbury Township to Monitor the Pump Station and Meter on a Regular Basis. The Township Engineer Monitors Flows on a Regular Basis.

b) Sewer System Maintenance:

Sadsbury Township has a Contract with P & B Maintenance Company for Pump Station Maintenance and will contract out with Local Contractors for Major Repairs.

c) Sewer System I&J Program:

The Township Road Crew is available on a continual basis for routine repairs. Major repairs will be performed by Local Contractors as the need arises.

7. Please provide discussion of the condition of your sewer system:

a) Portions where conveyance capacity is being exceeded or will be exceeded in the next 5 years:
The sewer system is in good working condition and no exceedances are anticipated in the next five years.

b) Proposed projects to increase conveyance capacity, i.e., repair, rehabilitation, new construction:
There are no projects proposed at the present time to increase conveyance capacity.

8. Please provide data and discussion of your sewage flow:

Basin/Gravity Point or Flow Meter Point or Pump Station Name	Agreement or Rated Capacity (gpm)	2007 2006 Average Daily Flow (gpm)*	2008 2007 Projected Average Daily Flow (gpm)*	2012 2011 Projected Average Daily Flow (gpm)*
Stottsville Pump Station	700	115	135	285

* Based on Average Annual Flow

a) Other discussion or information:

N/A

9. Please provide a discussion of the industrial waste discharged into your sewer system:

a) Date of adoption of the ordinance or regulation governing industrial waste discharges to your system:

b) Discussion of program for the surveillance and monitoring of the industrial waste discharges into your sewer system:

c) Discussion of specific problems in your sewer system, known or suspected to be caused by industrial waste discharges within the past 5 years:

VALLEY TOWNSHIP

PENNSYLVANIA-AMERICAN WATER COMPANY
 COATESVILLE DISTRICT
 2007 WASTELOAD MANAGEMENT REPORT SURVEY

Municipality: VALLEY TOWNSHIP

Information furnished by: _____ Date: 2-22-08

Company: PENNONI ASSOCIATES INC.

Name: EDWARD F. RASIUL, P.E., P.L.S., TOWNSHIP ENGINEER

Address: 62 ROCKFORD ROAD, SUITE 201

WILMINGTON, DE 19806

Phone: (302) 655-4451 Fax: (302) 654-2895

1. Total Present Number of EDU's connected to PAWC system:

Residential	2507
Commercial	304
Industrial	21

2. Total EDU's connected to PAWC system during 2007:

Residential	72
Commercial	0
Industrial (LIGHT)	0

3. Projections for future additional EDU's to be connected to PAWC system. These projections should reflect what is actually anticipated to be constructed and placed in service:

Year	Residential	Commercial	Industrial (LT)	Total EDU's
2008	347	33	83	463
2009	484	90	0	574
2010	208	30	170	408
2011	135	70	183	388
2012	185	70	100	355
Beyond 2012	602	457	200	1259
Total	1961	750	736	3447

4. Sewer extensions constructed during 2006/2007 that contribute flows to PAWC system:

Project/Development Name	Length & Diameter of Sewer Completed	Length & Diameter of Sewer Remaining	Total EDU's Connected	Total EDU's Remaining
Oakcrest	1030 ft., 2in.FM; 8852 ft., 18in	0.	20	168
Pound Hill	1210 ft., 2inFM; 880 ft., 6in.FM; 6765 ft., 8in.	0	11	190

Woodland Pointe	1250 ft., 8in.	0	4	5
Valley Farm	4884 ft., 8 in.	0	12	69

5. Proposed projects which shall require sewer extensions that will contribute flows to PAWC system but are not yet constructed:

Project Name	Length & Diameter of Sewer Proposed	Total EDU's Proposed	Start of Construction (Year)
1. Highlands Corp. Ctr Phase 3	1500 ft., 8in.	63	2008
2. Valley Suburban Center	1010 ft., 6in.FM; 3925 ft., 8in.	340	2008
3. Rainbow Village	4500 ft., 8 in.	30	2010
4. London Tract	850 ft., 3in.FM	14	2008
5 Valley View Business Center	4314 ft., 6in FM;1338ft.,8in.	450	2008
6 Chester Co. Airport	Not Determined Yet	111	2009
7.Green Trees	Not Determined Yet	80	2009
8 CASD	Not Determined Yet	200	2010
9.Heagy Tract	Not Determined Yet	250	2009

6. Please provide discussion of the following:

a) Sewer System Flow Monitoring:

Sanitary sewer flows are metered in each of the three basins, and meters are read by PAWCo and reported to the Township Engineer. Data is recorded and graphed with precipitation. Graphed data is analyzed and sent to the Board of Supervisors with comments relative to the results.

b) Sewer System Maintenance:

The sewer system is maintained by Township personnel with assistance from contract professionals as needed.

c) Sewer System I&I Program:

Repair work is performed on an "as necessary" basis. The different type of work includes cleaning, TV inspections, joint grouting, and slip lining.

7. Please provide discussion of the condition of your sewer system:

a) Portions where conveyance capacity is being exceeded or will be exceeded in the next 5 years:

1.) The Rock Run Pump Station's current capacity (300,000 gpd average flow and 650 gpm instantaneous maximum flow) is anticipated to be exceeded within the next five years if contributing developments are built out including the OTP Project in the City of Coatesville. A Corrective Action Plan was submitted as part of the Planning Module for the OTP Project.

2.) In the Hayti Basin 203' of 10" main (MH 512-10 to MH 511-1) along Lincoln Hwy is projected to be hydraulically overloaded when three approved developments on the northside of Lincoln Hwy are built-out within 5 years. Approval to upgrade the main has been received from DEP and the work is anticipated to be completed in 2008.

b) Proposed projects to increase conveyance capacity, i.e., repair, rehabilitation, new construction:

1.) The Rock Run Pump Station will be upgraded when the demand requires it. The station has been built to accommodate a third pump which will allow the pump station to handle expected flows. The addition of the third pump and other modifications will require a DEP Permit. Planning approval is currently being sought to reprogram the two pumps concurrently with planning approval for the OTP Project in the City of Coatesville.

2.) In the Hayti Basin 203' of 10" main (MH 512-10 to MH511-1) along Lincoln Hwy is projected to be hydraulically overloaded with built-out of three currently approved developments on north side of Lincoln Hwy. The Developers have jointly funded an upgrade of the 10" sewer to 12". The conveyance capacity of the replaced sewer will increase from 1,018,548 gpd to 1,482,139 gpd.

8. Please provide data and discussion of your sewage flow:

CONVEYANCE

Basin/Gravity Point or Flow Meter Point or Pump Station Name	Agreement or Rated Capacity (gpm)	2007 Average Daily Flow (gpm)*	2008 Projected Average Daily Flow (gpm)*	2012 Projected Average Daily Flow (gpm)*
Rock Run	650 Pump Sta	146.49	185.55	278.21
Hayti, Charles St.	707.36	149.95	183.23	361.05
Westwood, Valley Rd.	388.56	143.36	143.36	177.11

* Based on Average Annual Flow

a) Other discussion or information:

The average Daily Flows indicated are based on metered flow averages and projected averages

9. Please provide a discussion of the industrial waste discharged into your sewer system:

a) Date of adoption of the ordinance or regulation governing industrial waste discharges to your system: N/A

b) Discussion of program for the surveillance and monitoring of the industrial waste discharges into your sewer system:

N/A

c) Discussion of specific problems in your sewer system, known or suspected to be caused by industrial waste discharges within the past 5 years:

N/A

WEST BRANDYWINE TOWNSHIP

PENNSYLVANIA-AMERICAN WATER COMPANY
COATESVILLE DISTRICT
2007 WASTELOAD MANAGEMENT REPORT SURVEY

Municipality: West Brandywine Township

Information furnished by:

Date: 3/5/08

Herbert E. MacCombie, Jr., P.E.
Consulting Engineers & Surveyors, Inc.

Municipality/Engineering Company: _____

Name: James W. MacCombie, P.E., P.L.S.

Address: P.O. Box 118
Broomall, Pa. 19008

Phone: 610-356-9550 Fax: 610-356-5032

1. Total Present Number of EDU's connected to PAWC system:

Residential	550
Commercial	261
Industrial	0

2. Total EDU's connected to PAWC system during 2007:

Residential	1
Commercial	0
Industrial	0

3. Projections for future additional EDU's to be connected to PAWC system. These projections should reflect what is actually anticipated to be constructed and placed in service:

Year	Residential	Commercial	Industrial	Total EDU's
2008	91	111	0	202
2009	91	111	0	202
2010	80	111	0	191
2011	400	10	5	415
2012	200	10	0	210
Beyond 2012	200	5	0	205
Total	1062	358	5	1425

4. Sewer extensions constructed during 2007 that contribute flows to PAWC system:

Project/Development Name	Length & Diameter of Sewer Completed	Length & Diameter of Sewer Remaining	Total EDU's Connected	Total EDU's Remaining
None				

5. Proposed projects which shall require sewer extensions that will contribute flows to PAWC system but are not yet constructed:

Project Name	Length & Diameter of Sewer Proposed	Total EDU's Proposed	Start of Construction (Year)
Monacy Manor	Exist Capped 8"	42	2008
Bentley Communities	1600 L.F.-8" Gravity & Force Main	650	2008

6. Please provide discussion of the following:

a) Sewer System Flow Monitoring:
 a) Sewer System Monitoring: P & B Maintenance Company of Essington, Pa. is currently under contract with the West Brandywine Township Municipal Authority to monitor pump stations and meters on a regular basis. The Authority Manager & Engineer monitor flows on a regular basis.

b) Sewer System Maintenance:
 West Brandywine Township Municipal Authority has a contract with P & B Maintenance Co. for Pump Station Maintenance and will contract out with Local Contractors for Major Repairs.

c) Sewer System I&I Program:
 Township Road Crew is available on a continual basis for routine repairs. Major repairs will be performed by Local Contractors as the need arises.

7. Please provide discussion of the condition of your sewer system:

a) Portions where conveyance capacity is being exceeded or will be exceeded in the next 5 years:

The sewer system is in good working condition and no exceedances are anticipated in the next five years.

b) Proposed projects to increase conveyance capacity, i.e., repair, rehabilitation, new construction:
 Bentley Communities project is proposed at the present time which may need to increase the conveyance capacity after year 2009.

8. Please provide data and discussion of your sewage flow:

Basin/Gravity Point or Flow Meter Point or Pump Station Name	Agreement or Rated Capacity (gpm)	2007	2008	2012
		2006 Average Daily Flow (gpm)*	2007 Projected Average Daily Flow (gpm)*	2011 Projected Average Daily Flow (gpm)*
Friendship Village 1	600	145	155	335
Friendship Village 2	200	28	68	253
Hammell North	200	8	9	16

* Based on Average Annual Flow

a) Other discussion or information:

9. Please provide a discussion of the industrial waste discharged into your sewer system: N/A

a) Date of adoption of the ordinance or regulation governing industrial waste discharges to your system:

b) Discussion of program for the surveillance and monitoring of the industrial waste discharges into your sewer system:

c) Discussion of specific problems in your sewer system, known or suspected to be caused by industrial waste discharges within the past 5 years:

WEST CALN TOWNSHIP

(NO RESPONSE)

WEST SADBURY TOWNSHIP

WEST SADS BURY TOWNSHIP
6400 N. Moscow Rd. Parkesburg, PA 19365
Phone 610-857-5969 FAX 610-857-1415

January 24, 2008

Mr. Ted Reed
Pennsylvania Amercian Water
100 Cheshire Court, Suite 104
Coatesville, PA 19320

Dear Ted:

Enclosed please find the 2007 Wasteload Management Report Survey, which was completed by Jim Landis.

Please let me know if you have any questions.

Sincerely,



Cindy Mammarella
Secretary/Treasurer

PENNSYLVANIA-AMERICAN WATER COMPANY
 COATESVILLE DISTRICT
 2007 WASTELOAD MANAGEMENT REPORT SURVEY

WEST SADSBOURY TOWNSHIP

Municipality: ~~Borough of Parkersburg~~ (#3 & #5 ONLY NEEDED)

Information furnished by: Jim Landis Date: 1-24-08

Municipality/Engineering Company: WEST SADSBOURY TWP.

Name: Jim Landis

Address: 6400 N. Moscow Rd
PARKERSBURG PA 19365

Phone: 610 857 5969 Fax: 610 857 1415

1. Total Present Number of EDU's connected to PAWC system:

Residential	
Commercial	
Industrial	

2. Total EDU's connected to PAWC system during 2007:

Residential	
Commercial	
Industrial	

3. Projections for future additional EDU's to be connected to PAWC system. These projections should reflect what is actually anticipated to be constructed and placed in service:

Year	Residential	Commercial	Industrial	Total EDU's
2008	0	0	5	
2009			5	
2010	300	200		
2011	300	100		
2012	25	25	50	
Beyond 2012				
Total				

4. Sewer extensions constructed during 2007 that contribute flows to PAWC system:

Project/Development Name	Length & Diameter of Sewer Completed	Length & Diameter of Sewer Remaining	Total EDU's Connected	Total EDU's Remaining

5. Proposed projects which shall require sewer extensions that will contribute flows to PAWC system but are not yet constructed:

Project Name	Length & Diameter of Sewer Proposed	Total EDU's Proposed	Start of Construction (Year)
MAST PROPERTY		800	2009
H.D. ECKMAN		7	2008

6. Please provide discussion of the following:

a) Sewer System Flow Monitoring:

b) Sewer System Maintenance:

c) Sewer System I&I Program:

7. Please provide discussion of the condition of your sewer system:

a) Portions where conveyance capacity is being exceeded or will be exceeded in the next 5 years:

b) Proposed projects to increase conveyance capacity, i.e., repair, rehabilitation, new construction:

8. Please provide data and discussion of your sewage flow:

Basin/Gravity Point or Flow Meter Point or Pump Station Name	Agreement or Rated Capacity (gpm)	2006 Average Daily Flow (gpm)*	2007 Projected Average Daily Flow (gpm)*	2011 Projected Average Daily Flow (gpm)*

* Based on Average Annual Flow

a) Other discussion or information:

9. Please provide a discussion of the industrial waste discharged into your sewer system:

a) Date of adoption of the ordinance or regulation governing industrial waste discharges to your system:

b) Discussion of program for the surveillance and monitoring of the industrial waste discharges into your sewer system:

c) Discussion of specific problems in your sewer system, known or suspected to be caused by industrial waste discharges within the past 5 years:

APPENDIX E

PAWC 2008 CONNECTION MANAGEMENT PLAN



**Pennsylvania
American Water**

**COATESVILLE DISTRICT
CHESTER COUNTY**

**CONNECTION MANAGEMENT PLAN
WASTEWATER TREATMENT PLANT
AND
COLLECTION SYSTEM**

REPORTING 4th Quarter 2008 Data REVISED: January 2009

**PLEASE NOTE
CMP SUBMITTAL DATES BY PAWC TO PADEP BY:
1/15/2009**

**PADEP APPROVAL DATES:
PENDING**

**PREPARED BY:
PENNSYLVANIA - AMERICAN WATER COMPANY
COATESVILLE DISTRICT
GERALD A. DeBALKO, P.E.
4 WELLINGTON BLVD.
WYOMISSING, PA 19610
T: (610) 670-7789 EXT 127
F: (610) 678-6057**

**CONNECTION MANAGEMENT PLAN
WASTEWATER TREATMENT PLANT (WWTP)
&
COLLECTION SYSTEM
REPORTING 4th Quarter 2008 Data REVISED: January 2009**

SUMMARY OF MANAGEMENT PLAN GOALS FOR WWTP

PAWC, in coordination with tributary municipalities, provides on-going and revised projections through PAWC's Connection Management Plan (CMP) which is submitted to DEP on a quarterly basis as set forth in the Consent Order & Agreement (CO&A). The CMP has two summaries of projections on Table A2 in the report and reflects those developments approved by DEP for construction and connection to the sewer system which is located within the 2001 DEP approved Act 537 service areas of the tributary municipalities. These developments may be connected prior to the completion of the sewer plant expansion pending final DEP approval of the applicable sewer planning modules. The 5 year projected annual flows approved by DEP at this time project total flows in Summary # 1 of 4.648 mgd with a total construction of 4,565 EDUs by 2013. Summary # 2 is a PAWC projection of projects with Planning Modules signed by PAWC or pending submission by PAWC which is two more than Summary #1 in this submission. Valley Township has requested one EDU for the Weaver Lot and East Fallowfield requested one EDU for Emily Landis. PAWC has noted this change marked pending for approval.

On the CMP, Table A3, Summary #1 indicates all units as requested by developers and townships, and is a aggressive growth number which would produce an average flow in 2013 of 5.674 mgd. Summary #2 indicates all units requested which have planning modules signed by PAWC or pending, and is a more conservative growth number which would produce an average flow in 2013 of 4.648 mgd. Summary #3 shows the difference between Summary #1, the aggressive EDU projection, and Summary #2; and represents the remaining EDU's not yet signed by PAWC.

Table A1A is composed of two (2) different projections. The first projection at the top of the page (Projected Total per CMP Table A2 (2008 Q4, Revised January 2009), Summary No. 2) begins with the 2008 actual average flow of 3,475,308 gpd which will be reported in the 2008 Chapter 94 report and projects flows for the five year period of 2009-2013 resulting in a 2013 average flow of 4,487,758 gpd.

The second projection at the bottom of the page Summary No. 2 – Based on adjusted 5 Year Average refers to the CMP Table A2, Summary #2 for which PAWC has approved planning modules or considers to be pending. Starting with the most recent adjusted five year average flow of 3,635,891 gpd, the average flow in 2013 is projected to be 4,648,341 gpd. Table A1B shows the derivation of the adjusted 5 year average flow based on flow adjustments for prior year connections.

Looking at both summaries, PAWC anticipates the actual flow in the next five years will most realistically follow this second projection for pre-plant expansion. Once the expanded plant is completed and new, additional capacity provided, flows will be able to exceed the pre-plant capacity limits.

PAWC has Water Quality Management Permit on January 11, 2008 for the construction and operation of the proposed 7.0 MGD Coatesville Wastewater Treatment Facility. PAWC has issued a Notice of Award on April 14, 2008 and a Notice to Proceed to Allan Myers on May 5, 2008. Concrete work of the Headworks, Oxidation ditch, two clarifiers and RAS building is nearing completion. Completion of Phase 1 of the project is estimated by spring 2009 and substantial completion of the entire facility by January 2010.

CORRECTIVE ACTIONS TO ADDRESS PROJECTED HYDRAULIC OVER LOAD:

PAWC has been developing a Regional Act 537 Plan since 2001 and distributed the draft plan to the tributary municipalities, the Chester County Planning Commission and the Chester County Health Department for review and comment in 2005. Most of the municipalities and the County agencies did respond and their comments were reflected in a revised draft Plan. PAWC submitted this plan to DEP for review in the 4th Quarter of 2005. At a meeting with the tributary municipalities on December 7, 2005, in which PAWC and representatives from DEP attended, DEP explained it had made the decision that each tributary municipality must submit its own revised Act 537 Plan from which certain elements of these plans must be incorporated into PAWC's Regional Act 537 Plan.

East Fallowfield submitted its revised Act 537 Plan to DEP in 2004; however, DEP determined it was not administratively complete. East Fallowfield is in the process of revising and updating the Plan for submission in 2009.

Cain Township submitted its revised Act 537 to DEP on November 7, 2005, and has met a number of times with DEP to resolve issues pertaining to a proposed pump station which would separate flows to the Downingtown Area Regional Authority ("DARA") and PAWC's Coatesville Plant. By letter dated September 27, 2007, DEP advised Cain Township that it "...will be unable to issue an approval for the Townships Act 537 plan update until we have approved the PAWC Regional Plan that provides the expansion of the PAWC Regional Plant and will release the approval of the Township's plan concurrently with our approval of the regional plan."

Valley Township has also completed and submitted its ACT 537 Plan to DEP.

Only minor revisions were required to the City of Coatesville's and the Borough of Parkesburg's Act 537 Plan which pertains to projected capacity needs. The City of Coatesville planning effort has been submitted to DEP for final approval pending approval of the PAWC Act 537 Plan. The Borough of Parkesburg planning effort has been included as an appendix in the PAWC Act 537 Plan and concurrent DEP approvals are subsequently anticipated.

Sadsbury Township has determined there are no changes needed in its existing, approved Act 537 Plan at this time. Its Plan provides for present and future needs and is still appropriate for its planning period; therefore, their Plan will not need revisions.

The remaining municipalities, West Brandywine, West Cain and West Sadsbury Townships are in various stages of Act 537 revisions which are anticipated to be completed most likely in 2009. Highland Township is also considering proceeding with its first Act 537 Plan but has yet to authorize its preparation. All ten tributary municipalities are aware that their projected, future sewer capacity needs cannot be approved until PAWC's Act 537 Plan, as well as the individual municipality's Plan, is approved by DEP and, further, until the Coatesville sewage treatment plant expansion is completed.

PAWC has successfully worked with all tributary municipalities in the development of the needs analysis for sewer capacity which we are including in our ACT 537 Plan. We completed our Plan draft in August 2006 and sent it to the tributary municipalities and to South Coatesville Borough, the host municipality for our sewage treatment plant, for their review and comment. Draft Plan copies were also sent to the Chester County Planning Commission ("CCPC") and the Chester County Health Department ("CCHD").

PAWC and our consulting firm, URS, have met with each of the eleven municipal planning commissions (including South Coatesville) to discuss and respond to questions regarding our Plan. All ten of the tributary municipal planning commissions have sent their comments and recommendations to their respective governing bodies for consideration of the approval of the PAWC Act 537 Plan. The South Coatesville Borough Planning Commission has not made their recommendations yet although PAWC has met with the Borough Planning Commission several times. We continue to work with this planning body to encourage their recommendations.

It should be noted here that on September 11, 2007, the South Coatesville Borough Council approved the issuance to PAWC of a Letter of Consistency indicating compliance with its Chapter 52 Flood Management Ordinance. The Letter of Consistency dated September 28, 2007, was sent to PAWC. PAWC forwarded a copy of this letter to DEP for the final approval needed for the issuance of the construction permit.

We will finalize additional information for the Plan which will be sent to all municipal governing bodies by March 2009. We will then request meetings with all eleven governing bodies to make a formal presentation of the Plan and respond to questions and comments. We will present a sample resolution for the governing bodies to consider for adoption of the PAWC Plan. We anticipate receiving all municipal approvals in 2009.

We continue working with all municipalities to lend any assistance requested in the development of their individual ACT 537 Plans to try to assure continuity with all Plans. Because of time constraints and delays we have faced throughout this whole process, we will be requesting that DEP assist us by expediting its review and approval of our ACT 537 Plan submission.

On December 7, 2005, DEP directed that sewer connections would be allowed only in those sewer service areas of the Act 537 Plan approved by DEP on March 15, 2001. Any developments proposed in areas outside the 2001 service area will not be approved until after the plant expansion unless the municipality's limited scope Act 537 Plan revision is first approved by DEP and, further, provided the additional capacity requested does not exceed the CMP allocation of 4.6 mgd prior to the Plant expansion. For four projects (Bone Tract, London Tract, Southwoods, and Ridgecrest) that are outside the Act 537 2001 service areas, PAWC requested and DEP approved to move these projects from Table A3 to A2 in the Q2 2006 CMP revised July 2006. At this time there are no other requests for connections outside the 2001 sewer service areas.

PAWC submitted a re-rating study to DEP which shows the organic and hydraulic capacity of the facility to be 4.86 MGD. As part of the CO&A, DEP will permit flow allocations up to the average annual flow rate of 4.6 MGD to be used in the CMP projections prior to the completion of the sewer plant expansion. DEP received the Part I NPDES permit for the proposed 7.0 MGD facility on September 17, 2005. DEP received the Part II NPDES permit for the proposed 7.0 MGD facility on March 31, 2006. PAWC has completed the design engineering for the WWTP expansion. PAWC anticipates having the WWTP expanded capacity online by early 2010 pending issuance of Part 2 permit by DEP.

On January 24, 2008, PAWC submitted a request to DEP to establish a final rate of gallons per day per EDU for single family, detached homes, apartments/town houses, and senior housing. By letter dated May 29, 2008, DEP agreed on a flow of 225 gpd for all single family, detached dwelling units, and 200 gpd for all other residential units. This information has been incorporated in this and all future CMPs and will be incorporated in the PAWC Act 537 Plan.

SUMMARY OF MANAGEMENT PLAN GOALS FOR COLLECTION SYSTEM

Previous Connection Management Plans (CMP) identified MH #16 to #18 as the most critical section of the East End Trunk Line (EETL) and allocated new connections as shown in Table B2 of the CMP, until the line upgrade of this critical section was completed. Construction of this upgrade was substantially completed and placed into service on 5/10/06. There is no need for further allocation of new connections as it pertains to this section.

Previous Connection Management Plans (CMP) identified MH #20 to #21 as the most critical section of the East End Trunk Line (EETL) and allocated new connections as shown in Table B2 of the CMP, until the line upgrade of this critical section was completed. Construction of this upgrade was substantially completed and placed into service on 1/25/07. There is no need for further allocation of new connections as it pertains to this section.

All EETL segments previously awarded for replacement (sections 19 through 26 and 29 through 31) are now complete.

Utilizing flow projections for the next five years, and based on system flows as monitored in May 2002, Table B1 shows the next critical section of the Collection System to be between manholes 10 and 9. Peak flows are based on projections of average daily flow, which correlate to the increase in projected new connections based on Table A2 – summary #2, times a peaking factor of 2.8. The projected EDU's are based on the EDU's as submitted by the contributing municipalities and currently signed Planning Modules and PAW/developer estimates of buildout. Provided that all projected EDU's on Table A2 become active, we project a hydraulic overload in this critical section in 2010. The full pipe design capacity of the line is 10,741,680 gpd, and the present peak flow is 7,691,600 gpd. The projected EDU's remaining based on the average daily flow would be 4,841 EDU's.

As shown in Table 2, PAW currently has capacity to accept 4,841 new EDU's through this critical section of the collection system. All proposed connections on Table A2 are upstream of this section. Table B2 indicates that a total of 4,723 new EDU's through 2009 are approved to flow through this section and 466 have connected since establishing the limit, leaving a total of 4,257 EDU's remaining to be connected. The total EDU allowed through 2009 is consistent with DEP's September 5, 2007 approving the July 2007 submission of the CMP. PAWC is limiting connection until this critical section is upgraded and placed into service.

Manhole segment 10 to 9 is located within the Mittal Steel Property just north of the existing sewage treatment plant. The sewer main is part of the 30" interceptor that collects the sewage from the East and West End trunk lines which combine at manhole 15. The 30" interceptor conveys all the sewage in the Coatesville sewer service area from manhole 15 to the headworks of the existing treatment plant.

PAWC plans to upgrade this section in conjunction with its planned upgrades to the Coatesville WWTP. The following action items are underway with regards to this project.

PAWC installed surcharge level indicators at MH locations 9, 10, 12, 20, 21 and 22 to monitor operating conditions during wet weather conditions. Buchart Horn and PAWC has monitored them since July 28, 2006 and has not recorded any sewer overflows during the monitoring period.

- PAWC has received the Part II Permit January 8, 2007 for this upgrade. Permit No. 1506416.
- PAWC has received bids for construction on July 17, 2007.
- PAWC awarded the contract on October 12, 2007 and issued a Notice to Proceed on December 3, 2007.
- New 42" DIP Interceptor line is complete.

PAWC has recently signed planning modules for three developments with the Borough of Parkesburg, the Davis Tract 324 EDU's, Crystal Springs 129 EDU's, and HDC Site 75 EDU's. PAWC performed a capacity analysis and identified the combined total of the additional EDU's will cause specified segments to be greater than its design capacity. A restriction shall be placed upon these three developments that prior to connection of a combined total of 232 EDU's, pipe segments must be replaced. To assist the developers, PAWC will coordinate the design, permitting and construction of the improvements and offer the following Corrective Action Plan (CAP).

- PAWC has begun design efforts in October 2007.
- PAWC has submitted the Part II permit to DEP in March 2008.
- PAWC will receive bids for construction pending developer's construction schedule.
- Notice of Award and Proceed issued two months after receipt of bids.
- Construction timeframe – six months to final completion after Notice of Award.

CONNECTION MANAGEMENT PLAN - REPORTING 4th Quarter 2008 Data REVISED: January 2009
WASTEWATER TREATMENT PLANT (WWTP) CAPACITY PROJECTIONS
TABLE 1

CAPACITY BASED ON ACT 537 PLANNING	
<u>Line/Note</u>	
A	ANNUAL AVERAGE FLOW PER ACT 537 3.85 mgd
B	AVAILABLE ALLOCATION LIMIT PER CONSENT ORDER 4.60 mgd
C	ADJUSTED 5 YEAR ANNUAL AVERAGE FLOW 3.636 mgd
D	AVAILABLE CAPACITY TO ALLOCATE 0.964 mgd
E	AVAILABLE EDUS BASED ON AVAILABLE CAPACITY 4,284 edu
1	PERMITTED 3-MONTH MAXIMUM FLOW PER NPDES PERMIT 4.600 mgd
2	5 YEAR MAXIMUM 3-MONTH AVERAGE FLOW 3.981 mgd
3	5 YEAR AVERAGE PEAKING FACTOR: 3-MONTH MAXIMUM TO ANNUAL AVERAGE 1.095

Note

All referenced tables are located in Appendix

EDU = 225 gpd/edu

(A) Annual Average Flow per 1995 ACT 537 Plan

(B) Available capacity to be allocated per November 30, 2005 Consent Order prior to facility expansion in 2008.

(C) Calculated using the running Adjusted 5 Year Equivalent Base Flows from Table A1B.

(D) Calculated as Line A - Line B

(E) Calculated as (Line C * 1,000,000) divided by (225 gpd/edu). Available EDU's could be greater when lower EDU values for senior housing are factored in.

(1) 4.60 mgd is the Maximum Month Flow per the NPDES permit which is used to help determine hydraulic loading at WWTP. Hydraulic overload does not occur until the maximum month average is exceeded for 3 consecutive months.

(2) From Table A1A, calculated as Adjusted 5 year annual average flow times peak factor from Table A1.

(3) 5 Year Peak factor from Table A1.

CONNECTION MANAGEMENT PLAN - REPORTING 4th Quarter 2008 Data REVISED: January 2009
30" INTERCEPTOR CAPACITY PROJECTIONS
TABLE 2

CAPACITY BASED ON MOST CRITICAL SECTION		
<u>Line/Note</u>		
1	HYDRAULIC PEAK CAPACITY AT CRITICAL SECTION (MH# 10 to MH# 9)	10,741,680 gpd
2	INTERCEPTOR AVERAGE DAILY FLOW	2,747,000 gpd
3	INTERCEPTOR PEAK DAILY FLOW	7,691,600 gpd
4	AVAILABLE CAPACITY AS PEAK FLOW	3,050,080 gpd
5	AVAILABLE CAPACITY AS AVERAGE FLOW	1,089,314 gpd
6	AVAILABLE EDUS AT AVERAGE FLOW	4,841 edu
7	NUMBER OF CONNECTIONS MADE	466 edu

Note

- All referenced tables are located in Appendix
- (1) Critical Section as indicated on Table B1
 - (2) Average Daily Flow as indicated in Table B1 for critical section. Average Daily Flow values as indicated on Table B1 are obtained from the I&I Program's May 2002 metering of basins.
 - (3) Peak Daily Flow as calculated by multiplying Line 2 by 2.8
 - (4) Available Capacity as indicated on Table B1 for critical section.
 - (5) Calculated by removing peaking factors from Peak Flow on Line 4.
 - (6) Calculated as Line 5 divided by 225 gpd/EDU
 - (7) Connections made as detailed on Table B2

APPENDIX A

TABLE A1A

PROJECTED TOTAL PER CMP, TABLE A2 (2008 Q4, REVISED JANUARY 2009), SUMMARY NO. 2								
	Act 537 Approved Contracted Allocation	Chapter 94 Flow 2008	2009	2010	2011	2012	2013	5-year Net Increase
City of Coatesville	*	1,815,352	1,888,252	1,979,652	2,011,377	2,017,002	2,017,002	201,650
Valley Township	550,000	625,168	730,443	830,793	842,493	842,493	842,493	217,325
Cain Township	167,000	171,615	174,090	181,740	198,290	215,040	221,790	50,175
West Brandywine Township	345,000	138,103	177,928	217,528	235,753	247,228	265,453	127,350
Sadsbury Township	410,750	117,571	145,471	187,096	232,096	263,821	263,821	146,250
West Sadsbury Township	*	44,848	46,423	57,673	57,673	57,673	57,673	12,825
East Fallowfield Township	*	121,254	150,054	178,629	186,729	191,679	191,679	70,425
Borough of Parkesburg	*	327,239	409,289	499,739	499,739	499,739	499,739	172,500
West Cain Township	*	22,447	33,472	36,172	36,172	36,172	36,172	13,725
Veterans Hospital	*	87,262	87,262	87,262	87,262	87,262	87,262	-
Highland Township		225	450	450	450	450	450	225
Bulk Delivery		4,224	4,224	4,224	4,224	4,224	4,224	-
Ave. Total Flow (MGD)		3,475,308	3,847,358	4,260,958	4,392,258	4,462,783	4,487,758	1,012,450
3-Month Max (MGD)		3,791,000	4,196,846	4,648,017	4,791,244	4,868,176	4,895,420	1,104,420
Peak Factor		1.091	1.091	1.091	1.091	1.091	1.091	

PROJECTED TOTAL PER CMP (revised 1/09), TABLE A2 (SUMMARY NO. 2)- BASED ON 5 YEAR ADJUSTED AVERAGES								
Ave. Total Flow (MGD)		3,635,891	4,007,941	4,421,541	4,552,841	4,623,366	4,648,341	1,012,450
3-Month Max (MGD)		3,980,905	4,388,259	4,841,106	4,984,865	5,062,082	5,089,427	1,108,522
Peak Factor		1.095	1.095	1.095	1.095	1.095	1.095	

Contract and Planning Allocations For WWTF Expansion		
	Allocation	Contracted Capacity
City of Coatesville	2,391,490	
Valley Township		
Cain Township		1,540,000
West Brandywine Township		800,000
Sadsbury Township		345,000
West Sadsbury Township	111,951	410,750
East Fallowfield Township	329,232	
Borough of Parkesburg	633,416	
West Cain Township	251,089	
Veterans Hospital	74,271	
Highland Township	56,438	
Totals:	3,847,887	3,095,750
		6,943,637

**TABLE A1B
SUMMARY OF CONNECTIONS**

SOURCE	2004		2005 (2)		2006		2007		2008		5 Year Totals	
	New Flow	Equiv. EDU's	New Flow	Equiv. EDU's	New Flow	Equiv. EDU's	New Flow	Equiv. EDU's	New Flow	Equiv. EDU's	New Flow	Equiv. EDU's
Bulk Customers												
Valley Twp.	33,075	147	17,325	77	20,475	91	12,825	57	36,225	161	119,925	533
Calh Twp.	0	0	675	3	0	0	0	0	0	0	675	3
W. Brandywine Twp.	1,350	6	225	1	0	0	0	0	6,300	28	7,875	35
Sadsbury	25,200	112	31,500	140	7,650	34	0	0	450	2	64,800	288
Subtotal	59,625	265	49,725	221	28,125	125	12,825	57	42,975	191	193,275	859
Billed Customers (1)												
Veteran's Hospital	53,100 (3,542)	236 (16)	55,125 4,606	245 20	41,175 21,689	183 96	29,025 (4,488)	129 (20)	24,075 (8,816)	107 (39)	202,500 9,449	900 42
TOTAL	109,183	485	109,456	486	90,989	404	37,362	166	58,234	259	405,224	1801

(1) Net EDU addition for City of Coatesville, East Fallowfield Twp., Parkesburg Boro, West Sadsbury, West Caln, & Bulk Haulers
(2) The 2005 total was previously reported at 859 EDU's, however 2004 EDU's were counted as 2005 when updating the CMP to date.

Note: One EDU = 225 GPD

Base Flow Determination

	2004	2005	2006	2007	2008	5-YR Adjusted Average
Actual Annual Average	3.351	3.513	3.554	3.650	3.475	
Flow Adjustments 2005	0.109					
Flow Adjustments 2006	0.091	0.091				
Flow Adjustments 2007	0.037	0.037	0.037			
Flow Adjustments 2008	0.058	0.058	0.058	0.058		
Total Adjustment	0.296	0.187	0.096	0.058	0	
Equivalent Flow	3.647	3.700	3.650	3.708	3.475	3.636

CONNECTION MANAGEMENT PLAN - REPORTING 4th Quarter 2008 Data REVISED: January 2009
PROJECTED NEW CONNECTIONS WITH SIGNED PLANNING MODULES
PLEASE NOTE - CMP WAS SUBMITTED BY PAWC BUT NOT APPROVED BY DEP
TABLE A2

EST. GPD

LINE	DEP Code No	NAME	TOTAL EDU. EDU'S	EDUS EO ACTIVE	EDUS REMAINING	REMAINING	PLANNING (b) MODULE	EETL &WETL MH	TYPE	2009	2010	2011	2012	2013	TOTAL IN 5 YEARS	TOTAL BEYOND 2013
1	1-15001-036-3J	Cambridge Terrace	68	16	51	11,925	Y	16	R	22	22	9			53	
2	1-15001-029-3H	Penn Crossing	78	78			Y	40	R							
3	1-15001-029-3H	Millview	187	187			Y	523	R							
4	1-15001-023-3H	Millview Apartments	350	350			Y	523	R							
5	1-15001-032-3J	Cox II	11	11			Y	37	R							
6	1-15001-037-3J	Bond House (Mount Pleasant Street)	13	12	1		Y	523	R							
7		Brandywine View	638		638	225	Y	23	R	205	205				410	228
8		Power Office Building 1	8		8		Y	578	R							
9		Marriott Hotel & Restaurant	78	78			Y	578	R							
10		Cherty Towers 1 - Residential	60	60			Y	23	C	60	60				78	
11		Cherty Towers 2 - Residential	10	10			Y	23	C	10	10				60	
12		Cherty Towers 2 - Commercial	150	150			Y	23	C	10	10				150	
13		Cherty Towers 2 - Commercial	25	25			Y	16	R						25	
14		Cherty Towers 2 - Commercial	15	15			Y	16	R						15	
15		Cherty Towers 2 - Commercial	4	4			Y	33	R						4	
16		Cherty Towers 2 - Commercial	7	7			Y	33	R						7	
17		701 E.L.H. - Residential	9	9			Y	33	R						9	
18		Williams Trn	80	80			Y	16	R	25	25				80	
19		Coatesville VoTech	4	4			Y	16	R	1	1				4	
20		McCull-Coatesville Condominium	8	8			Y	16	R	8	8				8	
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
32																
33																
34																
35																
36																
37																
38																
39																
40																
41																
42																
43																
44																
45																
46																
47																
48																
49																
50																
51																
52																
53																
54																
55																
56																
57																
58																
59																
60																
61																
62																
63																
64																
65																
66																
67																
68																
69																
70																
71																
72																
73																
74																
75																
76																
77																
78																

CONNECTION MANAGEMENT PLAN - REPORTING 4th Quarter 2008 Data REVISED: January 2009
PROJECTED NEW CONNECTIONS
PLEASE NOTE - CMP WAS SUBMITTED BY PAWC BUT NOT APPROVED BY DEP
TABLE A3

LINE	DEP Code No	NAME	TOTAL EQ. EDU'S	EDUS EQ. ACTIVE	EDUS REMAINING	EST. GPD REMAINING	PLANNING (b) MODULE	EETL MH	TYPE	2009	2010	2011	2012	2013	TOTAL IN 5 YEARS	TOTAL BEYOND 2013
1	1-15001-036-3U	Gambria Terrace	69	16	53	11,925	Y	16	R	22	22	9			53	
2	1-15001-029-3H	Penn Crossing	78	78			Y	40	R							
3	1-15001-023-3H	Milview	187	187			Y		R							
4	1-15001-023-3H	Milview Apartments	350	350			Y		R							
5	1-15001-032-3J	Cox II	11	11			Y	37	R							
6	1-15001-037-3U	Bond House (Mount Pleasant Street)	13	12	1	225	Y	X	R	1					1	
7	1-15001-037-3U	Brandywine View	638	638		143,550	Y	X	R	205					205	
8	1-15001-037-3U	Pulver Office Building 1	8		8	1,800	Y	X	R						8	
9	1-15001-037-3U	Mannott Hotel & Restaurant	78	78		17,550	Y	X	C	60					60	
10	1-15001-037-3U	Chetty Towers 1 - Residential	60	60		12,000	Y	X	C	10					10	
11	1-15001-037-3U	Chetty Towers 1 - Commercial	10	10		2,250	Y	X	C	10					10	
12	1-15001-037-3U	Chetty Towers 2 - Residential	150	150		33,750	Y	X	C	60					60	
13	1-15001-037-3U	Chetty Towers 2 - Commercial	25	25		5,000	Y	X	C	5					5	
14	1-15001-037-3U	Chetty Towers 3 - Residential	325	325		73,125	Y	X	C	20					20	
15	1-15001-037-3U	Chetty Towers 3 - Commercial	66	66		14,850	Y	X	C						66	
16	1-15001-037-3U	Chetty Tower 4 - Residential	48	48		10,800	Y	X	C						48	
17	1-15001-037-3U	Chetty Tower 4 - Commercial	6	6		1,350	Y	X	C						6	
18	1-15001-037-3U	Chetty Tower 5 - Residential	195	195		43,875	Y	X	C						195	
19	1-15001-037-3U	Chetty Tower 5 - Commercial	34	34		7,650	Y	X	C						34	
20	1-15001-037-3U	Chetty Tower 6 - Residential	85	85		19,125	Y	X	C						85	
21	1-15001-037-3U	Chetty Tower 6 - Commercial	9	9		2,025	Y	X	C						9	
22	1-15001-037-3U	Flats Tract - Residential	90	90		190,000	Y	X	C						90	
23	1-15001-037-3U	Pulver Office Building 2	25	25		20,250	Y	X	C						25	
24	1-15001-037-3U	Pulver Office Building 3	25	25		5,625	Y	X	C						25	
25	1-15001-037-3U	Pulver Office Building 4	25	25		5,625	Y	X	C						25	
26	1-15001-037-3U	Pulver Office Building 5	12	12		2,700	Y	X	C						12	
27	1-15001-037-3U	Pulver Office Building 6	32	32		7,200	Y	X	C						32	
28	1-15001-037-3U	129-133 ELH - Residential	15	15		3,000	Y	X	C						15	
29	1-15001-037-3U	129-133 ELH - Commercial	4	4		900	Y	X	C						4	
30	1-15001-037-3U	ChesPerm - Residential	7	7		1,400	Y	X	R						7	
31	1-15001-037-3U	ChesPerm - Commercial	9	9		1,800	Y	X	R						9	
32	1-15001-037-3U	701 ELH - Residential	65	65		14,625	Y	X	R						65	
33	1-15001-037-3U	731 ELH - Residential	9	9		2,025	Y	X	R						9	
34	1-15001-037-3U	Canisler Tower East - Residential	40	40		9,000	Y	X	R						40	
35	1-15001-037-3U	Canisler Tower East - Commercial	6	6		1,350	Y	X	R						6	
36	1-15001-037-3U	Canisler Tower West - Residential	20	20		4,500	Y	X	R						20	
37	1-15001-037-3U	Canisler Tower West - Commercial	30	30		6,750	Y	X	R						30	
38	1-15001-037-3U	Regional Recreation Complex	5	5		1,125	Y	X	C						5	
39	1-15001-037-3U	Steel Heritage Museum	80	80		18,000	Y	X	C						80	
40	1-15001-037-3U	G.O. Calson/Mittal Steel Tract	4	4		900	Y	X	R						4	
41	1-15001-037-3U	Train Station	8	8		1,800	Y	X	R						8	
42	1-15001-037-3U	Williams Tract	60	60		13,500	Y	X	R						60	
43	1-15001-037-3U	Coatesville Vo Tech	8	8		1,800	Y	X	R						8	
44	1-15001-037-3U	McCole-Coatesville Condominium	4	4		900	Y	X	R						4	
45	1-15001-037-3U	City Request Other	50	50		13,500	Y	X	R						50	
46	1-15001-037-3U		4,001	654	3,347	726,425			EDU FLOW	342	488	862	255	405	1,852	1,495
47	1-15001-037-3U		900,225	147,150	753,075					74,925	107,550	78,990	53,625	87,375	402,475	324,000
48	1-15001-037-3U															
49	1-15956-117-3H	Hillview	512	313	199	39,800	Y	16	R	100	99				199	
50	1-15956-119-3H	Meadow Brook	88	88		36,225	Y	16	R	81	80				161	
51	1-15956-134-3U	Oak Crest (Dague)	188	27	161		Y		R							
52	1-15956-118-3H	Valley Crossing IV	46	46			Y		R							
53	1-15956-123-3J	Timberlane	46	46			Y		R							
54	1-15956-126-3J	Round Hill (Buckthorn Area)	230	118	112	25,200	Y		R	50	50				112	
55	1-15956-127-3J	Hanscom Subdivision	1	1		225	Y		R							
56	1-15956-127-3J	Lambert Subdivision	3	2	1	225	Y		R							
57	1-15956-124-3J	Highlands Corp. Center Phase I, II, III	90	27	63	14,175	Y	16	R	1	1				1	
58	1-15956-132-3J	Woodland Point (Ristobus)	9	6	3	675	Y		C	63	63				63	
59	1-15956-125-3J	Valley Suburban (Stoltz)	340		340	76,500	Y		C	100	200				340	
60	1-15956-125-3J	Valley Farm & Mt. Airy Road	81	22	59	13,275	Y		C	31	28				59	
61	1-15956-128-3U	Terry Middleton	1	1		6,750	Y		R							
62	1-15956-128-3U	Rainbow	30		30	3,150	Y		R						30	
63	1-15956-128-3U	London Tract	14		14	96,750	Y		R	14	14				14	
64	1-15956-128-3U	Bone Tract (Valley Portion)	430		430		Y		RIC	80	50				130	
65	1-15956-128-3U															
66	1-15956-128-3U															

APPENDIX B

CONNECTION MANAGEMENT PLAN - COLLECTION SYSTEM
COLLECTION SYSTEM HYDRAULIC MODEL USING MAY 2002 METERED FLOWS

TABLE B1

Upstream Manhole	Upstream Elevation	Downstream Manhole	Downstream Elevation	Pipe Diameter	Pipe Length	Pipe Slope	n	Nominal Capacity	Metered ADF (2002)	Metered ADF + Prof. ADF (2008)	Metered ADF + Metered ADF + Prof. ADF (2011)	Metered ADF + Metered ADF + Prof. ADF (2015)	Metered ADF + Metered ADF + Prof. ADF (2015)	Peak Calculated Flow (2009)	Peak Calculated Flow (2011)	Peak Calculated Flow (2015)	Peak Calculated Flow (Beyond 2015)	Available Capacity	% of capacity	
54	374.33	53	370.89	10	202.69	0.0171	0.013	2,005,540	141,000	141,000	171,150	213,000	213,000	401,100	422,500	441,400	479,200	429,400	1,420,900	29.7%
55	370.89	52	369.07	10	186.32	0.0098	0.013	1,518,480	141,000	141,000	159,227	198,500	198,500	350,727	372,127	391,027	428,927	378,027	1,420,900	29.7%
56	369.07	51	365.03	10	196.53	0.0153	0.013	1,896,480	141,000	141,000	152,400	191,700	191,700	340,900	362,300	381,200	419,100	368,200	1,420,900	29.7%
57	365.03	50	361.00	10	211.77	0.0093	0.013	1,478,520	141,000	141,000	167,472	210,456	210,456	398,916	420,316	439,216	477,116	426,216	1,420,900	29.7%
58	361.00	49	353.68	10	320.00	0.0136	0.013	1,224,360	141,000	141,000	147,507	187,507	187,507	336,014	357,414	376,314	414,214	363,314	1,420,900	29.7%
59	353.68	48	346.54	10	296.00	0.0133	0.013	1,180,000	141,000	141,000	158,597	198,597	198,597	350,194	371,594	390,494	428,394	377,494	1,420,900	29.7%
60	346.54	47	344.4	10	296.00	0.0084	0.013	1,402,000	141,000	141,000	151,700	191,700	191,700	340,000	361,400	380,300	418,200	367,300	1,420,900	29.7%
61	344.4	46	341.8	12	228.47	0.0098	0.013	2,056,300	300,000	300,000	421,246	498,968	498,968	814,400	835,800	856,700	894,600	793,700	2,056,300	45.5%
62	341.8	45	334.5	12	228.47	0.0098	0.013	2,056,300	300,000	300,000	421,246	498,968	498,968	814,400	835,800	856,700	894,600	793,700	2,056,300	45.5%
63	334.5	44	330.55	12	177.86	0.0224	0.013	3,230,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
64	330.55	43	326.6	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
65	326.6	42	322.6	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
66	322.6	41	318.5	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
67	318.5	40	314.4	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
68	314.4	39	310.3	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
69	310.3	38	306.2	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
70	306.2	37	302.1	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
71	302.1	36	298.0	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
72	298.0	35	293.9	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
73	293.9	34	289.8	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
74	289.8	33	285.7	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
75	285.7	32	281.6	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
76	281.6	31	277.5	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
77	277.5	30	273.4	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
78	273.4	29	269.3	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
79	269.3	28	265.2	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
80	265.2	27	261.1	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
81	261.1	26	257.0	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
82	257.0	25	252.9	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
83	252.9	24	248.8	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
84	248.8	23	244.7	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
85	244.7	22	240.6	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
86	240.6	21	236.5	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
87	236.5	20	232.4	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
88	232.4	19	228.3	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
89	228.3	18	224.2	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
90	224.2	17	220.1	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
91	220.1	16	216.0	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
92	216.0	15	211.9	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
93	211.9	14	207.8	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
94	207.8	13	203.7	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
95	203.7	12	199.6	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
96	199.6	11	195.5	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
97	195.5	10	191.4	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
98	191.4	9	187.3	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
99	187.3	8	183.2	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
100	183.2	7	179.1	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
101	179.1	6	175.0	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440	45.5%
102	175.0	5	170.9	12	262.26	0.0168	0.013	2,350,440	510,000	510,000	574,017	698,298	698,298	1,103,070	1,124,470	1,145,870	1,183,770	1,032,170	3,230,440</	

TABLE B2

30" Interceptor Allocation until Expansion is Complete from MH 10 to MH 9

Township	Development	Total Connections (1)	Connections Allowed (2)	Connections Made (3)	Connections Remaining (3)
City of Coatesville					
	Cambria Terrace	69	60	7	53
	Bond House (Mount Pleasant Street)	13	13	12	1
	Brandywine View	638	410	0	410
	Pulver Office Building 1	8	25	0	8
	Marriott Hotel & Restaurant	78	40	0	78
	Chetty Towers 1 - Residential	60	60	0	60
	Chetty Towers 1 - Commercial	10	10	0	10
	Chetty Towers 2 - Residential	150	150	0	150
	Chetty Towers 2 - Commercial	25	25	0	25
	ChesPenn - Residential	15	15	0	15
	ChesPenn - Commercial	4	4	0	4
	701 ELH - Residential	7	4	0	7
	731 ELH - Residential	9	9	0	9
	Williams Tract	80	80	0	48
	Coatesville VoTech	4	3	0	3
	McCook-Coatesville Condominium	8	0	0	8
	Subtotal	908	908	19	889
Valley Township					
	HilView	512	270	58	189
	Oak Crest (Daque)	188	174	13	181
	Timberlane	46	11	11	0
	Round Hill (Buckthorn Area)	230	180	95	85
	Hancock Subdivision	1	1	0	1
	Lambert Subdivision	3	3	2	1
	Highlands Corp. Center Phase I, II, III	90	63	0	63
	Woodland Point (Rabon)	9	7	0	9
	Valley Suburban (Stoltzfus Commercial)	340	300	0	300
	Valley Farm & Mt. Airy Road	81	60	19	41
	London Tract	14	14	0	14
	Bone Tract (Keytone Foods Portion)	20	20	0	20
	Albert Koenig	1	1	0	1
	Concain	3	0	0	3
	Valley Farm Associates	1	0	0	1
	Lawrence Professional Center	2	0	0	2
	Salzman Hangar	1	0	0	1
	John Woodward	1	0	0	1
	Olinck Lot	1	0	0	1
	Sainters Ltd.	1	0	0	1
	Albert W. Gault (705 Wagontown Rd.)	1	0	0	1
	Weaver Lot	1	0	0	1
	Valley Miscellaneous	1	0	0	1
	Subtotal	1104	1104	204	900
Cain Township					
	HilView (aka Hill Farm)	99	99	0	99
	Southwoods (Weiss)	20	20	0	20
	Low/Southdown (Ducce/Haron)	300	85	0	84
	Croft - 110 Walnut Street	1	0	0	1
	Subtotal	204	204	0	204
West Brandywine Township					
	Monacy Manor	42	42	0	42
	Freedom Village	297	28	28	0
	YMCA	67	48	0	48
	Brandywine Hospital	416	155	0	155
	Bunemaker Subdivision	2	2	1	1
	Culbertson Residential	78	80	0	90
	Swinehart Residential	113	50	0	50
	West Brandywine Twp MA	305	48	0	48
	Subtotal	483	483	29	434
Highland Township					
	SD Crook Property	1	1	1	0
	Walter Ross Jr.	1	0	0	1
Sadsbury Township					
	AIM Business Park - Betsire	132	82	0	36
	Morris Farm	12	1	0	1
	Sadsbury Park	461	320	0	320
	Bone Tract (Sadsbury Portion)	20	20	0	20
	O&S Developers	0	25	0	29
	Lafayette Square	130	60	0	130
	Comasny Partnership	2	2	0	2
	Sadsbury Township Misc	1	0	0	1
	Subtotal	510	510	0	510
East Fallowfield Township					
	Stone Creek (Robins Cove)	53	9	8	1
	Harkins Farm	21	21	0	21
	North Woods (Thompson North)	27	24	15	9
	Mansfield Tract	74	74	13	61
	Providence Hill (Chen Tract)	218	135	75	60
	Manchester Farms (Thompson South)	112	49	38	10
	Ridgecrest (Martin)	72	72	0	72
	Cardinal Drive Area	78	78	0	78
	Subtotal	481	481	149	312
Parkersburg Borough					
	Harkins Property	10	10	0	10
	Parkersburg Knoll	171	88	28	60
	Crystal Springs Expansion (Heritage)	129	250	0	129
	Lindale Village	31	31	0	31
	Davis Tract	324	368	0	324
	MK Builders	3	3	0	3
	Philips Site	4	4	0	4
	Library Site	131	131	0	131
	Minch Park East	1	1	0	1
	HDC Site	75	92	0	75
	CON-LYN	2	0	1	1
	Church - 94 East 2nd Avenue	1	0	0	1
	19 Boro Line Road	1	0	0	1
	Ross Property - 30 Beroline Road	1	0	0	1
	Williams Subdivision Rosemont Ave	2	0	0	2
	Shelley - 5th Avenue	1	0	0	1
	Parkersburg Borough Misc	115	0	0	115
	Subtotal	878	878	29	890
West Cain Township					
	Cainshire West	124	81	29	52
	Sandy Hill	87	15	6	9
	Subtotal	96	96	35	61
West Sadsbury Township (4)					
	JD Eckman	7	0	0	7
	Lower Valley Road Partners, LP	100	0	0	50
	Subtotal	107	0	0	57
Total Connections		4723	4723	486	4258
Total Connections Available		4841	4841	486	4258

NOTE (1) - Total projected new connections, both pre and post plant expansion from Table A2 upstream of critical section.
 (2) - Connection allowed prior to completion of Interceptor replacement of Manhole 10 to Manhole 9 as per DEP's March 27, 2007 and September 5, 2007 Letters.
 (3) - Connections made and remaining since the CMP revised January 2007.

APPENDIX F

**PAWC COLLECTION AND CONVEYANCE
SYSTEM ANALYSIS DATA**

EXISTING FLOW DATA						
Flow Input Manhole		Average Day (gpd)	Maximum Day (gpd)	Peak Factor	Peak Hour (gpd)	Peak Factor
638	Sadsbury PS	147,746	332,677	2.25	443,238	3.00
581	Valley Road MP	205,875	489,227	2.38	617,625	3.00
578	Charles Street MP	214,685	589,178	2.74	644,055	3.00
578	Portion (40%) Basin C2	276,986	480,000	1.73	830,958	3.00
523	Bradford Village PS	63,527	111,625	1.76	190,581	3.00
523	Portion (60%) Basin C2	415,478	945,000	2.27	1,246,434	3.00
371	Millview PS	18,000	26,620	1.48	54,000	3.00
371	Basin C1	30,000	70,000	2.33	90,000	3.00
	WETL Totals	1,372,297	3,044,327		4,116,891	
12	BW Homes - Caln PS	132,180	324,551	2.46	396,540	3.00
151	Carver Court - Caln	15,143	41,911	2.77	45,429	3.00
151	Brandywine Fab - Caln	2,866	2,866	1.00	8,598	3.00
151	West Brandywine PS	139,974	201,966	1.44	419,922	3.00
151	VA Hospital	96,078	207,859	2.16	288,234	3.00
323	Caln WM Reads	23,141	23,141	1.00	69,423	3.00
323	Basin C7 - 20%	39,849	109,029	2.74	119,547	3.00
535	Basin C7 - 5%	9,962	27,257	2.74	29,886	3.00
322	Basin C7 - 5%	9,962	27,257	2.74	29,886	3.00
224	Brinton Station PS	12,596	21,111	1.68	37,788	3.00
224	Stone Creek PS	27,534	40,438	1.47	82,602	3.00
224	Basin C7 - 60%	119,546	327,087	2.74	358,638	3.00
211	Basin C7 - 10%	19,924	54,515	2.74	59,772	3.00
204	Basin C6 - 10%	25,348	56,668	2.24	76,044	3.00
210	Basin C6 - 60%	152,086	318,473	2.09	456,258	3.00
214	Basin C6 - 5%	12,674	28,334	2.24	38,022	3.00
205	Basin C6 - 5%	12,674	28,334	2.24	38,022	3.00
434	Basin C6 - 5%	12,674	28,334	2.24	38,022	3.00
430	Basin C6 - 5%	12,674	28,334	2.24	38,022	3.00
429	Basin C6 - 10%	25,348	56,668	2.24	76,044	3.00
389	Basin C5 - 85%	531,071	1,187,266	2.24	1,593,213	3.00
388	Basin C5 - 5%	31,239	69,840	2.24	93,717	3.00
394	Basin C5 - 5%	31,239	69,840	2.24	93,717	3.00
414	Basin C5 - 5%	31,239	69,840	2.24	93,717	3.00
3	Basin C4	84,808	189,598	2.24	254,424	3.00
3	Basin C3	59,323	132,622	2.24	177,969	3.00
378a	Rock Run PS - Valley	209,742	524,447	2.50	629,226	3.00
	EETL Totals	1,880,894	4,197,586		5,642,682	
	WWTP Totals	3,253,191	7,241,913		9,759,573	

5 YEAR PROJECTION										
Flow Input Manhole	Existing		5 Year		5 Year Projected		Existing Max Day PF		5 Year Projected	
	Average Day (gpd)	Additional Flow (gpd)	ADF (gpd)	Max Day	to Project 5 year	ADF (gpd)	Max Day	to Project 5 year	MDF (gpd)	Peak Day PF
638	147,746	373,314	521,060	2.25	1,173,261	3.0	1,563,180	Existing Peak Day PF	5 Year Projected	PHF (gpd)
581	205,875	66,950	272,825	2.38	648,322	3.0	818,475	to Project 5 year	Peak Day PF	
578	214,685	254,863	469,548	2.74	1,288,620	3.0	1,408,644			
57B	276,986	276,986	553,972	1.73	480,000	3.0	830,958			
523	63,527	1,800	65,327	1.76	114,788	3.0	195,981			
523	415,478	415,478	830,956	2.27	943,135	3.0	1,246,434			
371	18,000	18,000	36,000	1.48	26,620	3.0	54,000			
371	30,000	52,300	82,300	2.33	192,033	3.0	246,900			
WETL Totals		1,372,297	2,121,524		4,866,780		6,364,572			
12	132,180	351,820	484,000	2.46	676,371	3.0	748,360			
151	15,143	-	15,143	2.77	41,911	3.0	45,429			
151	2,866	-	2,866	1.00	2,866	3.0	8,598			
151	139,974	507,011	646,985	1.44	933,523	3.0	1,940,955			
151	96,078	96,078	192,156	2.16	207,859	3.0	288,234			
323	23,141	2,250	25,391	1.00	25,391	3.0	76,173			
323	39,849	39,849	79,698	2.74	109,029	3.0	119,547			
535	9,962	-	9,962	2.74	27,257	3.0	29,886			
322	9,962	-	9,962	2.74	27,257	3.0	29,886			
224	12,596	12,596	25,192	1.68	21,111	3.0	37,788			
224	27,534	101,000	128,534	1.47	188,772	3.0	385,602			
224	119,546	16,050	135,596	2.74	371,001	3.0	406,788			
211	19,924	19,924	39,848	2.74	54,515	3.0	59,772			
204	25,348	25,348	50,696	2.24	56,668	3.0	76,044			
210	152,086	7,700	159,786	2.09	334,597	3.0	479,358			
210	-	24,300	24,300	2.24	54,432	3.0	72,900			
214	12,674	12,674	25,348	2.24	28,334	3.0	38,022			
205	12,674	12,674	25,348	2.24	28,334	3.0	38,022			
434	12,674	12,674	25,348	2.24	28,334	3.0	38,022			
430	12,674	12,674	25,348	2.24	28,334	3.0	38,022			
429	25,348	25,348	50,696	2.24	56,668	3.0	76,044			
389	531,071	54,375	585,446	2.24	1,308,827	3.0	1,756,338			
388	31,239	31,239	62,478	2.24	69,840	3.0	93,717			
394	31,239	31,239	62,478	2.24	69,840	3.0	93,717			
414	84,808	12,825	97,633	2.24	218,270	3.0	292,899			
3	59,323	296,900	356,223	2.24	796,369	3.0	1,068,669			
378a	209,742	170,200	379,942	2.50	950,022	3.0	1,139,826			
EETL Totals		1,880,894	3,425,325		6,785,572		9,572,335			
WWTP Totals		3,253,191	2,293,658		11,652,352		15,936,907			

Ultimate YEAR PROJECTION											
Flow Input Manhole	Existing		Ultimate		Ultimate Projected ADF (gpd)	Existing Max Day PF		Ultimate Projected MDF (gpd)	Existing Peak Day PF		Ultimate Projected PHF (gpd)
	Average Day (gpd)	Additional Flow (gpd)	Additional Flow (gpd)			to Project Ultimate Max Day	to Project Ultimate Peak Hour				
638	147,746	503,464	651,210	2.25	1,466,318	3.0	1,953,630				
581	205,875	136,925	342,800	2.38	814,606	3.0	1,028,400				
578	214,685	428,376	643,061	2.74	1,764,806	3.0	1,929,183				
578	276,986	156,175	219,702	1.73	480,000	3.0	830,958				
523	63,527	156,175	219,702	1.76	386,044	3.0	659,106				
523	415,478	18,000	415,478	2.27	943,135	3.0	1,246,434				
371	18,000	70,300	100,300	1.48	26,620	3.0	54,000				
371	30,000	70,300	100,300	2.33	234,033	3.0	300,900				
	1,372,297	1,295,240	2,667,537		6,115,563		8,002,611				
12	132,180	569,820	702,000	2.46	894,371	3.0	966,360				
151	15,143	2,857	18,000	2.77	49,818	3.0	54,000				
151	2,866	27,134	30,000	1.00	30,000	3.0	90,000				
151	139,974	725,026	865,000	1.44	1,248,093	3.0	2,595,000				
151	96,078	5,400	96,078	2.16	207,859	3.0	288,234				
323	23,141	5,400	28,541	1.00	28,541	3.0	85,623				
323	39,849	9,962	39,849	2.74	109,029	3.0	119,547				
535	9,962	9,962	9,962	2.74	27,257	3.0	29,886				
322	12,596	9,962	9,962	2.74	27,257	3.0	29,886				
224	27,534	111,575	139,109	1.68	21,111	3.0	37,788				
224	119,546	18,300	137,846	1.47	204,303	3.0	417,327				
211	19,924	18,300	19,924	2.74	37,157	3.0	413,538				
204	25,348	7,700	25,348	2.74	54,515	3.0	59,772				
210	152,086	50,000	159,786	2.24	334,597	3.0	376,044				
210	12,674	50,000	50,000	2.09	112,000	3.0	150,000				
214	12,674	12,674	12,674	2.24	28,334	3.0	38,022				
205	12,674	12,674	12,674	2.24	28,334	3.0	38,022				
434	12,674	12,674	12,674	2.24	28,334	3.0	38,022				
430	25,348	12,674	12,674	2.24	28,334	3.0	38,022				
429	531,071	54,375	585,446	2.24	56,668	3.0	76,044				
389	31,239	31,239	31,239	2.24	1,308,827	3.0	1,756,338				
388	31,239	31,239	31,239	2.24	69,840	3.0	93,717				
394	31,239	31,239	31,239	2.24	69,840	3.0	93,717				
414	84,808	17,325	102,133	2.24	69,840	3.0	93,717				
3	59,323	869,675	928,998	2.24	228,330	3.0	306,399				
3	209,742	361,150	570,892	2.24	2,076,860	3.0	2,786,994				
378a	1,880,894	2,820,337	4,701,231	2.50	1,427,480	3.0	1,712,676				
	3,253,191	4,115,577	7,368,768		9,203,599		12,964,053				
					15,319,161		20,966,664				

Existing Max Day Flows based on April 15, 2007 flow data							
Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
587_584	337.28	336.43	0.002	15	1.26	2.08	60.5
584_580	336.43	335.59	0.002	15	1.26	2.1	59.9
614_613	406.33	405.44	0.002	15	1.25	2.15	57.9
590_589	338.87	338.06	0.002	15	1.26	2.26	55.9
589_587	338.06	337.28	0.003	15	1.26	2.35	53.5
591_590	339.99	338.87	0.003	15	1.27	2.4	52.9
mh3_378a	300.41	300.28	0.002	24	3.66	7.05	51.9
401b_mh3	301.16	300.41	0.002	24	3.34	6.46	51.6
594_593	342.83	341.61	0.003	15	1.28	2.51	50.9
CO-35	484.64	484.57	0.001	18	0.92	1.85	49.7
620_619	418.6	417.38	0.003	15	1.25	2.56	49
613_612	405.44	404.13	0.003	15	1.24	2.57	48.4
599_598	346.72	346.15	0.003	15	1.28	2.66	48
604_60	359.86	358.97	0.003	15	1.27	2.65	48
624_623	423.07	422.07	0.003	15	1.25	2.62	47.9
CO-38	483.72	483.33	0.001	18	0.94	1.97	47.8
578_582	330.08	329.1	0.007	18	2.83	5.96	47.5
580_577	335.59	335.33	0.001	18	1.27	2.7	46.9
612_611	404.13	402.71	0.004	15	1.25	2.71	45.9
521_599	346.89	346.72	0.004	15	1.28	2.82	45.4
595_595	344.76	343.84	0.004	15	1.28	2.84	45.1
600_521	348.3	346.89	0.004	15	1.28	2.84	45.1
592_591	340.68	339.99	0.004	15	1.27	2.88	44.1
585_588	326.37	325.39	0.008	18	2.83	6.49	43.6
602_601	353.96	352.24	0.004	15	1.28	2.99	42.8
598_597	346.15	345.41	0.004	15	1.28	3	42.6
623_622	422.07	420.35	0.004	15	1.25	2.95	42.5
60_603	358.97	358.29	0.005	15	1.27	3.04	41.9
622_620	420.35	418.6	0.004	15	1.25	3	41.8
593_592	341.61	340.68	0.005	15	1.27	3.08	41.3
434_430	314.39	312.24	0.004	18	1.87	4.56	40.9
322A_322	330.89	328.57	0.009	12	0.94	2.32	40.5
583_579	317.99	315.28	0.009	18	2.84	7.1	40
632_631	491.58	490.27	0.005	15	1.25	3.16	39.7
210_214	320.35	319.81	0.004	18	1.78	4.62	38.6
635_632	493.21	491.58	0.005	15	1.25	3.28	38.2
597_596	345.41	344.76	0.006	15	1.28	3.37	37.9
611_610	402.71	400.43	0.005	15	1.25	3.32	37.6
CO-40	482.61	482.5	0.002	18	0.99	2.65	37.4
579_575	315.28	312.23	0.011	18	2.85	7.83	36.3
CO-39	483.33	482.61	0.002	18	0.97	2.67	36.3
605_604	360.7	359.86	0.006	15	1.27	3.54	35.8
151_324	345.94	344.12	0.008	12	0.78	2.17	35.7
324_150	344.12	341.92	0.008	12	0.78	2.18	35.7
CO-33	484.79	484.72	0.001	18	0.92	2.59	35.5
535_322A	333.91	330.89	0.011	12	0.94	2.66	35.3
595_594	343.84	342.83	0.007	15	1.28	3.69	34.6
388_394	307.44	306.45	0.004	24	3.2	9.59	33.4
CO-37	484.46	483.72	0.002	18	0.92	2.77	33.3
CO-13	300.87	299.98	0.002	30	3.95	12.5	31.6
CO-12	301.74	300.87	0.002	30	3.95	12.55	31.5
1044_434	315.75	314.39	0.006	18	1.84	5.86	31.4
CO-11	302.49	301.74	0.002	30	3.95	12.62	31.3
CO-14	299.98	299.28	0.002	30	3.96	12.8	30.9
234_151	347.36	345.94	0.005	10	0.32	1.06	30.7
588_586	325.39	322.79	0.016	18	2.83	9.25	30.6
CO-34	484.72	484.64	0.002	18	0.92	3.04	30.4
586_583	322.79	317.99	0.017	18	2.84	9.5	29.8
378a_378b	300.28	299.97	0.008	24	4.18	14.27	29.3
CO-15	299.28	298.88	0.003	30	3.96	13.69	28.9
323_535	338.06	333.91	0.016	12	0.91	3.17	28.7
413_414	304.57	302.85	0.005	24	3.27	11.39	28.7
601_59	352.24	350.3	0.01	15	1.28	4.46	28.7
CO-26	293.33	292.87	0.001	36	4.18	14.62	28.6
59_600	350.3	348.3	0.01	15	1.28	4.47	28.6
581_578	331.03	330.08	0.007	18	1.76	6.24	28.2

Existing Max Day Flows based on April 15, 2007 flow data							
Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
CO-30	288.4	287.86	0.002	42	8.3	30.53	27.2
394 413	306.45	304.57	0.006	24	3.27	12.03	27.2
214 205	319.81	317.66	0.008	18	1.81	6.73	26.9
CO-25	292.87	292.58	0.001	36	4.19	15.91	26.3
204 210	321.53	320.35	0.006	18	1.47	5.67	25.8
582 585	329.1	326.37	0.022	18	2.83	10.99	25.7
628 627	441.79	441.37	0.012	15	1.25	4.94	25.4
627 626	441.37	439.67	0.012	15	1.25	4.96	25.3
233 16	353.8	351.54	0.007	10	0.32	1.31	24.7
626 625	439.67	434.51	0.013	15	1.25	5.13	24.4
CO-17	289.52	288.4	0.004	30	3.96	16.47	24.1
430 429	312.24	310.56	0.012	18	1.89	7.91	23.9
224 211	325.35	324.21	0.006	18	1.35	5.72	23.7
CO-27	293.55	293.33	0.002	36	4.18	17.73	23.6
211 203	324.21	322.87	0.007	18	1.41	6.15	22.9
CO-8	306.55	305.74	0.002	30	2.88	12.66	22.7
203 204	322.87	321.53	0.007	18	1.41	6.28	22.4
CO-6	307.76	307.09	0.002	30	2.86	12.79	22.4
CO-7	307.09	306.55	0.002	30	2.87	12.93	22.2
631 630C	490.27	485.01	0.016	15	1.25	5.72	21.9
CO-5	308.2	307.76	0.003	30	2.86	13.49	21.2
150 323	341.92	338.06	0.022	12	0.78	3.68	21.1
389 388	309.05	307.44	0.009	24	3.13	15.04	20.8
429 393	310.56	309.96	0.004	24	1.95	9.48	20.6
603 602	358.29	353.96	0.019	15	1.28	6.22	20.5
617 614	414.51	406.33	0.019	15	1.25	6.31	19.8
CO-4	308.5	308.2	0.003	30	2.85	14.45	19.7
CO-36	484.57	484.46	0.005	18	0.92	4.7	19.6
322 224	328.57	325.35	0.012	15	0.97	5.05	19.1
608 607	387.69	378.23	0.023	15	1.26	6.85	18.4
16 234	351.54	347.36	0.014	10	0.32	1.83	17.7
619 617	417.38	414.51	0.025	15	1.25	7.18	17.4
414 401b	302.85	301.16	0.015	24	3.34	19.32	17.3
205 433	317.66	316.74	0.005	24	1.84	10.92	16.9
606 605	367.55	360.7	0.028	15	1.26	7.58	16.7
393 389	309.96	309.05	0.006	24	1.95	12.06	16.2
609 608	399.73	387.69	0.03	15	1.26	7.84	16
CO-22	289.71	289.16	0.002	42	4.31	27.84	15.5
433 1044	316.74	315.75	0.006	24	1.84	12.19	15.1
12 233	364.55	353.8	0.02	10	0.32	2.17	15
CO-20	288.85	288.4	0.002	42	4.38	29.61	14.8
CO-21	289.16	288.85	0.002	42	4.34	30.6	14.2
638 635	506.66	493.21	0.049	15	1.25	9.96	12.6
607 606	378.23	367.55	0.051	15	1.26	10.2	12.4
629 628	454.37	441.79	0.053	15	1.25	10.41	12
CO-23	290.68	289.71	0.003	42	4.29	36.08	11.9
625 624	434.51	423.07	0.064	15	1.25	11.4	11
630 629	477.33	454.37	0.091	15	1.25	13.62	9.2
630C 630	485.01	477.33	0.105	15	1.26	14.64	8.6
CO-24	292.58	290.68	0.014	36	4.19	50.22	8.3
577 581	335.33	331.03	0.045	18	1.27	15.53	8.2
CO-16	298.88	289.52	0.059	30	3.97	64.32	6.2
CO-32	287.86	287	0.047	42	8.36	140.65	5.9
CO-3	312.23	308.5	0.037	30	2.85	50.91	5.6
CO-28	299.94	293.55	0.056	36	4.21	101.61	4.1
371 524	299.97	299.91	0	24	0.1	2.39	4.1
CO-9	305.74	302.49	0.271	30	2.94	137.96	2.1
374 35	293.08	292.83	0.001	24	0.1	4.92	2.1
373 374	296.24	295.91	0.002	24	0.1	6.74	1.5
CO-31	292.52	290.68	0.006	24	0.12	11.04	1.1
35 479	292.83	292.52	0.001	30	0.11	10.48	1.1
524 524a	299.91	299.57	0.004	24	0.1	10.25	1
524a 373	298.32	297.38	0.006	24	0.1	12.4	0.8
CO-41	482.5	0	9.48	18	1.01	209.03	0.5

Existing Peak Flows based on Peak Hour Flows on April 15, 2007							
Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
587 584	337.28	336.43	0.002	15	1.83	2.08	87.9
584 580	338.43	335.59	0.002	15	1.84	2.1	87.3
614 613	406.33	405.44	0.002	15	1.8	2.15	83.5
590 589	338.87	338.06	0.002	15	1.83	2.26	81.2
589 587	338.06	337.28	0.003	15	1.83	2.35	77.7
591 590	339.99	338.87	0.003	15	1.84	2.4	77
594 593	342.83	341.61	0.003	15	1.86	2.51	74.3
CO-35	484.64	484.57	0.001	18	1.36	1.85	73.2
mh3 378a	300.41	300.28	0.002	24	4.99	7.05	70.8
401b_mh3	301.16	300.41	0.002	24	4.56	6.46	70.6
CO-38	483.72	483.33	0.001	18	1.38	1.97	70.4
620 619	418.6	417.38	0.003	15	1.8	2.56	70.4
599 598	346.72	346.15	0.003	15	1.87	2.66	70.2
613 612	405.44	404.13	0.003	15	1.8	2.57	69.8
604 60	359.86	358.97	0.003	15	1.84	2.65	69.5
624 623	423.07	422.07	0.003	15	1.8	2.62	68.7
580 577	335.59	335.33	0.001	18	1.84	2.7	68.4
521 599	346.89	346.72	0.004	15	1.87	2.82	66.3
612 611	404.13	402.71	0.004	15	1.8	2.71	66.2
578 582	330.08	329.1	0.007	18	3.94	5.96	66.2
596 595	344.76	343.84	0.004	15	1.87	2.84	65.9
600 521	348.3	346.89	0.004	15	1.87	2.84	65.7
592 591	340.68	339.99	0.004	15	1.85	2.88	64.4
598 597	346.15	345.41	0.004	15	1.87	3	62.3
602 601	353.96	352.24	0.004	15	1.86	2.99	62.1
623 622	422.07	420.35	0.004	15	1.8	2.95	61
585 588	326.37	325.39	0.008	18	3.95	6.49	60.8
60 603	358.97	358.29	0.005	15	1.85	3.04	60.7
593 592	341.61	340.68	0.005	15	1.86	3.08	60.3
622 620	420.35	418.6	0.004	15	1.8	3	60
322A 322	330.89	328.57	0.009	12	1.38	2.32	59.4
632 631	491.58	490.27	0.005	15	1.8	3.16	56.9
134 430	314.39	312.24	0.004	18	2.59	4.56	56.7
583 579	317.99	315.28	0.009	18	3.96	7.1	55.7
597 596	345.41	344.76	0.006	15	1.87	3.37	55.3
635 632	493.21	491.58	0.005	15	1.8	3.28	54.8
CO-40	482.61	482.5	0.002	18	1.45	2.65	54.7
611 610	402.71	400.43	0.005	15	1.8	3.32	54.3
210 214	320.35	319.81	0.004	18	2.48	4.62	53.7
CO-39	483.33	482.61	0.002	18	1.43	2.67	53.3
151 324	345.94	344.12	0.008	12	1.16	2.17	53.3
324 150	344.12	341.92	0.008	12	1.16	2.18	53
CO-33	484.79	484.72	0.001	18	1.36	2.59	52.3
605 604	360.7	359.86	0.006	15	1.83	3.54	51.8
535 322A	333.91	330.89	0.011	12	1.38	2.66	51.8
579 575	315.28	312.23	0.011	18	3.96	7.83	50.6
595 594	343.84	342.83	0.007	15	1.87	3.69	50.6
CO-37	484.46	483.72	0.002	18	1.36	2.77	49
388 394	307.44	306.45	0.004	24	4.38	9.59	45.7
CO-34	484.72	484.64	0.002	18	1.36	3.04	44.7
CO-13	300.87	299.98	0.002	30	5.47	12.5	43.8
CO-12	301.74	300.87	0.002	30	5.47	12.55	43.6
1044 434	315.75	314.39	0.006	18	2.55	5.86	43.5
CO-11	302.49	301.74	0.002	30	5.47	12.62	43.3
CO-14	299.98	299.28	0.002	30	5.48	12.8	42.8
588 586	325.39	322.79	0.016	18	3.95	9.25	42.7
323 535	338.06	333.91	0.016	12	1.35	3.17	42.5
601 59	352.24	350.3	0.01	15	1.86	4.46	41.7
59 600	350.3	348.3	0.01	15	1.86	4.47	41.7
586 583	322.79	317.99	0.017	18	3.95	9.5	41.6
CO-15	299.28	298.88	0.003	30	5.48	13.69	40
581 578	331.03	330.08	0.007	18	2.47	6.24	39.5
378a 378b	300.28	299.97	0.008	24	5.62	14.27	39.4
413 414	304.57	302.85	0.005	24	4.47	11.39	39.2
CO-26	293.33	292.87	0.001	36	5.62	14.62	38.5
234 151	347.36	345.94	0.005	10	0.4	1.06	37.5
214 205	319.81	317.66	0.008	18	2.52	6.73	37.4
394 413	306.45	304.57	0.006	24	4.47	12.03	37.2

Existing Peak Flows based on Peak Hour Flows on April 15, 2007

Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
CO-30	288.4	287.86	0.002	42	11.31	30.53	37
628 627	441.79	441.37	0.012	15	1.8	4.94	36.4
627 626	441.37	439.67	0.012	15	1.8	4.96	36.2
582 585	329.1	326.37	0.022	18	3.95	10.99	35.9
204 210	321.53	320.35	0.006	18	2.02	5.67	35.7
CO-25	292.87	292.58	0.001	36	5.64	15.91	35.4
626 625	439.67	434.51	0.013	15	1.8	5.13	35.1
CO-17	289.52	288.4	0.004	30	5.5	16.47	33.4
430 429	312.24	310.56	0.012	18	2.62	7.91	33.2
224 211	325.35	324.21	0.006	18	1.89	5.72	33
CO-8	306.55	305.74	0.002	30	4.02	12.66	31.7
CO-27	293.55	293.33	0.002	36	5.62	17.73	31.7
211 203	324.21	322.87	0.007	18	1.95	6.15	31.6
150 323	341.92	338.06	0.022	12	1.16	3.68	31.4
631 630C	490.27	485.01	0.016	15	1.8	5.72	31.4
CO-6	307.76	307.09	0.002	30	3.99	12.79	31.2
203 204	322.87	321.53	0.007	18	1.95	6.28	31
CO-7	307.09	306.55	0.002	30	4.01	12.93	31
233 16	353.8	351.54	0.007	10	0.4	1.31	30.2
603 602	358.29	353.96	0.019	15	1.85	6.22	29.7
CO-5	308.2	307.76	0.003	30	3.98	13.49	29.5
CO-36	484.57	484.46	0.005	18	1.36	4.7	28.9
389 388	309.05	307.44	0.009	24	4.29	15.04	28.5
429 393	310.56	309.96	0.004	24	2.7	9.48	28.5
617 614	414.51	406.33	0.019	15	1.8	6.31	28.5
322 224	328.57	325.35	0.012	15	1.41	5.05	27.8
CO-4	308.5	308.2	0.003	30	3.97	14.45	27.5
608 607	387.69	378.23	0.023	15	1.82	6.85	26.6
619 617	417.38	414.51	0.025	15	1.8	7.18	25
606 605	367.55	360.7	0.028	15	1.83	7.58	24.1
414 401b	302.85	301.16	0.015	24	4.56	19.32	23.6
205 433	317.66	316.74	0.005	24	2.55	10.92	23.4
609 608	399.73	387.69	0.03	15	1.82	7.84	23.2
393 389	309.96	309.05	0.006	24	2.7	12.06	22.4
16 234	351.54	347.36	0.014	10	0.4	1.83	21.7
CO-22	289.71	289.16	0.002	42	5.84	27.84	21
433 1044	316.74	315.75	0.006	24	2.55	12.19	20.9
CO-20	288.85	288.4	0.002	42	5.98	29.61	20.2
CO-21	289.16	288.85	0.002	42	5.91	30.6	19.3
12 233	364.55	353.8	0.02	10	0.4	2.17	18.3
638 635	506.66	493.21	0.049	15	1.8	9.96	18.1
607 606	378.23	367.55	0.051	15	1.83	10.2	17.9
629 628	454.37	441.79	0.053	15	1.8	10.41	17.3
CO-23	290.68	289.71	0.003	42	5.8	36.08	16.1
625 624	434.51	423.07	0.064	15	1.8	11.4	15.8
630 629	477.33	454.37	0.091	15	1.8	13.62	13.2
630C 630	485.01	477.33	0.105	15	1.8	14.64	12.3
577 581	335.33	331.03	0.045	18	1.85	15.53	11.9
CO-24	292.58	290.68	0.014	36	5.65	50.22	11.2
CO-16	298.88	289.52	0.059	30	5.5	64.32	8.5
CO-32	287.86	287	0.047	42	11.31	140.65	8
CO-3	312.23	308.5	0.037	30	3.97	50.91	7.8
371 524	299.97	299.91	0	24	0.14	2.39	6
CO-28	299.94	293.55	0.056	36	5.64	101.61	5.6
374 35	293.08	292.83	0.001	24	0.15	4.92	3
CO-9	305.74	302.49	0.271	30	4.08	137.96	3
373 374	296.24	295.91	0.002	24	0.15	6.74	2.2
35 479	292.83	292.52	0.001	30	0.16	10.48	1.5
CO-31	292.52	290.68	0.006	24	0.16	11.04	1.5
524 524a	299.91	299.57	0.004	24	0.14	10.25	1.4
524a 373	298.32	297.38	0.006	24	0.15	12.4	1.2
CO-41	482.5	0	9.48	18	1.47	209.03	0.7

Projected 5 Year Max Day Flow Based on Act 537 Planning							
Pipe Report Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
587_584	337.28	336.43	0.002	15	2.87	2.08	138.1
584_580	336.43	335.59	0.002	15	2.87	2.1	136.5
590_589	338.87	338.06	0.002	15	2.88	2.26	127.4
589_587	338.06	337.28	0.003	15	2.88	2.35	122.2
591_590	339.99	338.87	0.003	15	2.88	2.4	120.3
620_619	418.6	417.38	0.003	15	3.03	2.56	118.4
613_612	405.44	404.13	0.003	15	3.01	2.57	117.2
624_623	423.07	422.07	0.003	15	3.06	2.62	116.9
594_593	342.83	341.61	0.003	15	2.89	2.51	115.2
612_611	404.13	402.71	0.004	15	2.99	2.71	110.3
604_60	359.86	358.97	0.003	15	2.91	2.65	109.9
599_598	346.72	346.15	0.003	15	2.91	2.66	109.2
378b_PT001	299.97	299.94	0.002	24	6.76	6.31	107.1
580_577	335.59	335.33	0.001	18	2.87	2.7	106.5
623_622	422.07	420.35	0.004	15	3.06	2.95	103.7
521_599	346.89	346.72	0.004	15	2.9	2.82	103
600_621	348.3	346.89	0.004	15	2.9	2.84	102.2
CO-35	484.64	484.57	0.001	18	1.89	1.85	102.1
596_595	344.76	343.84	0.004	15	2.89	2.84	102
622_620	420.35	418.6	0.004	15	3.01	3	100.2
592_591	340.68	339.99	0.004	15	2.89	2.88	100.2
CO-38	483.72	483.33	0.001	18	1.93	1.97	98
632_631	491.58	490.27	0.005	15	3.06	3.16	96.9
602_601	353.96	352.24	0.004	15	2.89	2.99	96.8
598_597	346.15	345.41	0.004	15	2.9	3	96.7
60_603	358.97	358.29	0.005	15	2.9	3.04	95.3
593_592	341.61	340.68	0.005	15	2.89	3.08	93.7
635_632	493.21	491.58	0.005	15	3.06	3.28	93.3
611_610	402.71	400.43	0.005	15	2.95	3.32	88.9
578_582	330.08	329.1	0.007	18	5.29	5.96	88.8
322A_322	330.89	328.57	0.009	12	2.02	2.32	87.3
597_596	345.41	344.76	0.006	15	2.89	3.37	85.7
*151_324	345.94	344.12	0.008	12	1.86	2.17	85.7
324_150	344.12	341.92	0.008	12	1.86	2.18	85.2
mh3_378a	300.41	300.28	0.002	24	5.81	7.05	82.5
605_604	360.7	359.86	0.006	15	2.91	3.54	82.2
585_588	326.37	325.39	0.008	18	5.29	6.49	81.4
595_594	343.84	342.83	0.007	15	2.89	3.69	78.4
535_322A	333.91	330.89	0.011	12	2.02	2.66	76.1
CO-40	482.61	482.5	0.002	18	2.02	2.65	76
583_579	317.99	315.28	0.009	18	5.29	7.1	74.5
401b_mh3	301.16	300.41	0.002	24	4.8	6.46	74.3
CO-39	483.33	482.61	0.002	18	1.97	2.67	73.7
CO-33	484.79	484.72	0.001	18	1.89	2.59	73
434_430	314.39	312.24	0.004	18	3.21	4.56	70.3
CO-37	484.46	483.72	0.002	18	1.9	2.77	68.4
210_214	320.35	319.81	0.004	18	3.13	4.62	67.8
579_575	315.28	312.23	0.011	18	5.29	7.83	67.5
601_59	352.24	350.3	0.01	15	2.89	4.46	64.6
59_600	350.3	348.3	0.01	15	2.88	4.47	64.5
234_151	347.36	345.94	0.005	10	0.68	1.06	64
323_535	338.06	333.91	0.016	12	2	3.17	63
CO-34	484.72	484.64	0.002	18	1.89	3.04	62.3
628_627	441.79	441.37	0.012	15	3.06	4.94	62.1
627_626	441.37	439.67	0.012	15	3.06	4.96	61.7
626_625	439.67	434.51	0.013	15	3.06	5.13	59.7
588_586	325.39	322.79	0.016	18	5.29	9.25	57.2
581_578	331.03	330.08	0.007	18	3.52	6.24	56.4
586_583	322.79	317.99	0.017	18	5.29	9.5	55.7
1044_434	315.75	314.39	0.006	18	3.18	5.86	54.3
631_630C	490.27	485.01	0.016	15	3.06	5.72	53.6
CO-13	300.87	299.98	0.002	30	6.5	12.5	52
233_16	353.8	351.54	0.007	10	0.68	1.31	51.5
CO-12	301.74	300.87	0.002	30	6.43	12.55	51.2
CO-14	299.98	299.28	0.002	30	6.55	12.8	51.1
CO-11	302.49	301.74	0.002	30	6.39	12.62	50.6
150_323	341.92	338.06	0.022	12	1.86	3.68	50.5
388_394	307.44	306.45	0.004	24	4.67	9.59	48.7

Projected 5 Year Max Day Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
204 210	321.53	320.35	0.006	18	2.74	5.67	48.4
CO-15	299.28	298.88	0.003	30	6.62	13.69	48.3
582 585	329.1	326.37	0.022	18	5.29	10.99	48.1
617 614	414.51	406.33	0.019	15	3.03	6.31	47.9
378a 378b	300.28	299.97	0.008	24	6.76	14.27	47.4
214 205	319.81	317.66	0.008	18	3.16	6.73	46.9
603 602	358.29	353.96	0.019	15	2.89	6.22	46.5
CO-26	293.33	292.87	0.001	36	6.78	14.62	46.4
224 211	325.35	324.21	0.006	18	2.63	5.72	46
CO-30	288.4	287.86	0.002	42	13.74	30.53	45
211 203	324.21	322.87	0.007	18	2.69	6.15	43.7
203 204	322.87	321.53	0.007	18	2.69	6.28	42.8
CO-25	292.87	292.58	0.001	36	6.8	15.91	42.8
608 607	387.69	378.23	0.023	15	2.92	6.85	42.6
619 617	417.38	414.51	0.025	15	3.03	7.18	42.1
CO-8	306.55	305.74	0.002	30	5.29	12.66	41.8
413 414	304.57	302.85	0.005	24	4.73	11.39	41.6
CO-6	307.76	307.09	0.002	30	5.29	12.79	41.4
CO-7	307.09	306.55	0.002	30	5.29	12.93	40.9
430 429	312.24	310.56	0.012	18	3.23	7.91	40.9
322 224	328.57	325.35	0.012	15	2.05	5.05	40.6
CO-17	289.52	288.4	0.004	30	6.68	16.47	40.5
CO-36	484.57	484.46	0.005	18	1.89	4.7	40.3
394 413	306.45	304.57	0.006	24	4.73	12.03	39.3
CO-5	308.2	307.76	0.003	30	5.29	13.49	39.2
606 605	367.55	360.7	0.028	15	2.91	7.58	38.4
CO-27	293.55	293.33	0.002	36	6.76	17.73	38.1
609 608	399.73	387.69	0.03	15	2.93	7.84	37.3
16 234	351.54	347.36	0.014	10	0.68	1.83	37
CO-4	308.5	308.2	0.003	30	5.29	14.45	36.6
429 393	310.56	309.96	0.004	24	3.29	9.48	34.7
12 233	364.55	353.8	0.02	10	0.68	2.17	31.2
638 635	506.66	493.21	0.049	15	3.06	9.96	30.8
389 388	309.05	307.44	0.009	24	4.6	15.04	30.5
629 628	454.37	441.79	0.053	15	3.06	10.41	29.4
205 433	317.66	316.74	0.005	24	3.18	10.92	29.2
607 606	378.23	367.55	0.051	15	2.91	10.2	28.6
393 389	309.96	309.05	0.006	24	3.29	12.06	27.3
625 624	434.51	423.07	0.064	15	3.06	11.4	26.9
433 1044	316.74	315.75	0.006	24	3.18	12.19	26.1
CO-22	289.71	289.16	0.002	42	7.1	27.84	25.5
414 401b	302.85	301.16	0.015	24	4.8	19.32	24.9
CO-20	288.85	288.4	0.002	42	7.2	29.61	24.3
CO-21	289.16	288.85	0.002	42	7.2	30.6	23.5
630 629	477.33	454.37	0.091	15	3.07	13.62	22.5
630C 630	485.01	477.33	0.105	15	3.07	14.64	20.9
CO-23	290.68	289.71	0.003	42	7.05	36.08	19.6
577 581	335.33	331.03	0.045	18	2.87	15.53	18.5
CO-24	292.58	290.68	0.014	36	6.82	50.22	13.6
CO-3	312.23	308.5	0.037	30	5.29	50.91	10.4
CO-16	298.88	289.52	0.059	30	6.66	64.32	10.4
CO-32	287.86	287	0.047	42	13.74	140.65	9.8
371 524	299.97	299.91	0	24	0.22	2.39	9.2
CO-28	299.94	293.55	0.056	36	6.78	101.61	6.7
374 35	293.08	292.83	0.001	24	0.23	4.92	4.6
CO-9	305.74	302.49	0.271	30	5.35	137.96	3.9
373 374	296.24	295.91	0.002	24	0.22	6.74	3.3
CO-31	292.52	290.68	0.006	24	0.25	11.04	2.3
35 479	292.83	292.52	0.001	30	0.23	10.48	2.2
524 524a	299.91	299.57	0.004	24	0.22	10.25	2.1
524a 373	298.32	297.38	0.006	24	0.22	12.4	1.8
CO-41	482.5	0	9.48	18	2.05	209.03	1

Projected 5 Year Peak Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
610_609	400.43	399.73	0.002	15	2.99	2	149.2
624_623	423.07	422.07	0.003	15	3.88	2.62	148.1
620_619	418.6	417.38	0.003	15	3.74	2.56	146.4
CO-35	484.64	484.57	0.001	18	2.53	1.85	136.4
CO-38	483.72	483.33	0.001	18	2.65	1.97	134.8
604_60	359.86	358.97	0.003	15	3.53	2.65	133.2
587_584	337.28	336.43	0.002	15	2.74	2.08	131.9
584_580	336.43	335.59	0.002	15	2.73	2.1	129.7
623_622	422.07	420.35	0.004	15	3.82	2.95	129.3
632_631	491.58	490.27	0.005	15	4.02	3.16	127
622_620	420.35	418.6	0.004	15	3.77	3	125.5
590_589	338.87	338.06	0.002	15	2.8	2.26	124
151_324	345.94	344.12	0.008	12	2.67	2.17	122.7
613_612	405.44	404.13	0.003	15	3.15	2.57	122.6
635_632	493.21	491.58	0.005	15	4.02	3.28	122.3
mh3_378a	300.41	300.28	0.002	24	8.58	7.05	121.7
599_598	346.72	346.15	0.003	15	3.21	2.66	120.6
324_150	344.12	341.92	0.008	12	2.63	2.18	120.3
602_601	353.96	352.24	0.004	15	3.58	2.99	119.9
594_593	342.83	341.61	0.003	15	2.98	2.51	118.7
591_590	339.99	338.87	0.003	15	2.84	2.4	118.6
60_603	358.97	358.29	0.005	15	3.61	3.04	118.6
589_587	338.06	337.28	0.003	15	2.77	2.35	117.7
600_521	348.3	346.89	0.004	15	3.29	2.84	116.1
521_599	346.89	346.72	0.004	15	3.26	2.82	115.6
612_611	404.13	402.71	0.004	15	3.1	2.71	114.1
322A_322	330.89	328.57	0.009	12	2.58	2.32	111.4
401b_mh3	301.16	300.41	0.002	24	7.11	6.46	110
596_595	344.76	343.84	0.004	15	3.07	2.84	108.2
434_430	314.39	312.24	0.004	18	4.85	4.56	106.3
598_597	346.15	345.41	0.004	15	3.16	3	105.5
578_582	330.08	329.1	0.007	18	6.12	5.96	102.7
580_577	335.59	335.33	0.001	18	2.75	2.7	102
592_591	340.68	339.99	0.004	15	2.88	2.88	100.1
CO-40	482.61	482.5	0.002	18	2.65	2.65	99.9
CO-39	483.33	482.61	0.002	18	2.65	2.67	99.1
605_604	360.7	359.86	0.006	15	3.47	3.54	98.2
585_588	326.37	325.39	0.008	18	6.35	6.49	97.8
210_214	320.35	319.81	0.004	18	4.51	4.62	97.7
535_322A	333.91	330.89	0.011	12	2.59	2.66	97.4
CO-33	484.79	484.72	0.001	18	2.47	2.59	95.1
593_592	341.61	340.68	0.005	15	2.93	3.08	95.1
CO-37	484.46	483.72	0.002	18	2.64	2.77	95
583_579	317.99	315.28	0.009	18	6.59	7.1	92.8
597_596	345.41	344.76	0.006	15	3.11	3.37	92.3
611_610	402.71	400.43	0.005	15	3	3.32	90.4
579_575	315.28	312.23	0.011	18	6.67	7.83	85.2
323_535	338.06	333.91	0.016	12	2.68	3.17	84.4
CO-34	484.72	484.64	0.002	18	2.49	3.04	82
595_594	343.84	342.83	0.007	15	3.02	3.69	81.9
1044_434	315.75	314.39	0.006	18	4.78	5.86	81.6
628_627	441.79	441.37	0.012	15	3.94	4.94	79.9
601_59	352.24	350.3	0.01	15	3.55	4.46	79.5
627_626	441.37	439.67	0.012	15	3.94	4.96	79.3
626_625	439.67	434.51	0.013	15	3.92	5.13	76.4
59_600	350.3	348.3	0.01	15	3.33	4.47	74.5
CO-13	300.87	299.98	0.002	30	9.2	12.5	73.5
CO-12	301.74	300.87	0.002	30	9.18	12.55	73.1
CO-11	302.49	301.74	0.002	30	9.21	12.62	73
CO-14	299.98	299.28	0.002	30	9.26	12.8	72.3
CO-26	293.33	292.87	0.001	36	10.46	14.62	71.6
388_394	307.44	306.45	0.004	24	6.83	9.59	71.2
150_323	341.92	338.06	0.022	12	2.61	3.68	70.8
631_630C	490.27	485.01	0.016	15	4.02	5.72	70.2
588_586	325.39	322.79	0.016	18	6.42	9.25	69.4
CO-25	292.87	292.58	0.001	36	10.93	15.91	68.7
378a_378b	300.28	299.97	0.008	24	9.76	14.27	68.4

Projected 5 Year Peak Flow Based on Act 537 Planning

Pipe Report							
Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
214 205	319.81	317.66	0.008	18	4.6	6.73	68.3
586 583	322.79	317.99	0.017	18	6.49	9.5	68.3
CO-15	299.28	298.88	0.003	30	9.34	13.69	68.2
204 210	321.53	320.35	0.006	18	3.84	5.67	67.8
CO-30	288.4	287.86	0.002	42	19.75	30.53	64.7
430 429	312.24	310.56	0.012	18	4.87	7.91	61.6
413 414	304.57	302.85	0.005	24	6.97	11.39	61.2
224 211	325.35	324.21	0.006	18	3.43	5.72	60.1
CO-8	306.55	305.74	0.002	30	7.49	12.66	59.2
581 578	331.03	330.08	0.007	18	3.68	6.24	59
603 602	358.29	353.96	0.019	15	3.64	6.22	58.5
CO-17	289.52	288.4	0.004	30	9.52	16.47	57.8
394 413	306.45	304.57	0.006	24	6.95	12.03	57.8
617 614	414.51	406.33	0.019	15	3.65	6.31	57.8
203 204	322.87	321.53	0.007	18	3.59	6.28	57.2
233 16	353.8	351.54	0.007	10	0.75	1.31	56.9
211 203	324.21	322.87	0.007	18	3.5	6.15	56.9
582 585	329.1	326.37	0.022	18	6.2	10.99	56.4
CO-27	293.55	293.33	0.002	36	9.92	17.73	55.9
CO-7	307.09	306.55	0.002	30	7.19	12.93	55.6
CO-36	484.57	484.46	0.005	18	2.57	4.7	54.7
CO-6	307.76	307.09	0.002	30	6.95	12.79	54.3
429 393	310.56	309.96	0.004	24	4.94	9.48	52.2
619 617	417.38	414.51	0.025	15	3.72	7.18	51.8
322 224	328.57	325.35	0.012	15	2.6	5.05	51.5
CO-5	308.2	307.76	0.003	30	6.83	13.49	50.6
CO-4	308.5	308.2	0.003	30	6.79	14.45	47
389 388	309.05	307.44	0.009	24	6.71	15.04	44.6
608 607	387.69	378.23	0.023	15	2.97	6.85	43.3
205 433	317.66	316.74	0.005	24	4.7	10.92	43.1
234 151	347.36	345.94	0.005	10	0.44	1.06	41.9
606 605	367.55	360.7	0.028	15	3.17	7.58	41.8
393 389	309.96	309.05	0.006	24	4.95	12.06	41
16 234	351.54	347.36	0.014	10	0.75	1.83	40.8
638 635	506.66	493.21	0.049	15	4.02	9.96	40.3
CO-22	289.71	289.16	0.002	42	11.23	27.84	40.3
433 1044	316.74	315.75	0.006	24	4.73	12.19	38.8
629 628	454.37	441.79	0.053	15	3.96	10.41	38.1
609 608	399.73	387.69	0.03	15	2.98	7.84	38
CO-20	288.85	288.4	0.002	42	11.23	29.61	37.9
CO-21	289.16	288.85	0.002	42	11.23	30.6	36.7
414 401b	302.85	301.16	0.015	24	7.07	19.32	36.6
12 233	364.55	353.8	0.02	10	0.75	2.17	34.5
625 624	434.51	423.07	0.064	15	3.91	11.4	34.3
CO-23	290.68	289.71	0.003	42	11.23	36.08	31.1
607 606	378.23	367.55	0.051	15	3.06	10.2	30
630 629	477.33	454.37	0.091	15	4	13.62	29.4
630C 630	485.01	477.33	0.105	15	4.01	14.64	27.4
CO-24	292.58	290.68	0.014	36	10.93	50.22	21.8
577 581	335.33	331.03	0.045	18	2.78	15.53	17.9
CO-16	298.88	289.52	0.059	30	9.58	64.32	14.9
CO-32	287.86	287	0.047	42	19.75	140.65	14
371 524	299.97	299.91	0	24	0.33	2.39	13.6
CO-3	312.23	308.5	0.037	30	6.77	50.91	13.3
CO-28	299.94	293.55	0.056	36	9.84	101.61	9.7
374 35	293.08	292.83	0.001	24	0.38	4.92	7.7
373 374	296.24	295.91	0.002	24	0.39	6.74	5.7
CO-9	305.74	302.49	0.271	30	7.86	137.96	5.7
524 524a	299.91	299.57	0.004	24	0.35	10.25	3.4
35 479	292.83	292.52	0.001	30	0.35	10.48	3.3
524a 373	298.32	297.38	0.006	24	0.36	12.4	2.9
CO-31	292.52	290.68	0.006	24	0.3	11.04	2.7
CO-41	482.5	0	9.48	18	2.65	209.03	1.3

Projected 10 Year Max Day Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
624 623	423.07	422.07	0.003	15	3.69	2.62	141
620 619	418.6	417.38	0.003	15	3.59	2.56	140.4
CO-35	484.64	484.57	0.001	18	2.57	1.85	138.8
CO-38	483.72	483.33	0.001	18	2.7	1.97	137.1
587 584	337.28	336.43	0.002	15	2.75	2.08	132
584 580	336.43	335.59	0.002	15	2.74	2.1	130
604 60	359.86	358.97	0.003	15	3.4	2.65	128.3
590 589	338.87	338.06	0.002	15	2.8	2.26	123.8
623 622	422.07	420.35	0.004	15	3.65	2.95	123.5
613 612	405.44	404.13	0.003	15	3.13	2.57	121.6
632 631	491.58	490.27	0.005	15	3.82	3.16	120.7
622 620	420.35	418.6	0.004	15	3.61	3	120.2
599 598	346.72	346.15	0.003	15	3.16	2.66	118.8
591 590	339.99	338.87	0.003	15	2.83	2.4	118.3
594 593	342.83	341.61	0.003	15	2.96	2.51	117.9
589 587	338.06	337.28	0.003	15	2.77	2.35	117.6
602 601	353.96	352.24	0.004	15	3.48	2.99	116.3
635 632	493.21	491.58	0.005	15	3.82	3.28	116.3
60 603	358.97	358.29	0.005	15	3.52	3.04	115.7
600 521	348.3	346.89	0.004	15	3.24	2.84	114.4
521 599	346.89	346.72	0.004	15	3.21	2.82	113.9
612 611	404.13	402.71	0.004	15	3.06	2.71	112.9
596 595	344.76	343.84	0.004	15	3.03	2.84	107
598 597	346.15	345.41	0.004	15	3.11	3	103.9
580 577	335.59	335.33	0.001	18	2.75	2.7	102.1
CO-40	482.61	482.5	0.002	18	2.7	2.65	101.6
CO-39	483.33	482.61	0.002	18	2.7	2.67	100.8
592 591	340.68	339.99	0.004	15	2.87	2.88	99.7
CO-33	484.79	484.72	0.001	18	2.51	2.59	96.9
578 582	330.08	329.1	0.007	18	5.74	5.96	96.4
CO-37	484.46	483.72	0.002	18	2.67	2.77	96.3
mh3 378a	300.41	300.28	0.002	24	6.77	7.05	96.1
605 604	360.7	359.86	0.006	15	3.36	3.54	95.1
593 592	341.61	340.68	0.005	15	2.91	3.08	94.6
151 324	345.94	344.12	0.008	12	2.01	2.17	92.5
322A 322	330.89	328.57	0.009	12	2.14	2.32	92.4
585 588	326.37	325.39	0.008	18	5.98	6.49	92
324 150	344.12	341.92	0.008	12	2	2.18	91.8
597 596	345.41	344.76	0.006	15	3.07	3.37	91.1
611 610	402.71	400.43	0.005	15	2.98	3.32	89.9
583 579	317.99	315.28	0.009	18	6.26	7.1	88.2
CO-34	484.72	484.64	0.002	18	2.53	3.04	83.4
595 594	343.84	342.83	0.007	15	2.99	3.69	81.2
579 575	315.28	312.23	0.011	18	6.31	7.83	80.6
535 322A	333.91	330.89	0.011	12	2.14	2.66	80.6
401b mh3	301.16	300.41	0.002	24	5.01	6.46	77.5
601 59	352.24	350.3	0.01	15	3.45	4.46	77.4
628 627	441.79	441.37	0.012	15	3.68	4.94	74.6
627 626	441.37	439.67	0.012	15	3.69	4.96	74.3
434 430	314.39	312.24	0.004	18	3.36	4.56	74.2
59 600	350.3	348.3	0.01	15	3.29	4.47	73.6
626 625	439.67	434.51	0.013	15	3.7	5.13	72.1
210 214	320.35	319.81	0.004	18	3.31	4.62	71.7
323 535	338.06	333.91	0.016	12	2.12	3.17	67
631 630C	490.27	485.01	0.016	15	3.8	5.72	66.4
588 586	325.39	322.79	0.016	18	6.04	9.25	65.3
CO-12	301.74	300.87	0.002	30	8.17	12.55	65.1
CO-13	300.87	299.98	0.002	30	8.14	12.5	65.1
CO-11	302.49	301.74	0.002	30	8.2	12.62	65
586 583	322.79	317.99	0.017	18	6.12	9.5	64.4
CO-14	299.98	299.28	0.002	30	8.24	12.8	64.3
234 151	347.36	345.94	0.005	10	0.67	1.06	63.5
CO-15	299.28	298.68	0.003	30	8.28	13.69	60.5
1044 434	315.75	314.39	0.006	18	3.36	5.88	57.3
603 602	358.29	353.96	0.019	15	3.52	6.22	56.6
581 578	331.03	330.08	0.007	18	3.53	6.24	56.6
378a 378b	300.28	299.97	0.008	24	8.06	14.27	56.5
CO-26	293.33	292.87	0.001	36	8.2	14.62	56.1
CO-36	484.57	484.46	0.005	18	2.61	4.7	55.6
617 614	414.51	408.33	0.019	15	3.5	6.31	55.3
CO-8	306.55	305.74	0.002	30	6.91	12.66	54.6
150 323	341.92	338.06	0.022	12	1.99	3.68	54.1
582 585	329.1	326.37	0.022	18	5.83	10.99	53
CO-30	288.4	287.86	0.002	42	16.01	30.53	52.5
CO-25	292.87	292.58	0.001	36	8.2	15.91	51.5

Projected 10 Year Max Day Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
Label							
233_16	353.8	351.54	0.007	10	0.68	1.31	51.4
CO-17	289.52	288.4	0.004	30	8.46	16.47	51.3
CO-7	307.09	306.55	0.002	30	6.63	12.93	51.3
204_210	321.53	320.35	0.006	18	2.9	5.67	51.1
388_394	307.44	306.45	0.004	24	4.86	9.59	50.6
CO-6	307.76	307.09	0.002	30	6.43	12.79	50.3
619_617	417.38	414.51	0.025	15	3.57	7.18	49.7
214_205	319.81	317.66	0.008	18	3.33	6.73	49.5
224_211	325.35	324.21	0.006	18	2.77	5.72	48.5
CO-5	308.2	307.76	0.003	30	6.34	13.49	47
211_203	324.21	322.87	0.007	18	2.83	6.15	46.1
CO-27	293.55	293.33	0.002	36	8.15	17.73	46
203_204	322.87	321.53	0.007	18	2.84	6.28	45.2
CO-4	308.5	308.2	0.003	30	6.33	14.45	43.8
608_607	387.69	378.23	0.023	15	2.07	6.85	43.3
413_414	304.57	302.85	0.005	24	4.93	11.39	43.3
322_224	328.57	325.35	0.012	15	2.18	5.05	43.1
430_429	312.24	310.56	0.012	18	3.4	7.91	43
606_605	367.55	360.7	0.028	15	3.11	7.58	41
394_413	306.45	304.57	0.006	24	4.93	12.03	41
638_635	506.66	493.21	0.049	15	3.82	9.96	38.4
609_608	399.73	387.69	0.03	15	2.98	7.84	38
16_234	351.54	347.36	0.014	10	0.67	1.83	36.9
429_393	310.56	309.96	0.004	24	3.46	9.48	36.5
629_628	454.37	441.79	0.053	15	3.69	10.41	35.5
625_624	434.51	423.07	0.064	15	3.71	11.4	32.5
389_388	309.05	307.44	0.009	24	4.78	15.04	31.8
12_233	364.55	353.8	0.02	10	0.68	2.17	31.2
205_433	317.66	316.74	0.005	24	3.38	10.92	30.8
CO-22	289.71	289.16	0.002	42	8.43	27.84	30.3
607_606	378.23	367.55	0.051	15	3.03	10.2	29.7
393_389	309.96	309.05	0.008	24	3.46	12.06	28.7
CO-20	288.85	288.4	0.002	42	8.43	29.61	28.5
433_1044	316.74	315.75	0.006	24	3.36	12.19	27.6
CO-21	289.16	288.85	0.002	42	8.43	30.6	27.5
630_629	477.33	454.37	0.091	15	3.74	13.62	27.4
414_401b	302.85	301.16	0.015	24	4.99	19.32	25.8
630C_630	485.01	477.33	0.105	15	3.77	14.64	25.7
CO-23	290.68	289.71	0.003	42	8.43	36.08	23.4
577_581	335.33	331.03	0.045	18	2.79	15.53	17.9
CO-24	292.58	290.68	0.014	36	8.2	50.22	16.3
CO-16	298.88	289.52	0.059	30	8.5	64.32	13.2
CO-3	312.23	308.5	0.037	30	6.33	50.91	12.4
CO-32	287.86	287	0.047	42	16.01	140.65	11.4
371_524	299.97	299.91	0	24	0.26	2.39	10.7
CO-28	299.94	293.55	0.056	36	8.1	101.61	8
374_35	293.08	292.83	0.001	24	0.34	4.92	6.9
CO-9	305.74	302.49	0.271	30	7.23	137.96	5.2
373_374	296.24	295.91	0.002	24	0.34	6.74	5
524_524a	299.91	299.57	0.004	24	0.28	10.25	2.8
35_479	292.83	292.52	0.001	30	0.28	10.48	2.7
CO-31	292.52	290.68	0.006	24	0.27	11.04	2.4
524a_373	298.32	297.38	0.006	24	0.29	12.4	2.4
CO-41	482.5	0	9.48	18	2.7	209.03	1.3

Projected 10 Year Peak Flow Based on Act 537 Planning							
Pipe Report Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
CO-35	484.64	484.57	0.001	18	3.22	1.85	173.7
614 613	406.33	405.44	0.002	15	3.57	2.15	166.1
CO-38	483.72	483.33	0.001	18	3.16	1.97	160.9
610 609	400.43	399.73	0.002	15	3.04	2	151.5
632 631	491.58	490.27	0.005	15	4.73	3.16	149.6
635 632	493.21	491.58	0.005	15	4.88	3.28	148.6
604 60	359.86	358.97	0.003	15	3.93	2.65	148.5
mh3 378a	300.41	300.28	0.002	24	10.16	7.05	144.3
620 619	418.6	417.38	0.003	15	3.66	2.56	143.4
587 584	337.28	336.43	0.002	15	2.98	2.08	143.1
623 622	422.07	420.35	0.004	15	4.22	2.95	142.9
584 580	336.43	335.59	0.002	15	2.95	2.1	140.4
322A 322	330.89	328.57	0.009	12	3.22	2.32	139
CO-40	482.61	482.5	0.002	18	3.68	2.65	138.6
151 324	345.94	344.12	0.008	12	2.99	2.17	137.6
324 150	344.12	341.92	0.008	12	2.99	2.18	136.9
590 589	338.87	338.06	0.002	15	3.03	2.26	134
613 612	405.44	404.13	0.003	15	3.32	2.57	129.3
622 620	420.35	418.6	0.004	15	3.87	3	129.1
591 590	339.99	338.87	0.003	15	3.07	2.4	128.2
589 587	338.06	337.28	0.003	15	3	2.35	127.3
580 577	335.59	335.33	0.001	18	3.43	2.7	127.1
599 598	346.72	346.15	0.003	15	3.36	2.66	126.2
60 603	358.97	358.29	0.005	15	3.84	3.04	126.2
594 593	342.83	341.61	0.003	15	3.16	2.51	126.1
600 521	348.3	346.89	0.004	15	3.55	2.84	125
CO-33	484.79	484.72	0.001	18	3.24	2.59	125
578 582	330.08	329.1	0.007	18	7.44	5.96	125
521 599	346.89	346.72	0.004	15	3.44	2.82	122.2
535 322A	333.91	330.89	0.011	12	3.22	2.66	121.2
602 601	353.96	352.24	0.004	15	3.61	2.99	120.9
CO-39	483.33	482.61	0.002	18	3.22	2.67	120.6
605 604	360.7	359.86	0.006	15	4.1	3.54	116
612 611	404.13	402.71	0.004	15	3.13	2.71	115.3
CO-37	484.46	483.72	0.002	18	3.19	2.77	114.8
596 595	344.78	343.84	0.004	15	3.19	2.84	112.6
210 214	320.35	319.81	0.004	18	5.16	4.62	111.8
401b mh3	301.16	300.41	0.002	24	7.09	6.46	109.7
583 579	317.99	315.28	0.009	18	7.77	7.1	109.5
598 597	346.15	345.41	0.004	15	3.28	3	109.3
434 430	314.39	312.24	0.004	18	4.94	4.56	108.3
585 588	326.37	325.39	0.008	18	7.03	6.49	108.2
592 591	340.68	339.99	0.004	15	3.1	2.88	107.5
CO-34	484.72	484.64	0.002	18	3.23	3.04	106.3
593 592	341.61	340.68	0.005	15	3.12	3.08	101.4
628 627	441.79	441.37	0.012	15	4.98	4.94	100.9
323 535	338.06	333.91	0.016	12	3.19	3.17	100.7
627 626	441.37	439.67	0.012	15	4.98	4.96	100.3
579 575	315.28	312.23	0.011	18	7.73	7.83	98.8
626 625	439.67	434.51	0.013	15	4.94	5.13	96.2
597 596	345.41	344.76	0.006	15	3.22	3.37	95.6
611 610	402.71	400.43	0.005	15	3.04	3.32	91.6
1044 434	315.75	314.39	0.006	18	5.18	5.86	88.3
595 594	343.84	342.83	0.007	15	3.17	3.69	86
CO-14	299.98	299.28	0.002	30	10.57	12.8	82.6
CO-11	302.49	301.74	0.002	30	10.39	12.82	82.4
CO-13	300.87	299.98	0.002	30	10.26	12.5	82.1
378a 378b	300.28	299.97	0.008	24	11.69	14.27	81.9
CO-12	301.74	300.87	0.002	30	10.26	12.55	81.8
150 323	341.92	338.06	0.022	12	2.99	3.68	81.2
601 59	352.24	350.3	0.01	15	3.6	4.46	80.7
204 210	321.53	320.35	0.006	18	4.57	5.67	80.6
59 600	350.3	348.3	0.01	15	3.58	4.47	80.1
CO-15	299.28	298.88	0.003	30	10.96	13.69	80
CO-26	293.33	292.87	0.001	36	11.69	14.62	80
586 583	322.79	317.99	0.017	18	7.5	9.5	78.9
581 578	331.03	330.08	0.007	18	4.92	6.24	78.8
214 205	319.81	317.66	0.008	18	5.23	6.73	77.6
631 630C	490.27	485.01	0.016	15	4.41	5.72	77
588 586	325.39	322.79	0.016	18	7.05	9.25	76.2
388 394	307.44	306.45	0.004	24	7.28	9.59	75.9
CO-25	292.87	292.58	0.001	36	11.69	15.91	73.5
211 203	324.21	322.87	0.007	18	4.42	6.15	71.8
224 211	325.35	324.21	0.006	18	4.1	5.72	71.7
CO-30	288.4	287.86	0.002	42	21.82	30.53	71.5
203 204	322.87	321.53	0.007	18	4.47	6.28	71.3

Projected 10 Year Peak Flow Based on Act 537 Planning							
Pipe Report Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (In)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
608 607	387.69	378.23	0.023	15	4.83	6.85	70.5
CO-8	306.55	305.74	0.002	30	8.89	12.66	70.2
CO-7	307.09	306.55	0.002	30	9.01	12.93	69.7
CO-6	307.76	307.09	0.002	30	8.84	12.79	69.1
CO-36	484.57	484.46	0.005	18	3.2	4.7	68.2
430 429	312.24	310.56	0.012	18	5.3	7.91	67.1
582 585	329.1	326.37	0.022	18	7.36	10.99	66.9
CO-27	293.55	293.33	0.002	36	11.69	17.73	65.9
606 605	367.55	360.7	0.028	15	4.93	7.58	65
413 414	304.57	302.85	0.005	24	7.39	11.39	64.9
617 614	414.51	406.33	0.019	15	4.09	6.31	64.7
322 224	328.57	325.35	0.012	15	3.25	5.05	64.4
CO-17	289.52	288.4	0.004	30	10.38	16.47	63
CO-5	308.2	307.76	0.003	30	8.4	13.49	62.3
394 413	306.45	304.57	0.006	24	7.36	12.03	61.3
603 602	358.29	353.96	0.019	15	3.64	6.22	58.5
429 393	310.56	309.96	0.004	24	5.48	9.48	57.8
233 16	353.8	351.54	0.007	10	0.74	1.31	56.2
CO-4	308.5	308.2	0.003	30	8.05	14.45	55.7
638 635	506.66	493.21	0.049	15	5.01	9.96	50.2
205 433	317.66	316.74	0.005	24	5.33	10.92	48.8
619 617	417.38	414.51	0.025	15	3.5	7.18	48.7
607 606	378.23	367.55	0.051	15	4.94	10.2	48.5
389 388	309.05	307.44	0.009	24	7.26	15.04	48.3
629 628	454.37	441.79	0.053	15	4.95	10.41	47.6
393 389	309.96	309.05	0.006	24	5.52	12.06	45.8
625 624	434.51	423.07	0.064	15	4.93	11.4	43.3
433 1044	316.74	315.75	0.006	24	5.27	12.19	43.2
CO-22	289.71	289.16	0.002	42	11.99	27.84	43.1
609 608	399.73	387.69	0.03	15	3.29	7.84	41.9
16 234	351.54	347.36	0.014	10	0.74	1.83	40.6
CO-20	288.85	288.4	0.002	42	11.99	29.61	40.5
CO-21	289.16	288.85	0.002	42	11.99	30.6	39.2
414 401b	302.85	301.18	0.015	24	7.38	19.32	38.2
630 629	477.33	454.37	0.091	15	4.73	13.62	34.7
12 233	364.55	353.8	0.02	10	0.75	2.17	34.4
234 151	347.36	345.94	0.005	10	0.36	1.06	34.1
CO-23	290.68	289.71	0.003	42	11.99	36.08	33.2
630C 630	485.01	477.33	0.105	15	4.54	14.64	31
577 581	335.33	331.03	0.045	18	3.88	15.53	25
CO-24	292.58	290.68	0.014	36	11.69	50.22	23.3
CO-16	298.88	289.52	0.059	30	11.35	64.32	17.6
CO-32	287.86	287	0.047	42	21.82	140.65	15.5
CO-3	312.23	308.5	0.037	30	7.85	50.91	15.4
371 524	299.97	299.91	0	24	0.32	2.39	13.6
CO-28	299.94	293.55	0.056	36	11.69	101.61	11.5
CO-9	305.74	302.49	0.271	30	9.49	137.96	6.9
374 35	293.08	292.83	0.001	24	0.3	4.92	6.1
373 374	296.24	295.91	0.002	24	0.32	6.74	4.7
524 524a	299.91	299.57	0.004	24	0.43	10.25	4.2
524a 373	298.32	297.38	0.006	24	0.43	12.4	3.5
CO-31	292.52	290.68	0.006	24	0.35	11.04	3.2
35 479	292.83	292.52	0.001	30	0.33	10.48	3.1
CO-41	482.5	0	9.48	18	3.75	209.03	1.8

Projected Ultimate Max Day Flow Based on Act 537 Planning							
Pipe Report Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
587 584	337.28	336.43	0.002	15	4.28	2.08	205.5
584 580	336.43	335.59	0.002	15	4.27	2.1	203.2
590 589	338.87	338.06	0.002	15	4.29	2.26	189.8
589 587	338.06	337.28	0.003	15	4.28	2.35	181.9
620 619	418.6	417.38	0.003	15	4.64	2.56	181.5
624 623	423.07	422.07	0.003	15	4.75	2.62	181.1
CO-35	484.64	484.57	0.001	18	3.36	1.85	181.1
591 590	339.99	338.87	0.003	15	4.3	2.4	179.5
604 60	359.86	358.97	0.003	15	4.59	2.65	173.5
594 593	342.83	341.61	0.003	15	4.34	2.51	173.1
613 612	405.44	404.13	0.003	15	4.4	2.57	171.1
CO-38	483.72	483.33	0.001	18	3.35	1.97	170.5
599 598	346.72	346.15	0.003	15	4.4	2.66	165.5
612 611	404.13	402.71	0.004	15	4.38	2.71	161.4
623 622	422.07	420.35	0.004	15	4.7	2.95	159.2
580 577	335.59	335.33	0.001	18	4.28	2.7	158.6
521 599	346.89	346.72	0.004	15	4.41	2.82	156.7
600 521	348.3	346.89	0.004	15	4.43	2.84	156
622 620	420.35	418.6	0.004	15	4.66	3	155.3
596 595	344.76	343.84	0.004	15	4.37	2.84	154
632 631	491.58	490.27	0.005	15	4.82	3.18	152.5
602 601	353.96	352.24	0.004	15	4.54	2.99	151.9
60 603	358.97	358.29	0.005	15	4.59	3.04	151.1
592 591	340.68	339.99	0.004	15	4.31	2.88	149.7
635 632	493.21	491.58	0.005	15	4.83	3.28	146.9
598 597	346.15	345.41	0.004	15	4.39	3	146.5
593 592	341.61	340.68	0.005	15	4.33	3.08	140.4
611 610	402.71	400.43	0.005	15	4.37	3.32	131.7
597 596	345.41	344.76	0.006	15	4.38	3.37	129.8
CO-33	484.79	484.72	0.001	18	3.36	2.59	129.5
605 604	360.7	359.86	0.006	15	4.58	3.54	129.4
CO-40	482.61	482.5	0.002	18	3.41	2.65	128.4
CO-39	483.33	482.61	0.002	18	3.37	2.67	126.1
578 582	330.08	329.1	0.007	18	7.46	5.96	125.2
CO-37	484.46	483.72	0.002	18	3.35	2.77	120.8
595 594	343.84	342.83	0.007	15	4.35	3.69	118
585 588	328.37	325.39	0.008	18	7.5	6.49	115.5
mh3 378a	300.41	300.28	0.002	24	7.84	7.05	111.2
CO-34	484.72	484.64	0.002	18	3.36	3.04	110.6
151 324	345.94	344.12	0.008	12	2.4	2.17	110.6
322A 322	330.89	328.57	0.009	12	2.55	2.32	109.9
324 150	344.12	341.92	0.006	12	2.39	2.18	109.6
583 579	317.99	315.28	0.009	18	7.62	7.1	107.3
601 59	352.24	350.3	0.01	15	4.48	4.46	100.4
59 600	350.3	348.3	0.01	15	4.44	4.47	99.3
579 575	315.28	312.23	0.011	18	7.68	7.83	98
628 627	441.79	441.37	0.012	15	4.77	4.94	96.6
627 626	441.37	439.67	0.012	15	4.76	4.96	95.9
535 322A	333.91	330.89	0.011	12	2.55	2.66	95.7
626 625	439.67	434.51	0.013	15	4.76	5.13	92.7
401b mh3	301.16	300.41	0.002	24	5.48	6.46	84.8
434 430	314.39	312.24	0.004	18	3.86	4.56	84.5
631 630C	490.27	485.01	0.016	15	4.82	5.72	84.2
234 151	347.36	345.94	0.005	10	0.88	1.06	83.6
581 578	331.03	330.08	0.007	18	5.15	6.24	82.6
588 586	325.39	322.79	0.016	18	7.52	9.25	81.3
210 214	320.35	319.81	0.004	18	3.74	4.62	81.1
323 535	338.06	333.91	0.016	12	2.52	3.17	79.5
586 583	322.79	317.99	0.017	18	7.54	9.5	79.4
CO-13	300.87	299.98	0.002	30	9.47	12.5	75.7
CO-12	301.74	300.87	0.002	30	9.46	12.55	75.4
CO-11	302.49	301.74	0.002	30	9.45	12.62	74.9
CO-14	299.88	299.28	0.002	30	9.5	12.8	74.2
603 602	358.29	353.96	0.019	15	4.58	6.22	73.6
617 614	414.51	406.33	0.019	15	4.54	6.31	71.9
CO-36	484.57	484.46	0.005	18	3.35	4.7	71.4
CO-15	299.28	298.88	0.003	30	9.54	13.69	69.7
233 16	353.8	351.54	0.007	10	0.89	1.31	68
582 585	329.1	326.37	0.022	18	7.47	10.99	68
1044 434	315.75	314.39	0.006	18	3.83	5.86	65.3
378a 378b	300.28	299.97	0.008	24	9.28	14.27	65
150 323	341.92	338.06	0.022	12	2.39	3.68	64.8
619 617	417.38	414.51	0.025	15	4.63	7.18	64.5
608 607	387.69	378.23	0.023	15	4.36	6.85	63.7
CO-8	306.55	305.74	0.002	30	8.06	12.66	63.6

Projected Ultimate Max Day Flow Based on Act 537 Planning							
Pipe Report Label	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
CO-26	293.33	292.87	0.001	36	9.3	14.62	63.6
CO-7	307.09	306.55	0.002	30	7.98	12.93	61.7
CO-30	288.4	287.86	0.002	42	18.78	30.53	61.5
CO-6	307.76	307.09	0.002	30	7.85	12.79	61.4
606 605	367.55	360.7	0.028	15	4.5	7.58	59.4
CO-25	292.87	292.58	0.001	36	9.3	15.91	58.5
204 210	321.53	320.35	0.006	18	3.29	5.67	58
CO-17	289.52	288.4	0.004	30	9.54	16.47	57.9
CO-5	308.2	307.76	0.003	30	7.77	13.49	57.6
214 205	319.81	317.66	0.008	18	3.78	6.73	56.1
388 394	307.44	306.45	0.004	24	5.34	9.59	55.7
224 211	325.35	324.21	0.006	18	3.18	5.72	55.6
609 608	399.73	387.69	0.03	15	4.35	7.84	55.4
CO-4	308.5	308.2	0.003	30	7.73	14.45	53.5
211 203	324.21	322.87	0.007	18	3.23	6.15	52.5
CO-27	293.55	293.33	0.002	36	9.3	17.73	52.4
203 204	322.87	321.53	0.007	18	3.23	6.28	51.5
322 224	328.57	325.35	0.012	15	2.58	5.05	51
430 429	312.24	310.56	0.012	18	3.88	7.91	49.1
16 234	351.54	347.36	0.014	10	0.89	1.83	48.8
638 635	506.66	493.21	0.049	15	4.83	9.96	48.5
413 414	304.57	302.85	0.005	24	5.4	11.39	47.4
629 628	454.37	441.79	0.053	15	4.78	10.41	45.9
394 413	306.45	304.57	0.006	24	5.41	12.03	45
607 606	378.23	367.55	0.051	15	4.43	10.2	43.4
625 624	434.51	423.07	0.064	15	4.77	11.4	41.8
429 393	310.56	309.96	0.004	24	3.94	9.48	41.6
12 233	364.55	353.8	0.02	10	0.89	2.17	41.2
630 629	477.33	454.37	0.091	15	4.79	13.62	35.2
389 388	309.05	307.44	0.009	24	5.26	15.04	35
205 433	317.66	316.74	0.005	24	3.81	10.92	34.9
CO-22	289.71	289.16	0.002	42	9.56	27.84	34.3
630C 630	485.01	477.33	0.105	15	4.8	14.64	32.8
393 389	309.96	309.05	0.006	24	3.95	12.06	32.8
CO-20	288.85	288.4	0.002	42	9.56	29.61	32.3
433 1044	316.74	315.75	0.006	24	3.82	12.19	31.3
CO-21	289.16	288.85	0.002	42	9.56	30.6	31.2
414 401b	302.85	301.16	0.015	24	5.47	19.32	28.3
577 581	335.33	331.03	0.045	18	4.29	15.53	27.6
CO-23	290.68	289.71	0.003	42	9.56	36.08	26.5
CO-24	292.58	290.68	0.014	36	9.3	50.22	18.5
CO-3	312.23	308.5	0.037	30	7.71	50.91	15.2
CO-16	298.88	289.52	0.059	30	9.57	64.32	14.9
CO-32	287.86	287	0.047	42	18.78	140.65	13.3
371 524	299.97	299.91	0	24	0.28	2.39	11.5
CO-28	299.94	293.55	0.056	36	9.3	101.61	9.2
374 35	293.08	292.83	0.001	24	0.32	4.92	6.4
CO-9	305.74	302.49	0.271	30	8.13	137.96	5.9
373 374	296.24	295.91	0.002	24	0.32	6.74	4.8
524 524a	299.91	299.57	0.004	24	0.29	10.25	2.8
35 479	292.83	292.52	0.001	30	0.28	10.48	2.7
CO-31	292.52	290.68	0.006	24	0.28	11.04	2.5
524a 373	298.32	297.38	0.006	24	0.3	12.4	2.4
CO-41	482.5	0	9.48	18	3.42	209.03	1.6

Projected Ultimate Peak Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
584 580	336.43	335.59	0.002	15	5.52	2.1	262.5
614 613	406.33	405.44	0.002	15	5.53	2.15	257
590 589	338.87	338.06	0.002	15	5.46	2.26	241.6
589 587	338.06	337.28	0.003	15	5.54	2.35	235.3
CO-35	484.64	484.57	0.001	18	4.27	1.85	230.3
624 623	423.07	422.07	0.003	15	5.98	2.82	228.1
591 590	339.99	338.87	0.003	15	5.44	2.4	228.8
620 619	418.6	417.38	0.003	15	5.58	2.56	218.5
594 593	342.83	341.61	0.003	15	5.47	2.51	217.9
604 60	359.86	358.97	0.003	15	5.65	2.65	213.5
CO-38	483.72	483.33	0.001	18	4.19	1.97	213
613 612	405.44	404.13	0.003	15	5.46	2.57	212.5
580 577	335.59	335.33	0.001	18	5.89	2.7	210.9
599 598	346.72	346.15	0.003	15	5.52	2.66	207.6
612 611	404.13	402.71	0.004	15	5.46	2.71	201.2
521 599	346.89	346.72	0.004	15	5.53	2.82	196.5
600 521	348.3	346.89	0.004	15	5.55	2.84	195.7
623 622	422.07	420.35	0.004	15	5.74	2.95	194.5
596 595	344.76	343.84	0.004	15	5.5	2.84	193.9
592 591	340.68	339.99	0.004	15	5.44	2.88	189
602 601	353.96	352.24	0.004	15	5.64	2.99	188.6
632 631	491.58	490.27	0.005	15	5.93	3.16	187.4
622 620	420.35	418.6	0.004	15	5.62	3	187.4
60 603	358.97	358.29	0.005	15	5.67	3.04	186.3
635 632	493.21	491.58	0.005	15	6.11	3.28	186.1
598 597	346.15	345.41	0.004	15	5.52	3	184.2
151 324	345.94	344.12	0.008	12	3.9	2.17	179.2
324 150	344.12	341.92	0.008	12	3.9	2.18	178.4
322A 322	330.89	328.57	0.009	12	4.13	2.32	178.2
593 592	341.61	340.68	0.005	15	5.46	3.08	177.1
CO-40	482.61	482.5	0.002	18	4.46	2.65	168.3
CO-33	484.79	484.72	0.001	18	4.31	2.59	166.2
611 610	402.71	400.43	0.005	15	5.47	3.32	164.9
597 596	345.41	344.76	0.006	15	5.51	3.37	163.3
605 604	360.7	359.86	0.006	15	5.74	3.54	162.4
578 582	330.08	329.1	0.007	18	9.6	5.96	161.1
mh3 378a	300.41	300.28	0.002	24	11.33	7.05	160.8
CO-39	483.33	482.61	0.002	18	4.21	2.67	157.4
535 322A	333.91	330.89	0.011	12	4.13	2.66	155.4
CO-37	484.46	483.72	0.002	18	4.19	2.77	151.1
595 594	343.84	342.83	0.007	15	5.48	3.69	148.6
585 588	326.37	325.39	0.008	18	9.38	6.49	144.4
CO-34	484.72	484.64	0.002	18	4.29	3.04	141.3
583 579	317.99	315.28	0.009	18	9.47	7.1	133.4
434 430	314.39	312.24	0.004	18	5.91	4.56	129.6
323 535	338.06	333.91	0.016	12	4.1	3.17	129.3
210 214	320.35	319.81	0.004	18	5.86	4.62	127.1
601 59	352.24	350.3	0.01	15	5.65	4.46	126.7
628 627	441.79	441.37	0.012	15	6.24	4.94	126.4
59 600	350.3	348.3	0.01	15	5.61	4.47	125.4
401b mh3	301.16	300.41	0.002	24	8.06	6.46	124.7
627 626	441.37	439.67	0.012	15	6.15	4.96	124
579 575	315.28	312.23	0.011	18	9.54	7.83	121.8
626 625	439.67	434.51	0.013	15	6.06	5.13	118
581 578	331.03	330.08	0.007	18	6.93	6.24	111.1
150 323	341.92	338.06	0.022	12	3.9	3.88	105.7
631 630C	490.27	485.01	0.016	15	6.03	5.72	105.4
588 586	325.39	322.79	0.016	18	9.47	9.25	102.3
586 583	322.79	317.99	0.017	18	9.72	9.5	102.3
1044 434	315.75	314.39	0.006	18	5.87	5.86	100.2
CO-13	300.87	299.98	0.002	30	12.16	12.5	97.2
CO-12	301.74	300.87	0.002	30	12.17	12.55	96.9
CO-11	302.49	301.74	0.002	30	12.19	12.62	96.6
617 614	414.51	406.33	0.019	15	6.08	6.31	96.3
CO-14	299.98	299.28	0.002	30	12.3	12.8	96
603 602	358.29	353.96	0.019	15	5.79	6.22	93
204 210	321.53	320.35	0.006	18	5.23	5.67	92.3
CO-15	299.28	298.88	0.003	30	12.57	13.69	91.8
378a 378b	300.28	299.97	0.008	24	13.06	14.27	91.5
606 607	387.69	378.23	0.023	15	6.27	6.85	91.5
CO-36	484.57	484.46	0.005	18	4.23	4.7	90.1
CO-26	293.33	292.87	0.001	36	13.06	14.62	89.3
214 205	319.81	317.66	0.008	18	5.95	6.73	88.4
224 211	325.35	324.21	0.006	18	5.03	5.72	88
582 585	329.1	326.37	0.022	18	9.54	10.99	86.7

Projected Ultimate Peak Flow Based on Act 537 Planning							
Pipe Report	Start Invert (ft)	Stop Invert (ft)	Constructed Slope (ft/ft)	Diameter (in)	Flow (mgd)	Full Capacity (mgd)	Flow / Full Flow Capacity (%)
211_203	324.21	322.87	0.007	18	5.15	6.15	83.8
CO-30	288.4	287.86	0.002	42	25.43	30.53	83.3
388_394	307.44	306.45	0.004	24	7.93	9.59	82.7
606_605	367.55	360.7	0.028	15	6.26	7.58	82.6
203_204	322.87	321.53	0.007	18	5.18	6.28	82.5
322_224	328.57	325.35	0.012	15	4.16	5.05	82.3
234_151	347.36	345.94	0.005	10	0.87	1.06	82.3
CO-25	292.87	292.58	0.001	36	13.06	15.91	82.1
CO-8	306.55	305.74	0.002	30	10.29	12.66	81.3
CO-6	307.76	307.09	0.002	30	10.26	12.79	80.3
CO-7	307.09	306.55	0.002	30	10.37	12.93	80.2
619_617	417.38	414.51	0.025	15	5.68	7.18	79.2
430_429	312.24	310.56	0.012	18	5.98	7.91	75.3
609_608	399.73	387.69	0.03	15	5.9	7.84	75.2
CO-5	308.2	307.76	0.003	30	10.12	13.49	75
233_16	353.8	351.54	0.007	10	0.96	1.31	73
CO-17	289.52	288.4	0.004	30	12.01	16.47	72.9
CO-27	293.55	293.33	0.002	36	12.88	17.73	72.6
413_414	304.57	302.85	0.005	24	8.05	11.39	70.7
CO-4	308.5	308.2	0.003	30	9.79	14.45	67.8
394_413	306.45	304.57	0.006	24	8.12	12.03	67.4
429_393	310.56	309.96	0.004	24	6.09	9.48	64.3
638_635	506.66	493.21	0.049	15	6.32	9.96	63.4
607_606	378.23	367.55	0.051	15	6.31	10.2	61.9
629_628	454.37	441.79	0.053	15	6.28	10.41	60.3
205_433	317.66	316.74	0.005	24	5.97	10.92	54.7
625_624	434.51	423.07	0.064	15	6.1	11.4	53.6
16_234	351.54	347.36	0.014	10	0.96	1.83	52.6
389_388	309.05	307.44	0.009	24	7.88	15.04	52.4
393_389	309.96	309.05	0.006	24	6.14	12.06	50.9
433_1044	316.74	315.75	0.006	24	5.93	12.19	48.6
CO-22	289.71	289.16	0.002	42	13.42	27.84	48.2
630_629	477.33	454.37	0.091	15	6.23	13.62	45.7
CO-20	288.85	288.4	0.002	42	13.42	29.61	45.3
12_233	364.55	353.8	0.02	10	0.96	2.17	44.5
CO-21	289.16	288.85	0.002	42	13.42	30.6	43.8
630C_630	485.01	477.33	0.105	15	6.18	14.64	42.2
414_401b	302.85	301.16	0.015	24	8.07	19.32	41.8
577_581	335.33	331.03	0.045	18	5.89	15.53	37.9
CO-23	290.68	289.71	0.003	42	13.42	36.06	37.2
CO-24	292.58	290.68	0.014	36	13.06	50.22	26
CO-16	298.88	289.52	0.059	30	12.59	64.32	19.6
CO-3	312.23	308.5	0.037	30	9.65	50.91	18.9
CO-32	287.86	287	0.047	42	25.43	140.65	18.1
371_524	299.97	299.91	0	24	0.36	2.39	14.9
CO-28	299.94	293.55	0.056	36	12.97	101.61	12.8
CO-9	305.74	302.49	0.271	30	10.5	137.96	7.6
374_35	293.08	292.83	0.001	24	0.36	4.92	7.2
373_374	296.24	295.91	0.002	24	0.35	6.74	5.2
524_524a	299.91	289.57	0.004	24	0.45	10.25	4.4
35_479	292.83	292.52	0.001	30	0.37	10.48	3.5
524a_373	298.32	297.38	0.006	24	0.41	12.4	3.3
CO-31	292.52	290.68	0.006	24	0.35	11.04	3.2
CO-41	482.5	0	9.48	18	4.55	209.03	2.2