

**Application of SUEZ Water Pennsylvania Inc. for the Acquisition of the Wastewater Assets  
of the Township of Mahoning Pursuant to 66 Pa. C.S. §1329  
Application Filing Checklist – Wastewater  
Docket No. A-2018-\_\_\_\_\_**

20. Proof of Compliance. Provide proof of compliance with applicable design, construction and operation standards of DEP or of the county health department, or both, including:
- b. For **wastewater** system acquisitions, provide copies of the water quality management and National Pollution Discharge Elimination System (NPDES) permits for the utility plant.

**RESPONSE:**

- b. See enclosed water quality management permit (No. 471401).



## WATER QUALITY MANAGEMENT PERMIT

<p>A. PERMITTEE (Name and Address): <span style="float: right;">CLIENT ID#: 62411</span>  <b>Mahoning Township Montour County</b>  <b>1101 Bloom Street</b>  <b>Danville, PA 17821-1301</b></p>	<p>B. PROJECT/FACILITY (Name):  <b>(Former) Mahoning Township Municipal Authority                  Collection System</b></p>	
<p>C. LOCATION (Municipality, County): <span style="float: right;">SITE ID#: 1142</span>  <b>Mahoning Township, Montour County</b></p>		
<p>D. This permit transfer and consolidation approves the operation of sewage facilities consisting of:</p> <ul style="list-style-type: none"> <li>● Municipal sewage collection system contributory to the Borough of Danville collection system</li> <li>● The SR11 (former TRW) Pumping Station rated for 525 gpm @ 80.1' TDH (0.755 MGD)</li> <li>● Meadows at Maria Joseph Pumping Station rated for 175 gpm @ 47' TDH (0.048 MGD)</li> <li>● Additional piping, appurtenances, stream crossings and facilities as listed in the original permits prior to consolidation.</li> </ul> <p>The downstream sewage treatment facility is permitted under a separate WQM permit.</p>		
<p>Pump Stations: <u>Two (2) primary</u>                  Design Capacity: <u>Noted above.</u></p>	<p>Manure Storage:                  Volume: <u>N/A</u> MG                  Freeboard: <u>N/A</u> inches</p>	<p>Sewage Treatment Facility:                  Annual Average Flow: <u>N/A</u> MGD                  Design Hydraulic Capacity: <u>N/A</u> MGD                  Design Organic Capacity: <u>N/A</u> lb/day</p>
<p>E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING:</p> <p>1. <b>New Permits:</b> All construction, operations and procedures shall be in accordance with the Water Quality Management Permit application dated <u>N/A</u>, its supporting documentation and addendums dated <u>N/A</u>, which are hereby made a part of this permit.</p> <p><b>Amendments:</b> All construction, operations and procedures shall be in accordance with the Water Quality Management Permit Amendment application dated <u>N/A</u> and its supporting documentation and addendums dated <u>N/A</u>, which are hereby made a part of this amendment.</p> <p>Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums approved under Water Quality Management Permit No. <u>various (see attached list)</u> dated <u>various (see attached list)</u> shall remain in effect.</p> <p><b>Transfers:</b> Water Quality Management Permit No. <u>various (see attached list)</u> dated <u>various (see attached list)</u> and conditions, supporting documentation and addendums are also made part of this transfer.</p> <p>2. Permit Conditions Relating to Sewerage are attached and made part of this permit.</p> <p>3. Special Condition <u>A and Appendix 1 – Permit Listing</u> is attached and made part of this permit.</p>		
<p>F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS:</p> <p>1. If there is a conflict between the application or its supporting documents and amendments and the attached conditions, the attached conditions shall apply.</p> <p>2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the authority given to the permittee by the issuance of this permit.</p> <p>3. This permit is issued pursuant to the Clean Streams Law Act of June 22, 1937, P.L. 1987, as amended 35 P.S. §691.1 et seq. Issuance of this permit shall not relieve the permittee of any responsibility under any other law.</p>		
<p>PERMIT ISSUED:   <u>February 28, 2017</u></p>	<p>BY:                   Thomas M. Randis                  Clean Water Program Manager                  Northcentral Regional Office</p> <p>TITLE:</p>	



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

**PERMIT CONDITIONS RELATING TO SEWERAGE**  
For use in Water Quality Management Permits

(Check boxes that apply)

**General**

- 1. The Department of Environmental Protection (DEP) considers the licensed Professional Engineer whose seal is affixed to the design documents to be fully responsible for the adequacy of all aspects of the facility design.
- 2. The permittee shall adopt and enforce an ordinance requiring the abandonment of privies, cesspools or similar receptacles for human waste and onlot sewage disposal systems on the premises of occupied structures accessible to public sewers. All such structures must be connected to the public sewers.
- 3. The outfall sewer or drain shall be extended to the low water mark of the receiving body of water. Where necessary to ensure proper mixing and waste assimilation, an outfall sewer or drain may be extended with appurtenances below the low water mark and into the bed of a navigable stream provided that the permittee has secured an easement, right-of-way, license or lease from DEP in accordance with Section 15 of the Dam Safety and Encroachments Act, the Act of November 26, 1978, P.L. 1375, as amended.
- 4. The approval is specifically made contingent on the permittee acquiring all necessary property rights, by easement or otherwise, providing for the satisfactory construction, operation, maintenance and replacement of all sewers or sewerage structures in, along or across private property with full rights of ingress, egress and regress.
- 5. When construction of the approved sewerage facilities is completed and before they are placed in operation, the permittee shall notify DEP in writing so that a DEP representative may inspect the facilities.
- 6. The approval of the plans, and the authority granted in this permit, if not specifically extended, shall cease and be null and void 2 years from the issuance date of this permit unless construction or modification of the facilities covered by this permit has begun on or before the second anniversary of the permit date.
- 7. If, at any time, the sewerage facilities covered by this permit create a public nuisance, including but not limited to, causing malodors or causing environmental harm to waters of the Commonwealth, DEP may require the permittee to adopt appropriate remedial measures to abate the nuisance or harm.
- 8. If, after the issuance of this permit, DEP approves a municipal sewage facilities official plan or an amendment to an official plan under Act 537 (Pennsylvania Sewage Facilities Act, the Act of January 24, 1966, P.L. 1535 as amended) in which sewage from the herein approved facilities will be treated and disposed of at other planned facilities, the permittee shall, upon notification from the municipality or DEP, provide for the conveyance of its sewage to the planned facilities, abandon use and decommission the herein approved facilities including the proper disposal of solids, and notify DEP accordingly. The permittee shall adhere to schedules in the approved official plan, amendments to the plan, or other agreements between the permittee and municipality. This permit shall then, upon notice from DEP, terminate and become null and void and shall be relinquished to DEP.
- 9. This permit does not relieve the permittee of its obligations to comply with all federal, interstate, state or local laws, ordinances and regulations applicable to the sewerage facilities.
- 10. This permit does not give any real or personal property rights or grant any exclusive privileges, nor shall it be construed to grant or confirm any right, easement or interest in, on, to or over any lands which belong to the Commonwealth.
- 11. The authority granted by this permit is subject to all effluent requirements, monitoring requirements and other conditions as set forth in NPDES Permit No. N/A and all subsequent amendments and renewals. No discharge is authorized from these facilities unless approved by an NPDES Permit.

**Construction**

- 12. This permit is issued under the authorization of The Clean Streams Law and 25 Pa. Code Chapter 91. The permittee shall obtain all necessary permits, approvals and/or registrations under 25 Pa. Code Chapters 102, 105 and 106 prior to commencing construction of the facilities authorized by this permit, as applicable. The permittee should contact the DEP office that issued this permit if there are any questions concerning the applicability of additional permits.



COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

**WATER QUALITY MANAGEMENT  
 POST CONSTRUCTION CERTIFICATION**

PERMITTEE IDENTIFIER	
Permittee	Mahoning Township Montour County
Municipality	Mahoning Township
County	Montour
WQM Permit No.	4717401
Facility Type	Sewage
<b>All of the above information should be taken directly from the Water Quality Management Permit.</b>	
CERTIFICATION	
<p>This certification must be completed and returned to the permits section of the DEP's regional office issuing the WQM permit within 30 days of completion of the project and received by DEP prior to operation, and if requested, as-built drawings, photographs (if available) and a discussion of any DEP-approved deviations from the design plans during construction.</p>	
<p>I, being a Registered Professional Engineer in Pennsylvania, do hereby certify to the best of my knowledge and belief, based upon personal observation and interviews, that the above facility approved under the Water Quality Management Permit has been constructed in accordance with the plans, specifications and modifications approved by DEP.</p>	
<p>Construction Completion Date (MM/DD/YYYY): _____</p>	
<p>Engineer's Seal</p>	<b>Professional Engineer</b>
	Name _____ (Please Print or Type)
	Signature _____
	Date _____
	License Expiration Date _____
	Firm or Agency _____
	Telephone _____
	<b>Permittee or Authorized Representative</b>
	Name _____ (Please Print or Type)
	Signature _____
	Title _____
	Telephone _____

- 13. The facilities shall be constructed under the supervision of a Pennsylvania licensed Professional Engineer in accordance with the approved reports, plans and specifications.
- 14. A Pennsylvania licensed Professional Engineer shall certify that construction of the permitted facilities was completed in accordance with the application and design plans submitted to DEP, using "Post Construction Certification" form (3800-PM-WSFR0179a). It is the permittee's responsibility to ensure that a Professional Engineer is on-site to provide the necessary oversight and/or inspections to certify the facilities. The certification must be submitted to DEP before the facility is placed in operation. As-built drawings, photographs (if available) and a description of all deviations from the application and design plans must be submitted to DEP within 30 days of certification.
- 15. Manhole inverts shall be formed to facilitate the flow of the sewage and to prevent the stranding of sewage solids. The manhole structure shall be built to prevent undue infiltration, entrance of street wash or grit and provide safe access to facilitate manhole maintenance activities.
- 16. The local Waterways Conservation Officer of the Pennsylvania Fish and Boat Commission (PFBC) shall be notified when the construction of any stream crossing and/or outfall is started and completed. A written permit must be secured from the PFBC if the use of explosives in any waterways is required and the permittee shall notify the local Waterways Conservation Officer when explosives are to be used.

#### Operation and Maintenance

- 17. The permittee shall maintain records of "as-built" plans showing all the treatment facilities as actually constructed together with facility operation and maintenance (O&M) manuals and any other relevant information that may be required. Upon request, the "as-built" plans and O&M manuals shall be filed with DEP.
- 18. The sewers shall have adequate foundation support as soil conditions require. Trenches shall be back-filled to ensure that sewers will have proper structural stability, with minimum settling and adequate protection against breakage. Concrete used in connection with these sewers shall be protected from damage by water, freezing, drying or other harmful conditions until cured.
- 19. Stormwater from roofs, foundation drains, basement drains or other sources shall not be admitted directly to the sanitary sewers.
- 20. The approved sewers shall be maintained in good condition, kept free of deposits by flushing or other cleaning methods and repaired when necessary.
- 21. The sewerage facilities shall be properly operated and maintained to perform as designed.
- 22. The attention of the permittee is called to the highly explosive nature of certain gases generated by the digestion of sewage solids when these gases are mixed in proper proportions with air and to the highly toxic character of certain gases arising from such digestion or from sewage in poorly ventilated compartments or sewers. Therefore, at all places throughout the sewerage facilities where hazard of fire, explosion or danger from toxic gases may occur, the permittee shall post conspicuous permanent and legible warnings. The permittee shall instruct all employees concerning the aforesaid hazards, first aid and emergency methods of meeting such hazards and shall make all necessary equipment and material accessible.
- 23. An operator certified in accordance with the Water and Wastewater Systems Operator Certification Act of February 21, 2002, 63 P.S. §§1001, *et seq.* shall operate the sewage treatment plant.
- 24. The permittee shall properly control any industrial waste discharged into its sewerage system by regulating the rate and quality of such discharge, requiring necessary pretreatment and excluding industrial waste, if necessary, to protect the integrity or operation of the permittee's sewerage system.
- 25. There shall be no physical connection between a public water supply system and a sewer or appurtenance to it which would permit the passage of any sewage or polluted water into the potable water supply. No water pipe shall pass through or come in contact with any part of a sewer manhole.
- 26. All connections to the approved sanitary sewers must be in accordance with the official Act 537 Plan and, if applicable, a corrective action plan as contained in the approved Title 25 Pa. Code Chapter 94 Municipal Wasteload Management Annual Report.
- 27. Collected screenings, slurries, sludge and other solids shall be handled and disposed of in compliance with Title 25 Pa. Code Chapters 271, 273, 275, 283 and 285 (related to permits and requirements for land filling, land application, incineration and storage of sewage sludge), Federal Regulations 40 CFR 257 and the Federal Clean Water Act and its amendments.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

**SPECIAL CONDITIONS**  
Water Quality Management Permit No. 4717401  
Mahoning Township Montour County

A. Right of Entry

Pursuant to Sections 5(b) and 30.5 of Pennsylvania's Clean Stream Law, the permittee shall allow authorized representatives of Department of Environmental Protection upon the presentation of credentials and other documents as may be required by law:

1. To enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
2. To have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit.
3. To inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
4. To sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act or The Clean Streams Law, any substances or parameters at any location.

*Appendix 1 – Summary List attached as next page:*

**Water Quality Management Permit No. 4717401**

**Appendix 1 – Summary of Consolidated Permits**

<b>Consolidated Permit No.</b>	<b>Permits to be Retired<sup>(a)</sup></b>	<b>Date Issued</b>	
4717401  March 1, 2017	8164	7/17/1951	Proposed Sanitary Sewer – 19,000 LF of 8" gravity sewer
	661-S-10	5/24/1961	Sisters of Saint Cyril, Villa of Sacred Heart Permit – 15,000 gpd treatment facility for Maria Joseph Manor
	664-S-8	2/13/1964	Maple & Oak Street Sanitary Sewer – gravity extensions
	667-S-030	5/24/1967	Kaseville Road and Sidler Hill – 11,900 gpd extension to Spring Street
	4770402	12/22/1970	Kingsley Ave, Crestwood Drive & Frosty Hill Drive – 1,865 LF gravity extension
	4771401	1/19/1971	Blizzard Run Sanitary Sewer – 2,970 LF gravity along Blizzard Run
	4771404	7/15/1971	Mahoning Meadows "Section A" – 1,300 LF gravity
	4772401	3/2/1972	Montgomery Village Townhouse – gravity sewer for 76 units
	4772402	9/25/1972	Mahoning Meadows "Section B" – 1,448 LF gravity extension
	4774402	9/30/1974	Crestwood II – 3,300 LF of gravity sewer service to 68 dwelling units. Connection at Spring Street.
	4774403 <sup>(b)</sup>	1975	37 unit Grandview Terrace extension – 2,100 LF of gravity
	4775401 <sup>(b)</sup>	1975	1900 LF gravity extension to serve Danville Terrace Apartments & Shopping Center
	4779401	4/30/1979	Kaseville Road – construction of 2,000 LF of gravity sewer to convey flow from 400 proposed units (0.128 MGD).
	4779402 <sup>(b)</sup>	1979	Mahoning Meadows Section C – 43 units served by 3,340 LF gravity
	4780401	7/17/1980	TRW Industrial Development - 4,300 LF gravity, 4,700 LF force main and one (1) pump station rated for 250 gpd @ 51' TDH, 172,800 gpd total
	4781401 <sup>(c)</sup>		Permit application would become 4782402
	4782402 <sup>(c)</sup>	7/28/1982	Ridgeview Development – Gravity sewer, expansion of pumping station and requirement of relief sewer 4782403 (Danville 12" relief sewer). 6,410 LF of gravity line will serve 632 dwelling units (158,000 gpd). Connects to permit 4780401. Pumping station will receive new impellers and pump motors. Proposed capacity 0.755 MGD @ 80.1' TDH (525 gpm). The "relief sewer" is the railroad grade sewer replacing usage of the SR 11 sewer.
	4784402	9/20/1984	Village Gates Apartments – 27 lots served by 1,700 LF of gravity sewer
	4787403	11/6/1987	Bloom Street Gravity Extension – connection of 25 homes along Bloom, Diehl, Lindbergh and Bird. Connects to downstream permit 4782402.
	4788401	5/19/1988	Brittany Center – 1,100 LF of gravity sewer to connect commercial area in Mahoning and Cooper Townships. Connects to downstream permit 4782402.
4788403	9/29/1988	Millwood Subdivision – gravity sewers to connect 11 lots to downstream permit 4770402.	
4789403	6/13/1989	Old Bloom Road – 17 units in Mahoning and Cooper served by gravity sewer. 6,000 gpd allocated.	
4793402	12/10/1993	Edgewood Development – 6,000 gpd grinder pump station, (20 gpm @ 60' TDH), 2,700 LF of gravity, 500 LF force main, servicing 17 residential dwellings.	
4794401	8/10/1994	The Meadows at Maria Joseph Manor – Phases 2 and 3 – 3,360 LF of gravity and 1,200 LF of force main for 12,000 gpd (60 units). No permit was required for Phase 1 gravity sewers. Planning approved July 15, 1993 for all three (3) phases for 47,520 gpd via pump station rated at 175 gpm with 47 feet TDH.	

(a) – Permits issued prior to 1971 were issued by the Department of Health. Permits issued 1971-Present were issued by DER/DEP.

(b) – These permits did not appear on the list originally submitted by LDG and have been included herein.

(c) – Ridgeview development 4781401 was initially denied then permitted as 4782402.



Application Type New  
Facility Type Sewage Treatment Plant  
WQM Type Plant

**WATER QUALITY MANAGEMENT PERMIT  
INTERNAL REVIEW AND  
RECOMMENDATIONS**

Application No. 4717401  
APS ID 933315  
Authorization ID 1169472

**Applicant and Facility Information**

Applicant Name	<u>Mahoning Township Montour County</u>	Facility Name	<u>Mahoning Township Municipal Authority</u>
Applicant Address	<u>1101 Bloom Street</u> <u>Danville, PA 17821-1301</u>	Facility Address	<u>1101 Bloom Road</u> <u>Danville, PA 17821</u>
Applicant Contact	<u>Kenneth Woodruff</u>	Facility Contact	<u></u>
Applicant Phone	<u>(570) 275-5521</u>	Facility Phone	<u></u>
Client ID	<u>62411</u>	Site ID	<u>1142</u>
SIC Code	<u>4952</u>	Municipality	<u>Mahoning Township</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Montour</u>

Purpose of Application Transfer & consolidation of multiple sewage permits from Mahoning Township Municipal Authority to Mahoning Township.

**Internal Review and Recommendations**

A request for transfer of permits from the Mahoning Township Municipal Authority to Mahoning Township was received on February 9, 2017. The proposed transfer is signed by Thomas N. Mertz, Chairman of the MTMA and Kenneth Woodruff, Chairman of the MT Board of Supervisors.

Twenty four (24) permits cited on the attached page shall be transferred from the Municipal Authority to the Township.

The accumulated permits of the MTMA will be transferred and consolidated into WQM 4717401.

The Mahoning Township system includes two (2) major pumping stations:

- SR 11 (former TRW) 0.755 MGD @ 80.1' TDH (525 gpm)
- The Meadows at Maria Joseph Manor - 175 gpm @ 47' TDH (47,520 gpd)

*Continued next page*

Approve	Return	Deny	Signatures	Date
✓			Jeremiah W. Northridge, P.E. / Environmental Engineer <i>[Signature]</i>	February 27, 2017
x			Thomas M. Randis / Program Manager <i>[Signature]</i>	2/28/17

A summary of transferred permits includes the following:

Consolidated Permit No.	Permits to be Retired <sup>(a)</sup>	Date Issued	
4717401  March 1, 2017	8164	7/17/1951	Proposed Sanitary Sewer – 19,000 LF of 8" gravity sewer
	661-S-10	5/24/1961	Sisters of Saint Cyril, Villa of Sacred Heart Permit – 15,000 gpd treatment facility for Maria Joseph Manor
	664-S-8	2/13/1964	Maple & Oak Street Sanitary Sewer – gravity extensions
	667-S-030	5/24/1967	Kaseville Road and Sidler Hill – 11,900 gpd extension to Spring Street
	4770402	12/22/1970	Kingsley Ave, Crestwood Drive & Frosty Hill Drive – 1,865 LF gravity extension
	4771401	1/19/1971	Blizzard Run Sanitary Sewer – 2,970 LF gravity along Blizzard Run
	4771404	7/15/1971	Mahoning Meadows "Section A" – 1,300 LF gravity
	4772401	3/2/1972	Montgomery Village Townhouse – gravity sewer for 76 units
	4772402	9/25/1972	Mahoning Meadows "Section B" – 1,448 LF gravity extension
	4774402	9/30/1974	Crestwood II – 3,300 LF of gravity sewer service to 68 dwelling units. Connection at Spring Street.
	4774403 <sup>(b)</sup>	1975	37 unit Grandview Terrace extension – 2,100 LF of gravity
	4775401 <sup>(b)</sup>	1975	1900 LF gravity extension to serve Danville Terrace Apartments & Shopping Center
	4779401	4/30/1979	Kaseville Road – construction of 2,000 LF of gravity sewer to convey flow from 400 proposed units (0.128 MGD).
	4779402 <sup>(b)</sup>	1979	Mahoning Meadows Section C – 43 units served by 3,340 LF gravity
	4780401	7/17/1980	TRW Industrial Development - 4,300 LF gravity, 4,700 LF force main and one (1) pump station rated for 250 gpd @ 51' TDH, 172,800 gpd total
	4781401 <sup>(c)</sup>		Permit application would become 4782402
	4782402 <sup>(c)</sup>	7/28/1982	Ridgeview Development – Gravity sewer, expansion of pumping station and requirement of relief sewer 4782403 (Danville 12" relief sewer). 6,410 LF of gravity line will serve 632 dwelling units (158,000 gpd). Connects to permit 4780401. Pumping station will receive new impellers and pump motors. Proposed capacity 0.755 MGD @ 80.1' TDH (525 gpm). The "relief sewer" is the railroad grade sewer replacing usage of the SR 11 sewer.
	4784402	9/20/1984	Village Gates Apartments – 27 lots served by 1,700 LF of gravity sewer
	4787403	11/6/1987	Bloom Street Gravity Extension – connection of 25 homes along Bloom, Diehl, Lindbergh and Bird. Connects to downstream permit 4782402.
	4788401	5/19/1988	Brittany Center – 1,100 LF of gravity sewer to connect commercial area in Mahoning and Cooper Townships. Connects to downstream permit 4782402.
	4788403	9/29/1988	Millwood Subdivision – gravity sewers to connect 11 lots to downstream permit 4770402.
	4789403	6/13/1989	Old Bloom Road – 17 units in Mahoning and Cooper served by gravity sewer. 6,000 gpd allocated.
4793402	12/10/1993	Edgewood Development – 6,000 gpd grinder pump station, (20 gpm @ 60' TDH), 2,700 LF of gravity, 500 LF force main, servicing 17 residential dwellings.	
4794401	8/10/1994	The Meadows at Maria Joseph Manor – Phases 2 and 3 – 3,360 LF of gravity and 1,200 LF of force main for 12,000 gpd (60 units). No permit was required for Phase 1 gravity sewers. Planning approved July 15, 1993 for all three (3) phases for 47,520 gpd via pump station rated at 175 gpm with 47 feet TDH.	

- (a) – Permits issued prior to 1971 were issued by the Department of Health. Permits issued 1971-Present were issued by DER/DEP.
- (b) – These permits did not appear on the list originally submitted by LDG and have been included herein.
- (c) – Ridgeview development 4781401 was initially denied then permitted as 4782402.

Continued next page

Supplemental reports historically provided by Mahoning Township Municipal Authority to the Danville Municipal Authority for Chapter 94 purposes cite three (3) pumping stations:

- The Route 11 pumping station (expanded capacity within 4782402),
- the Meadows/Maria Joseph Manor (4794401) and
- the privately owned Emmanuel Home pumping station.

The Edgewood Development pumping station is not cited in these reports.