

**H**awke  
  **M**cKeon &  
   **S**niscak LLP

ATTORNEYS AT LAW

Thomas J. Sniscak  
(717) 703-0800  
[tjsniscak@hmslegal.com](mailto:tjsniscak@hmslegal.com)

Whitney E. Snyder  
(717) 703-0807  
[wesnyder@hmslegal.com](mailto:wesnyder@hmslegal.com)

100 North Tenth Street, Harrisburg, PA 17101 Phone: 717.236.1300 Fax: 717.236.4841 [www.hmslegal.com](http://www.hmslegal.com)

September 7, 2018

M-2016-2522508

**VIA HAND-DELIVERY**

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street, Filing Room  
Harrisburg, PA 17120

RECEIVED  
2018 SEP -7 PM 3:38  
PA PUC  
SECRETARY'S BUREAU  
FRONT DESK

Re: Pike County Light and Power Company; **SECOND QUARTER 2018  
QUARTERLY RELIABILITY REPORT FOR PIKE COUNTY LIGHT  
& POWER COMPANY**

Dear Secretary Chiavetta:

Enclosed for filing with the Commission is the Second Quarter 2018 Quarterly Reliability Report of Pike County Light & Power Company.

Should you have any questions or comments, please feel free to contact me directly.

Very truly yours,



Thomas J. Sniscak  
Whitney E. Snyder

WES/das  
Enclosure

cc: Steven L. Grandinali, General Manager  
Daniel Searfoorce, Bureau of Technical Utility Services (via e-mail and U.S. Mail)  
David Washko, Bureau of Technical Utility Services (via e-mail and U.S. Mail)  
Office of Consumer Advocate (via U.S. Mail)  
Office of Small Business Advocate (via U.S. Mail)  
Bureau of Investigation and Enforcement (via U.S. Mail)



**Pike County Light & Power Company  
Quarterly Reliability Report**

Second Quarter 2018

RECEIVED  
2018 SEP - 7 PM 3: 39  
PA PUC  
SECRETARY'S BUREAU  
FRONT DESK

**§ 57.195. (e)(1) A description of each major event that occurred during the preceding quarter, including the time and duration of the event, the number of customers affected, the cause of the event and any modified procedures adopted in order to avoid or minimize the impact of similar events in the future.**

**2nd Quarter 2018 Major Events**

There were no Major Events in the Pike County Light & Power Company ("PCL&P") service territory during the second quarter of 2018.

**2nd Quarter 2018 Pre-Arranged Outages**

There were no pre-arranged outages in the Pike County Light & Power Company ("PCL&P") service territory during the second quarter of 2018.

**§ 57.195. (e)(2) Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI, and if available, MAIFI) for the EDC's service territory for the preceding quarter. The report shall include the data used in calculating the indices, namely the average number of customers served, the number of sustained customer interruptions, the number of customers affected, and the customer minutes of interruption. If MAIFI values are provided, the report shall also include the number of customer momentary interruptions.**

**Interruption Data Rolling 12-Month Period**

Year	Quarter	Customers Served	Interruptions	Customers Affected	Customer Minutes of Interruptions
2017	3rd Qtr.	4,648	58	2,350	392,287
2017	4th Qtr.	4,648	60	2,570	475,003
2018	1st Qtr.	4,763	47	3,533	476,953
2018	2nd Qtr.	4,810	39	3,298	621,926

**Performance Ratios - Rolling 12-Month Data**

	Frequency SAIFI	Restoration CAIDI (min)	Duration SAIDI (min)
Benchmark	0.61	174	106
Rolling 12 Month Standard	0.82	235	195


Year	Quarter	Frequency SAIFI	Restoration CAIDI	Duration SAIDI
2017	3rd Qtr.	.51	167	84
2017	4th Qtr.	.55	185	102
2018	1st Qtr.	.74	135	100
2018	2nd Qtr.	.69	189	129

**§ 57.195. (e)(5) A rolling 12-month breakdown and analysis of outage causes during the preceding quarter, including the number and percentage of service outages, the number of customers interrupted, and customer interruption minutes categorized by outage cause such as equipment failure, animal contact, tree related, and so forth. Proposed solutions to identified service problems shall be reported.**

Cause	Number of Interruptions		Customers Affected		Customer Minutes of Interruption	
	12- Month	% of Total	12- Month	% of Total	12- Month	% of Total
Animal Contact	4	10.26%	135	4.09%	32,883	5.29%
Tree Contact	16	41.03%	955	28.96%	177,490	28.54%
Overload	0	0.00%	0	0.00%	0	0.00%
Work Error	0	0.00%	0	0.00%	0	0.00%
Equip. Failure	9	23.08%	1,828	55.43%	270,125	43.43%
Non-Comp Acc.	3	7.69%	4	0.12%	3,127	0.50%
Customer Problem	0	0.00%	0	0.00%	0	0.00%
Lightning	3	7.69%	231	7.00%	65,052	10.46%
Loss of Feed	2	5.13%	38	1.15%	52,820	8.49%
Unknown-Other	2	5.13%	107	3.24%	20,429	3.28%
All Causes	39		3,298		621,926	

**VERIFICATION**

I, Steven L. Grandinali, General Manager of Pike County Light and Power Company, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).



---

Steven L. Grandinali  
General Manager  
Pike County Light and Power Company

RECEIVED  
2018 SEP - 7 PM 3:39  
PA PUC  
SECRETARY'S BUREAU  
FRONT DESK