



PENNSYLVANIA  
AMERICAN WATER

**Brian Ardire**  
*Director, Corporate Counsel*  
Pennsylvania-American Water Company  
800 West Hersheypark Drive, Hershey, PA 17033  
P: 717.531.3362 F: 717.531.3399 C: 717.454.7606  
brian.ardire@amwater.com

Via – UPS Overnight Delivery

October 3, 2018

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility  
Commission  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, PA 17105-3265

RECEIVED  
OCT - 3 2018  
PA PUBLIC UTILITY COMMISSION  
SECRETARY'S BUREAU

**In Re: Application of Pennsylvania-American Water Company for approval (1) the transfer, by sale, of substantially all of the Borough of Turbotville's assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company, and (2) the right of Pennsylvania-American Water Company to begin to offer or furnish wastewater service to the public in the Borough of Turbotville, Northumberland County, Pennsylvania. A-2018-3004189.**

Dear Secretary Chiavetta:

In response to your letter dated September 19, 2018, attached for filing are Pennsylvania-American Water Company's answers to the Data Requests Set 1 regarding the above referenced docket number. Also, per PUC filing requirements, please find a CD containing a copy of said responses.

Sincerely,



Brian Ardire

blg

Enclosure

cc: C. McKinley

Tanya McCloskey/Christine Hoover, Office of Consumer Advocate  
John Evans, Office of Small Business Advocate  
Richard Kanaskie, PUC Bureau of Investigation and Enforcement

**Bureau of Technical Utility Services  
Water/Wastewater Division  
Data Request Set 1**

**Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189**

**A-1. Please identify the Pennsylvania Department of Environmental Protection (DEP) permitted treatment capacity limits, including hydraulic and organic loading, for the Turbotville Borough wastewater treatment plant (Turbotville WWTP).**

**Response: The treatment plant permitted hydraulic capacity is 0.136 MGD. The permitted organic capacity is 226.8 pounds per day of BOD5.**

**Responsible Witness: Michael J. Guntrum PE, PMP**

