



**REPORT OF METER ACCURACY
ISSUED BY METERING SUPPORT**

RECEIVED

2018 OCT 29 AM 11:40

To: Sherry Shaffer

PA PUC
SECRETARY'S BUREAU
FRONT DESK

Today's Date
7/13/18

Removed From		
B/A #20510-85022 (Scott Oatman)		
Date Removed		
7/9/18		
Reason		
Customer Complaint		
Meter Serial #	Average Accuracy	KWH Reading
300-279-286	100.00	15527
<input checked="" type="checkbox"/> Accuracy tests of the kWh meter are within the limits of the PUC Regulations. <input type="checkbox"/> Test results indicate the kWh meter is defective. <input type="checkbox"/> Accuracy tests of both the kWh meter and the Demand Register are within the limits of the PUC Regulations. <input type="checkbox"/> Accuracy tests of the kWh meter are within the limits of the PUC Regulations, but the Demand Register is defective. <input type="checkbox"/> Test results indicate the kWh meter to be defective, but all accuracy tests of the demand register are within the limits of the PUC Regulations. <input type="checkbox"/> Test results indicate that both the kWh Meter and the Demand Register are defective. <input checked="" type="checkbox"/> Test results indicate the AMR module is accumulating energy accurately. <input type="checkbox"/> Test results indicate the AMR module is defective.		
Comments		
Meter tested accurate.		

Please direct any questions you may have on these results to Metering Support at ETN 323-5315.