



Brian Ardire
Director, Corporate Counsel
Pennsylvania-American Water Company
800 West Hersheypark Drive, Hershey, PA 17033
P: 717.531.3362 F: 717.531.3399 C: 717.454.7606
brian.ardire@amwater.com

January 10, 2019

Ms. Rosemary Chiavetta, Secretary
Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

Re: Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

Dear Secretary Chiavetta:

In response to your letter dated December 26, 2018, attached for e-filing are Pennsylvania-American Water Company’s responses to Data Request Set 2, regarding the above referenced docket number.

Sincerely,

Brian A. Ardire

Enclosure

cc: C. McKinley
Tanya McClosky, Office of Small Business Advocate
John Evans, Office of Small Business Advocate
Richard Kanaskie, PUC Bureau of Investigation and Enforcement

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

A-33. Pennsylvania-American Water Company–Wastewater Division’s (PAWC-WD) response to the Bureau of Technical Utility Services (TUS) Data Request Set 1, question A-6, states that a certified contract operator will operate the wastewater treatment plant (WWTP) and be managed by PAWC-WD.

- a. Please describe any efficiencies, cost savings or other advantages this third-party arrangement would provide compared to utilizing a PAWC-WD employee to operate the system.

Response: Since the Turbotville Wastewater Treatment Plant is very small it would not be economical to hire a full time PAW employee to operate this system. Hiring a certified contract operator would be less expensive than hiring a full time employee with benefits. As we acquire more systems in this area or if the work load in this system increases we will re-evaluate to see if hiring our own employee to run multiple systems would be more economical than using a contract operator.

- b. If utilizing a certified contract operator in lieu of a PAWC-WD employee does not provide any efficiencies, cost savings or other advantages, explain why PAWC-WD must utilize this service.

Response: Using a contract operator to operate the Turbotville wastewater system is less expensive than hiring a full time PAW employee with benefits.

- c. Please identify if the \$24,747 shown for Contracted Services on Exhibit P, provided in response to TUS Data Request Set 1, question A-28, is the cost associated with using a certified contract operator to operate the WWTP. If not please estimate a yearly cost for this service.

Response: The \$24,747 identified in Exhibit P is the estimated yearly cost to use a certified contract operator for this system.

Responsible Witness: Joseph F. Woodward
Senior Manager, Central PA Operations

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company--Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville's assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

A-34. TUS Data Request Set 1, question A-9, requested an estimate of the cost PAWC-WD will incur to revise Turbotville Borough's Act 537 Plan. Provide an estimated cost and identify if this cost was included in the five-year capital plan mentioned in response to TUS Data Request Set 1, question A-11.

Response: The work to revise the Act 537 Plan Update is being performed by PAWC personnel. The cost of the Act 537 Plan Update will consist of the cost for the time spent by PAWC personnel, estimated at approximately \$9,600 and is included in the five year capital plan.

Responsible Witness: Michael J. Guntrum
Senior Project Engineer

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

A-35 PAWC-WD’s response to TUS Data Request Set 1, question A-10, states that Turbotville Borough’s recently submitted Act 537 Plan update was submitted and subsequently withdrawn. Please provide evidence of DEP’s acceptance of the withdrawal.

Response: Please see the attached letter from UNI-TEC withdrawing the Borough’s application for a Water Quality Management Part II permit. It is PAWC’s understanding DEP will accept the withdrawal of the Act 537 Plan Update when PAWC’s Act 537 Plan Update is accepted by DEP.

Responsible Witness: Michael J. Guntrum
Senior Project Engineer



October 6, 2017
File No. 0047-043-000

Mr. Jeremiah Northridge, P.E.
PA Department of Environmental Protection
Northcentral Regional Office
208 West Third Street, Suite 101
Williamsport, PA 17701-6448

RE: WQM Part II Permit Application
Turbotville Wastewater Treatment Plant
Borough of Turbotville, Northumberland County

Dear Jere:

On behalf of the Borough of Turbotville, we are requesting to withdraw the Borough's application dated July 28, 2017 for a Water Quality Management Part II Permit for the upgrade of the Turbotville Wastewater Treatment Plant.

Should you have any questions or need additional information, please do not hesitate to contact me by phone or email: maa@uni-tec.com. Thank you for your assistance in this matter.

Sincerely,
UNI-TEC CONSULTING ENGINEERS, INC.

A handwritten signature in black ink that reads "Michele A. Aukerman".

Michele A. Aukerman, P.E.
Project Engineer

cc: Borough of Turbotville (via email)

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

A-36 The copy of Turbotville Borough’s Act 537 Special Study (Special Study) filed in response to TUS Data Request Set 1, question A-10, identifies that the WWTP will be replaced at a cost of \$3,900,000. If DEP does not approve an alternative plan to replacing the WWTP, please identify:

- a. If PAWC-WD is prepared to move forward with the acquisition.
- b. If PAWC-WD is prepared to complete the replacement/upgrades outlined in the Special Study.
- c. If PAWC-WD agrees with the estimated replacement cost quantified in the Special Study.
- d. If PAWC-WD does not agree with the estimated replacement cost identified in the response to TUS Data Request Set 1, question Data Request A-10, please quantify PAWC-WD’s estimate to replace the WWTP as outlined in the Special Study identified above.

Response: As per Paragraph 6.1 (f) of the Asset Purchase Agreement, PAWC has the right, in its sole and absolute discretion, to terminate the Agreement if DEP shall impose or require any changes to the PAWC’s amended Act 537 Plan. PAWC will make a determination whether to exercise this right of termination once DEP’s final determination of PAWC’s Act 537 Plan Update is known.

Responsible Witness: Michael J. Guntrum
Senior Project Engineer

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

A-37 Please verify that Turbotville Borough’s WWTP is not currently receiving flow or connected to any properties in Lewis Township.

Response: Please see attached letter from Turbotville Borough regarding customers in Lewis Township.

Responsible Witness: Michael J. Guntrum
Senior Project Engineer

Turbotville Borough

267 Broadway Street, PO Box 264 Turbotville, PA 17772
Ph. 570-649-5476 Fax 570-649-6620
turbotville5476@windstream.net

January 4, 2019

To whom it may concern,

This letter is confirm the Turbotville Borough WWTP does not receive any flow from or have any connections from Lewis Township.

Sincerely,



Francis P. Betz
Council President
Turbotville Borough

Bureau of Technical Utility Services
Water/Wastewater Division
Data Request Set 2

Application of Pennsylvania-American Water Company–Wastewater Division for approval of the transfer, by sale, of substantially all the Borough of Turbotville’s assets, properties and rights related to its wastewater collection and treatment system to Pennsylvania-American Water Company at Docket No. A-2018-3004189

A-38. Please identify whether or not Turbotville Borough’s WWTP has been able to meet the effluent limitations that went into effect June 1, 2018, as identified in NPDES Permit No. PA0028100.

Response: Please see the attached Electronic Discharge Monitoring Report (eDMR) for the Turbotville WWTP for June 2018 through November 2018. According to the eDMR data, the Turbotville WWTP had exceedances for CBOD5 and Fecal Coliform in its July 2018 eDMR report and 4 exceedances for ammonia nitrogen in their August 2018 eDMR report. PAWC anticipates once the recommended alternative in PAWC’s Update to the Act 537 Plan is implemented the Turbotville WWTP will be able to meet its permitted effluent limits.

Responsible Witness: Michael J. Guntrum
Senior Project Engineer



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

Region: All
County: All
Municipality: 49929 - Turbotville Boro
Permit #: All
Monitoring Period Date Range: 6/1/2018 To 12/1/2018
Client: All
Parameter: All

| | | | |
|-----------------------------|--|-----------------------|---|
| Permit #: | PA0028100 | Facility Address: | TURBOTVILLE WWTP 2 ADAM ST TURBOTVILLE, PA 17772-9069 |
| Client ID / Name: | 80193 - TURBOTVILLE BORO NORTHUMBERLAND CNTY | County: | Northumberland |
| Primary Facility ID / Name: | 256655 - TURBOTVILLE WWTP | Municipality: | Turbotville Boro |
| Major Facility: | No | Latitude / Longitude: | 41.106389 / -76.771944 |
| Region: | NCRO | | |

| Monitoring Period Begin Date | Monitoring Period End Date | DMR Received Date | Outfall | Discharge | Monitoring Location | Parameter Name | Parameter Code | DMR Value | Permit Limit | Units | Statistical Base Code |
|------------------------------|----------------------------|-------------------|---------|-----------|---------------------|--|----------------|-----------|--------------|---------|-----------------------|
| 06/01/2018 | 06/30/2018 | 07/16/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen | 00610 | < 1.0 | 3.5 | mg/L | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | < 0.2 | 4.0 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 1.0 | 5.0 | mg/L | Weekly Average |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 0.3 | 5.5 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 2 | 13 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 5 | 12 | mg/L | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 10 | 18 | mg/L | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 4 | 20 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.002 | 0.04 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.002 | 0.08 | lbs/day | Daily Maximum |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|----------------------------------|-------|--------|--------------------|------------|-----------------------|
| 06/01/2018 | 06/30/2018 | 07/16/2018 | 001 | Yes | Final Effluent | Dissolved Oxygen | 00300 | 3.2 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 4 | 200 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 12 | 1000 | CFU/100 ml | Instantaneous Maximum |
| | | | | | Final Effluent | Flow | 50050 | 0.043 | Monitor and Report | MGD | Average Monthly |
| | | | | | Final Effluent | Flow | 50050 | 0.096 | Monitor and Report | MGD | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.02 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.02 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.4 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.0 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.14 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.04 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.25 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.09 | 2.96 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.26 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.56 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 1 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 5 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 2 | 34 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 5 | 30 | mg/L | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 171 | Monitor and Report | mg/L | Average Monthly |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|----------------|------------|------------|-------|--------------------|---------------------|--|-------|----------|--------------------|------------|-----------------------|
| 06/01/2018 | 06/30/2018 | 07/16/2018 | 001 | Yes | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 47 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 57 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 49 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 178 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 65 | Monitor and Report | lbs/day | Daily Maximum |
| 07/01/2018 | 07/31/2018 | 08/23/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 3.5 | mg/L | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 1.0 | 4.0 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 5.5 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 3.0 | 5.0 | mg/L | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 6 | 13 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 5 | 12 | mg/L | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 22 | 20 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 8 | 18 | mg/L | Weekly Average |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.0009 | 0.04 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.0009 | 0.08 | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Dissolved Oxygen | 00300 | 3.2 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | < 7 | 200 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | > 2420 | 1000 | CFU/100 ml | Instantaneous Maximum |
| Final Effluent | Flow | 50050 | 0.085 | Monitor and Report | MGD | Average Monthly | | | | | |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| 07/01/2018 | 07/31/2018 | 08/23/2018 | 001 | Yes | Final Effluent | Flow | 50050 | 0.33 | Monitor and Report | MGD | Daily Maximum |
|------------|------------|------------|-----|-----|---------------------|----------------------------------|-------|---------|--------------------|---------|-----------------------|
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.009 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.009 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.3 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.0 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.158 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.30 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.455 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 1.00 | 2.96 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.28 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.70 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 6 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 8 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 10 | 30 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 27 | 34 | lbs/day | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 139 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 61 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 115 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 45 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 89 | Monitor and Report | mg/L | Average Monthly |

**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|--|-------|---------|--------------------|------------|-----------------------|
| 07/01/2018 | 07/31/2018 | 08/23/2018 | 001 | Yes | Raw Sewage Influent | Total Suspended Solids | 00530 | 100 | Monitor and Report | lbs/day | Daily Maximum |
| 08/01/2018 | 08/31/2018 | 09/24/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen | 00610 | 4.0 | 3.5 | mg/L | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 5.0 | 4.0 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 6.0 | 5.0 | mg/L | Weekly Average |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 9.0 | 5.5 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 6 | 12 | mg/L | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 7 | 13 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 10 | 18 | mg/L | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 16 | 20 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 0.04 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 0.08 | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Dissolved Oxygen | 00300 | 3.1 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | < 2 | 200 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 14 | 1000 | CFU/100 ml | Instantaneous Maximum |
| | | | | | Final Effluent | Flow | 50050 | 0.121 | Monitor and Report | MGD | Average Monthly |
| | | | | | Final Effluent | Flow | 50050 | 0.309 | Monitor and Report | MGD | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | lbs/day | Daily Maximum |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|----------------------------------|-------|--------|--------------------|---------|-----------------------|
| 08/01/2018 | 08/31/2018 | 09/24/2018 | 001 | Yes | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.4 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.0 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.267 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | < 0.40 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.757 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 1.00 | 2.96 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.24 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.87 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 8 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 7 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 21 | 34 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 13 | 30 | mg/L | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 66 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 50 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 84 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 60 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 77 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 95 | Monitor and Report | lbs/day | Daily Maximum |
| 09/01/2018 | 09/30/2018 | 10/16/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 3.5 | mg/L | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 4.0 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 5.5 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 3.0 | 5.0 | mg/L | Weekly Average |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| 09/01/2018 | 09/30/2018 | 10/16/2018 | 001 | Yes | | | | | | | |
|------------|------------|------------|-----|-----|----------------|--|-------|---------|--------------------|------------|-----------------------|
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 6 | 13 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 5 | 12 | mg/L | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 12 | 20 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 8 | 18 | mg/L | Weekly Average |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.002 | 0.04 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.002 | 0.08 | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Dissolved Oxygen | 00300 | 2.6 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | < 3 | 200 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 5 | 1000 | CFU/100 ml | Instantaneous Maximum |
| | | | | | Final Effluent | Flow | 50050 | 0.128 | Monitor and Report | MGD | Average Monthly |
| | | | | | Final Effluent | Flow | 50050 | 0.263 | Monitor and Report | MGD | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.02 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.02 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.4 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.0 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.50 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.422 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 2.00 | 2.96 | lbs/day | Weekly Average |

**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|----------------|--|------------|---------|------|---------------------|----------------------------------|------------|------|--------------------|----------------|-----------------------|
| 09/01/2018 | 09/30/2018 | 10/16/2018 | 001 | Yes | Final Effluent | Total Phosphorus | 00665 | 1.06 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.29 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.80 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 5 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 5 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 5 | 30 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 7 | 34 | lbs/day | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 42 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 60 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 63 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 53 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 39 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 52 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | 10/01/2018 | 10/31/2018 | 11/17/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen |
| Final Effluent | Ammonia-Nitrogen | 00610 | < 0.5 | 4.0 | | | | | | lbs/day | Average Monthly |
| Final Effluent | Ammonia-Nitrogen | 00610 | 0.9 | 5.5 | | | | | | lbs/day | Weekly Average |
| Final Effluent | Ammonia-Nitrogen | 00610 | 1.0 | 5.0 | | | | | | mg/L | Weekly Average |
| Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 2 | 13 | | | | | | lbs/day | Average Monthly |
| Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 3 | 12 | | | | | | mg/L | Average Monthly |
| Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 3 | 18 | | | | | | mg/L | Weekly Average |
| Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 2 | 20 | | | | | | lbs/day | Weekly Average |
| Final Effluent | Copper, Total | 01042 | < 0.004 | 0.04 | | | | | | lbs/day | Average Monthly |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|----------------|-------------------------------|-------|---------|--------------------|------------|-----------------------|
| 10/01/2018 | 10/31/2018 | 11/17/2018 | 001 | Yes | Final Effluent | Copper, Total | 01042 | < 0.005 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.004 | 0.08 | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | < 0.005 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Dissolved Oxygen | 00300 | 3.1 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | < 1 | 2000 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 2 | 10000 | CFU/100 ml | Instantaneous Maximum |
| | | | | | Final Effluent | Flow | 50050 | 0.08 | Monitor and Report | MGD | Average Monthly |
| | | | | | Final Effluent | Flow | 50050 | 0.212 | Monitor and Report | MGD | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.04 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.04 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.4 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.2 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.20 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.288 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.472 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.30 | 2.96 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.29 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.59 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 3 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 5 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 5 | 30 | mg/L | Weekly Average |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|--|-------|--------|--------------------|------------|-----------------------|
| 10/01/2018 | 10/31/2018 | 11/17/2018 | 001 | Yes | Final Effluent | Total Suspended Solids | 00530 | < 4 | 34 | lbs/day | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 144 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 84 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 140 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 123 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 69 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 135 | Monitor and Report | lbs/day | Daily Maximum |
| 11/01/2018 | 11/30/2018 | 12/13/2018 | 001 | Yes | Final Effluent | Ammonia-Nitrogen | 00610 | 3.0 | 11.5 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 10.5 | mg/L | Average Monthly |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 4.0 | 17 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Ammonia-Nitrogen | 00610 | 2.0 | 15.0 | mg/L | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 4 | 12 | mg/L | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | < 5 | 13 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 5 | 18 | mg/L | Weekly Average |
| | | | | | Final Effluent | Carbonaceous Biochemical Oxygen Demand (CBOD5) | 80082 | 7 | 20 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Copper, Total | 01042 | 0.006 | 0.04 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | 0.0056 | 36.31 | ug/L | Average Monthly |
| | | | | | Final Effluent | Copper, Total | 01042 | 0.006 | 0.08 | lbs/day | Daily Maximum |
| | | | | | Final Effluent | Copper, Total | 01042 | 0.0056 | 72.62 | ug/L | Daily Maximum |
| | | | | | Final Effluent | Dissolved Oxygen | 00300 | 3.1 | Monitor and Report | mg/L | Minimum |
| | | | | | Final Effluent | Fecal Coliform | 74055 | < 2 | 2000 | CFU/100 ml | Geometric Mean |
| | | | | | Final Effluent | Fecal Coliform | 74055 | 4 | 10000 | CFU/100 ml | Instantaneous Maximum |



**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|----------------------------------|-------|--------|--------------------|---------|-----------------------|
| 11/01/2018 | 11/30/2018 | 12/13/2018 | 001 | Yes | Final Effluent | Flow | 50050 | 0.15 | Monitor and Report | MGD | Average Monthly |
| | | | | | Final Effluent | Flow | 50050 | 0.23 | Monitor and Report | MGD | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | 0.06 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.05 | Monitor and Report | mg/L | Daily Maximum |
| | | | | | Final Effluent | Lead, Total | 01051 | < 0.06 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.4 | 9.0 | S.U. | Maximum |
| | | | | | Final Effluent | pH | 00400 | 7.1 | 6.0 | S.U. | Minimum |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.45 | 2.60 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.60 | 2.96 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 1.00 | 2.96 | lbs/day | Weekly Average |
| | | | | | Final Effluent | Total Phosphorus | 00665 | 0.67 | 2.60 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.27 | 0.45 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Residual Chlorine (TRC) | 50060 | 0.72 | 1.48 | mg/L | Instantaneous Maximum |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 7 | 30 | mg/L | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | < 9 | 34 | lbs/day | Average Monthly |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 9 | 30 | mg/L | Weekly Average |
| | | | | | Final Effluent | Total Suspended Solids | 00530 | 14 | 34 | lbs/day | Weekly Average |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 61 | Monitor and Report | lbs/day | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 45 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Biochemical Oxygen Demand (BOD5) | 00310 | 75 | Monitor and Report | lbs/day | Daily Maximum |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 39 | Monitor and Report | lbs/day | Average Monthly |




**National Pollutant Discharge Elimination System (NPDES)
Electronic Discharge Monitoring Report (eDMR)**

1/8/2019 10:07:14 AM

| | | | | | | | | | | | |
|------------|------------|------------|-----|-----|---------------------|------------------------|-------|----|--------------------|---------|-----------------|
| 11/01/2018 | 11/30/2018 | 12/13/2018 | 001 | Yes | Raw Sewage Influent | Total Suspended Solids | 00530 | 30 | Monitor and Report | mg/L | Average Monthly |
| | | | | | Raw Sewage Influent | Total Suspended Solids | 00530 | 42 | Monitor and Report | lbs/day | Daily Maximum |

VERIFICATION

I, JOSEPH F. WOODWARD, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements made herein are made subject to the penalties of 18 Pa. Cons. Stat. § 4904 (relating to unsworn falsification to authorities).



Joseph F. Woodward
Senior Manager - Operations

Date: 1-7-19_____

VERIFICATION

I, MICHAEL J. GUNTRUM, hereby state that the facts above set forth above are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements made herein are made subject to the penalties of 18 Pa. Cons. Stat. §4904 relating to unsworn falsification to authorities.



Michael J. Guntrum, P.E., PMP
Senior Project Engineer

Dated: 1-10-2019