



January 16, 2019

VIA E-FILE

Jonathan P. Nase

Direct Phone 717-773-4191

Direct Fax 215-372-2340

jnase@cozen.com

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor – Filing Room
Harrisburg, PA 17120

**Re: TANYA J. MCCLOSKEY, ACTING CONSUMER ADVOCATE V. HIDDEN VALLEY
UTILITY SERVICES, L.P. – WATER, DOCKET NO. C-2014-2447138**

**TANYA J. MCCLOSKEY, ACTING CONSUMER ADVOCATE V. HIDDEN VALLEY
UTILITY SERVICES, L.P. – WASTEWATER, DOCKET NO. C-2014-2447169**

**HIDDEN VALLEY UTILITY SERVICES, L.P. – STATUS REPORT ON COMPLIANCE
WITH ORDER ENTERED JANUARY 18, 2018 AND RECONSIDERED MAY 3, 2018**

Dear Secretary Chiavetta:

Enclosed for filing with the Pennsylvania Public Utility Commission is the 60-day status report required by Ordering Paragraph No. 17 of the Commission's Order in the above-referenced matters.

All parties to this proceeding are being served as shown on the attached Certificate of Service.

Please contact me if you have any questions regarding this filing. Thank you.

Sincerely,

COZEN O'CONNOR

By: Jonathan P. Nase

Counsel for *Hidden Valley Utility Services, L.P.*

JPN:kmg

Enclosures

cc: Per Certificate of Service
Allison Kaster, Esq.
James Kettler

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Tanya J. McCloskey, Acting Consumer Advocate	:	
	:	
	:	Docket No. C-2014-2447138
v.	:	
	:	
Hidden Valley Utility Services, L.P. – Water	:	
	:	
and	:	
	:	
Tanya J. McCloskey, Acting Consumer Advocate	:	
	:	
	:	Docket No. C-2014-2447169
v.	:	
	:	
Hidden Valley Utility Services, L.P. – Wastewater	:	

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true copy of the foregoing **January 2019 Status Report** upon the parties, listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a party).

VIA E-MAIL AND FIRST CLASS MAIL:


Christine Maloni Hoover, Esq.
Erin L. Gannon, Esq.
Lauren M. Burge, Esq.
Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101-1923
Counsel for *Office of Consumer Advocate*

Hon. Jeffrey A. Watson
Pennsylvania Public Utility Commission
Piatt Place, Suite 220
301 5th Avenue
Pittsburgh, PA 15222

Robert J. Kollar, CPA and
Kellie A. Kuhleman
1374 Langport Dr.
Pittsburgh, PA 15241

Paige MacDonald-Matthes, Esq.
Obermayer Rebmann Maxwell & Hippel
200 Locust Street, Suite 400
Harrisburg, PA 17101-1508
Counsel for *Hidden Valley Foundation, Inc.*

DATED: January 16, 2019



Jonathan P. Nase, Esquire
Counsel for *Hidden Valley Utility Services, L.P.*

**Hidden Valley Utility Services, L.P (“HVUS”) Compliance Timeline
per May 3, 2018 PUC Order on Reconsideration in
Docket Nos. C-2014-2447138 and C-2014-2447169**

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
1-19-18	HVUS will pay all electric and telephone bills timely and execute forms authorizing Penelec to provide monthly billing and payment information for HVUS accounts to the OCA	15.	HVUS is paying all electric and telephone bills timely. On May 9, 2018, HVUS authorized Penelec to provide monthly billing and payment information for HVUS account to the OCA
1-19-18	HVUS will have a spare pump and motor available for Well No. 1 within 72 hours of the primary pump and motor becoming inoperable	22.	HVUS has confirmed with its supplier that pumps and motors necessary for well #1 can be available within 72 hours of notice.
1-19-18	HVUS will maintain an operable, installed second high lift pump	24.	The second high lift pump is installed and operational. The pump was installed in Dec. 2014, and a new electric check valve was installed in February 2015. Therefore, the second high lift pump has been operational since February 2015.
1-19-18	HVUS will provide annual update of telephone service numbers, including copies of bills, so that customers can reliably contact HVUS	15.	Customer bills include the following working telephone numbers for HVUS: (814) 443-0825 (877) 523-8181. In addition, in April, 2018, HVUS obtained the following toll-free number, which was listed in the customer notice of its rate

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
			increase in R-2018-3001306 and R-2018-3001307: (833) HVUS800 HVUS provided a copy of the phone bills from the last year to verify compliance
3-19-18	HVUS will consult with OCA re modifications to its consumer bills	12.	A new invoice format was sent to the OCA 3-15-18. The OCA made recommendations, which were adopted by HVUS.
3-19-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	17.	HVUS attempted to file on March 19, 2018, but used the wrong docket numbers. The status report was re-filed on April 11, 2018.
4-18-18	HVUS will file with the Commission a report from an engineer regarding its water system, including a schedule to replace/test customer meters to obtain compliance by April 30, 2019. Copies are to be provided to TUS and OCA within 14 days of receipt. If the means to address iron and manganese is treatment of water from Wells 1 and 2, HVUS will install instrumentation to control the on/off cycle of Well 2 ¹ .	6, 7 and 23	The report was filed with the Commission on April 18, 2018. A copy was provided to TUS and OCA that same day. Meter testing and replacement is on-going. HVUS is working with the engineers on 2 options to address iron and manganese treatment. HVUS has also met with local officials and the Pennsylvania Department of Environmental Protection regarding the options to address iron and manganese in the water.
4-18-18	HVUS will file with the Commission a report from an engineer regarding its wastewater	9. and 10.	The report was filed with the Commission on April 18, 2018. A copy was provided to TUS

¹ The Commission’s Order is unclear when HVUS is required to install the instrumentation. At this time, HVUS is meeting with engineers regarding options to address the iron and manganese in the water.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
	system. Copies are to be provided to TUS and OCA within 14 days.		and OCA that same day. HVUS is working on the items on the engineers report.
4-18-18	HVUS will modify its billing practices to ensure that all bills are compliant with Commission rules, regulations and orders. A copy of the revised bill form is to be submitted to the PUC for review by BCS and TUS.	12. and 13.	A revised bill was submitted to BCS and TUS on April 18, 2018. On April 24, 2018, BCS provided recommendations, which HVUS has agreed to implement. HVUS notified the OCA of BCS’s recommendations and HVUS’s agreement to implement them. HVUS used a modified billing format starting with the 3 rd Quarter billing cycle of 2018 and is in the process of further modifying its bill format for the 2 nd Quarter billing cycle of 2019.
4-18-18	HVUS will modify practices to comply with its tariff, the Code, the Commission’s regulations and orders	16.	To the knowledge and belief of HVUS, HVUS is in compliance with the Code, the Commission’s regulations and orders. Nevertheless, HVUS is constantly reviewing its practices to ensure compliance with the Code, the Commission’s regulations and orders.
5-18-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	17.	The Status Report was filed with the Commission on May 18, 2018
6-30-18	HVUS will replace 1,500 feet of 3-inch line to the Heights and 1,000 feet of 2-inch line to Valley View	5.a.	The line to the Heights was completed approximately June 8, 2016. A 6” diameter pipe to Valley View was installed by October 20, 2016. In addition, a loop was constructed

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
			at Lake Road, which was completed by November 14, 2016.
6-30-18	HVUS will begin conducting semi-annual customer meetings	5.b.	A customer meeting was held on May 19, 2018 with approximately 125 customers in attendance. Representatives from the OCA were present at the meeting.
7-17-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	17.	HVUS filed this Status Report on July 17, 2018
7-17-18	HVUS will amend any prior reports to the PUC containing incorrect information and ensure that it is filing reports with correct information	14.	HVUS submitted revised annual PUC reports to the Commission on July 17, 2018.
9-17-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	17.	HVUS filed this Status Report on September 17, 2018.
11-16-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	17.	HVUS filed this Status Report on November 16, 2018.
12-31-18	HVUS will conduct another semi-annual customer meeting	5.b.	HVUS conducted a semi-annual customer meeting on December 22, 2018.
12-31-18	HVUS will conduct a pressure survey in compliance with 52 Pa. Code § 65.6(d). HVUS	22.	HVUS conducted a pressure survey in May, 2018 and another pressure survey in December, 2018 (see attached). Based on

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
	shall install booster pumping stations if pressure is inadequate		those results, HVUS will not install booster pumping stations.
1-16-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order	5.b.	This document is the January 16, 2019 Status Report.
1-31-19	HVUS will comply with all recommendations in the engineer’s wastewater report	11.	
1-31-19 (or when all repairs required by the order have been made)	HVUS will file a final status report with copies to the OCA and TUS	19.	
March 31, 2019 or 60 days after the final status report	TUS will investigate the water quality and the water and wastewater services being provided by HVUS. If the repairs have not been made or the water quality is inadequate, OALJ will hold an evidentiary hearing in which the burden of proof will be on HVUS	20.	
4-16-19	Within 1 year of the date of the engineer’s report, HVUS will comply with all recommendations in the engineer’s water report	8.	
TBD	When HVUS complies with all ordering paragraphs, the Secretary’s Bureau will close the complaint proceedings	27	
6-30-19	HVUS will conduct another customer meeting	5.b.	
12-31-19	HVUS will conduct another customer meeting	5.b.	
12-31-19	HVUS will conduct a pressure survey in compliance with 52 Pa. Code § 65.6(d). HVUS	22.	

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
	shall install booster pumping stations if pressure is inadequate		

HIDDEN VALLEY UTILITY SERVICES L.P.
 FIRE HYDRANT LOG AND SYTEM PRESSURE SURVEY
 May 14, 2018

HYDRANT #	LOCATION	MAKE	MODEL	SIZE	MFG. YEAR	PRESSURE	MISC.	FLOW	COMMENTS
F1	LAKE ROAD @ LOT 14	AM. DARLING	B-50-B	4 1/2	1983	HP	40 HP AA		
F2	LAKE ROAD @ LOT 3	AM. DARLING	B-50-B	4 1/4	1983	HP	40 HP AA		
F3	4 SEASONS CONDOS	AM. DARLING				230			
F4	CONFERENCE CENTER	AM. DARLING				230			rebut 5/2009 seat leaking
F5	SKI LODGE	AM. DARLING	B-62-B	5 1/4	1983	60	54F GAA		
F6	IMPERIAL ROAD BOTTOM	AM. DARLING	B-62-B	5 1/4	1984	136	54F GAA		
F7	IMPERIAL ROAD @ PRS	AM. DARLING	B-62-B	5 1/4	1983	98	54F GAA		
F8	IMPERIAL ROAD TOP	AM. DARLING	B-62-B-1	5 1/4	1992	83	54F GAA		
F9	RIDGEVIEW ROAD	AM. DARLING	B-62-B	5 1/4	1983	60	54F GAA		76 psi static
F10	NORTH SUMMIT 30 UNIT	AM. DARLING	B-84-B	5 1/4	1988	65	85F GAA	1200 gpm	3-16-11 test
F11	NORTH SUMMIT VILLAS	AM. DARLING	B-62-B	5 1/4	1992	66	54F GAA		75 psi / 52 psi @ flow 3-16-11 tes
F12	GOLF COURSE	AM. DARLING	B-62-B-1	5 1/4	1988	80	54F GAA		
F13	ALPINE WOODS	AM. DARLING	B-62-B	5 1/4	1984	74	54F GAA		
F14	SADDLER WAY/GARDNER RD.	AM. DARLING	B-62-B	5 1/4	1984	66	54F GAA		
F15	GEBHART WAY	AM. DARLING	B-62-B	5 1/4	1983	50	54F GAA		
F16	KEPPLE/GRISTMILL	AM. DARLING	B-62-B	5 1/4	1984	44	54F GAA		
F17	TAILOR WAY	AM. DARLING	B-62-B	5 1/4	1983	38	54F GAA		
F18	WESTVIEW DRIVE	AM. DARLING	B-62-B-1	5 1/4	2001	58	54F GAA		
F19	WESTRIDGE DRIVE @ BLDG. 2	AM. DARLING	B-62-B	5 1/4	1983	44	54F GAA		
F20	WESTRIDGE DRIVE @ BLDG. 4	AM. DARLING	B-62-B-1	5 1/4	2003	54	54F GAA		
F21	TIMBERCREST/HIGHTOP DR.	AM. DARLING	B-82-B	5 1/4	1984	30	54F GAA		
F22	SNOWFIELD DRIVE @ 1565	AM. DARLING	B-62-B-1	5 1/4	1986	30	54F GAA		
F23	SNOWFIELD RUN	AM. DARLING	B-84-B	5 1/4	1987	38	85F GAA		
F24	SNOWFIELD DRIVE @ 1731	AM. DARLING	B-84-B	5 1/4	1987	24	85F GAA		
F25	SNOWFIELD DR./HIGHTOP DR.	AM. DARLING	B-84-B			24			
F26	HIGHTOP DRIVE	AM. DARLING	B-82-B-1	5 1/4	1988	55	54F GAA		
F27	GREENFIELD DRIVE	AM. DARLING				80			
F28	SOUTH RIDGE DR./COURT	AM. DARLING				34			
F29	EAGLES RIDGE WAY	AM. DARLING				34			rebut 7/2010 hit by plow
F30	EAGLES RIDGE COURT	AM. DARLING				42			
F31	SOUTH RIDGE DR./WAY	AM. DARLING				45			
F32	SOUTH RIDGE DR./PINES	AM. DARLING				52			
F33	SOUTHRIDGE DR./DUMPSTER	AM. DARLING				55			
F34	SOUTHRIDGE DR./EDDY	AM. DARLING				70			
F35	SOUTHRIDGE DR./BARNIACK	AM. DARLING				70			
F36	SOUTHRIDGE DR./BURGER	AM. DARLING				60			
F37	SOUTHRIDGE WAY/PINES	AM. DARLING				55			
F38	LAKEVIEW	MUELLER	584 N	5 1/4	2006	56			
F39	SKIERS SERVICES BLDG.	KENNEDY				HP	HP		

F40	SKI MAINT. FACILITY	KENNEDY	K-81-D		2008	HP	250 CWP		
F41	GREENTEE TERRACE	AM. DARLING				95			Installed 1/6/11
F42	GARDNER RD/PARKE DR.	AM. DARLING							Installed 5/3/16
F43	GARDNER RD @ HEIGHTS	AM. DARLING							Installed 6/1/16
F44	VALLEYVIEW	AM. DARLING				80			Installed 10/18/16

HIDDEN VALLEY UTILITY SERVICES L.P.
FIRE HYDRANT LOG AND SYTEM PRESSURE SURVEY
May 14, 2018

PRV 4 Seasons Condos	50	Out pressure	245	In pressure
PRV Imperial	58	Out pressure	102	In pressure
PRV Ski Lodge	65	Out pressure	235	In pressure
PRV 6" Beginners Slope	145	Out pressure	230	In pressure
PRV Westview	40	Out pressure	90	In pressure
Gardner Road	45	Out pressure	75	In pressure

HIDDEN VALLEY UTILITY SERVICES L.P.
 FIRE HYDRANT LOG AND SYTEM PRESSURE SURVEY
 December 12, 2018

HYDRANT #	LOCATION	MAKE	MODEL	SIZE	MFG. YEAR	PRESSURE	MISC.	FLOW	COMMENTS
F1	LAKE ROAD @ LOT 14	AM. DARLING	B-50-B	4 1/2	1983	HP	40 HP AA		
F2	LAKE ROAD @ LOT 3	AM. DARLING	B-50-B	4 1/4	1983	230	40 HP AA		
F3	4 SEASONS CONDOS	AM. DARLING				230			
F4	CONFERENCE CENTER	AM. DARLING				230			rebuil 5/2009 seat leaking
F5	SKI LODGE	AM. DARLING	B-62-B	5 1/4	1983	66	54F GAA		
F6	IMPERIAL ROAD BOTTOM	AM. DARLING	B-62-B	5 1/4	1984	140	54F GAA		
F7	IMPERIAL ROAD @ PRS	AM. DARLING	B-62-B	5 1/4	1983	100	54F GAA		
F8	IMPERIAL ROAD TOP	AM. DARLING	B-62-B-1	5 1/4	1992	84	54F GAA		
F9	RIDGEVIEW ROAD	AM. DARLING	B-62-B	5 1/4	1983	60	54F GAA		76 psi static
F10	NORTH SUMMIT 30 UNIT	AM. DARLING	B-84-B	5 1/4	1988	65	85F GAA	1200 gpm	3-16-11 test
F11	NORTH SUMMIT VILLAS	AM. DARLING	B-62-B	5 1/4	1992	68	54F GAA		75 psi / 52 psi @ flow 3-16-11 tes
F12	GOLF COURSE	AM. DARLING	B-62-B-1	5 1/4	1988	80	54F GAA		
F13	ALPINE WOODS	AM. DARLING	B-62-B	5 1/4	1984	72	54F GAA		
F14	SADDLER WAY/GARDNER RD.	AM. DARLING	B-62-B	5 1/4	1984	64	54F GAA		
F15	GEBHART WAY	AM. DARLING	B-62-B	5 1/4	1983	46	54F GAA		
F16	KEPPLE/GRISTMILL	AM. DARLING	B-62-B	5 1/4	1984	42	54F GAA		
F17	TAILOR WAY	AM. DARLING	B-62-B	5 1/4	1983	38	54F GAA		
F18	WESTVIEW DRIVE	AM. DARLING	B-62-B-1	5 1/4	2001	60	54F GAA		
F19	WESTRIDGE DRIVE @ BLDG. 2	AM. DARLING	B-62-B	5 1/4	1983	44	54F GAA		
F20	WESTRIDGE DRIVE @ BLDG. 4	AM. DARLING	B-62-B-1	5 1/4	2003	52	54F GAA		
F21	TIMBERCREST/HIGHTOP DR.	AM. DARLING	B-82-B	5 1/4	1984	32	54F GAA		
F22	SNOWFIELD DRIVE @ 1565	AM. DARLING	B-62-B-1	5 1/4	1986	34	54F GAA		
F23	SNOWFIELD RUN	AM. DARLING	B-84-B	5 1/4	1987	38	85F GAA		
F24	SNOWFIELD DRIVE @ 1731	AM. DARLING	B-84-B	5 1/4	1987	26	85F GAA		
F25	SNOWFIELD DR./HIGHTOP DR.	AM. DARLING	B-84-B			28			rebuil 6/4/18 seat leaking
F26	HIGHTOP DRIVE	AM. DARLING	B-82-B-1	5 1/4	1988	54	54F GAA		
F27	GREENFIELD DRIVE	AM. DARLING				80			
F28	SOUTH RIDGE DR./COURT	AM. DARLING				36			
F29	EAGLES RIDGE WAY	AM. DARLING				34			rebuil 7/2010 hit by plow
F30	EAGLES RIDGE COURT	AM. DARLING				42			
F31	SOUTH RIDGE DR./WAY	AM. DARLING				46			
F32	SOUTH RIDGE DR./PINES	AM. DARLING				52			
F33	SOUTHRIDGE DR./DUMPSTER	AM. DARLING				56			
F34	SOUTHRIDGE DR./ EDDY	AM. DARLING				70			
F35	SOUTHRIDGE DR./ BARNIACK	AM. DARLING				70			
F36	SOUTHRIDGE DR./ BURGER	AM. DARLING				64			
F37	SOUTHRIDGE WAY/ PINES	AM. DARLING				58			
F38	LAKEVIEW	MUELLER	584 N	5 1/4	2006	56			
F39	SKIER SERVICES BLDG.	KENNEDY				HP	HP		

F40	SKI MAINT. FACILITY	KENNEDY	K-81-D		2008	HP	250 CWP		
F41	GREENTEE TERRACE	AM. DARLING				98			Installed 1/6/11
F42	GARDNER RD/PARKE DR.	AM. DARLING				64			Installed 5/3/16
F43	GARDNER RD @ HEIGHTS	AM. DARLING				68			Installed 6/1/16
F44	VALLEYVIEW	AM. DARLING				80			Installed 10/18/16

HIDDEN VALLEY UTILITY SERVICES L.P.
FIRE HYDRANT LOG AND SYSTEM PRESSURE SURVEY
December 12, 2018

PRV 4 Seasons Condos	52	Out pressure	245	In pressure
PRV Imperial	36	Out pressure	102	In pressure
PRV Ski Lodge	68	Out pressure	235	In pressure
PRV 6" Beginners Slope	140	Out pressure	230	In pressure
PRV Westview	38	Out pressure	90	In pressure