

Elizabeth Rose Triscari

Director, Corporate Counsel

Pennsylvania-American Water Company

852 Wesley Drive, Mechanicsburg, PA 17055

P: 717.550.1574 F: 717.550.1255 C: 717.585.1934

elizabeth.triscari@amwater.com

April 5, 2019

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17105-3265

In Re: Application of Pennsylvania-American Water Company for approval of the right to offer, render, furnish or supply wastewater service in an additional portion of Highland Township, Chester County, Pennsylvania – Docket No. A-2019-3008055

Dear Secretary Chiavetta:

In response to the informal data request made by the Bureau of Technical Utility Services (“TUS”) on March 20, 2019, Pennsylvania-American Water Company responds as follows:

Informal Data Request: TUS would like for PAWC to submit additional information to our Secretary’s Bureau at Docket No. A-2019-3008055 clarifying the material types the existing 8” sewer main and the proposed 6” lateral.

Amended Response All materials used in the existing 8” sewer main and the proposed 6” lateral are PVC pipe.

Responsible Witness: James P. Kelly, Sr. Supervisor – Operations (Coatesville)

Sincerely,




Elizabeth Rose Triscari

cc: Paul Zander

VERIFICATION

I, JAMES P. KELLY, hereby state that the facts above set forth above are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements made herein are made subject to the penalties of 18 Pa. Cons. Stat. §4904 relating to unsworn falsification to authorities.


James P. Kelly, Senior Supervisor

Dated: 4-4-19