



Emily M. Farah
Counsel, Regulatory

411 Seventh Avenue
Mail drop 15-7
Pittsburgh, PA 15219

Tel: 412-393-6431
efarah@duqlight.com

April 10, 2019

VIA ELECTRONIC FILING


Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building, 2nd Floor
400 North Street
Harrisburg, PA 17120

Re: Municipal Contract - Right of Way Agreement between Duquesne Light Company and
the Township of O'Hara
Docket No. U-2019-_____

Dear Secretary Chiavetta:

Enclosed for review and approval in accordance with Section 507 of the Public Utility Code, 66 Pa.C.S. § 507 and 52 Pa. Code § 3.101, is a Right of Way agreement dated April 2, 2019 between Duquesne Light Company and the Township of O'Hara. The Township of O'Hara granted to Duquesne Light Company a right of way on its property situated on SR 1013 also known as Saxonburg Boulevard in the Township of O'Hara, Allegheny County, which provides the right to erect, install, use, own, operate, maintain, repair, renew and remove an electrical line. No compensation was provided to the Township of O'Hara.

Should you have any questions regarding the enclosed right of way, please contact Dan Antosik at 412-393-8628

Respectfully Submitted,

Emily M. Farah
Attorney ID#322559

Enclosures

POLECORP. 02/01
474681

DUQUESNE LIGHT CO. COPY

RIGHT OF WAY AGREEMENT

The undersigned Grantor, **THE TOWNSHIP OF O'HARA**, a political subdivision of the Commonwealth of Pennsylvania, for good and valuable consideration, the receipt of which is hereby acknowledged, does hereby grant unto Duquesne Light Company, its successors and assigns, for providing, transmitting and/or distributing electric and/or communications services for any and all purposes, the right, privilege and authority to erect, install, use, own, operate, maintain, repair, renew and finally remove an electric line, consisting of one (1) pole #472848, together with crossarms, cables, wires, one (1) anchor, guys and other fixtures and apparatus thereto belonging, upon, over, under, along, across and through Grantors land, fronting on SR 1013, a.k.a. Saxonburg Blvd., situate in The Township of O'Hara, Allegheny County, Pennsylvania, (having tax I.D.356-M-128), and shown on Duquesne Light Company Drawing No. 474681, a copy of which has been attached to and made part hereof. Duquesne Light Company shall also have the following rights: to trim or remove any trees or shrubbery which, at any time or times, may interfere or threaten to interfere with the erection, installation, use, operation, maintenance, repair, renewal or removal of the electric line; to enter upon the land at any time for such purposes; to permit others to attach crossarms, cables, wires and related apparatus, and to use the poles and apparatus erected hereunder; and to sell, assign, lease or otherwise transfer any or all of the rights hereunder.

Utility shall file a copy of this Agreement with the Pennsylvania Public Utility Commission as required by Title 66, Section 507 of the Public Utility Code, and this Agreement shall become effective in accordance therewith.

Intending to be legally bound the Grantor has executed this agreement this 2nd day of April, 2019.

GRANTOR:

THE TOWNSHIP OF O'HARA, a political subdivision of the Commonwealth of Pennsylvania

WITNESS:

[Signature]
Township Engineer (Assistant) Secretary

By: [Signature]
Julie A. Jakubec, CPA
Manager, Township of O'Hara

COMMONWEALTH OF PENNSYLVANIA
COUNTY OF ALLEGHENY
SS:

On this 2nd day of April, 2019, before me, a Notary Public in and for the Commonwealth and County, personally appeared Julie A. Jakubec, CPS and Manager of The Township of O'Hara, a political subdivision of the Commonwealth of Pennsylvania, and as such Manager, being authorized to do so, executed the foregoing instrument for the purposes therein contained.




WITNESS my hand and seal the day and year aforesaid.

Catherine L. Bubas
Notary Public

COMMONWEALTH OF PENNSYLVANIA
NOTARIAL SEAL
Catherine L. Bubas, Notary Public
O'Hara Twp., Allegheny County
My Commission Expires June 27, 2021
MEMBER, PENNSYLVANIA ASSOCIATION OF NOTARIES

* THE TOWNSHIP OF O'HARA


356-M-128



THIRD PARTY ATTACHMENTS	
COMPASS	
CONCAST	
VERIZON	

SUMMARY				
DLC WORK	QTY	PRIVATE PROPERTY	QTY	STATE R/W
REPLACE POLE	1		1	(1)
INSTALL POLE	1		1	1


CONDUIT DETAIL ITEM 3



- 1**
DLB34864
25'1 POLE
1-10M AG
30'1 POLE
1-10M AG
- REPLACE LEANING GUY STUB
 - TRANSFER 1-10M LG FROM ITEM 2
 - NJANS TIC#3821384 - VZ GUY

- 2**
DLB34863
9'DXD BUCK (OH-7-31)
1-358 BKT
1-CN BKT
- LOWER SECONDARY TO MINIMUM 40\"/>

- 3**
DLB472848
48'2 POLE
9'DXD (OH-7-30A)
1-10M AG (23DV1-ROD)
3-50KVA CSP XFMR (OH-10-82)
(13 2223KV) 277/480V 3Ø 4W SITE 100
1-CN BKT
1-3Ø 4W BUS BAR
(CLEARANCES PER OH-10-87)
1-OBL HLX ANC
- INSTALL NEW XFMR ON PRIVATE PROPERTY
 - CONNECT CUST OWNED UG SVC TO BUS BAR (PARALLEL 4-350KCMIL)



DLC CANNOT MOVE POLE TO EDGE OF R/W DUE TO SEVERE IMPACT ON LINE ANGLE AND WOULD REQUIRE ADDITIONAL PRIVATE PROPERTY R/W TO BE OBTAINED

GENERAL NOTE

- ALL EQUIPMENT AND WORK SHALL CONFORM WITH THE NATIONAL ELECTRICAL CODE AND APPLICABLE UNDERWRITERS AND GOVERNMENTAL BUILDING CODES.
- PRIOR TO REQUESTED SERVICE INSTALLATION, AN UNOBSTRUCTED ACCESS WAY CAPABLE OF 10200-LB (32,000 POUNDS PER SQ. FT.) TRUCK LOADING SHALL BE PROVIDED AND PERMANENTLY MAINTAINED BY THE CUSTOMER.
- DUQUESNE LIGHT COMPANY IS TO HAVE THE RIGHT OF ACCESS AND EGRESS AT ALL TIMES. DUQUESNE LIGHT COMPANY SHALL BE ABSOLVED FROM ALL PROPERTY DAMAGES DUE TO NOT NEGLIGENT ACCESS OR EGRESS OF DUQUESNE LIGHT COMPANY PERSONNEL OR EQUIPMENT.

DUQUESNE LIGHT WORK

- INSTALL NEW POLE AND ANCHOR ON PRIVATE PROPERTY WITH ALL NECESSARY EQUIPMENT AND TRANSFORMERS.
- INSTALL 3Ø PRIMARY AND NEUTRAL.
- SECURE CUSTOMER'S SECONDARY CONDUCTORS TO POLE WITH CUSTOMER SUPPLIED U-GUARD.
- CONNECT CUSTOMER'S SECONDARY CONDUCTORS TO THE BUS BAR WITH CUSTOMER SUPPLIED LUGS.

CONDUIT SYSTEM CONDUIT DETAIL ITEM 3

- CUSTOMER TO FURNISH, INSTALL, AND MAINTAIN THE SERVICE CONDUIT FROM THE TRANSFORMER POLE TO THE SERVICE EQUIPMENT. THE FOLLOWING REQUIREMENTS MUST BE FOLLOWED:
- A MAXIMUM OF (2) ELECTRICAL CONDUITS MAY BE INSTALLED ON A DUQUESNE LIGHT OWNED POLE.
 - A MINIMUM OF PVC SCHEDULE 40 FOR BURIED SECTIONS.
 - PVC SCHEDULE 80 OR RIGID METALLIC SHEEPS INSTALLED AT THE POLE AND SERVICE EQUIPMENT LOCATION.
 - PVC SCHEDULE 80 OR RIGID METALLIC CONDUIT INSTALLED WITHIN THE FIRST 30 FT. ABOVE FINISHED GRADE AT BOTH THE POLE AND SERVICE EQUIPMENT.
 - FURNISH PVC SCHEDULE 40 U-GUARD TO REACH WITHIN 1 FT. OF THE BOTTOM OF THE SECONDARY BUS BAR FOR DUQUESNE LIGHT TO SECURE THE SERVICE CONDUCTORS TO THE POLE.

SERVICE CABLES

- CUSTOMER IS TO FURNISH, INSTALL AND MAINTAIN THE SERVICE CONDUCTORS FROM THE TRANSFORMER POLE TO THE METERING EQUIPMENT AND FROM THE METERING EQUIPMENT TO THE SERVICE.
- THE SERVICE CONDUCTORS SHALL BE LONG ENOUGH TO REACH THE TOP OF THE BUS BAR MOUNTED ON THE TRANSFORMER POLE PLUS 3 FT.
- THE CUSTOMER IS TO FURNISH UL APPROVED COMPRESSION TYPE CONNECTORS HAVING A MINIMUM OF TWO COMPRESSIONS OVER EACH CONDUCTOR AND THE CONNECTOR TONGUE WIDTH SHALL NOT EXCEED 1-3/4\"/>

METERING

- DUQUESNE LIGHT TO SUPPLY THE CT'S, P.T'S AND REMOTE METER SOCKET. PLEASE CONTACT CENTRAL METERING AT (512) 262-5722 TO SCHEDULE A PICK-UP OR DELIVERY.
- THE CUSTOMER IS TO INSTALL THE DUQUESNE LIGHT PROVIDED EQUIPMENT FOR METERING STANDARDS. THE METER SOCKET MUST BE MOUNTED ON THE OUTSIDE OF THE STRUCTURE.
- THE CUSTOMER IS TO INSTALL, INSTALL AND MAINTAIN A CT CABINET. THE TWO MINIMUM RECOMMENDED SIZES FOR PARALLEL 3Ø/3Ø ARE:
 a. 24\"/>
- THE CUSTOMER IS TO FURNISH, INSTALL, AND MAINTAIN A 1-1/2\"/>
- THE CUSTOMER IS TO MOUNT ALL CT'S AND P.T'S IN THE CUSTOMER SUPPLIED ENCLOSURE. PLEASE CONTACT CENTRAL METERING REGARDING THE INSTALLATION REQUIREMENTS.

DLC DUQUESNE LIGHT CO. DISTRIBUTION ENGINEERING

NEW BUSINESS - EAST LITTLE PINE CREEK PUMP SVC
1112 SAXONSBURG BLVD. GLENSHAW, 15116 O'HARA TWP.

DATE	BY	SCALE	DATE	BY	DATE	DATE	DATE	DATE	DATE
	J. NEWCOMER	02/20/2019	RSC	03/14/2019					
	J. NEWCOMER	02/22/2019	R. CARR	03/14/2019					

RIGHT OF WAY AND CONSTRUCTION DETAILS			
INSTALL (1) POLE AND 2Ø R/W SET FOR 277/480V 3Ø 4W SVC			
C	19-0005	474681	0