



RECEIVED

2019 APR 18 PM 4:11

PA PUC
SECRETARY'S BUREAU
FIRST DEPT

17 North Second Street
12th Floor
Harrisburg, PA 17101-1601
717-731-1970 Main
717-731-1985 Main Fax
www.postschell.com

Jessica R. Rogers

jrogers@postschell.com
202-661-6964 Direct
202-661-6944 Direct Fax
File #: 140066

April 18, 2019

VIA ELECTRONIC FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

Re: Letter of Notification of PPL Electric Utilities Corporation, Filed Pursuant to 52 Pa. Code Chapter 57 Subchapter G, for Approval of the Face Rock - Five Forks 115 kV Line Project in York County and Lancaster County, PA
Docket No. A-2019-3008816

Dear Secretary Chiavetta:

Enclosed for filing are the Responses of PPL Electric Utilities Corporation to the Data Requests of the Bureau of Technical Utility Services in the above-referenced proceeding.

Respectfully submitted,

Jessica R. Rogers

Enclosures

cc: Jordan Van Order (*via E-Mail only*)

[WITNESS: Frank J. Richardson]

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.1 Reference the Letter of Notification, Attachment 1, Section 4.3.
Please provide a copy of the assessment conducted by Georgia Tech
National Electric Energy Testing and Research and Application
Center.

A.1 Please see attachment TUS A-1.

[WITNESS: Frank J. Richardson]

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.2 Reference the Letter of Notification, Attachment 1, Section 4.3. Please provide a copy of the assessment conducted by Osmose Utilities Services, Inc.

A.2 Please see attachment TUS A-2.

[WITNESS: Frank J. Richardson]

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

- Q.3 Reference the Letter of Notification, Attachment 1, Section 4.3. Please explain whether either Georgia Tech National Electric Energy Testing and Research and Application Center or Osmose Utilities Services, Inc. are affiliates of PPL Electric.
- A.3 Neither Georgia Tech National Electric Energy Testing and Research and Application Center (NEETRAC) nor Osmose Utilities Services, Inc. are affiliates of PPL Electric Utilities Corporation (PPL EU).

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

- Q.4 Reference the Letter of Notification, Attachment 1, Section 4.2. Please explain whether any customer loads are served by the face Rock-Five Forks 115 kV Transmission Line and whether any customer loads are impacted by outages on the line.
- A.4 No PPL EU customers are directly served by the Face Rock-Five Forks 115 kV Transmission Line and therefore no PPL EU customer loads are impacted by outages on the line.

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.5 Reference the Letter cation, Paragraph 12. Please provide a breakdown of maintenance/repair costs for the previous five years.

A.5 A breakdown of the cost to maintain and repair the Face Rock-Five Forks 115 kV Transmission Line in each of the previous five years is shown in the table below. To ensure consistency with the data provided in the Letter of Notification, 2013 maintenance data is also included.

Year	Approximate Total Maintenance and Repair Costs (\$)
2013	245,674
2014	0
2015	148,715
2016	57,561
2017	375,405
2018	29,545
Total	856,809

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.6 Reference the Letter of Notification, Paragraph 12. Please provide the total outage minutes or hours per year.

A.6 The total annual outage minutes of the Face Rock-Five Forks 115 kV Transmission Line during each of the previous five years is shown in the table below.

Year	Total Outage Minutes
2014	1,446.9
2015	1,437.4
2016	4,073.1
2017	4,270.7
2018	205.4
Total	11,433

[WITNESS: Frank J. Richardson]

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.7 Reference the Letter of Notification, Paragraph 10. For the Holtwood Hydroelectric Generating Plant, please provide the total number of forced outage minutes or hours per year for the previous five years.

A.7 PPL EU does not have this information because the Holtwood Hydroelectric Generating Plant is not a PPL EU asset.

**PPL Electric Utilities Corporation
Response to Data Requests of the
Bureau of Technical Utility Services
Dated April 18, 2019
Docket No. A-2019-3008816**

Q.8 Reference the Letter of Notification, Paragraph 31. Please provide the proposed construction and in-service dates.

A.8 PPL EU's Letter of Notification (LON) proposed to begin construction upon commission approval to meet a Q4 2020 in-service date. Assuming Commission approval is received before PJM's June 2019 deadline to coordinate outage planning activities, construction will begin within approximately 6-months of that date.

VERIFICATION

I, FRANK J. RICHARDSON, MANAGER – PJM & FEDERAL REGULATORY POLICY at PPL Electric Utilities Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: April 17, 2019

Frank J. Richardson

RECEIVED
2019 APR 18 PM 4:11
PA PUP
SECRETARY BUREAU
FRONT DESK