

RECEIVED

Tori L. Giesler
(610) 921-6658
(610) 315-9263 (fax)

2019 MAY -9 AM 10:06

PA PUC
SECRETARY'S BUREAU
May 3, 2019

M-2016-2522508

VIA FIRST CLASS MAIL

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

**Re: Joint 1st Quarter 2019 Reliability Report – Metropolitan Edison Company,
Pennsylvania Electric Company, Pennsylvania Power Company and West Penn
Power Company – Public Version – Correction**


Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 57.195(d) and (e), enclosed for filing on behalf of Metropolitan Edison Company ("Met-Ed"), Pennsylvania Electric Company ("Penelec"), Pennsylvania Power Company ("Penn Power") and West Penn Power Company ("West Penn") (collectively, the "Companies") are two copies of the **Corrected** page 3 for the Joint 1st Quarter 2019 Reliability Report – Public Version ("Joint Report") that was filed. This corrected for the fact that the SAIFI and CAIDI values that were transposed for West Penn.

Please date stamp the additional copy and return it in the postage-prepaid envelope provided.

Please feel free to contact me if you have any questions or need additional information regarding this matter.

Sincerely,



Tori L. Giesler

Enclosures

- c: As Per Certificate of Service
- D. Searfoorce - Bureau of Technical Utility Services (via email and first class mail)
- D. Washko – Bureau of Technical Utility Services (via email and first class mail)
- J. Van Zant – Bureau of Technical Utility Services (via email and first class mail)

Section 57.195(e)(2): Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI, and if available MAIFI) for the EDC's service territory for the preceding quarter. The report shall include the data used in calculating the indices, namely the average number of customers served, the number of sustained customer interruptions, the number of customers affected, and the customer minutes of interruption. If MAIFI values are provided, the report shall also include the number of customer momentary interruptions.

Reliability Index Values₃

1Q 2019 (12-Mo Rolling)	Met-Ed ~			Penelec			Penn Power			West Penn		
	Benchmark	12-Month Standard	12-Month Actual	Benchmark	12-Month Standard	12-Month Actual	Benchmark	12-Month Standard	12-Month Actual	Benchmark	12-Month Standard	12-Month Actual
SAIFI	1.15	1.38	1.37	1.26	1.52	2.00	1.12	1.34	1.35	1.05	1.26	1.49
CAIDI	117	140	145	117	141	129	101	121	197	170	204	282
SAIDI	135	194	200	148	213	258	113	162	266	179	257	420
MAIFI ⁴			1.59			2.78			0.093			
Customers Served ⁵	565,751			580,343			163,974			716,811		
Number of Sustained Interruptions	11,983			15,190			3,766			15,439		
Customers Affected	776,586			1,163,450			221,808			1,065,700		
Customer Minutes	112,908,152			149,841,373			43,665,643			301,017,165		
Number of Customer Momentary Interruptions	901,100			1,615,374			15,282					

³ Pending major events are included in the reliability information.

⁴ MAIFI values are not available for West Penn.

⁵ Represents the average number of customers served during the reporting period.

RECEIVED
 2019 MAY -9 AM 10:06
 PA PUC
 SECRETARY'S BUREAU

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Joint 1st Quarter 2019 Reliability Report – :
Metropolitan Edison Company, :
Pennsylvania Electric Company :
Pennsylvania Power Company and West :
Penn Power Company – Public Version :**

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true and correct copy of the foregoing document upon the individuals listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

Service by first class mail, as follows:

John R. Evans
Office of Small Business Advocate
Suite 1102, Commerce Building
300 North Second Street
Harrisburg, PA 17101

Tanya McCloskey
Office of Consumer Advocate
555 Walnut Street – 5th Floor
Harrisburg, PA 17101-1923

Richard A. Kanaskie
Bureau of Investigation & Enforcement
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

Scott Rubin
Utility Workers Union of America
333 Oak Lane
Bloomsburg, PA 17815-2036

Service by electronic mail, as follows:

David Dulick, General Counsel
David.Dulick@ccsenergy.com

Rich Geosits, Manager, Power Delivery
Rich.Geosits@ccsenergy.com

Dated: May 3, 2019



Tori L. Giesler
Attorney No. 207742
FirstEnergy Service Company
2800 Pottsville Pike, P.O. Box 16001
Reading, Pennsylvania 19612-6001
(610) 921-6203
tgiesler@firstenergycorp.com


Counsel for Metropolitan Edison Company,
Pennsylvania Electric Company,
Pennsylvania Power Company and
West Penn Power Company

FRST 1CL MAILED 0196 052269 050412


FirstEnergy

2800 Pottsville Pike
P.O. Box 16001
Reading, PA 19612-6001

PRESORTED



U.S. POSTAGE >>> PITNEY BOWES



ZIP 19605 \$ 000.45⁹
02 4W
0000363885 MAY 03 2019

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

GENCHLSTMP 17120

