



Emily M. Farah
Counsel, Regulatory

411 Seventh Avenue
Mail drop 15-7
Pittsburgh, PA 15219

Tel: 412-393-6431
efarah@duqlight.com

June 27, 2019

Via Electronic Filing

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building, 2nd Floor
400 North Street
Harrisburg, PA 17120

**Re: Municipal Agreement between Duquesne Light Company and the Allegheny County
Airport Authority
Docket No. U-2019-3009855**

Dear Secretary Chiavetta:

Enclosed please find Duquesne Light Company's responses to Data Requests Propounded by the Bureau of Technical Utility Services ("TUS") Set I, in the above-captioned proceeding. Please feel free to contact me with any questions.

Respectfully Submitted,

A handwritten signature in blue ink, appearing to read "Emily M. Farah", is written over the typed name and title.

Emily M. Farah
Counsel, Regulatory

Enclosure

cc: Jordan Van Order (jvanorder@pa.gov)

Bureau of Technical Utility Services
Data Requests
Docket No. U-2019-3009855

TUS-1 Reference the License Agreement, First page. Please provide a quantified breakdown of the facilities to be relocated by Duquesne Light.

Response:

In connection with the License Agreement, Duquesne Light will be removing six poles (5 of which with anchors), along with their respective crossarms and brackets and wire (4,194' in total). Duquesne Light will also be removing one single-phase overhead transformer and one 3-phase terminal pole that runs to the existing customer primary metering setup.

In place of the above, Duquesne Light will be extending the 4kV circuit two spans, installing a new terminal pole, and installing 1,075' of 3-2/C-#2 Al underground cable through a new customer-installed ductbank (with manholes) to a pad mounted, four compartment switch. One of the load sides will feed the relocated customer primary metering setup. The other will feed roughly 342' of 1-2/C-#2 Al. cable to a new single-phase terminal pole. This terminal pole feeds a pole line that goes back to an airport maintenance garage.

Bureau of Technical Utility Services
Data Requests
Docket No. U-2019-3009855

TUS-2 Reference the License Agreement, Paragraph 5. Please provide the estimated cost to Duquesne Light for relocating its facilities.

Response:

- Material (install): \$28,710.49
- Removal: \$12,257.57
- Install Labor: \$45,593.37
- Taxes: \$13,883.38
- Total: \$100,444.81

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Municipal Agreement between Duquesne Light : Docket No.U-2019-3009855
Company and the Allegheny County Airport :
Authority :

VERIFICATION

I, Michael Palladino, hereby state that the facts set forth above are true and correct to the best of my knowledge, information and belief, and I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 (relating to unsworn falsification to authorities).



Michael F. Palladino, Jr.
Senior Technician

Date: June 25, 2019