



Elizabeth Rose Triscari

Director, Corporate Counsel

Pennsylvania-American Water Company

852 Wesley Drive, Mechanicsburg, PA 17055

P: 717.550.1574 F: 717.531.3399 C: 717.585.1934

elizabeth.triscari@amwater.com

February 14, 2020

VIA ELECTRONIC FILING

Ms. Rosemary Chiavetta, Secretary
Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

**In Re: Application of Pennsylvania-American Water Company for approval
of the right to offer, render, furnish or supply wastewater service to
the public in an additional portion of South Coatesville Borough,
Chester County Pennsylvania – Docket No. A-2020-3015680**

Dear Secretary Chiavetta:

In response to your letter of February 13, 2020, attached for filing please find Pennsylvania-American Water Company's Responses to Data Request Set III propounded by the Bureau of Technical Utility Services.

If you should have any questions, please do not hesitate to contact me.

Sincerely,

Elizabeth Rose Triscari

jrh

enclosures

cc: Janelle Eckman (*via electronic and first-class mail*)

Bureau of Technical Utility Services

Water/Wastewater Division

Data Request Set 3

Application of Pennsylvania American Water Company – Wastewater Division for the approval of the right to offer, render, furnish or supply wastewater service to the public in an additional portion of South Coatesville Borough, Chester County at Docket No. A-2020-3015680


A-13. PAWC-WD's response to Data Request A-10 indicated PAWC-WD there are two existing force mains in West Chester Road, a 4-inch diameter pipe on the northside of the road and a 6-diameter pipe in the center of the road. Please indicate the respective material types for the existing 4-inch and 6-inch diameter force mains in West Chester Road.

Response: The 6-inch pipe is made of ductile iron and the 4-inch pipe is made of PVC.

Response Provided by: James R. Kelly, Senior Supervisor – Operations (Coatesville)
Pennsylvania-American Water Company

VERIFICATION

I, James P. Kelly hereby state that the facts above set forth above are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements made herein are made subject to the penalties of 18 Pa. Cons. Stat. §4904 (relating to unsworn falsification to authorities).


James P. Kelly, Senior Supervisor
Pennsylvania-American Water Company

Dated:

2/14/20