



***Duquesne Light Company
Fourth Quarter 2019***

Electric Reliability Report

to the

Pennsylvania Public Utility Commission

RECEIVED

JAN 29 2020

PA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU

January 29, 2020

57.195 Reporting Requirements

(e)(1) *A description of each major event that occurred during the preceding quarter, including the time and duration of the event, the number of customers affected, the cause of the event and any modified procedures adopted in order to avoid or minimize the impact of similar events in the future.*

Duquesne Light had no major events during the fourth quarter of 2019.

(e)(2) *Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI, and if available, MAIFI) for the electric distribution company's service territory for the preceding quarter. The report shall include the data used in calculating the indices, namely the average number of customers served, the number of sustained customer interruptions, the number of customers affected, and the customer minutes of interruption. If MAIFI values are provided, the report shall also include the number of customer momentary interruptions.*

RELIABILITY BENCHMARKS AND STANDARDS

Duquesne Light Company

System Performance Measures with Major Events Excluded

Entire System				
	SAIDI	SAIFI	CAIDI	MAIFI
Benchmark	126	1.17	108	*
12 Month Standard	182	1.40	130	*
2019 4Q (Rolling 12 mo)	106	1.01	106	*

* Sufficient information to calculate MAIFI is unavailable.

Formulas used in calculating the indices

$$\text{SAIFI} = \frac{(\text{Total KVA interrupted}) - (\text{KVA impact of major events})}{\text{System Connected KVA}}$$

$$\text{SAIDI} = \frac{(\text{Total KVA-minutes interrupted}) - (\text{KVA-minute impact of major events})}{\text{System Connected KVA}}$$

$$\text{CAIDI} = \text{SAIDI/SAIFI}$$

Data used in calculating the indices

Total KVA Interrupted for the Period: (excludes the 2/24/19 Major Event that is listed below)	7,296,110 KVA
Total KVA-Minutes Interrupted: (excludes the 2/24/19 Major Event that is listed below)	772,081,564 KVA-Minutes
System Connected Load as of 12/31/19	7,259,129 KVA
February 24, 2019 Major Event	1,682,200 KVA (23% of System Load) 784,246,585 KVA-Minutes

- (e)(3)** *Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI, and if available, MAIFI) and other pertinent information such as customers served, number of interruptions, customer minutes interrupted, number of lockouts, and so forth, for the worst performing 5% of the circuits in the system. An explanation of how the electric distribution company defines its worst performing circuits shall be included.*

Circuits are evaluated based on a rolling twelve-month count of lockouts of protective devices (circuit breakers, reclosers, sectionalizers, and line fuses) and on total accumulated KVA-Minutes of customer outage time. Circuits that experience multiple lockouts for a device in combination with high total accumulated KVA-Minutes of customer outage time in each quarterly rolling twelve-month period are identified and the top 5% are reported as Worst-Performing Circuits.

The list of worst-performing circuits is ranked first by the number of KVA-Minutes of outage experienced by customers on these circuits (highest to lowest) and then by device lockouts from highest to lowest. This places a higher priority on circuits with repeat outages affecting customers (SAIFI) while also focusing on outage duration for customers on these circuits (SAIFI and SAIDI).

While repairs are made as quickly as possible following every customer outage, circuits that appear on the worst performing circuits list are targeted for more extensive remediation based on a detailed review of historical outage records looking at root cause problems, field evaluations, and engineering analysis. Project scopes developed as a result of this analysis are incorporated into the Company's Work Plan for engineering, design, and construction. Since the focus is on reducing future customer outage duration and not just outage frequency, special attention is given to establishing/optimizing sectionalizing switch locations and alternate feeds to problem-prone areas of circuits and, where possible, replacing or eliminating equipment that has historically required lengthy repair times as well as a high failure rates.

At the end of each quarter all previously identified circuits are reviewed to verify that past remediation efforts are working and to look for new reliability issues that may be developing. Serious new reliability problems are addressed immediately without waiting additional periods to collect information. This analysis method provides for timely review of circuit performance by in-house staff and it adapts to the dynamic nature of Duquesne Light's distribution system.

Special Note: *Because of sophisticated protection and remote automation technologies that the Company uses on its distribution circuits, not all customers on a circuit identified as a worst performing circuit actually experience significant reliability issues. Circuit problems are generally isolated to one load block of a circuit in less than five minutes with downstream customers only experiencing short momentary operations. Customers upstream of a circuit problem may not even experience a momentary outage. Therefore, many customers on a circuit identified as a poor performer do not experience problems with reliability.*

See Attachment A for a list of worst-performing circuits showing feeder device lockouts and reliability index values associated with each circuit.

(e)(4) Specific remedial efforts taken and planned for the worst performing 5% of the circuits as identified in paragraph (3).

Fourth Quarter 2019 Rolling 12 Month Circuit Data

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>1 23701 North Fuse Link</p>	<p>9 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • Three outages were caused by tree fall-in, one during a storm. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. • The cause of three outages were unknown, one during a storm. • One outage was caused by equipment failure. • One outage was caused by wires wrapped together due to high wind. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2021.
<p>2 23631 Sewickley Fuse Link</p>	<p>6 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by tree fall-in. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Four outages were caused by tree fall-in, one during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2017. Proposed for 2021.

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>3 23770 Traverse Run Breaker</p>	<p>5 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by equipment failure. • The cause of two outages were unknown, one during a storm. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in. • One outage was caused by high current overload. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2020.
<p>4 23953 Evergreen Recloser</p>	<p>5 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by contact with company equipment by vehicle. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Three outages were caused by tree fall-in. • One outage was caused by flood. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2016. Proposed for 2020.
<p>5 23711 Pine Creek Breaker</p>	<p>5 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Four outages were caused by tree fall-in. • One outage was caused by equipment failure. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2015. Proposed for 2020.

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>6 23869 Wildwood Recloser</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Three outages were caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2020.
<p>7 23716 Pine Creek Breaker</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by equipment failure. • One outage was caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q1 2019. Proposed for 2023.
<p>8 22869 Midland-Cooks Ferry Recloser</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by wires wrapped together. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by wires wrapped together. • One outage was caused by tree fall-in, during a storm. • One outage was caused by equipment failure. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2017. Proposed for 2022. • This circuit was reviewed by Protection Engineering to identify any potential device coordination issues. Further work to resolve device coordination issues was completed Q1 2019.

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>9 23921 Logans Ferry Fuse Link</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by tree fall-in, one during a storm. • The cause of one outage was unknown. • One outage was caused by wires wrapped together due to high wind. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2020.
<p>10 23840 Arsenal Recloser</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by contact with company equipment by animal. • Two outages were caused by equipment failure. • One outage was caused by wires wrapped together. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Overhead Line Inspection of Arsenal 23840 is slated to be performed in 2020. • Vegetation Management completed Q3 2018. Proposed for 2022.

Duquesne Light Company
 Fourth Quarter 2019 Electric Reliability Report

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>11 23714 Pine Creek Fuse Link</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by equipment failure. • One outage was caused by tree fall-in. • One outage was caused by contact with company equipment by animal. • One outage was caused by contact with company equipment by vehicle. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2018. Proposed for 2023. • This circuit was reviewed by Protection Engineering to identify any potential device coordination issues. The devices were coordinating properly and no further action is necessary.
<p>12 23871 Mt Nebo Recloser</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Four outages were caused by tree fall-in, one during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2017. Proposed for 2021.
<p>13 23870 Mt Nebo Fuse Link</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Four outages were caused by tree fall-in, two during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2017. Proposed for 2021.

Duquesne Light Company
Fourth Quarter 2019 Electric Reliability Report

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>14 4484 Manchester Breaker</p>	<p>4 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • The cause of two outages were unknown, one during a storm. • Two outages were caused by equipment failure. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Failed substation equipment has been replaced. • Vegetation Management completed Q2 2019. Proposed for 2023.
<p>15 23882 Rankin Fuse Link</p>	<p>3 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • The cause of one outage was unknown. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q1 2017. Proposed for 2021.
<p>16 23679 Woodville Recloser</p>	<p>3 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • The cause of one outage was unknown. • One outage was caused by tree fall-in. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q2 2016. Proposed for 2020.
<p>17 23630 Sewickley Recloser</p>	<p>3 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by tree fall-in. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2017. Proposed for 2021.

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>18</p> <p>23791 Legionville</p> <p>Recloser</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2019. Proposed for 2024.
<p>19</p> <p>23732 Universal</p> <p>Breaker</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • The cause of one outage was unknown. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by equipment failure. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2016. Proposed for 2021.
<p>20</p> <p>23844 Arsenal</p> <p>Recloser</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by wires wrapped together, during a storm. • One outage was caused by tree fall-in, during a storm. <p>Previous Outages:</p> <ul style="list-style-type: none"> • No outages. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2021.
<p>21</p> <p>22556 Logans Ferry- U.S. Gypsum</p> <p>Breaker</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2016. Proposed for 2020.

Duquesne Light Company
Fourth Quarter 2019 Electric Reliability Report

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
<p>22</p> <p>23841 Arsenal</p> <p>Fuse Link</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by contact with company equipment by animal. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by equipment failure. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2018. Proposed for 2022.
<p>23</p> <p>23820 Highland</p> <p>Sectionalizer</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • Two outages were caused by contact with company equipment by vehicle. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q2 2017. Proposed for 2021.
<p>24</p> <p>23680 Woodville</p> <p>Breaker</p>	<p>2 Total Outages</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • No outages. <p>Previous Outages:</p> <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. • One outage was caused by wires wrapped together due to high wind, during a storm. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q2 2016. Proposed for 2020.
<p>25</p> <p>23707 North</p> <p>Fuse Link</p>	<p>1 Total Outage</p> <p>Fourth Quarter Outages:</p> <ul style="list-style-type: none"> • One outage was caused by contact with company equipment by animal. <p>Previous Outages:</p> <ul style="list-style-type: none"> • No outages. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q3 2017. Proposed for 2021.

Duquesne Light Company
 Fourth Quarter 2019 Electric Reliability Report

Rank, Circuit Name, Device	Outages	Remedial Actions Planned or Taken
26 23781 Valley Recloser	1 Total Outage Fourth Quarter Outages: <ul style="list-style-type: none"> • One outage was caused by tree fall-in, during a storm. Previous Outages: <ul style="list-style-type: none"> • No outages. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q4 2018. Proposed for 2023.
27 4428 Suffolk Breaker	1 Total Outage Fourth Quarter Outages: <ul style="list-style-type: none"> • No outages. Previous Outages: <ul style="list-style-type: none"> • One outage was caused by tree fall-in. 	<ul style="list-style-type: none"> • Permanent repairs were made following each outage as necessary. • The Company will continue to monitor this circuit for reliability issues. • Vegetation Management completed Q1 2019. Proposed for 2023.

(e)(5) *A rolling 12-month breakdown and analysis of outage causes during the preceding quarter, including the number and percentage of service outages, the number of customers interrupted, and customer interruption minutes categorized by outage cause such as equipment failure, animal contact, tree related, and so forth. Proposed solutions to identified service problems shall be reported.*

Proposed solutions to identified service problems are listed in Section (e)(4) above.

January 1, 2019 through December 31, 2019
Excludes One PUC Major Event that occurred on February 24, 2019

CAUSE	NO. OF OUTAGES	OUTAGE PERCENTAGE	KVA TOTAL	KVA PERCENTAGE	KVA-MINUTE TOTAL	KVA-MINUTE PERCENTAGE
Storms	357	11%	933,511	13%	119,004,324	15%
Trees (Inside ROW)	360	11%	330,331	4%	58,540,342	8%
Trees (Outside ROW)	845	26%	1,942,015	27%	258,246,809	33%
Equipment Failures	768	24%	2,102,217	29%	196,429,852	25%
Overloads	49	1%	20,295	1%	1,462,984	1%
Vehicles	183	6%	597,611	8%	55,330,726	7%
Contact/Dig In	20	1%	91,615	1%	3,130,864	1%
Animal Contact	120	4%	262,093	4%	12,217,572	2%
Unknown	355	11%	615,090	8%	33,689,339	4%
Other	183	5%	401,332	5%	34,028,752	4%
TOTALS	3,240	100%	7,296,110	100%	771,081,564	100%

(e)(6) Quarterly and year-to-date information on progress toward meeting transmission and distribution inspection and maintenance goals/ objectives.

2019 Transmission and Distribution Goals and Objectives							
Program Project	Unit of Measurement	Target for 2019 4Q	Actual for 2019 4Q	4Q Percent Complete	Targets for Year 2019	Actual YTD for 2019	Year End % Complete
Communications Goals							
Communication Battery Maintenance	Battery Tasks	29	39	134%	117	117	100%
Overhead Distribution Goals							
Recloser Inspections	Circuits	0	0	NA	130	131	101%
Pole Inspections	Poles	0	0	NA	17945	18117	101%
OH Line Inspections	Circuits	0	0	NA	130	131	101%
OH Transformer Inspections	Circuits	0	0	NA	130	131	101%
Padmount & Below Grade Insp	Circuits	0	0	NA	81	81	100%
Overhead Transmission Goals							
Helicopter Inspections	Number of Structures	0	0	NA	576	576	100%
Ground Inspections	Number of Structures	0	14	NA	370	370	100%
Substations Goals							
Circuit Breaker Maintenance	Breaker Tasks	0	76	NA	408	461	113%
Station Transformer Maintenance	Transformer Tasks	0	3	NA	44	48	109%
Station Battery Maintenance ¹	Battery Tasks	228	226	104%	906	903	100%
Station Relay Maintenance	Relay Tasks	0	208	NA	865	996	115%
Station Inspections ²	Site Visits	483	470	97%	1942	1908	98%
Underground Distribution Goals							
Manhole Inspections	Manholes	0	4	NA	700	721	103%
Major Network Insp (Prot Relay)	Network Protectors	0	0	NA	94	97	103%
Minor Network Visual Inspection (Transformer/Protector/Vault)	Network Transformers	0	124	NA	572	694	121%
Underground Transmission Goals							
Pressurization and Cathodic Protection Plant Inspection	Work Orders	90	95	106%	372	372	100%
Vegetation Management Goals							
Overhead Line Clearance	Circuit Overhead Miles	210	256	122%	1300	1300	100%
Total Units		1040	1356	130%	26682	27154	102%

1 – Station Battery Maintenance end of year underage due to asset movement and station retirements.

2 – End of year underage due to station retirements.

(e)(7) Quarterly and year-to-date information on budgeted versus actual transmission and distribution operation and maintenance expenditures in total and detailed by the EDC's own functional account code or FERC account code as available.

Budget Variance Recap – O&M Expenses
 For the Three Months Ending December 31, 2019
 (In Whole Dollars)
 Favorable/(Unfavorable)

	Total Actual	Total Budget	Variance
Customer Service	\$16,770,766	\$14,625,488	\$(2,145,278)
Human Resources	3,934,599	4,606,299	671,700
Operations/Operation Services	8,513,572	16,234,012	7,720,440
Technology	15,924,938	14,950,395	(974,543)
General Corporate*	17,058,982	9,488,352	(7,570,630)
Total	\$62,202,857	\$59,904,546	\$(2,298,311)

*Includes Finance, Office of General Counsel, and Senior Management costs.

Budget Variance Recap – O&M Expenses
 For the Twelve Months Ending December 31, 2019
 (In Whole Dollars)
 Favorable/(Unfavorable)

	Total Actual	Total Budget	Variance
Customer Service	\$59,618,238	\$61,399,832	\$1,781,594
Human Resources	14,355,978	15,540,131	1,184,153
Operations/Operation Services	60,265,231	67,729,498	7,464,267
Technology	58,316,586	61,672,441	3,355,855
General Corporate*	44,509,969	36,273,901	(8,236,068)
Total	\$237,066,002	\$242,615,803	\$5,549,801

*Includes Finance, Office of General Counsel, and Senior Management costs.

(e)(8) *Quarterly and year-to-date information on budgeted versus actual transmission and distribution capital expenditures in total and detailed by the EDC's own functional account code or FERC account code as available.*

Budget Variance Recap -Capital
 For the Three Months Ending December 31, 2019
 (In Whole Dollars)
 Favorable/(Unfavorable)

	Total Actual	Total Budget	Variance
Customer Service	\$6,703,163	\$2,519,006	\$(4,184,157)
Human Resources	2,805,070	3,104,529	299,459
Operations/Operation Services	89,956,580	62,360,871	(27,595,709)
Technology	9,651,871	15,599,219	5,947,348
General Corporate*	3,928,852	7,269,711	3,340,859
Total	\$113,045,536	\$90,853,336	\$(22,192,200)

*Includes Finance, Office of General Counsel, and Senior Management costs.

Budget Variance Recap - Capital
 For the Twelve Months Ending December 31, 2019
 (In Whole Dollars)
 Favorable/(Unfavorable)

	Total Actual	Total Budget	Variance
Customer Service	\$18,435,636	\$9,375,101	\$(9,060,535)
Human Resources	10,955,064	12,198,506	1,243,442
Operations/Operation Services	229,016,014	264,679,039	35,663,025
Technology	50,451,687	66,480,721	16,029,034
General Corporate*	32,929,179	31,233,951	(1,695,228)
Total	\$341,787,580	\$383,967,318	\$42,179,738

*Includes Finance, Office of General Counsel, and Senior Management costs.

Duquesne Light Company
 Fourth Quarter 2019 Electric Reliability Report

(e)(9) *Dedicated staffing levels for transmission and distribution operation and maintenance at the end of the quarter, in total and by specific category (e.g. linemen, technician, and electrician).*

Job Title	Number of Employees
Telecom Splicer/Trouble Tech	6
Electronic Technician	16
Telecom Technician	2
Total Telecom	24
Electrical Equipment Technician	38
Protection & Control Technician	27
Yard Group Leader	3
Rigger	6
Laborer	2
Total Substation	76
UG Splicer	39
UG Cable Inspector	9
Cable Tester	1
Network Operator	12
Equipment Material Handler	1
Total Underground	62
Apprentice T&D	40
Equipment Attendant	1
Lineworker	140
Service Crew Leader	4
Equipment Material Handler	5
Total Overhead	190
Right of Way Agent	4
Surveyor	4
Total Real Estate	8
Total Street Light Changer	6
Engineering Technician	34
GIS Technician	7
T&D Mobile Worker	3
Test Technician, Mobile	6
Total Engineering	50
Senior Operator Apprentice	20
Senior Operator	2
Traveling Operator	0
Troubleshooter	11
Total Traveling Operator/Troubleshooter	33
Total Switching Dispatcher	12
Total Employees	461

(e)(10) *Quarterly and year-to-date information on contractor hours and dollars for transmission and distribution operation and maintenance.*

CONFIDENTIAL INFORMATION

4th Quarter 2019

Contractor Dollars: \$ REDACTED
Contractor Hours: REDACTED

YTD 2019

Contractor Dollars: \$ REDACTED
Contractor Hours: REDACTED

(e)(11) *Monthly call-out acceptance rate for transmission and distribution maintenance workers presented in terms of both the percentage of accepted call-outs and the amount of time it takes the EDC to obtain the necessary personnel. A brief description of the EDC's call-out procedure should be included when appropriate.*

CONFIDENTIAL INFORMATION

Call-Out Acceptance Rate –4th Quarter 2019

REDACTED

Amount of Time it Takes to Obtain the Necessary Personnel – 4th Quarter 2019

REDACTED

Duquesne Light Company
Fourth Quarter 2019 Electric Reliability Report

(d)(2) *The name, title, telephone number and e-mail address of the persons who have knowledge of the matters, and can respond to inquiries.*

Matthew G. Bucek – General Manager, Asset Management
(412) 393-8878, mbucek@duqlight.com

Jaime Bachota – Assistant Controller, Accounting & Financial Reporting
(412) 393-1122, jbachota@duqlight.com

Jason Keller – General Manager, Operations Center
(412) 393-2897, jkeller@duqlight.com

ATTACHMENT A

(e)(3) *Rolling 12-month reliability index values (SAIFI, CAIDI, SAIDI, and if available, MAIFI) and other pertinent information such as customers served, number of interruptions, customer minutes interrupted, number of lockouts, and so forth, for the worst performing 5% of the circuits in the system.*

Rank	Circuit No	Circuit Name	Feeder Device	Device Lockouts	Last Lockout	Circuit KVA	Total KVA Interrupted	Total KVA-Minutes	SAIDI	SAIFI	CAIDI
1	23701	North	65K	9	2019-11-01	20748	103235	8352594	402.57345	4.97566	80.90855
2	23631	Sewickley	80E	6	2019-12-06	32880	79843	7757217	235.92509	2.42832	97.15588
3	23770	Traverse Run	BKR	5	2019-12-17	28580	109028	14436061	505.11060	3.81484	132.40691
4	23953	Evergreen	ER703	5	2019-11-09	31030	113835	10291025	331.64760	3.66855	90.40300
5	23711	Pine Creek	BKR	5	2019-06-21	22021	122059	8854816	402.10781	5.54285	72.54538
6	23869	Wildwood	100	4	2019-12-14	24841	103450	9151487	368.40252	4.16449	88.46290
7	23716	Pine Creek	BKR	4	2019-11-27	34563	130749	13271706	383.98594	3.78292	101.50522
8	22869	Midland-Cooks Ferry	SWR262	4	2019-11-02	45166	191957	18868373	417.75612	4.25003	98.29479
9	23921	Logans Ferry	100	4	2019-09-22	32477	161137	16147896	497.21021	4.96157	100.21222
10	23840	Arsenal	WR453	4	2019-08-28	39579	128659	8977058	226.81366	3.25069	69.77404
11	23714	Pine Creek	80E	4	2019-07-31	24285	48340	13200801	543.57838	1.99053	273.08235
12	23871	Mt Nebo	WR853	4	2019-07-11	23485	73036	23685068	1008.51897	3.10990	324.29306
13	23870	Mt. Nebo	65K	4	2019-07-11	33379	77098	10931130	327.48525	2.30978	141.78228
14	4484	Manchester	BKR	4	2019-06-28	2940	11733	8305903	2825.13707	3.99082	707.90957
15	23882	Rankin	80E	3	2019-12-01	25319	77348	11005947	434.69122	3.05494	142.29129
16	23679	Woodville	R100	3	2019-11-27	18070	53064	7698055	426.01300	2.93658	145.07114
17	23630	Sewickley	WR601	3	2019-11-27	23425	43993	7177001	306.38211	1.87804	163.13961
18	23791	Legionville	100	2	2019-12-17	16815	38050	8474019	503.95593	2.26286	222.70746
19	23732	Universal	BKR	2	2019-12-02	22516	40431	7720999	342.91166	1.79566	190.96730
20	23844	Arsenal	WR872	2	2019-11-27	30732	64187	7934071	258.16969	2.08860	123.60869
21	22556	Logans Ferry-U.S. Gypsum	BKR	2	2019-10-31	3750	17127	7066882	1884.50187	4.56720	412.61645
22	23841	Arsenal	65K	2	2019-10-27	34765	94632	9501657	273.31100	2.72205	100.40638
23	23820	Highland	EA891	2	2019-08-29	29944	73650	8710791	290.90272	2.45959	118.27279
24	23680	Woodville	BKR	2	2019-08-15	25698	111293	7592802	295.46276	4.33080	68.22354
25	23707	North	15K	1	2019-11-29	24830	59973	7292985	293.71667	2.41534	121.60447
26	23781	Valley	100	1	2019-11-27	21397	25818	8092235	378.19484	1.20662	313.43384
27	4428	Suffolk	BKR	1	2019-08-17	3893	4376	7443308	1911.97226	1.12407	1700.93876