

APPENDIX D

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR  
RELIABILITY REPORTING PURPOSES TO  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
P O BOX 3265  
HARRISBURG, PA 17105-3265

**An original of this request is to be either electronically filed (eFiled) with the Commission or filed in paper form with the Secretary's Bureau.**

Information Required:

1. Requesting Utility: PECO Energy Company  
Address: 2301 Market Street  
Philadelphia, PA 19101

2. Name and title of person making request:

Richard Cornforth

*(Name)*

Director of Engineering

*(Title)*

3. Telephone number: 215-841-5843  
*(Telephone Number)*

4. Interruption or Outage:

(a) Number of customers affected: 456,480  
Total number of customers in service territory: 1,668,225

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Outage Cases	
Delaware County	407
Chester County	466
Montgomery County	398
Bucks County	807
Philadelphia	290
York County	8

(c) Reason for interruption or outage, including weather data where applicable:

PECO Service territory was hit with a Derecho (rare straight-line windstorm) with storm gusts ranging from 60-80 mph throughout the service territory. Downed trees and falling tree limbs on power lines interrupted electric service to 456,480 customers.

**Forecast issued on TUESDAY, JUNE 2, 2020 TIME: 12:55**

There will be a chance of strong storms Wednesday afternoon and evening as another trough moves across the Mid-Atlantic. Any strong storms that develop could produce strong wind gusts, frequent lightning and small hail. An isolated tornado will also be possible. This trough will be followed by a cold front on Thursday, which will bring another round of thunderstorms.

**Forecast issued on WEDNESDAY, JUNE 3, 2020 TIME: 12:55**

Strong to severe thunderstorms continue to push eastward across the region with additional scattered thunderstorm development possible late this afternoon into the early evening. Any strong storms that develop could produce strong wind gusts, frequent lightning and small hail. An isolated tornado will also be possible.

---

(d) The number of utility workers and others assigned specifically to the repair work:  
4,643

---

(e) The date and time of the first notification of a service interruption: 06/03/2020 11:15

(f) The actual time that service was restored to the last affected customer: 06/09/2020 19:00

---

Remarks: All PECO employees supported emergency response efforts in conjunction with crews from PECO's Exelon sister utilities BGE, ComEd, and Pepco. Over 3750 contractors from 25 states and Canada assisted in PECO's restoration efforts.

---