

**Application of Pennsylvania-American Water Company for Acquisition of
the Wastewater Assets of Royersford Borough**

66 Pa. C.S. §1329

**Application Filing Checklist – Water/Wastewater
Docket No. A-2020-3019634**

20. Proof of Compliance - provide proof of compliance with applicable design, construction and operation standards of DEP or of the county health department, or both, including:
- e. Provide documentation evidencing a 5-year compliance history with DEP with an explanation of each violation for the seller's utilities that have been providing service as well as provide a copy of any DEP-approved corrective action plans.

RESPONSE:

- e. See enclosed letter from Mike Leonard, Borough Manager and a copy of the DEP Approved Correction Action Plan, referred to on Page 4 of the 2019 Chapter 94 report filed as part of the Application's **Appendix A-20-c** both of which are attached as **Amended Appendix A-20-e**.



BOROUGH OF ROYERSFORD

300 MAIN STREET
ROYERSFORD, PENNSYLVANIA 19468
(610) 948-3737 • FAX (610) 948-2915



June 24, 2020

Royersford Borough's wastewater treatment and collections system has had a strong track record of compliance with applicable design, construction and operations standards of DEP. In the past five years, the Borough has not received any Notice of Violations.

Sincerely,

Michael A. Leonard
Borough Manager
Royersford Borough



Pennsylvania Department of Environmental Protection

2 East Main Street
Norristown, PA 19401
November 14, 2005

Southeast Regional Office

Phone: 484-250-5970
Fax: 484-250-5971

Robert T. Umstead
Borough Manager
Borough of Royersford
P.O. Box 188
Royersford, PA 19468

Re: Municipal Wasteload Management Program
Corrective Action Plan
Royersford Borough
Montgomery County


Dear Mr. Umstead:

We have received and reviewed Mr. Michael D. Sassaman's October 27, 2005 submission of the Borough's Corrective Action Plan (CAP). By means of this letter, we are approving your Corrective Action Plan.

We are requesting your submission of quarterly reports, which are due on the 15th day following each calendar quarter. Your quarterly reports will provide us with an update on tasks completed in the previous quarter and proposed efforts for the next calendar quarter. We anticipate that your first quarterly report, which is due on January 15, 2006, will incorporate a more thorough Connection Management Plan. Please refer to the attached example for processing a Connection Management Plan.

If you should have any comments or questions regarding this letter, please call Mr. Jim McTish of my staff at 484 250-5180.

Sincerely,


James Newbold, P.E.
Regional Manager
Water Management

Cc: Mr. Sassaman – ARRO Consulting, Inc.
Re 30



Borough of Royersford
Corrective Action Plan

The Borough of Royersford has begun work on addressing the Chapter 94 hydraulic and organic overload condition. The following Corrective Action Plan and Schedule is submitted to PaDEP for consideration.

The Borough completed televising of the main sewer trunk line along First Avenue to the wastewater treatment plant. This work identified defects admitting an estimated 32,400 GPD of infiltration/inflow.

1. The Borough will prepare plans and specifications for bidding the sewer repair work along First Avenue. Bidding will be completed by December 15, 2005, and the work performed as soon as groundwater conditions and weather permit.
2. The Borough will prepare plans and specifications for cleaning, televising and recording all of the remaining sewers in the Borough. Bidding will be completed by January 15, 2006, and the work will be completed by May 15, 2006.
3. The Borough will have its engineer review the results of the system-wide televising and prepare a report that prioritizes the infiltration/inflow sources and defects, and presents cost estimates for repairs to eliminate infiltration/inflow. This report will be complete by June 30, 2006.
4. The Borough will prepare plans and specifications for sewer rehabilitation based on the findings and recommendations of the engineer's report in Item 3 above. The bidding will be completed by August 2006 and rehabilitation will follow as soon as groundwater and weather conditions allow.
5. The Borough will proceed with the design and permitting of additional facilities at the wastewater treatment plant to expand the capacity to 750,000 GPD. The current design organic capacity of the plant is 1,329 pounds of BOD and the Borough will submit calculations to PaDEP justifying that revision to the permit.

The design work will begin by December 1, 2005, and will be completed by April 2006. Permit applications will be submitted to PaDEP and DRBC for the expanded plant capacity. Following approvals, the construction contracts will be bid and construction started.

6. The Borough will pay for all of the above-listed repairs and improvements by using the \$1,273,872 in tap-in fees that will come from the currently-proposed 455 EDUs.