



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA WRTPMunicipality: City of ChesterWatershed: 3gCounty: DelawareMonth: NovemberYear: 2015NPDES Permit No.: PA0027103 A3Renewal application due 180 days prior to expiration.This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	27.98			224	52,271	3440.00	2.18	23330
2	27.76			284	65,751	3275.00	0.80	251910
3	27.07			297	67,052	4410.00	0.30	177990
4	27.27	298	67,775	316	71,868	3800.00	0.40	223600
5	27.41			389	88,925	3090.00	0.46	251470
6	25.88			321	69,284	3640.00	0.75	212980
7	22.69			293	55,446	3770.00	1.36	
8	25.74			190	40,788	3445.00	1.81	38060
9	24.58			366	75,029	3260.00	1.36	197940
10	31.78			276	73,152	3315.00	1.03	244560
11	26.42	342	75,357	264	58,170	3710.00	1.23	225290
12	26.52			244	53,967	4275.00	1.61	220560
13	27.11			281	63,533	3805.00	1.19	240170
14	23.92			260	51,868	3950.00	2.06	241120
15	24.43			123	25,061	3935.00	1.47	37130
16	27.90			340	79,113	3935.00	0.98	159640
17	28.19			224	52,663	4000.00	0.94	200840
18	25.15	364	76,349	452	94,807	4135.00	1.02	199210
19	37.46			532	166,206	4435.00	1.22	227970
20	30.81			423	108,692	4470.00	1.38	0
21	26.25			250	54,731	4930.00	2.01	0
22	25.67			177	37,894	3540.00	2.46	237360
23	26.75			307	68,490	2880.00	1.79	228540
24	27.89			300	69,781	3480.00	1.67	268180
25	27.47	392	89,807	317	72,625	3675.00	2.07	214360
26	27.27			240	54,584	3720.00	2.69	237740
27	26.85			370	82,854	3545.00	1.48	236890
28	26.49			251	55,453	3565.00	1.96	241700
29	28.08			220	51,521	3065.00	2.00	255550
30	27.20			363	82,346	2840.00	1.71	248080
31								
Avg	27.2	349	77,322	296	68,131	3,711	1	198,351
Max	37.46	392	89,807	532	166,206	4,930	3	268,180

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By:

Michael DiSantis

Title:

Dir. Of Operations and MaintenanceLicense No.: T0403

Date:

12/28/2015



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

3800-FM-BPNPMSM0437 3/2012

Facility Name: DELCO STA STP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: November Year: 2015
NPDES Permit No.: PA0027103 A3
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify):			Domestic Holding Tank			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)
1				Headworks				Sludge Thickening				Headworks		
2				Headworks				Sludge Thickening	68350			Headworks	68,350	0
3				Headworks				Sludge Thickening	47850			Headworks	47,850	0
4				Headworks				Sludge Thickening	100400			Headworks	100,400	0
5				Headworks				Sludge Thickening	63750			Headworks	63,750	0
6				Headworks				Sludge Thickening	49200			Headworks	49,200	0
7				Headworks				Sludge Thickening	42500			Headworks	42,500	0
8				Headworks				Sludge Thickening				Headworks		
9				Headworks				Sludge Thickening	38450			Headworks	38,450	0
10				Headworks				Sludge Thickening	70650			Headworks	70,650	0
11				Headworks				Sludge Thickening	55213			Headworks	55,213	0
12				Headworks				Sludge Thickening	74800			Headworks	74,800	0
13				Headworks				Sludge Thickening	70100			Headworks	70,100	0
14				Headworks				Sludge Thickening	33400			Headworks	33,400	0
15				Headworks				Sludge Thickening				Headworks		
16				Headworks				Sludge Thickening	79300			Headworks	79,300	0
17				Headworks				Sludge Thickening	74880			Headworks	74,880	0
18				Headworks				Sludge Thickening	59970			Headworks	59,970	0
19				Headworks				Sludge Thickening	63137			Headworks	63,137	0
20				Headworks				Sludge Thickening	48000			Headworks	48,000	0
21				Headworks				Sludge Thickening	24000			Headworks	24,000	0
22				Headworks				Sludge Thickening				Headworks		
23				Headworks				Sludge Thickening	56900			Headworks	56,900	0
24				Headworks				Sludge Thickening	44050			Headworks	44,050	0
25				Headworks				Sludge Thickening	66560			Headworks	66,560	0
26				Headworks				Sludge Thickening				Headworks		
27				Headworks				Sludge Thickening	49360			Headworks	49,360	0
28				Headworks				Sludge Thickening	35125			Headworks	35,125	0
29				Headworks				Sludge Thickening				Headworks		
30				Headworks				Sludge Thickening	73850			Headworks	73,850	0
31				Headworks				Sludge Thickening				Headworks		
Avg									57,908			Monthly Totals:	1,389,795	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 12/28/2015



DEPARTMENT OF ENVIRONMENTAL PROTECTION

3800-FM-BPNPSM0450 3/2012

This permit will expire on: April 30, 2018

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

12/28/2015



SUPPLEMENTAL REPORT
DAILY EFFLUENT MONITORING

Facility Name: DELCORA WRTTP
Municipality: City of Chester
Watershed: 3G
Laboratories: DELCORA, ALS Environmental

Month: 11 (select number)
Year: 2015
Permit No.: PA0027103 A3
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

County: Delaware

Parameter	Flow	TSS	CBOD5
Sample Date	1	RI	RI
1	11/07/15	22.5	194
Mon	11/08/15	22.5	204
Tue	11/09/15	29.7	242
Wed	11/10/15	21.8	272
Thu	11/11/15	21.8	272
Fri	11/12/15	24.4	280
Sat	11/13/15	20.0	181
Sun	11/14/15	20.0	158
Mon	11/15/15	24.5	158
Tue	11/16/15	27.8	220
Wed	11/17/15	24.4	201
Thu	11/18/15	24.4	223
Fri	11/19/15	21.1	278
Sat	11/20/15	20.0	178
Sun	11/21/15	24.4	111
Mon	11/22/15	27.8	302
Tue	11/23/15	22.5	308
Wed	11/24/15	24.4	324
Thu	11/25/15	24.4	324
Fri	11/26/15	24.4	324
Sat	11/27/15	24.4	477
Sun	11/28/15	24.4	308
Mon	11/29/15	24.4	308
Tue	11/30/15	24.4	401
Wed	11/01/16	24.4	308
Thu	11/02/16	24.4	308
Fri	11/03/16	24.4	308
Sat	11/04/16	24.4	308
Sun	11/05/16	24.4	308
Mon	11/06/16	24.4	308
Tue	11/07/16	24.4	308
Wed	11/08/16	24.4	308
Thu	11/09/16	24.4	308
Fri	11/10/16	24.4	308
Sat	11/11/16	24.4	308
Sun	11/12/16	24.4	308
Mon	11/13/16	24.4	308
Tue	11/14/16	24.4	308
Wed	11/15/16	24.4	308
Thu	11/16/16	24.4	308
Fri	11/17/16	24.4	308
Sat	11/18/16	24.4	308
Sun	11/19/16	24.4	308
Mon	11/20/16	24.4	308
Tue	11/21/16	24.4	308
Wed	11/22/16	24.4	308
Thu	11/23/16	24.4	308
Fri	11/24/16	24.4	308
Sat	11/25/16	24.4	308
Sun	11/26/16	24.4	308
Mon	11/27/16	24.4	308
Tue	11/28/16	24.4	308
Wed	11/29/16	24.4	308
Thu	11/30/16	24.4	308
Fri	12/01/16	24.4	308
Sat	12/02/16	24.4	308
Sun	12/03/16	24.4	308
Mon	12/04/16	24.4	308
Tue	12/05/16	24.4	308
Wed	12/06/16	24.4	308
Thu	12/07/16	24.4	308
Fri	12/08/16	24.4	308
Sat	12/09/16	24.4	308
Sun	12/10/16	24.4	308
Mon	12/11/16	24.4	308
Tue	12/12/16	24.4	308
Wed	12/13/16	24.4	308
Thu	12/14/16	24.4	308
Fri	12/15/16	24.4	308
Sat	12/16/16	24.4	308
Sun	12/17/16	24.4	308
Mon	12/18/16	24.4	308
Tue	12/19/16	24.4	308
Wed	12/20/16	24.4	308
Thu	12/21/16	24.4	308
Fri	12/22/16	24.4	308
Sat	12/23/16	24.4	308
Sun	12/24/16	24.4	308
Mon	12/25/16	24.4	308
Tue	12/26/16	24.4	308
Wed	12/27/16	24.4	308
Thu	12/28/16	24.4	308
Fri	12/29/16	24.4	308
Sat	12/30/16	24.4	308
Sun	12/31/16	24.4	308
Mon	01/01/17	24.4	308
Tue	01/02/17	24.4	308
Wed	01/03/17	24.4	308
Thu	01/04/17	24.4	308
Fri	01/05/17	24.4	308
Sat	01/06/17	24.4	308
Sun	01/07/17	24.4	308
Mon	01/08/17	24.4	308
Tue	01/09/17	24.4	308
Wed	01/10/17	24.4	308
Thu	01/11/17	24.4	308
Fri	01/12/17	24.4	308
Sat	01/13/17	24.4	308
Sun	01/14/17	24.4	308
Mon	01/15/17	24.4	308
Tue	01/16/17	24.4	308
Wed	01/17/17	24.4	308
Thu	01/18/17	24.4	308
Fri	01/19/17	24.4	308
Sat	01/20/17	24.4	308
Sun	01/21/17	24.4	308
Mon	01/22/17	24.4	308
Tue	01/23/17	24.4	308
Wed	01/24/17	24.4	308
Thu	01/25/17	24.4	308
Fri	01/26/17	24.4	308
Sat	01/27/17	24.4	308
Sun	01/28/17	24.4	308
Mon	01/29/17	24.4	308
Tue	01/30/17	24.4	308
Wed	01/31/17	24.4	308
Thu	02/01/17	24.4	308
Fri	02/02/17	24.4	308
Sat	02/03/17	24.4	308
Sun	02/04/17	24.4	308
Mon	02/05/17	24.4	308
Tue	02/06/17	24.4	308
Wed	02/07/17	24.4	308
Thu	02/08/17	24.4	308
Fri	02/09/17	24.4	308
Sat	02/10/17	24.4	308
Sun	02/11/17	24.4	308
Mon	02/12/17	24.4	308
Tue	02/13/17	24.4	308
Wed	02/14/17	24.4	308
Thu	02/15/17	24.4	308
Fri	02/16/17	24.4	308
Sat	02/17/17	24.4	308
Sun	02/18/17	24.4	308
Mon	02/19/17	24.4	308
Tue	02/20/17	24.4	308
Wed	02/21/17	24.4	308
Thu	02/22/17	24.4	308
Fri	02/23/17	24.4	308
Sat	02/24/17	24.4	308
Sun	02/25/17	24.4	308
Mon	02/26/17	24.4	308
Tue	02/27/17	24.4	308
Wed	02/28/17	24.4	308
Thu	02/29/17	24.4	308
Fri	02/30/17	24.4	308
Sat	03/01/17	24.4	308
Sun	03/02/17	24.4	308
Mon	03/03/17	24.4	308
Tue	03/04/17	24.4	308
Wed	03/05/17	24.4	308
Thu	03/06/17	24.4	308
Fri	03/07/17	24.4	308
Sat	03/08/17	24.4	308
Sun	03/09/17	24.4	308
Mon	03/10/17	24.4	308
Tue	03/11/17	24.4	308
Wed	03/12/17	24.4	308
Thu	03/13/17	24.4	308
Fri	03/14/17	24.4	308
Sat	03/15/17	24.4	308
Sun	03/16/17	24.4	308
Mon	03/17/17	24.4	308
Tue	03/18/17	24.4	308
Wed	03/19/17	24.4	308
Thu	03/20/17	24.4	308
Fri	03/21/17	24.4	308
Sat	03/22/17	24.4	308
Sun	03/23/17	24.4	308
Mon	03/24/17	24.4	308
Tue	03/25/17	24.4	308
Wed	03/26/17	24.4	308
Thu	03/27/17	24.4	308
Fri	03/28/17	24.4	308
Sat	03/29/17	24.4	308
Sun	03/30/17	24.4	308
Mon	03/31/17	24.4	308
Tue	04/01/17	24.4	308
Wed	04/02/17	24.4	308
Thu	04/03/17	24.4	308
Fri	04/04/17	24.4	308
Sat	04/05/17	24.4	308
Sun	04/06/17	24.4	308
Mon	04/07/17	24.4	308
Tue	04/08/17	24.4	308
Wed	04/09/17	24.4	308
Thu	04/10/17	24.4	308
Fri	04/11/17	24.4	308
Sat	04/12/17	24.4	308
Sun	04/13/17	24.4	308
Mon	04/14/17	24.4	308
Tue	04/15/17	24.4	308
Wed	04/16/17	24.4	308
Thu	04/17/17	24.4	308
Fri	04/18/17	24.4	308
Sat	04/19/17	24.4	308
Sun	04/20/17	24.4	308
Mon	04/21/17	24.4	308
Tue	04/22/17	24.4	308
Wed	04/23/17	24.4	308
Thu	04/24/17	24.4	308
Fri	04/25/17	24.4	308
Sat	04/26/17	24.4	308
Sun	04/27/17	24.4	308
Mon	04/28/17	24.4	308
Tue	04/29/17	24.4	308
Wed	04/30/17	24.4	308
Thu	05/01/17	24.4	308
Fri	05/02/17	24.4	308
Sat	05/03/17	24.4	308
Sun	05/04/17	24.4	308
Mon	05/05/17	24.4	308
Tue	05/06/17	24.4	308
Wed	05/07/17	24.4	308
Thu	05/08/17	24.4	308
Fri	05/09/17	24.4	308
Sat	05/10/17	24.4	308
Sun	05/11/17	24.4	308
Mon	05/12/17	24.4	308
Tue	05/13/17	24.4	308
Wed	05/14/17	24.4	308
Thu	05/15/17	24.4	308
Fri	05/16/17	24.4	308
Sat	05/17/17	24.4	308
Sun	05/18/17	24.4	308
Mon	05/19/17	24.4	308
Tue	05/20/17	24.4	308
Wed	05/21/17	24.4	308
Thu	05/22/17	24.4	308
Fri	05/23/17	24.4	308
Sat	05/24/17	24.4	308
Sun	05/25/17	24.4	308
Mon	05/26/17	24.4	308
Tue	05/27/17	24.4	308
Wed	05/28/17	24.4	308
Thu	05/29/17	24.4	308
Fri	05/30/17	24.4	308
Sat	05/31/17	24.4	308
Sun	06/01/17	24.4	308
Mon	06/02/17	24.4	308
Tue	06/03/17	24.4	308
Wed	06/04/17	24.4	308
Thu	06/05/17	24.4	308
Fri	06/06/17	24.4	308
Sat	06/07/17	24.4	308
Sun	06/08/17	24.4	308
Mon	06/09/17	24.4	308
Tue	06/10/17	24.4	308
Wed	06/11/17	24.4	308
Thu	06/12/17	24.4	308
Fri	06/13/17	24.4	308
Sat	06/14/17	24.4	308
Sun	06/15/17	24.4	308
Mon	06/16/17	24.4	308
Tue	06/17/17	24.4	308
Wed	06/18/17	24.4	308
Thu	06/19/17	24.4	308
Fri	06/20/17	24.4	308
Sat	06/21/17	24.4	308
Sun	06/22/17	24.4	308
Mon	06/23/17	24.4	308
Tue	06/24/17	24.4	308
Wed	06/25/17	24.4	308
Thu	06/26/17	24.4	308
Fri	06/27/17	24.4	308
Sat	06/28/17	24.4	308
Sun	06/29/17	24.4	308
Mon	06/30/17	24.4	308
Tue	07/01/17	24.4	308
Wed	07/02/17	24.4	308
Thu	07/03/17	24.4	308
Fri	07/04/17	24.4	308
Sat	07/05/17	24.4	308
Sun	07/06/17	24.4	308
Mon	07/07/17	24.4	308
Tue	07/08/17	24.4	308
Wed	07/09/17	24.4	308
Thu	07/10/17	24.4	308
Fri	07/11/17	24.4	308
Sat	07/12/17	24.4	308
Sun	07/13/17	24.4	308
Mon	07/14/17	24.4	308
Tue	07/15/17	24.4	308
Wed	07/16/17	24.4	308
Thu	07/17/17	24.4	308
Fri	07/18/17	24.4	308
Sat	07/19/17	24.4	308
Sun	07/20/17	24.4	308
Mon	07/21/17	24.4	308
Tue	07/22/17	24.4	308
Wed	07/23/17	24.4	308
Thu	07/24/17	24.4	308
Fri	07/25/17	24.4	308
Sat	07/26/17	24.4	308
Sun	07/27/17	24.4	308
Mon	07/28/17	24.4	308
Tue	07/29/17	24.4	308
Wed	07/30/17	24.4	308
Thu	07/31/17	24.4	308
Fri	08/01/17	24.4	308
Sat	08/02/17	24.4	308
Sun	08/03/17		



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name:
Municipality:
Watershed:

Delaware County Regional Water Quality Control Authority
City of Chester
3G

County: Delaware
Month: November
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Year: 2015

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	
010	5th & Pusey	Yes	
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	No	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	
			Total overflow from Outfalls 009 and 010 Discharges to Outfall 009 Regulator

Copy this report as needed to include more CSO outfalls.
* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 12/14/2015

Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Monday, January 25, 2016 4:34 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 8116 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 8116
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 12/01/2015-12/31/2015
Monitoring Report Due Date : 01/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

January 25, 2015

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for December, 2015. All parameters were in compliance during the month.

Parameter averages for December, 2015 were: Flow – 33.89; cBOD₅ – 11mg/L; TSS – 13 mg/L; cBOD₂₀ % removal – 91.37%; and cBOD₂₀ – 5,903 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELCORA STP
Permit Number:	PA0027103	Monitoring Period:	12/01/2015-12/31/2015
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	Stage Code			Final Effluent	No Discharge Indicator		N
		Load 1	Load 2	Units		Conc 1	Conc 2	
pH	Sample Measurement Permit Measurement	6.45	6.45	Inst Min	6.97	6.97	9.0	1/day
Total Suspended Solids	Sample Measurement Permit Measurement	3905	5269	lbs/day	20	45	Wkly Avg	1/day
Oil and Grease	Sample Measurement Permit Measurement	11000	16500	Wkly Avg	45	45	Wkly Avg	1/day
	Sample Measurement Permit Measurement	<1413		lbs/day	<5	<5		1/day
Ammonia-Nitrogen	Sample Measurement Permit Measurement	5500			30	30	IMAX	1/day
	Sample Measurement Permit Measurement				12.19	12.19		2/month
Nitrite an N	Sample Measurement Permit Measurement				<4	<4	Monitor & Report Avg Mo	2/month
	Sample Measurement Permit Measurement				17.1	17.1	Monitor & Report Daily Max	2/month
Nitrate as N	Sample Measurement Permit Measurement				8.76	8.76	Monitor & Report Avg Mo	2/month
	Sample Measurement Permit Measurement				12.2	12.2	Monitor & Report Avg Mo	2/month
Total Kjeldahl Nitrogen	Sample Measurement Permit Measurement				.012	.012	Monitor & Report Avg Mo	1/month
Cyanide, Total	Sample Measurement Permit Measurement				<.001	<.001	Monitor & Report Avg Mo	1/month
Chlorodibromomethane	Sample Measurement Permit Measurement				<.001	<.001	Monitor & Report Avg Mo	1/month
Cadmium, Total	Sample Measurement Permit Measurement				<.005	<.005	Monitor & Report Avg Mo	1/month
Copper, Total	Sample Measurement Permit Measurement				<.025	<.025	Monitor & Report Avg Mo	1/month
Lead, Total	Sample Measurement Permit Measurement				<.015	<.015	Monitor & Report Avg Mo	1/month
Zinc, Total	Sample Measurement Permit Measurement				<.05	<.05	Monitor & Report Avg Mo	1/day
Dichlorobromomethane	Sample Measurement Permit Measurement				<.001	<.001	Monitor & Report Avg Mo	1/month

Flow	Sample Measurement	33.39	56.25	MGD		***	***	***	***	***	***	Meiered	Continuous
	Permit Measurement	Monitor & Report Avg Mo	Monitor & Report Daily Max			***	***	***	***	***	***	Metered	Continuous
Total Residual Chlorine (TRC)	Sample Measurement	***	***	***		***	***	.4	.65	mg/L	Grab	1/day	
	Permit Measurement	***	***			***	***	.5	1.0	IMAX	Grab	1/day	
Total Dissolved Solids	Sample Measurement	***	***	***		***	***	592	712	mg/L	24-Hr Composite	5/week	
	Permit Measurement	***	***			***	***	Monitor & Report Avg Mo	Monitor & Report Daily Max		24-Hr Composite	2/month	
Fecal Coliform	Sample Measurement	***	***	***		***	***	21	41	CFU/100 ml	Grab	1/day	
	Permit Measurement	***	***			***	***	200	1000		Grab	1/day	
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	Sample Measurement	3284	4278	lbs/day		***	***	11	14	mg/L	24-Hr Composite	1/day	
	Permit Measurement	7000	10500	Wkly Avg		***	***	19	29		24-Hr Composite	1/day	
BOD, carbonaceous, 20 day, 20 C	Sample Measurement	5903	***	lbs/day		***	***	Avg Mo	Wkly Avg		24-Hr Composite	3/week	
	Permit Measurement	10500	***			***	***	***	***		24-Hr Composite	1/week	
BOD, carbonaceous, 20 day, 20 C	Sample Measurement	***	***	***		91.37	***	***	***	%	24-Hr Composite	3/week	
	Permit Measurement	***	***			89.25	***	***	***		24-Hr Composite	1/week	
Biochemical Oxygen Demand (BOD ₅)	Sample Measurement	119387	***	lbs/day		***	***	400	***	mg/L	24-Hr Composite	1/week	
	Permit Measurement	Monitor & Report Avg Mo	***			***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/week	
Total Suspended Solids	Sample Measurement	80007	***	lbs/day		***	***	280	***	mg/L	24-Hr Composite	1/day	
	Permit Measurement	Monitor & Report Avg Mo	***			***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/day	
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	Sample Measurement	77152	***	lbs/day		***	***	275	***	mg/L	24-Hr Composite	1/day	
	Permit Measurement	Monitor & Report Avg Mo	***			***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/day	
Facility Comments						.							

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
Daily Effluent Monitoring Dec 2015.xlsx	Daily Effluent Monitoring Form	2016-01-25T11:15:33-05:00	
Cryptographic Hash Value of File (SHA-512)		0A6A71671EE2DCB78BAFA2A32CD3CDD5F4BBA35170A1225A5EACA4015AF3A5D862F782767C3C867C299337CD9B73A519A200C3C1CC2ED0031F32EE4C3320FC693C	
Daily Influent Monitoring Dec 2015.xlsx	Daily Influent Monitoring Form	2016-01-25T11:16:08-05:00	Daily Influent Monitoring Dec 2015
Cryptographic Hash Value of File (SHA-512)		26F1E5F9AD5112ED0987E1B54A16844E51ACF005D825959EABE011B3B83485D9F081C3B7D1C1D149D0E0A3703CE268303FEC8E44E4F455AAAB63507D204D981D7	
December 2015 SWMM Report.xlsx	Other	2016-01-25T11:17:09-05:00	December 2015 SWMM Report
Cryptographic Hash Value of File (SHA-512)		EC4E956284FA1CA868D734FDBC55CDA11B1AE97F0D7755064B7ABDEA32F9EDA058E5AE83270A2BDFD20746D0B5396C7C9C25899B29665E7FF314D2938167FB6	
Influent and Process Control DEC2015.xls	Influent and Process Control Form	2016-01-25T11:18:28-05:00	
Cryptographic Hash Value of File (SHA-512)		230031407E7F68720F3A030857306E5D2D988404944A580D0E3EE132F7359A2C364D18F8169AAEB9A4E246204CA4E3897DDD74363453DE272C8C5726E0F1EF59	
ALS_Biweekly N 2_DEC2015.PDF	Laboratory Analytical Report	2016-01-25T11:20:31-05:00	
Cryptographic Hash Value of File (SHA-512)		FC0C5507A3B7D365947CBE598CA7C880BBBC12C83887EE4F0F77C2E1AD3A326C3624C4326F0C82422293F72F9134588FA189D8B8B8D868E68C093741B93FCABB3C	
12-31-15 hauled sludge from holding tank.xlsx	Other	2016-01-25T11:15:03-05:00	12-31-15 hauled liquid sludge from holding tank
Cryptographic Hash Value of File (SHA-512)		A0CCBD733CD8DFBCCD0A20C33BE5CA01B5B3006A9D901A6D291E5EB32F6BBEC2FB4EAEACB0D1685CDD0BBF047A46729CC307B092B87C1FC88602FB95006FE3587	
Hauled in Municipal Waste (SHA-512)	Hauled in Municipal Waste Form	2016-01-25T11:17:46-05:00	
Cryptographic Hash Value of File (SHA-512)		49582458DBCC362BFC09A647B9C46A86FA4D43D749A3835EDACD4ADADA699D85D173D743F42A597251D5EC0959A783C4E28F938FDE2A29C1C85579F9EDF2275	
Hauled in Residual Wastes_DEC2015.xls	Hauled in Residual Waste Form	2016-01-25T11:18:05-05:00	Hauled in Residual Wastes_DEC2015
Cryptographic Hash Value of File (SHA-512)		94685343E7A066F7D83D06CECED7763807B7E62189A69750FC932A68D2FC97331E6E30B452D94530C738C7B023E92F58113F676878801F5ECA3E9FBD18F58C4	
Sludge Production and Disposal_DEC 2015.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-01-25T11:18:52-05:00	
Cryptographic Hash Value of File (SHA-512)		73CFA47A6506C8D7FE365473A9A8B818E43E9658427C65A6735B8B526BDF123B8F74D7A97084051FA49511890256D80E526A1E8EE3830EF196637973867CC836C4	
DMR Laboratory Accreditation-ALS-DEC 2015.doc	Laboratory Accreditation Form	2016-01-25T11:19:19-05:00	
Cryptographic Hash Value of File (SHA-512)		8B2D6032FEB069BD671520E583E3F7B2CBBDD80BF07E985166DF38131006FB76CFB1E07366D2053B9E9A0E9297E3BEF3C9668BCC4A09522F96CA144A98C6D40	
ALS_Biweekly N 1_DEC2015.PDF	Laboratory Analytical Report	2016-01-25T11:20:08-05:00	
Cryptographic Hash Value of File (SHA-512)		53DB65D72A2A15C819EF8E2FEADF145AF71D4328B6E71A7A063849FD2458A4A417508957351478404F2540951D02AAB3C6F365C19C22D1DE7A7806F2DF792BA6	
WRTP Lab. Daily Effluent Monitoring Dec 2015.xlsx	Laboratory Analytical Report	2016-01-25T11:21:26-05:00	
WRTP Lab. Daily Effluent Monitoring Dec 2015.xlsx	Laboratory Analytical Report	2016-01-25T11:21:44-05:00	
Cryptographic Hash Value of File (SHA-512)		FC90A7478B98D5048DBE9A9DEFF121FE61240A9E61D2846FA7723D35E5AC3EA14C4FC0C4C0C341E445D918EA030322263E0A7F0B534348E481AE5EDF64C	
WRTP Lab. Sludge Production and Disposal_DEC 2015.xlsx	Laboratory Analytical Report	2016-01-25T11:23:05-05:00	
Cryptographic Hash Value of File (SHA-512)		5F485FAF959BE03D190E0FC5B0499CE0C436A1C046D800F32A18CC11C03D67D276870191600682AA928898A026A14405FE1F58082BA5D27159037323C3FDB04	
ALS_CBOD20_12-3-15.PDF	Cryptographic Hash Value of File (SHA-512)		
DMR Cover Letter DEC 2015.doc	Cover Letter	2016-01-25T16:32:22-05:00	
Cryptographic Hash Value of File (SHA-512)		510B938CE8E8661940A6E6D1B56527BD98E4D4FC7F7C55813B6834492036D0243CD07505596F414C647B6D7225022ABE2AC1F7BB6199F1236A2F8D78F8D0AAF2	
ALS_CBOD20_12-6-15.PDF	Laboratory Analytical Report	2016-01-25T11:25:01-05:00	
Cryptographic Hash Value of File (SHA-512)		F2530D266B8A383A4801F7E96D5960E2239F54E40644C70B30042826C9DB28BF67DD86A8AD2F8448F2B322D832183880DF9E3F5CE8E9DF0A378CD38AB48D9509	
ALS_CBOD20_12-8-15.PDF	Laboratory Analytical Report	2016-01-25T11:25:31-05:00	
Cryptographic Hash Value of File (SHA-512)		637A304D4572D83D343976426D81C6D37CB5F231C93DC1F4B6F84957AAD71C95DD66236E5AE350B877FAD221F181E30D9247AD46B88944C39CFD6224F56E5	
ALS_CBOD20_12-17-15.PDF	Laboratory Analytical Report	2016-01-25T11:27:32-05:00	
ALS_CBOD20_12-20-15.PDF	Laboratory Analytical Report	2016-01-25T11:28:13-05:00	
Cryptographic Hash Value of File (SHA-512)		B3625A0F0156D9AD4591819873CE2710F6A047D2450245FA364DEDA21CCFC02C3D0E156EB936FA7F34F39C6927F7395737BD06B630B852BED8D618E53655	
ALS_CBOD20_12-22-15.PDF	Laboratory Analytical Report	2016-01-25T11:28:44-05:00	
Cryptographic Hash Value of File (SHA-512)		8CA62B40DD268B1B9C10929805B44293545248E06A789AF5945B6E19DAFCB5342E27E4FA548D5AC2BFF244BE4D837E0060221D46EEC58A7A01FAAC1E98BC16728	
ALS_CBOD20_12-29-15.PDF	Laboratory Analytical Report	2016-01-25T11:29:45-05:00	
Cryptographic Hash Value of File (SHA-512)		9237E77963C38899450C3CA6A9A0C5E9FC810918D7BCE3CEFF9690CA3F90A8D9D0E08C6E886692BF409D0906EA16361AD33056888B5216E2724C8F359F	
ALS_CBOD20_12-13-15.PDF	Laboratory Analytical Report	2016-01-25T11:26:25-05:00	
Cryptographic Hash Value of File (SHA-512)		42F9A2AE93831311481A5F7C7050E6FC70B0C57548A682D68724A1EEB07F36E441E35E5E554B487709D0A3A6C037B3650A60867F91D80711A553441E5D6773C4AE	
DMR Laboratory Accreditation-WRTP-DEC 2015.doc	Laboratory Accreditation Form	2016-01-25T11:19:39-05:00	
Cryptographic Hash Value of File (SHA-512)		4FF2668036ED83ABB8DAE8EF6917743F7B34E681C28F4602A569216B798E7F2840F9A5452F073D0898EA58F6B203F5B40B6D46D8C4433590D158DFDCC888209	
ALS_Effluent_DEC2015.PDF	Laboratory Analytical Report	2016-01-25T11:20:59-05:00	
Cryptographic Hash Value of File (SHA-512)		F2FAE095DEBE0398DF801C7C738CD62FB2DB9235E8654B4D2D2D20D4C1BA1733EE688005983AC60906DF579039496E68FA3C447D89C39C6C53876AB6E86C21F3BA	

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

WRTPLab_Influent and Process Control DEC2015.docx	Laboratory Analytical Report	2016-01-25T11:22:25-05:00	D6BE020FB0F27717591C01CC6649565766C6D4D8D70FACAD664557989B6DA09CFFCAF96A100BA273B19C03DA7C65635FD73184838C0CC66ABA42469B80EB6D0
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-01-25T11:23:51-05:00	
ALS_CBOD20_12-1-15.PDF	Laboratory Analytical Report	2016-01-25T11:23:51-05:00	E45A52E2BA7D8FE318745185C8C365743731A84389D80C6DE91CD884A4328D18BF0AEE40FBC5785E42CFC4ED321760E6874C30CF74D323065D1705E20126DC
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-01-25T11:25:59-05:00	
ALS_CBOD20_12-10-15.PDF	Laboratory Analytical Report	2016-01-25T11:25:59-05:00	F66F72B600C6003894B8C194F1F54875676DA251C008D4B631A0EE49DA37953FE1A14A1E78AE048F46461CC0EBD35ACC18C429C771F0A67BE79F9F2048A0450
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-01-25T11:27:00-05:00	
ALS_CBOD20_12-15-15.PDF	Laboratory Analytical Report	2016-01-25T11:27:00-05:00	E6A938B945BEC59A3B45DC8E0E03B4E77521A38EDE3D434CBE9B9F3D112C533411A136FC91A21CAAAA62C45D15F501C331CA1E01A6C85A5245C7CDB8E595DBB
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-01-25T11:29:16-05:00	
ALS_CBOD20_12-27-15.PDF	Laboratory Analytical Report	2016-01-25T11:29:16-05:00	060BB169735C2AC2C8B699094DF683DF298BE9437C4977423A55A06B956503E62BE4F6F36D2607B6056322DD1EF66A92784936964BFA7E01A8164AFBF1D146
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report		

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

PERMIT VIOLATIONS												
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type									Comments
COMMENTS DETAILS												
Comment			Operator Name				Operator Certification Number		Operator Contact Number			
			Michael J. DiSantis				TD403		6108765623			
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User			DISANTISM			Submitted By Full Name			Michael DiSantis			
Email Address			disantism@delcova.org			Document Generated			1/25/2016			



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				15	12	01	TO	15	12	31
PARAMETER	ANALYSIS METHOD	LAB NAME				LAB ID NUMBER²				
Copper, Total	EPA 200.7	ALS Environmental				PA 22-293				
Lead, Total	EPA 200.7	ALS Environmental				PA 22-293				
Zinc, Total	EPA 200.7	ALS Environmental				PA 22-293				
Dichlorobromomethane	EPA 624	ALS Environmental				PA 22-293				
BOD20/cBOD20	SM5210 B	ALS Environmental				PA 22-293				
Chlorodibromomethane	EPA 624	ALS Environmental				PA 22-293				
TKN-N	EPA 351.2	ALS Environmental				PA 22-293				
Ammonia as N	D6919-09	ALS Environmental				PA 22-293				
Nitrate as N	EPA 300.0	ALS Environmental				PA 22-293				
Total Cyanide	EPA 335.4	ALS Environmental				PA 22-293				
Total Cadmium	200.7	ALS Environmental				PA 22-293				
Nitrite as N	EPA 300.0	ALS Environmental				PA 22-293				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 01/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				15	12	01	TO 15 12 31
PARAMETER							
ANALYSIS METHOD							
LAB NAME							
LAB ID NUMBER²							
BOD5/cBOD5		SM5210 B		DELCORA - Central Laboratory		23-00671	
TSS		SM 2540 D		DELCORA - Central Laboratory		23-00671	
O&G		EPA 1664 A		DELCORA - Central Laboratory		23-00671	
Total Residual Cl		SM4500-Cl G		DELCORA - Central Laboratory		23-00671	
N-Nitrite		SM4500-NO2 B		DELCORA - Central Laboratory		23-00671	
NH3-N		EPA 350.1		DELCORA - Central Laboratory		23-00671	
TKN-N		SM4500-N-org B/SM4500-NH3 C		DELCORA - Central Laboratory		23-00671	
Fecal Coliform		SM 9222 D		DELCORA - Central Laboratory		23-00671	
BOD20/cBOD20		SM5210 B		DELCORA - Central Laboratory		23-00671	
pH		SM 4500 H+B		DELCORA - Central Laboratory		23-00671	
Ammonia as N		EPA 350.1		DELCORA - Central Laboratory		23-00671	
TDS		SM 2540 C		DELCORA - Central Laboratory		23-00671	

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibly of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 01/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: **December**
NPDES Permit No.: **PA0027103**

Year: 2015

Renewal application due **180 days** prior to expiration
This permit will expire on: **April 30, 2018**

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month

[illegible]

TOTAL:	18,477
---------------	---------------

TOTAL:	720.480
---------------	----------------

TOTAL:	681.432
---------------	----------------

SEWAGE SLUDGE/BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Starks Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**

Dir. Of Operations and Maintenance

License No.:

January 28, 2016

T0403



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA WRTP
Municipality: City of Chester
Watershed: 3g

County: Delaware

Month: December
NPDES Permit No.: PA0027103 A3
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Year: 2015

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	44.79			446	166,603	3175.00	1.97	208590
2	40.16	259	86,748	244	81,724	3090.00	1.60	219710
3	31.42			278	72,848	3285.00	1.97	238750
4	29.52			440	108,327	3400.00	1.99	246040
5	28.06			208	48,676	3890.00	1.98	246480
6	28.79			184	44,180	3640.00	2.26	290690
7	29.36			384	94,027	2595.00	1.52	271790
8	28.56			221	52,640	3255.00	1.69	225780
9	29.26	559	136,412	454	110,789	3205.00	1.55	183380
10	27.33			382	87,070	3560.00	1.31	46850
11	27.51			354	81,219	3495.00	1.10	226690
12	26.88			226	50,664	3745.00	1.96	184170
13	27.25			200	45,453	3710.00	1.51	170700
14	29.49			403	99,116	3550.00	0.85	195470
15	28.95			324	78,228	3995.00	0.99	203860
16	27.72	538	124,377	304	70,280	3590.00	1.16	215860
17	46.79			442	172,481	3795.00	0.90	157290
18	35.83			338	101,002	3395.00	0.93	202450
19	29.72			174	43,128	4270.00	1.70	41650
20	28.92			184	44,379	4090.00	2.14	13110
21	28.90			344	82,913	3995.00	1.09	112260
22	31.30			328	85,622	4150.00	0.81	156990
23	47.56	396	157,074	318	126,135	4135.00	1.15	165470
24	51.61			124	53,373	3670.00	1.12	184710
25	41.69			137	47,634	4595.00	2.61	184050
26	38.86			176	57,040	4295.00	2.01	223750
27	35.59			153	45,414	4305.00	2.23	228620
28	34.07			244	69,331	4050.00	1.32	31660
29	57.16			208	99,157	2920.00	1.14	155270
30	44.28	250	92,324	252	93,062	3880.00	1.23	203840
31	39.40			206	67,691	4705.00	1.47	205300
Avg	34.733	400	119,387	280	80,007	3,724	2	181,975
Max	57.16	559	157,074	454	172,481	4,705	3	290,690

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C. S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 1/28/2016



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: December
NPDES Permit No.: PA0027103 A3

Year: 2015

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify):			Domestic Holding Tank			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)
1				Headworks				Sludge Thickening	57410			Headworks	57,410	0
2				Headworks				Sludge Thickening	98350			Headworks	98,350	0
3				Headworks				Sludge Thickening	49550			Headworks	49,550	0
4				Headworks				Sludge Thickening	99300			Headworks	99,300	0
5				Headworks				Sludge Thickening	17900			Headworks	17,900	0
6				Headworks				Sludge Thickening	63689			Headworks	63,689	0
7				Headworks				Sludge Thickening	101531			Headworks	101,531	0
8				Headworks				Sludge Thickening	69230			Headworks	69,230	0
9				Headworks				Sludge Thickening	86538			Headworks	86,538	0
10				Headworks				Sludge Thickening	58350			Headworks	58,350	0
11				Headworks				Sludge Thickening	50800			Headworks	50,800	0
12				Headworks				Sludge Thickening	106750			Headworks	106,750	0
13				Headworks				Sludge Thickening	58550			Headworks	58,550	0
14				Headworks				Sludge Thickening	66500			Headworks	66,500	0
15				Headworks				Sludge Thickening	83450			Headworks	83,450	0
16				Headworks				Sludge Thickening	60200			Headworks	60,200	0
17				Headworks				Sludge Thickening	22200			Headworks	22,200	0
18				Headworks				Sludge Thickening	67250			Headworks	67,250	0
19				Headworks				Sludge Thickening	68600			Headworks	68,600	0
20				Headworks				Sludge Thickening	96250			Headworks	96,250	0
21				Headworks				Sludge Thickening	56900			Headworks	56,900	0
22				Headworks				Sludge Thickening	23300			Headworks	23,300	0
23				Headworks				Sludge Thickening	132250			Headworks	132,250	0
24				Headworks				Sludge Thickening	61420			Headworks	61,420	0
25				Headworks				Sludge Thickening	88950			Headworks	88,950	0
26				Headworks				Sludge Thickening	83750			Headworks	83,750	0
27				Headworks				Sludge Thickening	70,345			Headworks	70,345	0
28				Headworks				Sludge Thickening	132250			Headworks	132,250	0
29				Headworks				Sludge Thickening	61420			Headworks	61,420	0
30				Headworks				Sludge Thickening	88950			Headworks	88,950	0
31				Headworks				Sludge Thickening	83750			Headworks	83,750	0
Avg									70,345			Monthly Totals:	1,823,968	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 1/28/2016



DEPARTMENT OF ENVIRONMENTAL PROTECTION

3800-FM-BPNSM0450 3/2012

Renewal application due **180 days** prior to expiration.
This permit will expire on: **April 30, 2018**

Total	13,390,028
-------	------------

Date: 1/28/2016

SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name:	DELCOA WRP	Month:	12	Year:	2015
Municipality:	City of Chester	Permit No.:	PA0227103-A3	Cause:	001
Watershed:	3G	County:	Delaware	Renewal application due	130 days prior to expiration.
Baraboders:	DELCOA, ALS Environmental	This permit will expire on:	April 30, 2018		

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or persons directly responsible for gathering the information, the information submitted is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of imprisonment for knowing violations. See 18 P.S. § 9124 (relating to uniform violations).

Prepared By: Micheal DiSantis
Title: Dir. Of Operations and Maintenance
License No.: T0403
Date: 1/28/2016

CSO SUPPLEMENTAL REPORT
MONTHLY INSPECTION REPORT

Facility Name:
Municipality:
Watershed:

Delaware County Regional Water Quality Control Authority
City of Chester County: Delaware
3G

Month: **December** Year: **2015**
 NPDES Permit No.: **PA0027103**
 Renewal application due **180 days** prior to expiration.
 This permit will expire on: **April 30, 2018**

CSO Outfall No.	Outfall Location	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	Total overflow from Outfalls 009 and 010
010	5th & Pusey	Yes	Discharges to Outfall 009 Regulator
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael J. DiSantis**
Dir. Of Operations and Maintenance

License No.: T0403
Date: 1/11/2016

Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Monday, January 25, 2016 3:48 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 8101 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 8101
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Annually
Monitoring Report Period : 01/01/2015-12/31/2015
Monitoring Report Due Date : 01/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

January 25, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed is DELCORA's Annual Stormwater Discharge Monitoring Report for 2015

Should any further information be required concerning this report, please contact me at 610-876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523

☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526

☐ FAX: 610-876-1480

PURCHASING & STORES

☐ 610-876-5523

☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523

☐ FAX: 610-497-7950



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

**ADDITIONAL INFORMATION
FOR THE REPORTING OF STORMWATER DISCHARGE MONITORING**

(This form must be completed and submitted with the DMR form for each outfall sampled)

A. PERMITTEE'S NAME: DELCORA		OUTFALL/DISCHARGE NO.: 028
FACILITY/LOCATION: Western Regional Treatment Plant, 3201 West Front Street, Chester, PA 19016		
B. SAMPLED STORM EVENT		
Provide the date of storm event: 09/29/2015	Provide the duration (in hours) of storm event: 48hrs	
Estimate rainfall measurements (in inches) of the storm which generated the sample runoff: .80 inches	Estimate the duration between the storm event sampled and the end of the previous measurement (greater than 0.1 inch rainfall) storm event: 18 days.	
Drainage area and volume of runoff (1) Paved area <u>217,800</u> square feet x 0.9 (estimated runoff coefficient) x rainfall <u>.80</u> inches x 0.6234 = <u>97759.09</u> gallons (2) Unpaved area 108,900 square feet x 0.5 (estimated runoff coefficient) x rainfall <u>.80</u> inches x 0.6234 = <u>27155.30</u> gallons Total area <u>326,700</u> square feet Total volume of discharge <u>124914.39</u> gallons		
C. GRAB SAMPLE METHODOLOGY		
If a grab sample during the first 30 minutes of the discharge was impracticable, and the sample was instead taken during the first hour of the discharge, describe the circumstances: N/A		
D. SAMPLE WAIVER		
If samples could not be collected due to adverse climatic conditions, describe why samples could not be collected. Attach available documentation of the event. N/A		
If monitoring data submitted is being used to represent other substantially identical outfalls, summarize on a drainage area and volume of runoff under item B. above for each outfall.		

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELCORA STP
Permit Number:	PA0027103	Monitoring Period:	01/01/2015-12/31/2015
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES												
Sampling Point	028			Stage Code			Final Effluent			No Discharge Indicator	N	
Parameter	Limit Type	Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency		
Chemical Oxygen Demand (COD)	Sample Measurement	mg	mg	mg	mg	mg	65	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
pH	Sample Measurement	mg	mg	mg	mg	mg	7.52	S.U.	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Total Suspended Solids	Sample Measurement	mg	mg	mg	mg	mg	52	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Oil and Grease	Sample Measurement	mg	mg	mg	mg	mg	<2.0	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Total Kjeldahl Nitrogen	Sample Measurement	mg	mg	mg	mg	mg	1.7	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Total Phosphorus	Sample Measurement	mg	mg	mg	mg	mg	.44	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Iron, Dissolved	Sample Measurement	mg	mg	mg	mg	mg	.10	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Carbonaceous Biochemical Oxygen Demand (CBOD5)	Sample Measurement	mg	mg	mg	mg	mg	6	mg/L	Grab	1/year		
	Permit Measurement	mg	mg		mg		Monitor & Report Daily Max		Grab	1/year		
Facility Comments												

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS			
File Name	Attachment Type	Uploaded Time	Attachment Comment
Stormwater Monitoring 2015.docx	Stormwater Additional Information Form	2016-01-25T12:08:22-05:00	
Cryptographic Hash Value of File (SHA-512)			C967537048323865A0DD82BA4224DCCCFDE4151108CA1B0DAE565C7782831547ADBD1BD4385E5B2759E08FD4746DEB3A9E521D2E0A8570CE5E6A8342B6CAE9CE
DMR Laboratory Accreditation-WRTP-SEP 2015.doc	Laboratory Accreditation Form	2016-01-25T15:46:56-05:00	
Cryptographic Hash Value of File (SHA-512)			32E8856CA73573C13CB86520BD1FF15CE6B6C9788B03F6A0C41FDD8DCEFE0E9C7F4D1B6071C1C31EBFF2B673A305A989FF524D346B1BE1E29D68C8117A7532E
ALS_Stormwater 2015.pdf	Laboratory Analytical Report	2016-01-25T12:07:32-05:00	
Cryptographic Hash Value of File (SHA-512)			8FEB03BF9BAC24B5AF434D70830F80C320C65353232F774BA368D3DB9C2D73A8EF5AD3000BCB965D974C6D386CC104F938A3BF72D5183CE85481B6FB19C6076C
DMR Laboratory Accreditation-ALS-SEP 2015.doc	Laboratory Accreditation Form	2016-01-25T15:46:05-05:00	
Cryptographic Hash Value of File (SHA-512)			295EBA7BECFF25CE8F5D467BC1F7E4C480353A8B542A5C3EECD518E7FD12D600F121E02ADA4AD614769CD33FE93EECD2B4A74E38BC1D600E5475FFFEDE0D03F80
Stormwater DMR Cover Letter 2015.doc	Cover Letter	2016-01-25T15:47:31-05:00	
Cryptographic Hash Value of File (SHA-512)			E0BC5D032461AC4DE8A0CAC1C819F7C353D5C0D7DA4A72BF57E12FCE707BE1ADD33BBCCD398AC363D09094B277C153F5DF649EE46BFC499C75CE5D0455739A6

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

PERMIT VIOLATIONS											
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments
UNAUTHORISED DISCHARGES											
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	Comments
OTHER PERMIT VIOLATIONS											
Non Compliance ID	Stage Code (Sampling Point)		Reported Parameter	Non Compliance Type		Comments					
COMMENTS DETAILS											
Comment			Operator Name				Operator Certification Number		Operator Contact Number		
			Michael J. DiSantis				T0403		6108765523		
SUBMISSION INFORMATION											
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).											
Submitted By GreenPort User			DISANTISM		Submitted By Full Name		Michael DiSantis				
Email Address			disantism@delcora.org		Document Generated		1/25/2016				



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				15	09	01	TO 15 09 30
PARAMETER							
ANALYSIS METHOD							
LAB NAME							
LAB ID NUMBER²							
Phosphorous, Total		EPA 365.1		ALS Environmental		PA 22-293	
Total Suspended Solids		S2540D-11		ALS Environmental		PA 22-293	
Chemical Oxygen Demand		EPA 410.4		ALS Environmental		PA 22-293	
Oil and Grease		EPA 1664-B		ALS Environmental		PA 22-293	
BOD20/cBOD20		SM5210 B		ALS Environmental		PA 22-293	
Dissolved Iron		EPA 220.7		ALS Environmental		PA 22-293	
TKN-N		EPA 351.2		ALS Environmental		PA 22-293	

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 10/28/15

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				15	09	01	TO 15 09 30
PARAMETER	ANALYSIS METHOD	LAB NAME		LAB ID NUMBER²			
pH	SM 4500 H+B	DELCORA - Central Laboratory		23-00671			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 10/28/15

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



34 Dogwood Lane ■ Middletown, PA 17057 ■ Phone: 717-944-5541 ■ Fax: 717-944-1430 ■ www.alsglobal.com

NELAP Certifications: NJ PA010, NY 11759, PA 22-293
State Certifications: DE ID 11, MA PA0102, MD 128, VA 460157, WV 343

October 13, 2015

Mr. Mike Krause
DELCORA
P.O. Box 999
Chester, PA 19016

Certificate of Analysis

Project Name:	Annual Stormwaters	Workorder:	2098597
Purchase Order:		Workorder ID:	Annual Stormwaters

Dear Mr. Krause:

Enclosed are the analytical results for samples received by the laboratory on Tuesday, September 29, 2015.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Mr. Brad W Kintzer (Project Coordinator) at (717) 944-5541.


Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads.

This laboratory report may not be reproduced, except in full, without the written approval of ALS Environmental.

ALS Spring City: 10 Riverside Drive, Spring City, PA 19475 610-948-4903

CC: Mr. Ray Rios, Ms. Irene Fitzgerald

This page is included as part of the Analytical Report and must be retained as a permanent record thereof.


Mr. Brad W Kintzer
Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver · Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

SAMPLE SUMMARY

Workorder: 2098597 Annual Stormwaters

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Collected By
2098597001	Stormwater	Water	9/29/2015 13:45	9/29/2015 19:15	Mr. Mike Krause

Notes

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- All Waste Water analyses comply with methodology requirements of 40 CFR Part 136.
- All Drinking Water analyses comply with methodology requirements of 40 CFR Part 141.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze Immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".

Standard Acronyms/Flags

J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey



34 Dogwood Lane ■ Middletown, PA 17057 ■ Phone: 717-944-5541 ■ Fax: 717-944-1430 ■ www.alsglobal.com

NELAP Certifications: NJ PA010, NY 11759, PA 22-293
State Certifications: DE ID 11, MA PA0102, MD 128, VA 460157, WV 343

ANALYTICAL RESULTS

Workorder: 2098597 Annual Stormwaters

Lab ID: 2098597001

Date Collected: 9/29/2015 13:45

Matrix: Water

Sample ID: Stormwater

Date Received: 9/29/2015 19:15

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed	By	Cntr
WET CHEMISTRY									
Carbonaceous BOD	5.6		mg/L	2.0	S5210B-11		9/30/15 11:50	LEW	A
Chemical Oxygen Demand (COD)	65		mg/L	5	EPA 410.4		10/6/15 02:00	JAM	B
Oil/Grease Hexane Extractable	ND		mg/L	2.0	EPA 1664B		10/2/15 08:55	MPP	C
Phosphorus, Total	0.44		mg/L	0.10	EPA 365.1	10/1/15 LJF	10/7/15 11:39	SYB	B
Total Kjeldahl Nitrogen	1.7		mg/L	1.0	S4500NH3G-11	10/2/15 J1H	10/5/15 09:11	C_W	B
Total Suspended Solids	52		mg/L	5	S2540D-11		10/1/15 04:17	NV	A
METALS									
Iron, Dissolved	0.10		mg/L	0.060	EPA 200.7	9/30/15 TSS	10/6/15 03:26	TSS	E


Mr. Brad W Kintzer
Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver · Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

STORM WATER

SAMPLE DATE 9/29/15 1345

TOTAL RAINFALL 0.8 INCHES

pH CALIBRATION BUFFERS 4.0 4.00
7.0 7.02
9/29/15 0900 10.0 10.65
Slope 96.8

pH FIELD 7.52 S.U. 9/29/15 1425
(pH GRAB TAKEN AT 1420)

RAINFALL STARTED AT 1330 9/29/15



Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Friday, February 26, 2016 2:49 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 12554 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 12554
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 01/01/2016-01/31/2016
Monitoring Report Due Date : 02/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

February 26, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for January, 2016. All parameters were in compliance during the month.

Parameter averages for January, 2016 were: Flow – 32.43; cBOD₅ – 11mg/L; TSS – 16 mg/L; cBOD₂₀ % removal – 93.64%; and cBOD₂₀ – 6,381 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELORA STP
Permit Number:	PA0027103	Monitoring Period:	01/01/2016-01/31/2016
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19018-0999

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	Load			Stage Code			Final Effluent			No Discharge Indicator	
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency		
pH	Sample Measurement Permit Measurement	***	***	***	6.29	***	6.99	S.U.	Grab	1/day		
		***	***	***	6.0	***	9.0	IMAX	Grab	1/day		
Total Suspended Solids	Sample Measurement Permit Measurement	4298	5382	lbs/day	***	16	19	mg/L	24-Hr Composite	1/day		
		11000	16500	Wkly Avg	***	30	45	mg/L	24-Hr Composite	1/day		
		Avg Mo	***	***	***	Avg Mo	***	***	***	***		
Oil and Grease	Sample Measurement Permit Measurement	<1352	***	lbs/day	***	<5	<5	mg/L	Grab	1/day		
		5500	***	***	***	15	30	mg/L	Grab	1/day		
		Avg Mo	***	***	***	Avg Mo	IMAX	***	***	***		
Ammonia-Nitrogen	Sample Measurement Permit Measurement	***	***	***	***	3.53	***	mg/L	24-Hr Composite	2/month		
		***	***	***	***	Monitor & Report	***	***	24-Hr Composite	2/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Nitrite an N	Sample Measurement Permit Measurement	***	***	***	***	<5	<5	mg/L	24-Hr Composite	2/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	2/month		
		***	***	***	***	Avg Mo	Daily Max	***	***	***		
Nitrate as N	Sample Measurement Permit Measurement	***	***	***	***	9.1	10.6	mg/L	24-Hr Composite	2/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	2/month		
		***	***	***	***	Avg Mo	Daily Max	***	***	***		
Total Kjeldahl Nitrogen	Sample Measurement Permit Measurement	***	***	***	***	5.5	***	mg/L	24-Hr Composite	2/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	2/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Cyanide, Total	Sample Measurement Permit Measurement	***	***	***	***	.02	***	mg/L	24-Hr Composite	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Chlorodibromomethane	Sample Measurement Permit Measurement	***	***	***	***	<.001	***	mg/L	Grab	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	Grab	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Cadmium, Total	Sample Measurement Permit Measurement	***	***	***	***	<.005	***	mg/L	24-Hr Composite	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Copper, Total	Sample Measurement Permit Measurement	***	***	***	***	<.025	***	mg/L	24-Hr Composite	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Lead, Total	Sample Measurement Permit Measurement	***	***	***	***	<.015	***	mg/L	24-Hr Composite	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Zinc, Total	Sample Measurement Permit Measurement	***	***	***	***	<.05	***	mg/L	24-Hr Composite	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	24-Hr Composite	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		
Dichlorobromomethane	Sample Measurement Permit Measurement	***	***	***	***	.001	***	mg/L	Grab	1/month		
		***	***	***	***	Monitor & Report	Monitor & Report	***	Grab	1/month		
		***	***	***	***	Avg Mo	***	***	***	***		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
Hauled-In Municipal Waste_JAN2016.xls	Hauled-In Municipal Waste Form	2016-02-26T14:20:08-05:00	
Cryptographic Hash Value of File (SHA-512)	0B941E450E3F1D7F0D067253F09CA5C8290F17E4CD5854F91082035A17EDE468F98D4ACE5E98CF5B3F679A4064D4B3A86D537601F68A47C8AE77902B544		
ALS_CBO020_1-5-16.PDF	Laboratory Analytical Report	2016-02-26T14:28:18-05:00	
Cryptographic Hash Value of File (SHA-512)	0DABEA9203BCB0D7A15EDCAE1409F871385D83358A2FE5D2AFF32CE76A70D6707D02E9D9CDA63B4C16BC7EAC66A9B14E9D0308F617D56E81EF97BB398D38A9		
ALS_CBO020_1-3-16.PDF	Laboratory Analytical Report	2016-02-26T14:24:50-05:00	
Cryptographic Hash Value of File (SHA-512)	2DDFF1FF1716ABF178E5F20C11A3A05159FD9EA7F918FD8E8626248D41A87E933398F153E540F5A0E386A71C7207E944A1285073E9AE2D0983365B5E90E2AA		
ALS_CBO020_1-7-16.PDF	Laboratory Analytical Report	2016-02-26T14:29:10-05:00	
Cryptographic Hash Value of File (SHA-512)	E1DD867DEA02B88BA0949E01A9D638431541BACFDE2A027474486A4224282D488945231A85C9DF0A9D5F6B030A6D4869F1BF049071C7312F1694D2B2BE569E071		
ALS_CBO020_1-21-16.PDF	Laboratory Analytical Report	2016-02-26T14:34:47-05:00	
Cryptographic Hash Value of File (SHA-512)	BC521C10DF47909E40292D2B761E9C388E57794E7685495A73D4FE7CFCA91781F4F4EB4F2392A624389284F824604D87C23E9FB7D01F54368EC7E4C1E3AC3D3A		
ALS_CBO020_1-24-16.PDF	Laboratory Analytical Report	2016-02-26T14:35:37-05:00	
Cryptographic Hash Value of File (SHA-512)	D97928F6D30A790576019D3E9E5E579D5F227C1B771A11DA8F28F45D27217EAS47E5021DBEA38D31D5415DB949E0421B2039842E7BE735E7DEE56970F62D5F		
ALS_CBO020_1-19-16.PDF	Laboratory Analytical Report	2016-02-26T14:33:14-05:00	
Cryptographic Hash Value of File (SHA-512)	FE76EE6F39C1B91C7DFE00598EB4B30ABDC7A83357DD83EB5E958E4BD831DF5AFAF0F9B811940CD9AA78D498146C2B570D3E74F941A9F1B834A942C6C53D429		
ALS_CBO020_1-17-16.PDF	Laboratory Analytical Report	2016-02-26T14:32:28-05:00	
Cryptographic Hash Value of File (SHA-512)	3896CF27F395D02E3D2A7B0D7236216B0D95E7F756A948F18C0367B6365A0234B6C217391B4A0E61E78CD498A2632B50CA4649CB8E48D0CD10DB6915498A64979		
ALS_CBO020_1-14-16.PDF	Laboratory Analytical Report	2016-02-26T14:31:37-05:00	
Cryptographic Hash Value of File (SHA-512)	36A8BA6681194400123E13EA7F919A3598E743860C15C978B4F4CE35C141A8DD028BEABCE0B1BA328646D9FEC02EB1DDAD3978F03AC2BE071CA04DB565452044		
Daily Effluent Monitoring JAN 2016.xlsx	Daily Effluent Monitoring Form	2016-02-26T14:18:56-05:00	
Cryptographic Hash Value of File (SHA-512)	ED107DB8ED2B5E0D057119BC75E85238CDBDB8E4C5545FD070A6C07EAA008D8D46D4E8CFBFD39CB60D1A70EDE4EB65E1960A50CB2B8B80B4CE9AAD224714EFB4		
Daily Influent Monitoring JAN 2016.xlsx	Daily Influent Monitoring Form	2016-02-26T14:19:37-05:00	
Cryptographic Hash Value of File (SHA-512)	D345609BA6267D97D0B49C650155CACF658934CE549CA8EB44EFD9DBB46986F70234889839A08B3AC588E27A7936444B551A93BD2AFC88CAD5AA9782C9948C8		
Cryptographic Hash Value of File (SHA-512)	CAE5564C4E455B888AC88B6E09CA3D31E1255948AC9993193679445B5C8F280A6A9E0136F4BB760747C777E454DB8232CF101DC75EFC44E03C99D3119EA069		
DMR Laboratory Accreditation-ALS-JAN 2016.doc	Laboratory Accreditation Form	2016-02-26T14:23:30-05:00	
Cryptographic Hash Value of File (SHA-512)	68A2217D33194D42162F4175BF7B66C0FDA422FFD68CA2F7732AFE190CC0180C00241945030EE15954E4A0CB78FC5E2C4274D6446575221D8163703789C4F8C9		
DMR Laboratory Accreditation-WRTP-JAN 2016.doc	Laboratory Accreditation Form	2016-02-26T14:24:05-05:00	
Cryptographic Hash Value of File (SHA-512)	0F586D2912B4E78EDBADEE702B143FD7080FEAB18D17304ED225123CF9DDB568303E7EECB617805356065E002CB34C579A5A45E68407DCCD5A74DA96042B357		
DMR Cover Letter JAN 2016.doc	Cover Letter	2016-02-26T14:48:42-05:00	
Cryptographic Hash Value of File (SHA-512)	533660BD93F6DE31EE6073D70D1A8312EAF8C1BD04D91A8B93599F85DFD416FC6F0783C19E6D27B90FA2B9B1778DAD61FBD412AF77C56182F4C75D201B332BFE		
ALS_CBO020_1-10-16.PDF	Laboratory Analytical Report	2016-02-26T14:30:02-05:00	
Cryptographic Hash Value of File (SHA-512)	D62B3D081FB0B574653200535AC7C4FAC0C4ADDC1526F092FFE1D0214B779FA977DEDA03888FA7F75D34680180EE2DBAD5EE0E8C1CA731B813953786C3AFB568		
ALS_CBO020_1-12-16.PDF	Laboratory Analytical Report	2016-02-26T14:30:48-05:00	
Cryptographic Hash Value of File (SHA-512)	8A12CBE8F61C2E048B342B227EB475BF0D38ADFCC29E3E1AA64EC1C1B8F3C9FBEF45AA6B2A294592014280B9FDC79BA14A3FFEC3B357499DBF55C97A73AFB0		
Hauled In Residual Wastes_JAN2016.xls	Hauled-In Residual Waste Form	2016-02-26T14:20:35-05:00	
Cryptographic Hash Value of File (SHA-512)	AD0C96784CF096EC4992AA36F2A9AB81632F7C0329D3B56021E68EF23AD7A93D1ACD11B09E778C238BF332B3DE23B5FA3B7501500DE464B29F7B825A54565		
Influent and Process Control_JAN2016.xls	Influent and Process Control Form	2016-02-26T14:21:03-05:00	
Cryptographic Hash Value of File (SHA-512)	E5023A752481590BDD17DA8EDC260685FDBA9A8031DAC5A3165D8A389CABA6B72B34BD5DF73CDD41E1BF0036459E2D14F48C444C9A9FA0CE068B12C6C2D202101		
January 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-02-26T14:22:14-05:00	January 2016 SWMM Report
Cryptographic Hash Value of File (SHA-512)	36CA0C72937C2C5DA5D8CEED08672AC3C8748A613198230D8A5FC76A2C022693C13A34F02F9700B511EABD1B97768A1735A0A5599D2613F75FFE63654A97CA05		
Sludge Production and Disposal_JAN 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-02-26T14:22:50-05:00	
Cryptographic Hash Value of File (SHA-512)	5ABD3C80FDD1E1907371FB6558F9ED9D400218FBA90BF11736CF3E8CDA90CC7B1BB253810661043B86C2472DF95D81D668B4804F5A456E512E5B3889367839F92		
ALS_CBO020_1-26-16.PDF	Laboratory Analytical Report	2016-02-26T14:36:20-05:00	
Cryptographic Hash Value of File (SHA-512)	0CA0F4DB5A0D4141E4A921CAD92ECA31824828572FCFCA7BC556A4285663B55183CBA30A0EEF32F48D0AFF86891EAA4F4C82FB49DC8CF38712C0A07C18DBE9866E		
ALS_CBO020_1-31-16.PDF	Laboratory Analytical Report	2016-02-26T14:39:21-05:00	
Cryptographic Hash Value of File (SHA-512)	23F01A8F9555419519211954C1B8E9C3D3C95603A02D2538B63BA5DBA443FBC1B3864AA8D1CED2BABA65DBA28F3B30FC9202F112C8B455A52F9EBD29CE0		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

PERMIT VIOLATIONS:												
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non Compliance ID	Stage Code (Sampling Point)		Reported Parameter	Non Compliance Type		Comments						
COMMENTS DETAILS												
Comment			Operator Name				Operator Certification Number		Operator Contact Number			
			Michael J. DiSantis				TD403		6108765523			
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P. S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User			DISANTISM				Submitted By Full Name			Michael DiSantis		
Email Address			disantism@delcora.org				Document Generated			2/26/2016		



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	01	01	TO 16 01 31
PARAMETER	ANALYSIS METHOD	LAB NAME		LAB ID NUMBER²			
Copper, Total	EPA 200.7	ALS Environmental		PA 22-293			
Lead, Total	EPA 200.7	ALS Environmental		PA 22-293			
Zinc, Total	EPA 200.7	ALS Environmental		PA 22-293			
Dichlorobromomethane	EPA 624	ALS Environmental		PA 22-293			
BOD20/cBOD20	SM5210 B	ALS Environmental		PA 22-293			
Chlorodibromomethane	EPA 624	ALS Environmental		PA 22-293			
TKN-N	EPA 351.2	ALS Environmental		PA 22-293			
Ammonia as N	D6919-09	ALS Environmental		PA 22-293			
Nitrate as N	EPA 300.0	ALS Environmental		PA 22-293			
Total Cyanide	EPA 335.4	ALS Environmental		PA 22-293			
Total Cadmium	200.7	ALS Environmental		PA 22-293			
Nitrite as N	EPA 300.0	ALS Environmental		PA 22-293			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 02/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	01	01	TO 16 01 31
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
BOD5/cBOD5	SM5210 B	DELCORA - Central Laboratory	23-00671				
TSS	SM 2540 D	DELCORA - Central Laboratory	23-00671				
O&G	EPA 1664 A	DELCORA - Central Laboratory	23-00671				
Total Residual Cl	SM4500-Cl G	DELCORA - Central Laboratory	23-00671				
N-Nitrite	SM4500-NO2 B	DELCORA - Central Laboratory	23-00671				
NH3-N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TKN-N	SM4500-N-org B/SM4500-NH3 C	DELCORA - Central Laboratory	23-00671				
Fecal Coliform	SM 9222 D	DELCORA - Central Laboratory	23-00671				
BOD20/cBOD20	SM5210 B	DELCORA - Central Laboratory	23-00671				
pH	SM 4500 H+B	DELCORA - Central Laboratory	23-00671				
Ammonia as N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TDS	SM 2540 C	DELCORA - Central Laboratory	23-00671				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 02/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: January Year: 2016
 NPDES Permit No.: PA0027103
 Renewal application due 180 days prior to expiration
 This permit will expire on: April 30, 2018

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month[illegible]**TOTAL:**

TOTAL:	810,520
--------	---------

TOTAL:	762.150
---------------	----------------

SEWAGE SLUDGE/BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Wicks Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
 Title: **Dir. Of Operations and Maintenance**

License No.: T0403
Date: February 28, 2016



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA WRTP
 Municipality: City of Chester
 Watershed: 3G

County: Delaware

Month: January Year: 2016

NPDES Permit No.: PA0027103

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	34.06			87	24,713	4685.00	2.01	261970
2	33.27			170	47,170	4740.00	2.20	0
3	32.36			138	37,244	4710.00	1.92	208850
4	32.03			322	86,016	4235.00	1.36	149720
5	30.94			496	127,988	3970.00	1.41	165690
6	31.28	458	119,481	336	87,654	4305.00	1.10	169970
7	30.88			354	91,169	4065.00	1.34	15766
8	30.70			269	68,874	4080.00	1.10	212120
9	30.17			200	50,324	4360.00	1.24	209270
10	43.65			193	70,260	2990.00	1.42	149500
11	34.95			264	76,952	3615.00	1.34	208500
12	32.67			240	65,392	4085.00	0.99	188050
13	30.41	320	81,158	244	61,883	4175.00	1.10	140370
14	31.30			287	74,919	4405.00	1.09	214120
15	32.04			263	70,277	4070.00	0.92	205960
16	37.33			176	54,794	4285.00	1.74	215150
17	31.40			147	38,496	4015.00	1.83	203970
18	31.86			282	74,931	3680.00	1.25	206790
19	30.72			252	64,564	4095.00	1.23	201440
20	31.07	401	103,909	312	80,847	3575.00	1.12	214580
21	30.36			426	107,864	4540.00	1.19	148970
22	30.45			338	85,836	3450.00	0.94	168670
23	29.94			180	44,946	3450.00	1.79	164750
24	31.66			156	41,191	4180.00	2.96	224780
25	32.43			200	54,093	3650.00	1.69	125250
26	34.74			254	73,592	3200.00	1.59	0
27	38.48			256	82,156	3210.00	1.55	0
28	37.54			198	61,991	3215.00	1.44	0
29	35.75			476	141,922	3220.00	1.32	0
30	33.97	116	32,864	222	62,895	3990.00	1.85	0
31	35.88			220	65,833	3775.00	2.62	37570
Avg	33.042	324	84,353	257	70,219	3,936	2	142,315
Max	43.65	458	119,481	496	141,922	4,740	3	261,970

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis
 Title: Dir. Of Operations and Maintenance

License No.: T0403
 Date: 2/28/2016



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

3800-FM-BPNFMSM0437 3/2012

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: January
NPDES Permit No.: PA0027103

Year: 2016

Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify):			PACKAGE PLANT			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)
1														
2	10150												10,150	0
3														
4	35435													
5	51470			74974						Sludge Thickening	109200	Headworks	219,609	0
6	34400			90219						Sludge Thickening	125930	Headworks	267,619	0
7	28260			86383						Sludge Thickening	114850	Headworks	235,433	0
8	26420			93398						Sludge Thickening	145900	Headworks	267,556	0
9	4400			69240						Sludge Thickening	102900	Headworks	198,560	0
10				44900						Sludge Thickening	4600	Headworks	53,900	0
11	40560													
12	57150			19307						Sludge Thickening	61800	Headworks	121,667	0
13	31350			12270						Sludge Thickening	101700	Headworks	171,120	0
14	27660			31617						Sludge Thickening	58000	Headworks	120,967	0
15	29000			38414						Sludge Thickening	111691	Headworks	177,765	0
16	2250			44399						Sludge Thickening	58900	Headworks	132,299	0
17											9600	Headworks	11,850	0
18	46080													
19	32900			19171						Sludge Thickening	67950	Headworks	133,201	0
20	28225			19000						Sludge Thickening	46500	Headworks	98,400	0
21	24450			32615						Sludge Thickening	122250	Headworks	183,090	0
22	39500			13006						Sludge Thickening	86750	Headworks	124,206	0
23				68718						Sludge Thickening	126264	Headworks	234,482	0
24														
25	12300													
26	22900			31100						Sludge Thickening	28000	Headworks	71,400	0
27	20250			18902						Sludge Thickening	59900	Headworks	101,702	0
28	12450			56279						Sludge Thickening	96800	Headworks	173,329	0
29	22760			67377						Sludge Thickening	85750	Headworks	165,577	0
30	4400			81396						Sludge Thickening	124400	Headworks	228,556	0
31				18000						Sludge Thickening	6300	Headworks	28,700	0
Avg	26,863			46,849							80,984	Monthly Totals:	3,531,138	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 2/28/2016



SUPPLEMENTAL REPORT - HAULED IN RESIDUAL WASTES

Facility Name:

DELCORA STP

Municipality:

City of Chester

Watershed:

County: Delaware

Month: January

NPDES Permit No.: PA0027103 A3

Year: 2016

Renewal application due 180 days prior to expiration.

This permit will expire on: **April 30, 2018**

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**

Michael DiSantis
Dir. Operations and Maintenance

License No.:

Date: 2/28/2016

SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name: DELCOIRA WTRP
 Municipality: City of Chester County: Delaware
 Watershed: 3G
 Laboratories: DELCOIRA; ALS Environmental
 Permit No.: PA0027103 A3
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018
 Month: 1 (select number) Year: 2016
 Outfall: 001

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 P.S. § 912 (relating to unsworn statements).

Prepared By: Micheal DiSantis
Title: Dir. Of Operations and Maintenance
License No.: T0403
Date: 2/28/2016



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name: Delaware County Regional Water Quality Control Authority Month: January Year: 2016
 Municipality: City of Chester NPDES Permit No.: PA0027103
 Watershed: 3G County: Delaware
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	
010	5th & Pusey	Yes	
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	
			Total overflow from Outfalls 009 and 010
			Discharges to Outfall 009 Regulator

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis
 Title: Dir. Of Operations and Maintenance

License No.: T0403
 Date: 2/17/2015

From: depgreenporthelpdesk@state.pa.us
Sent: Thursday, March 24, 2016 3:09 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 15111 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 15111
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 02/01/2016-02/29/2016
Monitoring Report Due Date : 03/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

March 24, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for February, 2016. We regret to report that there was one (1) effluent violation during the month as we exceeded the instantaneous maximum for Total Residual Chlorine with a reading of 1.08 mg/L on 2/28/16.

Parameter averages for February, 2016 were: Flow – 41.4 MGD; cBOD₅ – 11 mg/L; TSS – 15 mg/L; cBOD₂₀ % removal – 92.17; and cBOD₂₀ – 9,025 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:vm
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	462685	Facility Name:	DELOORA STP
Permit Number:	PA0027103	Monitoring Period:	02/01/2016-02/29/2016
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O. BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES												
Sampling Point	Limit Type	Load 1	Load 2	Units	Stage Code	Conc 1	Conc 2	Conc 3	Units	No Discharge Indicator	Sample Type	Sample Frequency
pH	Sample Measurement	***	***	***	***	6.46	***	6.99	S.U.		Grab	1/day
	Permit Measurement	***	***			6.0	***	9.0	IMAX		Grab	1/day
Total Suspended Solids	Sample Measurement	5192	6727	lbs/day	***	***	15	18	mg/L		24-Hr Composite	1/day
	Permit Measurement	11000	16500	Wkly Avg	***	***	30	45			24-Hr Composite	1/day
Oil and Grease	Sample Measurement	<1726	***	lbs/day	***	***	<5	<5	mg/L		Grab	1/day
	Permit Measurement	5500	***		***	***	15	30	IMAX		Grab	1/day
Ammonia-Nitrogen	Sample Measurement	***	***	***	***	***	7.58	***	mg/L		24-Hr Composite	2/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	Monitor & Report Avg Mo			24-Hr Composite	2/month
Nitrite as N	Sample Measurement	***	***	***	***	***	<5	<5	mg/L		24-Hr Composite	2/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	Monitor & Report Daily Max			24-Hr Composite	2/month
Nitrate as N	Sample Measurement	***	***	***	***	***	5.3	6.2	mg/L		24-Hr Composite	2/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	Monitor & Report Daily Max			24-Hr Composite	2/month
Total Kjeldahl Nitrogen	Sample Measurement	***	***	***	***	***	8.6	***	mg/L		24-Hr Composite	2/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	2/month
Cyanide, Total	Sample Measurement	***	***	***	***	***	.036	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	1/month
Chlorodibromomethane	Sample Measurement	***	***	***	***	***	.001	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			Grab	1/month
Cadmium, Total	Sample Measurement	***	***	***	***	***	<.001	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	1/month
Copper, Total	Sample Measurement	***	***	***	***	***	.0076	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	1/month
Lead, Total	Sample Measurement	***	***	***	***	***	<.003	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	1/month
Zinc, Total	Sample Measurement	***	***	***	***	***	.068	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			24-Hr Composite	1/month
Dichlorobromomethane	Sample Measurement	***	***	***	***	***	.0013	***	mg/L		24-Hr Composite	1/month
	Permit Measurement	***	***		***	***	Monitor & Report Avg Mo	***			Grab	1/month

[illegible]

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
DMR Cover Letter Feb 2016.doc	Cover Letter	2016-03-24T15:06:34-04:00	
Cryptographic Hash Value of File (SHA-512)	964711FA5B09B5B0C99454587266295718E37AB93925907FBCF53B149A237575FDD72279EEBD3C95C715A2712CAA8CEDACA15CEDB981BFBA781CD012A7749D71		
Daily Influent Monitoring FEB 2016.xlsx	Daily Effluent Monitoring Form	2016-03-24T14:31:11-04:00	
Cryptographic Hash Value of File (SHA-512)	35094BF44072DD096998C9354824C40A0BB14C2A5949D7A803721719B0FF84CD2D743163395F9234D2DA7CCF1AD8D2A715296DE3A9F1B8958059A0D955745		
Daily Effluent Monitoring FEB 2016.xlsx	Daily Effluent Monitoring Form	2016-03-24T14:30:42-04:00	
Cryptographic Hash Value of File (SHA-512)	940B4960C1787265EDD2A44364856982F50F1F512F5048B9593CA7F47D8AE430265DE1D92113003666F114965DA109BEFCBAE5F6614DE56CD23FF1B3D08B8B43		
DMR Laboratory Accreditation-WRTP-FEB 2016.doc	Laboratory Accreditation Form	2016-03-24T13:55:05-04:00	
Cryptographic Hash Value of File (SHA-512)	768AE9882E97F566C41EC65AD65E92454C3DCD72B7B00A18B7BD3C389A49CC7C0DFFEAEEDB25B45C82452B3D4FFADD360F9FED0BF8FE2F341B2D992F0D952AB		
DMR Laboratory Accreditation-ALS-FEB 2016.doc	Laboratory Accreditation Form	2016-03-24T13:54:44-04:00	
Cryptographic Hash Value of File (SHA-512)	00A7BF4E75E188940421B880AD8C6D817975F9FF2E9CAFF20013BC355B94B0BD634C82A5801FB0C2B99D85DFDA0F760311FBFBF037B94AC2EB2F2446744C0C517		
Hauled in Municipal Waste, FEB2016.xls	Hauled-in Municipal Waste Form	2016-03-24T14:09:54-04:00	
Cryptographic Hash Value of File (SHA-512)	1D3CFD5DEA25EFBF6157618E4CCB8328250E2B9AD7BE52E5ACBD1039142976D53065BEBF6FA53FB143E17B9963B58114450A12063073E05A58E2FEES3E272B		
Hauled in Residual Wastes, FEB2016.xls	Hauled-in Residual Waste Form	2016-03-24T14:10:16-04:00	
Cryptographic Hash Value of File (SHA-512)	8795F40DFFB38AC40E01E1BC4156487E99CA1D167C1006099A69661EC7D75960320020514AD36050A4133EAB2550029BA397DF600D4DC311CF184DC4A4008CC		
Influent and Process Control, FEB2016.xls	Influent and Process Control Form	2016-03-24T14:10:35-04:00	
Cryptographic Hash Value of File (SHA-512)	688C139BBEA98ED16A9BE33BA20C6821942D96B83C2D8E1A92C614F2325467FA357B14C88B632AC1EBC9DBADEE1DE8DC6C70B739BDB5BA7D2924D90CE3A8E9A		
Sludge Production and Disposal, FEB 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-03-24T14:10:55-04:00	
Cryptographic Hash Value of File (SHA-512)	6FB3B6497EB8C2E0D0186E5C48E9B6F4F69787FAB948EF255F1D59D2A2A8AF6FC989BEC88B633E1CFCC22F92E9C9DAF48F5BAD0788F4116C3E48B2C29010F15F		
February 2016 SWMM Report.xlsx	Surface Water Monitoring Data Report Form	2016-03-24T14:31:55-04:00	
Cryptographic Hash Value of File (SHA-512)	52DD72447D7FA42ED8F7899AF2A8CF46ADE49A1E0D5D029EDF34580C40A5C97E049479AB93DD1C89FC2771FCD7A0D136EF76DF4EA629BD3FF8F59AD23B219		
Non-Compliance Form Feb 2016.doc	Other	2016-03-24T15:07:14-04:00	Non-Compliance Form
Cryptographic Hash Value of File (SHA-512)	A9B5901234186576A5AC2DB7670B1073EE5238D15B084E25DEC7E9C5ED8BB7C4C1CEDF58A3D27D4B1F1E33C47B0D586829CA1FAF95240CBA68CF8BF2681B20		
ALS_CBO020_2-18-16.PDF	Laboratory Analytical Report	2016-03-24T13:59:10-04:00	
Cryptographic Hash Value of File (SHA-512)	5EC3822F3685935A4AAB6EC2C20AE4AF7830C7E18F8F5E65F161E0283D46D4368975E3C1B9D080981D5E185BFA43610B6E6E6132CE3C7985B846B6138FCD		
ALS_CBO020_2-14-16.PDF	Laboratory Analytical Report	2016-03-24T13:58:08-04:00	
Cryptographic Hash Value of File (SHA-512)	3C8BD0A5311B81844C7A33682A5777F7F65E1F32249E3C366478Q2CA74609FB4E1E662FB6FC0EBC258ED72A893D6A44FED9CB98E8CD6A51B23AE15C289D5F		
ALS_CBO020_2-11-16.PDF	Laboratory Analytical Report	2016-03-24T13:57:40-04:00	
Cryptographic Hash Value of File (SHA-512)	80A42C517BD8E3AEFA757EA873A1BB43767C5EEB830971878A8F8B66BA1E5878977F98E7B8B5A5EEDDD7FB400DA6287387B87E955C93E324B1CF217CCE1F0D6		
Biweekly N1, FEB2016.PDF	Laboratory Analytical Report	2016-03-24T14:02:55-04:00	
Cryptographic Hash Value of File (SHA-512)	7B1A12D8EBA09790B1941BF0CB02327BAC2D496C12762D27C059D50569A5B0B29A6D3403F32D6EAC0DF224A6618EC0FFD239B9708685742BC2688802BDS57		
ALS_Effluent, FEB2016.PDF	Laboratory Analytical Report	2016-03-24T14:02:30-04:00	
Cryptographic Hash Value of File (SHA-512)	AC09152D06F3D4E6737D81025060ACE7553DB81F36D16F15A2EB0F89EEB192C4F358613BDF9C528198415AD258D73652DEED3EE97A93EA74A56618E5CF8E24D741		
ALS_CBO020_2-25-16.PDF	Laboratory Analytical Report	2016-03-24T14:00:50-04:00	
Cryptographic Hash Value of File (SHA-512)	F65B24CBFEF30386B1F9EC67A8AE2C0B058D0DFFD98FA7D9C6885FEB3A327667F1326B10E9218A0B8CAF3586076B09763EC2A4F920DF8762A2C462F61ACE3AE5CF2		
ALS_CBO020_2-4-16.PDF	Laboratory Analytical Report	2016-03-24T13:56:07-04:00	
Cryptographic Hash Value of File (SHA-512)	57A0FDABF111004B1F986FD6400D3DF747084F25BD696EABD747475CD584777CC8D17FE23B0643E29CFB6F0888589CE13A749EEAE620AEAB90325955AEBA81AF57		
ALS_CBO020_2-9-16.PDF	Laboratory Analytical Report	2016-03-24T13:57:11-04:00	
Cryptographic Hash Value of File (SHA-512)	4E60CD604EE2E2BBA285FA93689F1ABEFF11BBF76A8B8DF1715041F118E0A6A73301B7D0462B21D166CF6B3769A1120A0D34F638A789AC4A46C9F196C2F583		
ALS_CBO020_2-7-16.PDF	Laboratory Analytical Report	2016-03-24T13:56:36-04:00	
Cryptographic Hash Value of File (SHA-512)	BFB45584A8F16C2CA07186647A00D71A399ECA3F05BED8EEC3027E58EED257FFA611B1A92D7AE452754006574FE8A29723784AAAF058598137D86F2634317C26		
WRTP Lab_Influent and Process Control_02-16.pdf	Laboratory Analytical Report	2016-03-24T14:03:19-04:00	
Cryptographic Hash Value of File (SHA-512)	FC1AE780C3E5110D3AA373D3B3489CD1607B8E2E5CCAA45FEE5B9D718CAA724BE17D831E1E6D913F0B996DA00DE36698F74F47850121FF6DE9D71C46D24A115E		
ALS_CBO020_2-21-16.PDF	Laboratory Analytical Report	2016-03-24T13:59:41-04:00	
Cryptographic Hash Value of File (SHA-512)	975AE1D40C25903EFA4206FD8ED87FD354834CDA939068DAB8A86851EF67E5C981AE7E9B1D29540D43567592836537FAFAC1D541333AE66ECC2E7F1D43893699C		
ALS_CBO020_2-16-16.PDF	Laboratory Analytical Report	2016-03-24T13:58:41-04:00	
Cryptographic Hash Value of File (SHA-512)	C7C7C5030A04080D7D835D00F7B2864655BE06943B6B78F9C82C93F6BCD59D0AD81B26B9194ADE00679BABE8EE4B98F546C1B46D82CA6EA448ADAD274CB87C9		
WRTP_Influent, FEB2016.pdf	Laboratory Analytical Report	2016-03-24T14:04:04-04:00	
Cryptographic Hash Value of File (SHA-512)	459C202C87F3D564D0D016A790E9BBAF353FDC6267907E26E0FC028E0B0ABE1BCC96BA922EE017332C9C7880B61D894C7EEA33501BC9E94FD052198806B56CD		
WRTP_Effluent, FEB2016.pdf	Laboratory Analytical Report	2016-03-24T14:03:46-04:00	
Cryptographic Hash Value of File (SHA-512)	9B023277CE22D76C335F15172703862412DF295C91A5DA2DCCCEB80636F6F50563585FD155665591A90E980BDE481EBB943CD168B3CD28A4ADAB8D71B9CDA568CB		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ALS_Biweekly N2_FEB2016.PDF	Laboratory Analytical Report	2016-03-24T14:02:04-04:00	
Cryptographic Hash Value of File (SHA-512)	9B737B410C0610A1B5F4D3805AD821C9EC9AA1EC1D29F68462C2EDDE791AE60A4636B34505AEFFCCD40365CCDF12C115E34FA77E7B1075B06953C1A10059B4866		
ALS_CBOD20_2-28-16.PDF	Laboratory Analytical Report	2016-03-24T14:01:14-04:00	
Cryptographic Hash Value of File (SHA-512)	6649126CE403C68012F8803F1EA13D7DA06F4B6076E35A304A8844CAEB81CAFE6D6B51458F900357E11310E3B18AF2E328BB5AAE5425343267CE75A217B7DD4F		
ALS_CBOD20_2-23-26.PDF	Laboratory Analytical Report	2016-03-24T14:00:18-04:00	
Cryptographic Hash Value of File (SHA-512)	C4C69A1FE5E9BDF086F8AEC8C632442C522F62AE59B34CE5E5DE821B20117E9F5172EFD8147C9524822BE08E6A7E445A90A1D74D09A1452D6B0175335A5A3959		
ALS_CBOD20_2-2-16.PDF	Laboratory Analytical Report	2016-03-24T13:55:31-04:00	
Cryptographic Hash Value of File (SHA-512)	4B8855B8A553508ECCD519F54B15E21E43FB715D061FEF705F47D7B84CF6B5AB0BF649368B70SCA04E5627F3DE3F4AF60323BB698E3BC653CEE05707B5837BA5A		

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

PERMIT VIOLATIONS

Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments
29120	02/01/2016	02/29/2016	Total Residual Chlorine (TRC)	Instantaneous Maximum	1.08	1		001	Operator error	Other	Reinforced SOP for disinfection process with operator

UNAUTHORISED DISCHARGES

Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
-------------------	------------------	----------------	-----------------	----------------------	----------------	--------	----------	------------------	-----------------	--------------------	--------------	----------

OTHER PERMIT VIOLATIONS

Non Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type	Comments
-------------------	-----------------------------	--------------------	---------------------	----------

COMMENTS DETAILS

Comment	Operator Name	Operator Certification Number	Operator Contact Number
	Michael J. DiSantis	T0403	6108765523

SUBMISSION INFORMATION

*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).

Submitted By GreenPort User	DISANTISM	Submitted By Full Name	Michael DiSantis
Email Address	disantism@delcora.org	Document Generated	3/24/2016



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	02	01	TO	16	02	29
PARAMETER		ANALYSIS METHOD		LAB NAME			LAB ID NUMBER²			
Copper, Total		EPA 200.7		ALS Environmental			PA 22-293			
Lead, Total		EPA 200.7		ALS Environmental			PA 22-293			
Zinc, Total		EPA 200.7		ALS Environmental			PA 22-293			
Dichlorobromomethane		EPA 624		ALS Environmental			PA 22-293			
BOD20/cBOD20		SM5210 B		ALS Environmental			PA 22-293			
Chlorodibromomethane		EPA 624		ALS Environmental			PA 22-293			
TKN-N		EPA 351.2		ALS Environmental			PA 22-293			
Ammonia as N		D6919-09		ALS Environmental			PA 22-293			
Nitrate as N		EPA 300.0		ALS Environmental			PA 22-293			
Total Cyanide		EPA 335.4		ALS Environmental			PA 22-293			
Total Cadmium		200.7		ALS Environmental			PA 22-293			
Nitrite as N		EPA 300.0		ALS Environmental			PA 22-293			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 03/21/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	02	01	TO 16 29 31
PARAMETER	ANALYSIS METHOD	LAB NAME		LAB ID NUMBER²			
BOD5/cBOD5	SM5210 B	DELCORA - Central Laboratory		23-00671			
TSS	SM 2540 D	DELCORA - Central Laboratory		23-00671			
O&G	EPA 1664 A	DELCORA - Central Laboratory		23-00671			
Total Residual Cl	SM4500-Cl G	DELCORA - Central Laboratory		23-00671			
N-Nitrite	SM4500-NO2 B	DELCORA - Central Laboratory		23-00671			
NH3-N	EPA 350.1	DELCORA - Central Laboratory		23-00671			
TKN-N	SM4500-N-org B/SM4500-NH3 C	DELCORA - Central Laboratory		23-00671			
Fecal Coliform	SM 9222 D	DELCORA - Central Laboratory		23-00671			
BOD20/cBOD20	SM5210 B	DELCORA - Central Laboratory		23-00671			
pH	SM 4500 H+B	DELCORA - Central Laboratory		23-00671			
Ammonia as N	EPA 350.1	DELCORA - Central Laboratory		23-00671			
TDS	SM 2540 C	DELCORA - Central Laboratory		23-00671			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 03/21/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.





SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA W RTP County: Delaware Month: February Year: 2016
Municipality: City of Chester NPDES Permit No.: PA0027103
Watershed: 3G Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	42.01			326	114,218	3405.00	1.35	202440
2	40.47			434	146,484	3470.00	1.30	187180
3	48.02	391	156,590	588	235,486	3970.00	0.93	158840
4	44.90			406	152,033	3452.50	1.20	143910
5	54.29			260	117,722	3360.00	1.68	194160
6	43.12			114	40,997	5000.00	1.94	152670
7	36.95			150	46,224	4495.00	2.42	170350
8	37.26			280	87,010	4035.00	1.29	230950
9	39.27			236	77,293	3990.00	0.98	227690
10	39.02	303	98,604	246	80,055	4270.00	1.08	216080
11	35.37			592	174,632	4465.00	1.15	224880
12	34.40			510	146,317	4335.00	1.21	230960
13	33.56			314	87,886	4070.00	1.62	238950
14	32.60			252	68,515	4385.00	2.36	230910
15	34.97			251	73,204	3455.00	1.68	227060
16	57.71			440	211,773	3545.00	1.51	205680
17	45.06	303	113,868	269	101,090	3860.00	1.48	202510
18	39.57			260	85,804	4315.00	1.34	171820
19	37.62			254	79,693	4530.00	1.38	115870
20	36.35			149	45,171	4925.00	1.39	154630
21	34.83			114	33,115	4505.00	2.01	179440
22	35.21			544	159,746	4710.00	1.23	181330
23	39.12			330	107,666	4285.00	1.29	204020
24	57.20	234	111,629	398	189,865	3510.00	0.95	145970
25	65.44			274	149,541	3350.00	1.53	163050
26	48.01			138	55,256	3680.00	1.66	138270
27	42.70			52	18,518	4480.00	1.84	217250
28	38.32			146	46,660	4060.00	2.66	157290
29	38.15			246	78,270	4170.00	1.53	201360
30								
31								
Avg	41.776	308	120,173	296	103,801	4,072	2	188,811
Max	65.44	391	156,590	592	235,486	5,000	3	238,950

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis License No.: T0403
Title: Dir. Of Operations and Maintenance Date: 3/28/2016



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

County: DelawareMonth: February Year: 2016NPDES Permit No.: PA0027103Renewal application due 180 days prior to expiration.This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify):			PACKAGE PLANT			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)
1	35860				80911				190450				307,221	0
2	9650			Headworks	94459				132900				237,009	0
3	37160				92300				111405				240,865	0
4	33850			Headworks	100000			Sludge Thickening	180700			Headworks	314,550	0
5	24736			Headworks	88835			Sludge Thickening	153600			Headworks	267,171	0
6	1500			Headworks	102500			Sludge Thickening				Headworks	104,000	0
7				Headworks				Sludge Thickening				Headworks		
8	34105			Headworks	87267			Sludge Thickening	62934			Headworks	184,306	0
9	49200			Headworks	88115			Sludge Thickening	85168			Headworks	222,483	0
10	19250				99562				83500				202,312	0
11	31850			Headworks	76500			Sludge Thickening	30400			Headworks	138,750	0
12	34050			Headworks	81740			Sludge Thickening	99000			Headworks	214,790	0
13	1000			Headworks	11827			Sludge Thickening				Headworks	12,827	0
14				Headworks				Sludge Thickening				Headworks		
15	19960			Headworks	75311			Sludge Thickening	35000			Headworks	130,271	0
16	33900			Headworks	69100				74763			Headworks	177,763	0
17	26750				84200				118807				229,757	0
18	20650			Headworks	54752			Sludge Thickening	96600			Headworks	172,002	0
19	42660			Headworks	75514			Sludge Thickening	101800			Headworks	219,974	0
20				Headworks				Sludge Thickening	3000			Headworks	3,000	0
21				Headworks				Sludge Thickening				Headworks		
22	13950			Headworks	74500			Sludge Thickening	100800			Headworks	189,250	0
23	30350				82659				75200				188,209	0
24	41550				74641				114400				230,591	0
25	31900			Headworks	86007			Sludge Thickening	67400			Headworks	185,307	0
26	25750			Headworks	75652			Sludge Thickening	119100			Headworks	220,502	0
27	8200			Headworks				Sludge Thickening	6100			Headworks	14,300	0
28				Headworks				Sludge Thickening				Headworks		
29	35175			Headworks	60870			Sludge Thickening	82700			Headworks	178,745	0
30				Headworks				Sludge Thickening				Headworks		
31														
AVG	26,614				79,413				92,423				Monthly Totals: 4,585,955	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantisTitle: Dir. Operations and MaintenanceLicense No.: T0403Date: 3/28/2016

SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name: DELORA WRP County: Delaware Month: 2 (boxed number) Year: 2016
 Municipality: City of Chester Permit No.: PA0027103 A3 Outfall: 001
 Watershed: 3G Renewal application due 180 days prior to expiration.
 Laboratories: DELORA; ALS Environmental This permit will expire on: April 30, 2018

Parameter	Flow	Fecal Coliform	pH	CBOD5	CBOD20	CBOD20	7966	TSS	TDS	Oil and Grease	TRC	NH3-N	NO3-N	NO2-N	TKN	Total Copper	Total Lead
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, true, accurate and complete. I am not aware of any falsification of this information. I am not a party to any information submitted hereon that I know to be false, untrue or misleading. I understand the importance of providing accurate and complete information and I am committed to doing so. I am not aware of any falsification of this information. I am not a party to any information submitted hereon that I know to be false, untrue or misleading. I understand the importance of providing accurate and complete information and I am committed to doing so.

Prepared By: Micheal DiSantis License No. T0403
 Title: Dir. Of Operations and Maintenance Date: 3/28/2016



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name: Delaware County Regional Water Quality Control Authority Month: February Year: 2016
 Municipality: City of Chester County: Delaware NPDES Permit No.: PA0027103
 Watershed: 3G Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	Total overflow from Outfalls 009 and 010
010	5th & Pusey	Yes	Discharges to Outfall 009 Regulator
011	2nd & Parker	Yes	
012	2nd & Edgmont	Yes	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Spraul	Yes	
022	6th & Spraul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	Yes	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	Yes	
033	Elkington Blvd. and Ridley Creek	Yes	

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis License No.: T0403
 Title: Dir. Of Operations and Maintenance Date: 3/13/2015

MAR 2016

From: depgreenporthelpdesk@state.pa.us
Sent: Wednesday, April 27, 2016 12:04 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 17665 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 17665
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 03/01/2016-03/31/2016
Monitoring Report Due Date : 04/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

April 27, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for March, 2016. All parameters were in compliance during the month.

Parameter averages for March, 2016 were: Flow – 34.74; cBOD₅ – 14mg/L; TSS – 15 mg/L; cBOD₂₀ % removal – 92.65%; and cBOD₂₀ – 8,987 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:vm
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELCORA STP
Permit Number:	PA0027103	Monitoring Period:	03/01/2016-03/31/2016
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES											
Sampling Point	001	Stage Code									
Parameter	Limit Type	Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Final Effluent	Units	No Discharge Indicator	N
pH	Sample Measurement	***	***	***	6.45	***	7.04		S.U.	Grab	1/day
	Permit Measurement	***	***		6.0	***	9.0			Grab	1/day
					Inst Min		IMAX				
Total Suspended Solids	Sample Measurement	4256	5261	lbs/day	***	15	19		mg/L	24-Hr Composite	1/day
	Permit Measurement	11000	16500		***	30	45			24-Hr Composite	1/day
		Avg Mo	Wkly Avg			Avg Mo	Wkly Avg				
Oil and Grease	Sample Measurement	<1449	***	lbs/day	***	<5	<5		mg/L	Grab	1/day
	Permit Measurement	5500	***		***	15	30			Grab	1/day
		Avg Mo				Avg Mo	IMAX				
Ammonia-Nitrogen	Sample Measurement	***	***	***	***	13.5	***		mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	2/month
						Avg Mo					
Nitrite an N	Sample Measurement	***	***	***	***	1.1	1.1		mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***		***	Monitor & Report	Monitor & Report			24-Hr Composite	2/month
						Avg Mo	Daily Max				
Nitrate as N	Sample Measurement	***	***	***	***	2.3	2.7		mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***		***	Monitor & Report	Monitor & Report			24-Hr Composite	2/month
						Avg Mo	Daily Max				
Total Kjeldahl Nitrogen	Sample Measurement	***	***	***	***	15.9	***		mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	2/month
						Avg Mo					
Cyanide, Total	Sample Measurement	***	***	***	***	.041	***		mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	1/month
						Avg Mo					
Chlorodibromomethane	Sample Measurement	***	***	***	***	.0016	***		mg/L	Grab	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			Grab	1/month
						Avg Mo					
Cadmium, Total	Sample Measurement	***	***	***	***	<.001	***		mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	1/month
						Avg Mo					
Copper, Total	Sample Measurement	***	***	***	***	.011	***		mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	1/month
						Avg Mo					
Lead, Total	Sample Measurement	***	***	***	***	<.003	***		mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	1/month
						Avg Mo					
Zinc, Total	Sample Measurement	***	***	***	***	.047	***		mg/L	24-Hr Composite	1/day
	Permit Measurement	***	***		***	Monitor & Report	***			24-Hr Composite	1/month
						Avg Mo					
Dichlorobromomethane	Sample Measurement	***	***	***	***	.0015	***		mg/L	Grab	1/month
	Permit Measurement	***	***		***	Monitor & Report	***			Grab	1/month
						Avg Mo					

[illegible]

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
ALS_Biweekly N2_MAR2016.PDF	Laboratory Analytical Report	2016-04-27T10:05:07-04:00	
Cryptographic Hash Value of File (SHA-512)		59D5972DEEC0C5584FA56167F9EAF41F3BF611FBF37C74454581110E6A2786CC3E3D9B795C1A060660395690DC8F92E37EC0B823D08	
ALS_cBOD20_3-16.PDF	Laboratory Analytical Report	2016-04-27T10:23:02-04:00	
Cryptographic Hash Value of File (SHA-512)		0D72D12DF05837520D07D3598A47101F9686CBEF9B480726A40CC189CA50980CBFC42E5C286025145073973CDE2E2488B234CE3ABF108F67633CC24576F127D0CD	
ALS_cBOD20_3-6-16.PDF	Laboratory Analytical Report	2016-04-27T10:23:53-04:00	
Cryptographic Hash Value of File (SHA-512)		0E9860A53896FC0AE1C064C0C02E176CFD0828FC2CCE1B495203D594C359A4A02C0B9C9CAE3F3DA596C58A4FD348BF0578096F05783AC65E67B2	
ALS_cBOD20_3-15-16.PDF	Laboratory Analytical Report	2016-04-27T10:25:36-04:00	
Cryptographic Hash Value of File (SHA-512)		CC4930CB77A1BF90E11B504C157E29070F96514B084486B37C03E1B15B775828E1ED367BA86708F587108F5E6E314E673AC8CD3398EA3353E842A3DE6E92C45C1	
ALS_cBOD20_3-24-16.PDF	Laboratory Analytical Report	2016-04-27T10:27:32-04:00	
Cryptographic Hash Value of File (SHA-512)		64DC13E8C002FB53A422D051F54ADAB1653DCDB716992AC026407B55D0A7301229168C64D67CF8FA0D2E01FB83FEC27FCE834A63006615AE692ED40CFE15F3	
ALS_cBOD20_3-3-16.PDF	Laboratory Analytical Report	2016-04-27T10:23:30-04:00	
Cryptographic Hash Value of File (SHA-512)		FD9937B31AD0F46E56C589CF1611AA2F32F23D79CD7494950A298483DD3ADDCC5F734898A02EFC09F4604522368B5EC045A24D1D7C7C0D6D71A7DCB1C34894B	
ALS_cBOD20_3-10-16.PDF	Laboratory Analytical Report	2016-04-27T10:24:15-04:00	
Cryptographic Hash Value of File (SHA-512)		370CE8D9FC543873C38BF4E4F895FC508793BEDB82D1EE5D0E6D4D7DC762AAE2345A2AB873921096BF1720D7E4A18CC567562B6B1B03D1444DE42EF78214890	
ALS_cBOD20_3-13-16.PDF	Laboratory Analytical Report	2016-04-27T10:24:41-04:00	
Cryptographic Hash Value of File (SHA-512)		BD1EF99D935824630A51359589A12C5A5BC606C1011F3AFC0CB18CEFA4229E3CE5A48B8373B78038FD88187D9F5A48B83F5314860BF9BA8EE03AC155D34F52	
ALS_cBOD20_3-17-16.PDF	Laboratory Analytical Report	2016-04-27T10:25:08-04:00	
Cryptographic Hash Value of File (SHA-512)		30405F7AC49F532AA8822CBB1D806630652908D9042D6D50D569253A1F3348EB3748FA44DB870ADE7691034F7AA43A78018AAE08AAE8D7FAC1E6A2498D8B	
Cryptographic Hash Value of File (SHA-512)		1961BDA8371E8F0E90C8CD82C28E48DDBCB04B358C0698E172AD01AE033B7389891169C577D2D8C0DBD210C310A7D9C6FCDC28850CA828D4D7D1B5E591C26E4	
ALS_cBOD20_3-20-16.PDF	Laboratory Analytical Report	2016-04-27T10:26:31-04:00	
Cryptographic Hash Value of File (SHA-512)		710AEEFF4ADE4959D072B6FDB8FD4CA0164FD3C12B7289BF6897DC0258F63AC21C931E39328A7F7809E9B0CE7C0A8EB89850E48B763FEFC6B8C8EA0BEA3E420	
Daily Effluent Monitoring MAR 2016.xlsx	Daily Effluent Monitoring Form	2016-04-27T10:34:16-04:00	
Cryptographic Hash Value of File (SHA-512)		17D51C4C93575300AE34C2D608A0B4C4A47A349BD9FAD2E886EBF48AB5F3813595E1027A589A01C15033CE03FE3F78BD7A78CC6726250AFB4E045C6C77E6484	
Sludge Production and Disposal_MAR 2016.xlsx	Sludge Production / Biosolids Production and Disposal Form	2016-04-27T09:59:53-04:00	
Cryptographic Hash Value of File (SHA-512)		3CF8F518C7458A4C800A8D28E78BDFD755CA47C4669D381EA8E9AD5727CFB80830085ED3E2FAED198B44DD2F4F462040F01FEB04AEFF2725BFAF240D7ACD9	
DMR Laboratory Accreditation-ALS-MAR 2016.doc	Laboratory Accreditation Form	2016-04-27T09:54:27-04:00	
Cryptographic Hash Value of File (SHA-512)		28F5186137C39E421D98E7DF03460833CEDA86A3940D072848A73D7923294C9A79F2958375DF544E4B7D02E6E6C60E0743EE4F3841488C3E8F652D2007096	
DMR Laboratory Accreditation-WRTP-MAR 2016.doc	Laboratory Accreditation Form	2016-04-27T09:54:44-04:00	
Cryptographic Hash Value of File (SHA-512)		A01C46D857CF3420F3DECF48BDD8BF7462A3E7665FBF56A1768714FFE4886E48B8EB982887A0E3B1A6A78D7A1B08229385B387E38ED1857F86F2CDEFF7F	
ALS_Biweekly N1_MAR2016.PDF	Laboratory Analytical Report	2016-04-27T09:59:16-04:00	
Cryptographic Hash Value of File (SHA-512)		F3A0A619609FDC1721C9EDDD9861D01F0366BEDA739FA468E8638B7F71039E985B108F1C178D8CD414EB33B2294988E05DDBDA40B2C9655FCA96CD7FBE4249F12D	
WRTP Lab Influent and Process Control_03-16.pdf	Laboratory Analytical Report	2016-04-27T10:19:53-04:00	
Cryptographic Hash Value of File (SHA-512)		B396A986DD1A673AB9679E8D51CB2927C7E71D714701B84D0379055546D08B16863F1C033B8B60E638343D7624B7FC3B1DFC4175391CA03A91DE0F8012E4	
ALS_Effluent_MAR2016.PDF	Laboratory Analytical Report	2016-04-27T10:13:59-04:00	
Cryptographic Hash Value of File (SHA-512)		048AC421D2012E60C0C45829408E7209C0C3394C8E0689A07C0C976BF429C59F4B0F08B9694F9AD0F4D468E2DB310C355AC395DDE4F6F442801DA882B1FCEEF	
Fecal 10% Mar2016.xlsx	Other	2016-04-27T12:00:55-04:00	10% Rule Calculation sheet
Cryptographic Hash Value of File (SHA-512)		C44DC972D7D4E68A3933C682E0C65AA988248C4087BDB8E3AC0C5668E618F587C7F76570D1815D84EDF02AF8582BCE9A47C81E607C76AF74DBF73DB00BFFC	
Influent and Process Control_MAR2016.xls	Influent and Process Control Form	2016-04-27T10:20:16-04:00	
Cryptographic Hash Value of File (SHA-512)		8337681CE66C113995C8BFAC086BD19E8E1DF26873D1C5A83E8930DF81894313CE6818171C742DB8F20D07F47EEC234104B7B50A7AB24DC0C0A0A5F1BEEBDA	
WRTP_Influent_MAR2016.pdf	Laboratory Analytical Report	2016-04-27T10:22:21-04:00	
Cryptographic Hash Value of File (SHA-512)		5ECAE489F959AAC3072AE18358597CAFF0E87D2D09E9F08B9C5F8BF08D1EAE8CF40042B3A82A49E42ECAD4F91D67F2618008035EB8CF57068256F07C23D	
Hauled in Municipal Waste_MAR2016.xls	Hauled in Municipal Waste Form	2016-04-27T09:56:50-04:00	
Cryptographic Hash Value of File (SHA-512)		93179A94F59ED8EEF11B39C6C2C873AE7D508F749EC3CQC06086AD74AC8D0F961E2C1D31C18592D237400533B763364D312F082A5E18295AFB8C8E7E946EACC	
Hauled in Residual Wastes_MAR2016.xls	Hauled in Residual Waste Form	2016-04-27T09:57:11-04:00	
Cryptographic Hash Value of File (SHA-512)		6ADDEB9402C138359582A51B0366BC4E60D7CA59115B591C23D6BCD050D2E7CED2C01A5673AE08F3C2071C353F60179AC3BC2D9B02751B7F2BA5600ACDC	
Daily Influent Monitoring MAR 2016.xlsx	Daily Influent Monitoring Form	2016-04-27T10:32:30-04:00	Daily Influent Monitoring MAR 2016
Cryptographic Hash Value of File (SHA-512)		846BF5E5941C61C6C0E2B87D62CB3452A4BE18F2124DC2E5CFDE467776890AAE313022B1813CAE1EB1CC3F444B7FD9A443D081622B8ED59F5D07B52FDC9	
March 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-04-27T09:58:22-04:00	March 2016 SWMM Report
Cryptographic Hash Value of File (SHA-512)		AE5533A584103170938BEF4E76020813F95C3E3E4585188898B8663DCCCE5C5E2ADB7F3E40DBB0FF329DC08D40F2E2B8AE406287B8A2986EE1ED9C3E07112A53AE6	

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

WTRP_Effluent_MAR2016.pdf	Laboratory Analytical Report	2016-04-27T10:16:11-04:00
Cryptographic Hash Value of File (SHA-512)	97FBD8E182FE2C31094C1053CF7514373E0D7FCB68D44A7BBFE49A7E2B8956F555F674C30F8CAFE66DD1EC79160A4860A1FB16DBE45D9E7B8EA9CD059E07A7	
ALS_c80D20_3-27-16 PDF	Laboratory Analytical Report	2016-04-27T10:28:04-04:00
Cryptographic Hash Value of File (SHA-512)	2E50B81BD14AC921CF33EED00995D5548951957E248AAAF18A03B8F28D33555C244C0B04E27F772FF52A337649CB8C55D83F6634EE9BADC51D38ABCA16EF9C03	
ALS_c80D20_3-29-16 PDF	Laboratory Analytical Report	2016-04-27T10:28:38-04:00
Cryptographic Hash Value of File (SHA-512)	D64C9749790637F49C0D7C38F8F498E1EF7668046540180299B1C917A6C56D9B10A9ADB74E3C3FAE6912E4880C3A818E496D8E25A88811F2065E83E95C6D833951E7	
ALS_c80D20_3-31-16 PDF	Laboratory Analytical Report	2016-04-27T10:28:08-04:00
Cryptographic Hash Value of File (SHA-512)	CB251632A3734527FAFC0C34ED7D89D04C55272D391CC3B7589542E122242108250551E453C3E2772336CA0CA576B2355FE7DC8FD69BE4087B62358772605D	
DMR Cover Letter MAR 2016.doc	Cover Letter	2016-04-27T11:02:28-04:00
Cryptographic Hash Value of File (SHA-512)	6AE898E8BC77F47AB4CB14DFAADD8CADA4D96E58B717E05F05C65FB5CB17A93439E32EA3EE67D07DDE45E19FB1CC322AD01F2E1EA9A234CECF37E006A3613EC33735	
ALS_c80D20_3-22-16 PDF	Laboratory Analytical Report	2016-04-27T10:27:00-04:00
Cryptographic Hash Value of File (SHA-512)	23C44AD6B83717D4CCCE87C868FC86842D58590CE7D786FD6895EC8B3F587D62C0C21D690EAA24EE2C9D19C5EE6B91F7F6F3AB3D05FB681A760FC2E0D4025944	

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

PERMIT VIOLATIONS												
Non-Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non-Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non-Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type	Comments								
COMMENTS DETAILS												
Comment	Operator Name											
	Michael J. DiSantis											
	Operator Certification Number	Operator Contact Number										
	T0403	6108765523										
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 60, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User	DISANTISM		Submitted By Full Name									
Email Address	disantism@delcora.org		Document Generated									
	4/27/2016											



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	03	01	TO	16	03	31
PARAMETER										
ANALYSIS METHOD										
LAB NAME										
LAB ID NUMBER²										
Copper, Total										
EPA 200.7										
ALS Environmental										
PA 22-293										
Lead, Total										
EPA 200.7										
ALS Environmental										
PA 22-293										
Zinc, Total										
EPA 200.7										
ALS Environmental										
PA 22-293										
Dichlorobromomethane										
EPA 624										
ALS Environmental										
PA 22-293										
BOD20/cBOD20										
SM5210 B										
ALS Environmental										
PA 22-293										
Chlorodibromomethane										
EPA 624										
ALS Environmental										
PA 22-293										
TKN-N										
EPA 351.2										
ALS Environmental										
PA 22-293										
Ammonia as N										
D6919-09										
ALS Environmental										
PA 22-293										
Nitrate as N										
EPA 300.0										
ALS Environmental										
PA 22-293										
Total Cyanide										
EPA 335.4										
ALS Environmental										
PA 22-293										
Total Cadmium										
200.7										
ALS Environmental										
PA 22-293										
Nitrite as N										
EPA 300.0										
ALS Environmental										
PA 22-293										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 04/21/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	03	01	TO	16	03	31
PARAMETER		ANALYSIS METHOD		LAB NAME		LAB ID NUMBER²				
BOD5/cBOD5		SM5210 B		DELCORA - Central Laboratory		23-00671				
TSS		SM 2540 D		DELCORA - Central Laboratory		23-00671				
O&G		EPA 1664 A		DELCORA - Central Laboratory		23-00671				
Total Residual Cl		SM4500-Cl G		DELCORA - Central Laboratory		23-00671				
N-Nitrite		SM4500-NO2 B		DELCORA - Central Laboratory		23-00671				
NH3-N		EPA 350.1		DELCORA - Central Laboratory		23-00671				
TKN-N		SM4500-N-org B/SM4500-NH3 C		DELCORA - Central Laboratory		23-00671				
Fecal Coliform		SM 9222 D		DELCORA - Central Laboratory		23-00671				
BOD20/cBOD20		SM5210 B		DELCORA - Central Laboratory		23-00671				
pH		SM 4500 H+B		DELCORA - Central Laboratory		23-00671				
Ammonia as N		EPA 350.1		DELCORA - Central Laboratory		23-00671				
TDS		SM 2540 C		DELCORA - Central Laboratory		23-00671				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 04/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: **March** Year: **2016**
 NPDES Permit No.: **PA0027103**
 Renewal application due **180 days** prior to expiration
 This permit will expire on: **April 30, 2018**

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month[illegible]**TOTAL:**

TOTAL:	854.890
---------------	----------------

TOTAL:	1,042,820
---------------	------------------

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION

(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Wicks Community Landfill and Recycling	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use *	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**

License No.:

T0403

Dir. Of Operations and Maintenance

Date: April 28, 2016

April 28, 2016



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA W RTP County: Delaware Month: March Year: 2016
 Municipality: City of Chester NPDES Permit No.: PA0027103
 Watershed: 3G Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	37.24			298	92,553	3690.00	1.31	189940
2	38.50	482	154,765	480	154,123	4175.00	1.16	185450
3	35.60			256	76,007	4955.00	1.34	161490
4	36.00			239	71,757	4490.00	1.46	218290
5	34.53			213	61,340	4195.00	1.60	167450
6	34.47			144	41,397	4820.00	2.47	170800
7	36.07			262	78,816	4560.00	1.50	170620
8	34.75			290	84,046	4065.00	1.24	186630
9	34.15	291	82,880	282	80,317	4520.00	1.32	238670
10	33.49			352	98,316	4580.00	1.31	239720
11	33.78			356	100,294	5000.00	1.11	236870
12	34.32			188	53,811	4870.00	1.42	204890
13	34.97			166	48,414	4785.00	1.51	200330
14	55.01			334	153,234	4420.00	1.33	209190
15	42.58			268	95,171	3840.00	1.40	178280
16	38.18	377	120,045	234	74,511	4315.00	1.07	204090
17	36.21			310	93,617	4440.00	1.11	224220
18	34.55			644	185,567	4280.00	1.30	197900
19	33.08			258	71,179	4145.00	2.19	208450
20	33.58			138	38,648	3670.00	2.82	189770
21	33.82			332	93,644	4045.00	1.37	223630
22	33.06			286	78,856	4240.00	0.98	173230
23	33.57	399	111,710	296	82,872	4150.00	0.97	220830
24	33.44			356	99,285	3645.00	1.09	228680
25	32.67			230	62,668	4070.00	1.01	209060
26	32.05			184	49,183	4190.00	1.38	188310
27	32.74			212	57,887	4480.00	1.43	220100
28	39.38			348	114,293	2605.00	1.01	182860
29	33.65			378	106,082	3950.00	0.89	234560
30	32.30	494	133,075	372	100,210	5000.00	0.91	203390
31	33.53			328	91,722	4220.00	0.97	150390
Avg	35.525	409	120,495	291	86,768	4,271	1	200,584
Max	55.01	494	154,765	644	185,567	5,000	3	239,720

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis License No.: T0403
 Title: Dir. Of Operations and Maintenance Date: 4/28/2016



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Facility Name: **DELCORA STP**
Municipality: **City of Chester**
Watershed: **3G**

County: **Delaware**Month: **March** Year: **2016**NPDES Permit No.: **PA0027103**Renewal application due **180 days** prior to expiration,This permit will expire on: **April 30, 2018**

Day	SEPTAGE			SLUDGE			OTHER (specify): Package Plant			DAILY TOTALS		
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)	Gallons	BOD ₅ (lbs)
1	38510				89500				84400		212,410	0
2	42685			Headworks	55508				122400		220,593	0
3	28600				99488				43935		172,023	0
4	26050			Headworks	75431			Sludge Thickening	96700		198,181	0
5				Headworks	96700			Sludge Thickening			96,700	0
6				Headworks				Sludge Thickening				0
7	17800			Headworks	61718			Sludge Thickening	84600		164,118	0
8	27550			Headworks	88614			Sludge Thickening	41200		157,364	0
9	25700			Headworks	79903			Sludge Thickening	88800		194,403	0
10	29300				86187				70800		186,287	0
11	22700			Headworks	74760			Sludge Thickening	58000		155,460	0
12	3600			Headworks				Sludge Thickening	6500		10,100	0
13				Headworks				Sludge Thickening				0
14	36910			Headworks	67412			Sludge Thickening	65700		170,022	0
15	17650			Headworks	87775			Sludge Thickening	97900		203,325	0
16	34620			Headworks	80451				160700		275,771	0
17	50900				86977				76723		214,600	0
18	28850			Headworks	87509			Sludge Thickening	84400		200,759	0
19				Headworks	6500			Sludge Thickening	16700		23,200	0
20				Headworks				Sludge Thickening				0
21	41050			Headworks	74063			Sludge Thickening	44650		159,763	0
22	37900			Headworks	76100			Sludge Thickening	99200		213,200	0
23	35850				79051				140100		255,001	0
24	59650				86847				197250		343,747	0
25	42870			Headworks	48723			Sludge Thickening	95970		187,563	0
26	4400			Headworks				Sludge Thickening			4,400	0
27				Headworks				Sludge Thickening				0
28	39360			Headworks	81100			Sludge Thickening	40550		161,010	0
29	25300			Headworks	105436			Sludge Thickening	133400		264,136	0
30	42100			Headworks	78809			Sludge Thickening	124000		244,909	0
31	35500				61168				144170		240,838	0
Avg	31,816				76,629				88,750		Monthly Totals: 4,929,883	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Operations and Maintenance**

License No.: **T0403**
Date: **4/28/2016**

SUPPLEMENTAL REPORT - HAULED IN RESIDUAL WASTES

Facility Name: DELCORA STP
 Municipality: City of Chester
 Watershed: 3G
 County: Delaware
 Month: March Year: 2016
 NPDES Permit No.: PA0027103 A:
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

[illegible]

Total:	16,768.068
--------	------------

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Operations and Maintenance**

License No.: **T0403**
Date: **4/28/2016**



Month: 3 (select number) Year: 2016
 Permit No.: PA0027103 A3 Outfall: 001
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

Parameter	Unit	Flow	Fecal Coliform		pH	BOD ₅		CBOD ₂₀		CBOD ₂₀		TSS		TSS		TDS		Oil and Grease		TRC		NH ₃ -N		NO ₃ -N		TKN		Total Copper		Total Lead	
			Q	CFU/100 ml		Q	SL	Q	mgd	Q	mgd	Q	%	Q	mgd	Q	mgd	Q	mgd	Q	mgd	Q	mgd	Q	mgd	Q	mgd	Q	mgd	Q	mgd
1	Sum	26.57																													
2	Min	26.57																													
3	Max	26.57																													
4	Avg	26.57																													
5	Std	26.57																													
6	Var	26.57																													
7	Coef	26.57																													
8	Skew	26.57																													
9	Kurt	26.57																													
10	Mean	26.57																													
11	Median	26.57																													
12	Mode	26.57																													
13	Range	26.57																													
14	Min	26.57																													
15	Max	26.57																													
16	Avg	26.57																													
17	Std	26.57																													
18	Var	26.57																													
19	Coef	26.57																													
20	Skew	26.57																													
21	Kurt	26.57																													
22	Mean	26.57																													
23	Median	26.57																													
24	Mode	26.57																													
25	Range	26.57																													
26	Min	26.57																													
27	Max	26.57																													
28	Avg	26.57																													
29	Std	26.57																													
30	Var	26.57																													
31	Coef	26.57																													
32	Skew	26.57																													
33	Kurt	26.57																													
34	Mean	26.57																													
35	Median	26.57																													
36	Mode	26.57																													
37	Range	26.57																													
38	Min	26.57																													
39	Max	26.57																													
40	Avg	26.57																													
41	Std	26.57																													
42	Var	26.57																													
43	Coef	26.57																													
44	Skew	26.57																													
45	Kurt	26.57																													
46	Mean	26.57																													
47	Median	26.57																													
48	Mode	26.57																													
49	Range	26.57																													
50	Min	26.57																													
51	Max	26.57																													
52	Avg	26.57																													
53	Std	26.57																													
54	Var	26.57																													
55	Coef	26.57																													
56	Skew	26.57																													
57	Kurt	26.57																													
58	Mean	26.57																													
59	Median	26.57																													
60	Mode	26.57																													
61	Range	26.57																													
62	Min	26.57																													
63	Max	26.57																													
64	Avg	26.57																													
65	Std	26.57																													
66	Var	26.57																													
67	Coef	26.57																													
68	Skew	26.57																													
69	Kurt	26.57																													
70	Mean	26.57																													
71	Median	26.57																													
72	Mode	26.57																													
73	Range	26.57																													
74	Min	26.57																													
75	Max	26.57																													
76	Avg	26.57																													
77	Std	26.57																													
78	Var	26.57																													
79	Coef	26.57																													
80	Skew	26.57																													
81	Kurt	26.57																													
82	Mean	26.57																													
83	Median	26.57																													
84	Mode	26.57																													
85	Range	26.57																													
86	Min	26.57																													
87	Max																														

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel performed the information submitted. I declare that I am the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for providing false information. See 18 U.S.C. 1001 (relating to custom falsification).

License No.: **TD403**
 Date: **4/28/2016**

Prepared By: **Micheal DiSantis**
 Title: **Dir. Of Operations and Maintenance**

CSO SUPPLEMENTAL REPORT
MONTHLY INSPECTION REPORT

Watershed: 3G

Renewal application due 180 days prior to expiration.

This permit will expire on: **April 30, 2018**

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	Total overflow from Outfalls 009 and 010
010	5th & Pusey	Yes	Discharges to Outfall 009 Regulator
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Title: Dir. Of Operations and Maintenance

Date: 4/12/2016

T0403

Fecal

1	2400
2	184
3	128
4	84
5	42
6	38
7	38
8	29
9	23
10	23
11	23
12	23
13	18
14	17
15	16
16	13
17	11
18	8
19	8
20	8
21	7
22	6
23	6
24	6
25	4
26	4
27	3
28	3
29	3
30	3
31	2

APR 2016

From: depgreenporthelpdesk@state.pa.us
Sent: Friday, May 27, 2016 8:01 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 20292 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 20292
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 04/01/2016-04/30/2016
Monitoring Report Due Date : 05/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

May 27, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

Steven O'Neil
Regional Manager – Water Management
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. O'Neil:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for April, 2016. All parameters were in compliance during the month.

Parameter averages for April, 2016 were: Flow – 31.97; cBOD₅ – 8 mg/L; TSS – 12 mg/L; cBOD₂₀ % removal – 93.11%; and cBOD₂₀ – 5,907 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:vm
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELORA STP
Permit Number:	PA0027103	Monitoring Period:	04/01/2016-04/30/2016
		Location Address:	3201 W FRONT ST. CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	001		Stage Code		Final Effluent		No Discharge Indicator		Sample Frequency
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	
pH	Sample Measurement	***	***	***	6.44	***	6.89	S.U.	Grab	1/day
	Permit Measurement	***	***	***	6.0 Inst Min	***	9.0 IMAX		Grab	1/day
Total Suspended Solids	Sample Measurement	3170	4410	lbs/day	***	12	16	mg/L	24-Hr Composite	1/day
	Permit Measurement	11000 Avg Mo	16500 Wkly Avg	***	***	30 Avg Mo	45 Wkly Avg		24-Hr Composite	1/day
Oil and Grease	Sample Measurement	<1333	***	lbs/day	***	<5	5	mg/L	Grab	1/day
	Permit Measurement	5500 Avg Mo	***	***	***	15 Avg Mo	30 IMAX		Grab	1/day
Ammonia-Nitrogen	Sample Measurement	***	***	***	***	<.77	***	mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	2/month
Nitrite as N	Sample Measurement	***	***	***	***	.44	.8	mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	Monitor & Report Daily Max		24-Hr Composite	2/month
Nitrate as N	Sample Measurement	***	***	***	***	9.85	12.7	mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	Monitor & Report Daily Max		24-Hr Composite	2/month
Total Kjeldahl Nitrogen	Sample Measurement	***	***	***	***	3.22	***	mg/L	24-Hr Composite	2/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	2/month
Cyanide, Total	Sample Measurement	***	***	***	***	.031	***	mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/month
Chlorodibromomethane	Sample Measurement	***	***	***	***	<.001	***	mg/L	Grab	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		Grab	1/month
Cadmium, Total	Sample Measurement	***	***	***	***	<.001	***	mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/month
Copper, Total	Sample Measurement	***	***	***	***	.012	***	mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/month
Lead, Total	Sample Measurement	***	***	***	***	<.003	***	mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/month
Zinc, Total	Sample Measurement	***	***	***	***	.07	***	mg/L	24-Hr Composite	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		24-Hr Composite	1/month
Dichlorobromomethane	Sample Measurement	***	***	***	***	.001	***	mg/L	Grab	1/month
	Permit Measurement	***	***	***	***	Monitor & Report Avg Mo	***		Grab	1/month

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

[illegible]

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
ALS_cBOD20_4-17-16.PDF	Laboratory Analytical Report	2016-05-27T10:02:47-04:00	
Cryptographic Hash Value of File (SHA-512)	98E0692F84668C31E29592DF9139EA681E070A95DD8CDD8EEFD849D09790529071C2088D6C19B53256832EEEF7A0C4335A621E2426180321627331A9E2C0DFAA		
Daily Effluent Monitoring APR 2016.xlsx	Daily Effluent Monitoring Form	2016-05-27T09:54:53-04:00	
Cryptographic Hash Value of File (SHA-512)	0E836EFF1F59330D567AE37AD01E745BDDAA4A5090A6CCDDCF6F0483755600BE4A5A1D122F7DE8255473C90AD0647B5231A59F67837519943B7AD7FCA3FE0A3C		
Influent and Process Control_APR2016.xls	Influent and Process Control Form	2016-05-27T09:56:35-04:00	
Cryptographic Hash Value of File (SHA-512)	4F3335938D0244D68C6A7A45AF04B5949B2AB0B4F7AE7894E9B737FE24B08469827901A056A22EB12635D93843381DF1AA9824B4CB1305F9A18E043B49EBB6A95		
Sludge Production and Disposal_MAR 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-05-27T09:56:54-04:00	
Cryptographic Hash Value of File (SHA-512)	7D8F9B58D9598888AC8FA348D5126A8EC554CDFEB76BB93ADE0D8873AFFF4ABA7364AABE74B689C72BF5D84F3E4A150294308AAADDEA5114A9C1CA7F63F469A38		
DMR Laboratory Accreditation-WRTP-APR 2016.doc	Laboratory Accreditation Form	2016-05-27T09:57:38-04:00	
Cryptographic Hash Value of File (SHA-512)	33F154CA037E575F423B16C91080CE58FBEB2D84FCF399E58E0FA0B3ED15D20C00A4F566B886AE05B4DC3DB1A276F0AA1A8FCB780557BA597CACFA854F55E0228		
ALS_Effluent_APR 2016.PDF	Laboratory Analytical Report	2016-05-27T09:58:24-04:00	
Cryptographic Hash Value of File (SHA-512)	53000953499A073B36D7D5D1404BD8D06788F6D01B26619E9DF03B368B36AC05C08733588963D1DA80734211648D843D8F6E6AD913CSD098E8DEAEF70F5B7E5FD9		
WRTP_Effluent_APR 2016.pdf	Laboratory Analytical Report	2016-05-27T09:59:01-04:00	
Cryptographic Hash Value of File (SHA-512)	BE23DC0939C4B33DEF618D0E1484290F06004F03DE7D9ACA199535AEAE80F7D3815EC9352F0300EB1B066071652F9D2684C5DED2C89E672281E100B53EE0F274		
WRTP_Influent_APR 2016.pdf	Laboratory Analytical Report	2016-05-27T09:59:21-04:00	
Cryptographic Hash Value of File (SHA-512)	C1D6FC509758EA6F0A0B35FE26E38776F15C4B896611EDBACD50F884B38A65AE389558BCB28579F97F90BD60AC30042513CED7B2BC08696DBCA30CFB8FA76B92		
ALS_cBOD20_4-21-16.PDF	Laboratory Analytical Report	2016-05-27T10:03:32-04:00	
Cryptographic Hash Value of File (SHA-512)	63D187DCAAF167E0FF757BA5074848C78760486037DA8A7BA1B197701AFC8BE7453701788043B8374EB778128F68C194ECA8F51EB2DD5FFE37E330F134A55564		
ALS_cBOD20_4-7-16.PDF	Laboratory Analytical Report	2016-05-27T10:00:56-04:00	
Cryptographic Hash Value of File (SHA-512)	871ECD9B11E6990AE92CED40AB7BA571A7630820DE551DCD3314E7D28E8088C7313F85516622FE9AA939D02F24711CCCE9841E35E7CEA669694A77D0A79E241		
ALS_cBOD20_4-10-16.PDF	Laboratory Analytical Report	2016-05-27T10:01:39-04:00	
Cryptographic Hash Value of File (SHA-512)	234077E94073706402B8E93A0F7B344E90E873CA5A15500B5D5462FE1498DB1FED1C3D59BAC61E0FEDC97825217511E417DF9BBA4A825DDEE4DF9C46CC0AC4		
ALS_cBOD20_4-14-16.PDF	Laboratory Analytical Report	2016-05-27T10:02:24-04:00	
Cryptographic Hash Value of File (SHA-512)	79A0285D8F2181472862E599E0EA07B1D1AC79B19F30AE1E55FA13B95F150E279D23DF7A098827D7A1173C4420B03E683D099701EDB6D03BFFBFF603A9ED415A		
ALS_cBOD20_4-24-16.PDF	Laboratory Analytical Report	2016-05-27T10:03:56-04:00	
Cryptographic Hash Value of File (SHA-512)	548094D49BD5A9E6A5F0C10B959E19A0A4F62F02D0F59B3CEBC748330F6FB5B1F1D0D4F0A28C0549C53076B2716A48F22DC1EAF39E03E8EE3F1981F0910A0		
Cryptographic Hash Value of File (SHA-512)	April 2016 SWMM Report.xlsx	2016-05-27T09:54:26-04:00	SWMM Report
Cryptographic Hash Value of File (SHA-512)	C8864DCDF007A7FCC4504A321880479733EA8BBBF041A44331704E9331B98C4943D0F04D7C9D760C482328D74CD3F347418A7D7E5870DBF65956530FD473B82D		
Daily Influent Monitoring APR 2016.xlsx	Other	2016-05-27T09:55:39-04:00	Daily Influent Monitoring APR 2016
WRTP Lab_Influent & Process Control_APR2016.pdf	Laboratory Analytical Report	2016-05-27T09:58:41-04:00	
Cryptographic Hash Value of File (SHA-512)	8FD2C7D598F62C97506921C329A4F4D0DE95330E474538986683A5963D5968AABSC20C657ED16EED4D749333551F52946B68F44AE324AE7A0E2B2866ED		
ALS_cBOD20_4-28-16.PDF	Laboratory Analytical Report	2016-05-27T10:05:47-04:00	
Cryptographic Hash Value of File (SHA-512)	730AAB7080659C82F3CBE7909FCF66184F25968E5E4692E9173F74491E612DE22591B92295273DBC1AF6F384E04CC854D472F3845EF4284427791261E8E7839D		
Healed In Residual Wastes_APR2016.xls	Healed-In Residual Waste Form	2016-05-27T09:56:18-04:00	
Cryptographic Hash Value of File (SHA-512)	2DED618A3CD37ABA32B9D8E0BC207845A12A19D0E107FDD8AB1927852730BBCC3A0860B3EC7BD7260CDC71406D16D71C88AC35527678B00D35D74A334B279A7B9		
ALS_cBOD20_4-3-16.PDF	Laboratory Analytical Report	2016-05-27T10:00:10-04:00	
Cryptographic Hash Value of File (SHA-512)	A9E283FEED08E0E777B03F1FCF87A56F8759B3A37DD534C672A49A901E92B5AE6734D5262F9616DBDC4E90C54C36054FFADF6E483AD7539E99E2C7D5155306963		
DMR Laboratory Accreditation-ALS-APR 2016.doc	Healed-In Municipal Waste Form	2016-05-27T09:56:00-04:00	
Cryptographic Hash Value of File (SHA-512)	C4581C761FAE5124C8C82A000F1BDC215DCE3B323A6AE49F56F565B844A8C78EC34AA12C5994F3274B967C2BA4F9C6DFCSA004E7BB8ED6F8BAFC7D394B5B1		
Cryptographic Hash Value of File (SHA-512)	6DBEE044B975866ADD64329B3390A10430249F3364B48B9A8E566E50CEEE65A17287123DEA1468404FB11E4A7DA1661309C29538D5B083903624744654C32094		
ALS_cBOD20_4-19-16.PDF	Laboratory Analytical Report	2016-05-27T10:03:08-04:00	
Cryptographic Hash Value of File (SHA-512)	QDC088006398C3B4494A3C5F53E07439360C20F984E7D6AC3F7BA508B67294B1571E74F72627A4C5F80ACC2776ECF3596133D70599D0AC9FE57B5D1948CDF20		
ALS_cBOD20_4-5-16.PDF	Laboratory Analytical Report	2016-05-27T10:00:34-04:00	
Cryptographic Hash Value of File (SHA-512)	A2CB628F0EBE910C02375ACE01836951E50C108B82DF9BA9417F10C37E518036CAF5E79D695E45DDB7D543AA8A836DE5A6942278F334263283321A56071DE		
ALS_cBOD20_4-12-16.PDF	Laboratory Analytical Report	2016-05-27T10:02:02-04:00	
Cryptographic Hash Value of File (SHA-512)	6F93B2B35EEA435447F0EBBA21F395C149B0704F4F6A28BF76A19B92A3070DE/833B4191F2738C1D15DD83D69A0468E7F36D4616B51C90851CA90BC360E7051882		
DMR Cover Letter APR 2016.doc	Cover Letter	2016-05-27T20:00:32-04:00	
Cryptographic Hash Value of File (SHA-512)	62CCDB662F1570DE30733464447E58B1751D9D86684CDD00B771EDC02764B7E8ABBB291EA59F03DE47DBB552176C8C35D9E23B5015AA-C98BC89DC7237B9A0A88B		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ALS_cBOD20_4-26-16.PDF	Laboratory Analytical Report	2016-05-27T10:05:15-04:00	
Cryptographic Hash Value of File (SHA-512)	658149EB64CDD8A91D4CCD4AFDEAFDD00428E2A69368F1F7C31A38855682148E27EF6CC2EF581CA5B8E8BBD2080DD558A8BA21697D77792FC3A092E1F62E69E		

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

PERMIT VIOLATIONS												
Non-Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Corrective Action	Comments		
UNAUTHORISED DISCHARGES												
Non-Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non-Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type	Comments								
COMMENTS DETAILS												
Comment	Operator Name					Operator Certification Number		Operator Contact Number				
	Michael J. DiSantis					T0403		6108765523				
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User			DISANTISM			Submitted By Full Name			Michael DiSantis			
Email Address			disantism@delcora.org			Document Generated			5/27/2016			



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	04	01	TO	16	04	30
PARAMETER		ANALYSIS METHOD		LAB NAME			LAB ID NUMBER²			
Copper, Total		EPA 200.7		ALS Environmental			PA 22-293			
Lead, Total		EPA 200.7		ALS Environmental			PA 22-293			
Zinc, Total		EPA 200.7		ALS Environmental			PA 22-293			
Dichlorobromomethane		EPA 624		ALS Environmental			PA 22-293			
BOD20/cBOD20		SM5210 B		ALS Environmental			PA 22-293			
Chlorodibromomethane		EPA 624		ALS Environmental			PA 22-293			
TKN-N		EPA 351.2		ALS Environmental			PA 22-293			
Ammonia as N		D6919-09		ALS Environmental			PA 22-293			
Nitrate as N		EPA 300.0		ALS Environmental			PA 22-293			
Total Cyanide		EPA 335.4		ALS Environmental			PA 22-293			
Total Cadmium		200.7		ALS Environmental			PA 22-293			
Nitrite as N		EPA 300.0		ALS Environmental			PA 22-293			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 05/21/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	04	01	TO	16	04	30
PARAMETER		ANALYSIS METHOD		LAB NAME			LAB ID NUMBER²			
BOD5/cBOD5		SM5210 B		DELCORA - Central Laboratory			23-00671			
TSS		SM 2540 D		DELCORA - Central Laboratory			23-00671			
O&G		EPA 1664 A		DELCORA - Central Laboratory			23-00671			
Total Residual Cl		SM4500-Cl G		DELCORA - Central Laboratory			23-00671			
N-Nitrite		SM4500-NO2 B		DELCORA - Central Laboratory			23-00671			
NH3-N		EPA 350.1		DELCORA - Central Laboratory			23-00671			
TKN-N		SM4500-N-org B/SM4500-NH3 C		DELCORA - Central Laboratory			23-00671			
Fecal Coliform		SM 9222 D		DELCORA - Central Laboratory			23-00671			
BOD20/cBOD20		SM5210 B		DELCORA - Central Laboratory			23-00671			
pH		SM 4500 H+B		DELCORA - Central Laboratory			23-00671			
Ammonia as N		EPA 350.1		DELCORA - Central Laboratory			23-00671			
TDS		SM 2540 C		DELCORA - Central Laboratory			23-00671			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 05/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

Month: **April** Year: **2016**
 NPDES Permit No.: **PA0027103**
 Renewal application due **180 days** prior to expiration
 This permit will expire on: **April 30, 2018**

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month[illegible]

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	ks Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Of Operations and Maintenance**

License No.: T0403
Date: May 28, 2016



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Facility Name: DELCORA WRTTP County: Delaware Month: April Year: 2016
Municipality: City of Chester NPDES Permit No.: PA0027103
Watershed: 3G Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Influent					Process Control			
Day	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	33.46			333	92,926	3795.00	0.96	225090
2	33.97			174	49,296	3890.00	1.14	245750
3	33.12			174	48,062	3305.00	1.38	222870
4	34.87			412	119,816	2750.00	1.07	235630
5	30.98			402	103,866	2995.00	1.14	169120
6	33.38	286	79,619	364	101,334	3605.00	1.21	0
7	35.32			382	112,525	3515.00	1.22	0
8	33.72			530	149,049	3540.00	1.33	0
9	42.31			200	70,573	3615.00	1.73	0
10	36.67			186	56,884	3710.00	2.88	147220
11	33.91			340	96,155	3600.00	1.42	95170
12	39.78			158	52,419	4090.00	1.02	192440
13	34.09	354	100,646	394	112,018	4050.00	1.27	137630
14	33.41			410	114,242	3965.00	1.45	143710
15	32.37			488	131,743	4165.00	1.37	168560
16	31.72			280	74,073	4210.00	1.49	191060
17	32.13			172	46,090	3920.00	2.24	185320
18	32.43			330	89,254	3415.00	1.37	195660
19	32.84			310	84,905	3055.00	1.39	161660
20	33.03	301	82,917	290	79,886	4125.00	1.26	215040
21	31.80			424	112,450	4105.00	1.27	215530
22	31.12			370	96,030	4010.00	1.14	204250
23	33.46			266	74,229	4265.00	1.31	151700
24	31.41			188	49,248	4060.00	2.15	208540
25	32.67			436	118,796	3420.00	1.67	156690
26	35.77			382	113,959	3770.00	1.33	175730
27	31.73	399	105,587	400	105,851	4350.00	1.45	205520
28	30.53			394	100,320	4615.00	1.43	238080
29	35.03			410	119,782	4360.00	1.53	235490
30	31.47			208	54,592	4810.00	1.70	218180
31								
Avg	33.617	335	92,192	327	91,012	3,836	1	164,721
Max	42.31	399	105,587	530	149,049	4,810	3	245,750

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis License No.: T0403
Title: Dir. Of Operations and Maintenance Date: 5/28/2016



SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

County: DelawareMonth: April Year: 2016NPDES Permit No.: PA0027103Renewal application due 180 days prior to expiration.This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify): Package Plant			DAILY TOTALS		
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Gallons
1	37000			Headworks	74823			Sludge Thickening	84200			196,023
2	9250			Headworks	96900			Sludge Thickening				106,150
3												0
4	41750			Headworks	67448			Sludge Thickening	197401			306,599
5	42150			Headworks	87862			Sludge Thickening	266000			396,012
6	47450			Headworks	85712			Sludge Thickening	173100			306,262
7	36400			Headworks	112360			Sludge Thickening	213800			362,560
8	37850			Headworks	81028			Sludge Thickening	200706			319,584
9	6720			Headworks				Sludge Thickening	10600			17,320
10												0
11	25600			Headworks	61420			Sludge Thickening	27350			114,370
12	48300			Headworks	24947			Sludge Thickening	116600			189,847
13	49250			Headworks	31050			Sludge Thickening	131100			211,400
14	13950			Headworks	18601			Sludge Thickening	173300			205,851
15	20650			Headworks	37935			Sludge Thickening	78450			137,035
16				Headworks								0
17												0
18	29175			Headworks	65163			Sludge Thickening	78900			173,238
19	37060			Headworks	72600			Sludge Thickening	122000			231,660
20	48600			Headworks	91458			Sludge Thickening	111300			251,358
21	34450			Headworks	65679			Sludge Thickening	181640			281,769
22	24700			Headworks	80325			Sludge Thickening	164025			269,050
23									5000			5,000
24												0
25	65950			Headworks	67406			Sludge Thickening	128350			261,706
26	39300			Headworks	92938			Sludge Thickening	95840			228,078
27	40550			Headworks	91701			Sludge Thickening	165245			297,496
28	42250			Headworks	104363			Sludge Thickening	121800			268,413
29	25250			Headworks	112765			Sludge Thickening	128374			266,389
30	7400			Headworks				Sludge Thickening	3800			11,200
31												0
Avg	33,792				73,840				124,969			Monthly Totals: 5,414,370

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantisTitle: Dir. Operations and MaintenanceLicense No.: T0403Date: 5/28/2016



SUPPLEMENTAL REPORT - HAULED IN RESIDUAL WASTES

Facility Name: **DELCORA STP**
 Municipality: **City of Chester**
 Watershed: **3G**

County: Delaware

Month: **April**
NPDES Permit No.: **PA0027103 A**

Year: 2016

Renewal application due **180 days** prior to expiration.
This permit will expire on: **April 30, 2018**

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**

License No.: T0403

Title: **Dir. Operations and Maintenance**Date: 5/28/2016

DEPARTMENT OF ENVIRONMENTAL PROTECTION

1000-PM-APPENDICES 3/2013

SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name: DELCORA WRTP
Municipality: City of Chester
County: Delaware
Month: 4 (noted water)
Year: 2016
Permit No.: PA0027103 A
Outfall: 001
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Parameter	Flow	Fecal Coliform	pH	CBOD5	CBOD20	CBOD20	TSS	TSS	TSS	Oil and Grease	TRC	NH3-N	NO3-N	TKN	Total Copper	Total Lead
Unit	MGD	1000 CFU/100 ML	1	1	1	1	MG/L	MG/L	MG/L	1	1	1	1	1	1	1
1	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
2	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
3	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
4	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
5	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
6	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
7	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
8	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
9	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
10	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
11	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
12	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
13	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
14	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
15	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
16	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
17	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
18	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
19	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
20	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
21	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
22	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
23	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
24	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
25	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
26	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
27	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
28	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
29	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
30	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
31	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
32	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
33	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
34	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
35	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
36	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
37	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
38	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
39	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
40	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
41	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
42	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
43	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
44	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
45	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
46	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
47	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
48	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
49	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
50	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
51	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
52	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
53	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
54	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
55	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
56	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
57	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
58	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
59	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
60	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
61	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
62	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
63	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
64	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
65	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
66	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
67	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
68	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
69	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
70	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
71	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
72	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
73	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
74	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
75	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
76	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
77	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
78	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
79	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003
80	26.60	200	8.80	19	23	87.22	19	15	15	5	0.90	1.04	0.90	3.89	0.012	0.003



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name: Delaware County Regional Water Quality Control Authority

Municipality: City of Chester County: Delaware

Watershed: 3G

Month: April Year: 2016

NPDES Permit No.: PA0027103

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tilghman	Yes	
009	2nd & Lloyd	Yes	
010	5th & Pusey	Yes	
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	No	
015	4th & Melrose	Yes	
016	8th & McDowell	No	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	No	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	No	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	No	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	
Total overflow from Outfalls 009 and 010			
Discharges to Outfall 009 Regulator			

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis

Title: Dir. Of Operations and Maintenance

License No.: T0403

Date: 5/10/2016



SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name:	DELORA WRP	Month:	4	Year:	2016
Municipality:	City of Chester	Permit No.:	PA0027103.43	Outfall:	001
Watershed:	3G	County:	Delaware		
Laboratories:	DELORA; ALS Environmental				

Renewal application due **180** days prior to expiration.
This permit will expire on: April 30, 2018

Parameter		Flow	TSS	BOD5	CBOD5																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
Time	Date	1	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d	1d

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted, based on the inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 U.S.C. § 1001 (false information furnished).

Prepared By: Micheal DiSantis License No: T0403
Title: Dir. Of Operations and Maintenance Date: 5/28/2016



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

3800-FM-BPNP-SM0436 3/2012

Facility Name: DELCORA W RTP County: Delaware Month: April Year: 2016
Municipality: City of Chester NPDES Permit No.: PA0027103
Watershed: 3G Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	Influent					Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)	
1	33.46			333	92,926	3795.00	0.96	225090	
2	33.97			174	49,296	3890.00	1.14	245750	
3	33.12			174	48,062	3305.00	1.38	222870	
4	34.87			412	119,816	2750.00	1.07	235630	
5	30.98			402	103,866	2995.00	1.14	169120	
6	33.38	286	79,619	364	101,334	3605.00	1.21	0	
7	35.32			382	112,525	3515.00	1.22	0	
8	33.72			530	149,049	3540.00	1.33	0	
9	42.31			200	70,573	3615.00	1.73	0	
10	36.67			186	56,884	3710.00	2.88	147220	
11	33.91			340	96,155	3600.00	1.42	95170	
12	39.78			158	52,419	4090.00	1.02	192440	
13	34.09	354	100,646	394	112,018	4050.00	1.27	137630	
14	33.41			410	114,242	3965.00	1.45	143710	
15	32.37			488	131,743	4165.00	1.37	168560	
16	31.72			280	74,073	4210.00	1.49	191060	
17	32.13			172	46,090	3920.00	2.24	185320	
18	32.43			330	89,254	3415.00	1.37	195660	
19	32.84			310	84,905	3055.00	1.39	161660	
20	33.03	301	82,917	290	79,886	4125.00	1.26	215040	
21	31.80			424	112,450	4105.00	1.27	215530	
22	31.12			370	96,030	4010.00	1.14	204250	
23	33.46			266	74,229	4265.00	1.31	151700	
24	31.41			188	49,248	4060.00	2.15	208540	
25	32.67			436	118,796	3420.00	1.67	156690	
26	35.77			382	113,959	3770.00	1.33	175730	
27	31.73	399	105,587	400	105,851	4350.00	1.45	205520	
28	30.53			394	100,320	4615.00	1.43	238080	
29	35.03			410	119,782	4360.00	1.53	235490	
30	31.47			208	54,592	4810.00	1.70	218180	
31									
Avg	33.617	335	92,192	327	91,012	3,836	1	164,721	
Max	42.31	399	105,587	530	149,049	4,810	3	245,750	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis License No.: T0403
Title: Dir. Of Operations and Maintenance Date: 5/28/2016

Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Monday, June 27, 2016 10:14 AM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 22169 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 22169
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 05/01/2016-05/31/2016
Monitoring Report Due Date : 06/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

June 27, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

William Collins
Water Quality Specialist – Water Management Program
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. Collins:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for May, 2016. All parameters were in compliance during the month.

Parameter averages for May, 2016 were: Flow – 37.28; cBOD₅ – 7 mg/L; TSS – 12 mg/L; cBOD₂₀ % removal – 95.76%; and cBOD₂₀ – 4,969 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION

Facility ID:	482685	Facility Name:	DELCORA STP	Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
Permit Number:	PA0027103	Monitoring Period:	05/01/2016-05/31/2016	Mailing Address:	100 EAST FIFTH STREET P.O. BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	D01		Stage Code		Final Effluent			No Discharge Indicator		N
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency	
pH	Sample Measurement Permit Measurement	6.38	6.0	Inst Min	6.38	6.83	9.0	IMAX	S.U.	Grab	1/day
Total Suspended Solids	Sample Measurement	3870	4423	lbs/day	12	13			mg/L	24-Hr Composite	1/day
	Permit Measurement	11000 Avg Mo	16500 Wkly Avg		30 Avg Mo	45 Wkly Avg				24-Hr Composite	1/day
Oil and Grease	Sample Measurement	<1555		lbs/day	<5				mg/L	Grab	1/day
	Permit Measurement	5500 Avg Mo			15 Avg Mo	30 IMAX				Grab	1/day
Ammonia-Nitrogen	Sample Measurement				1.23				mg/L	24-Hr Composite	2/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	2/month
Nitrite an N	Sample Measurement				<.32				mg/L	24-Hr Composite	2/month
	Permit Measurement				Monitor & Report Avg Mo	Monitor & Report Daily Max				24-Hr Composite	2/month
Nitrate as N	Sample Measurement				4.81	6.4			mg/L	24-Hr Composite	2/month
	Permit Measurement				Monitor & Report Avg Mo	Monitor & Report Daily Max				24-Hr Composite	2/month
Total Kjeldahl Nitrogen	Sample Measurement				3.23				mg/L	24-Hr Composite	2/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	2/month
Cyanide, Total	Sample Measurement				.036				mg/L	24-Hr Composite	1/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	1/month
Chlorodibromomethane	Sample Measurement				.0055				mg/L	Grab	1/month
	Permit Measurement				Monitor & Report Avg Mo					Grab	1/month
Cadmium, Total	Sample Measurement				<.001				mg/L	24-Hr Composite	1/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	1/month
Copper, Total	Sample Measurement				.009				mg/L	24-Hr Composite	1/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	1/month
Lead, Total	Sample Measurement				<.003				mg/L	24-Hr Composite	1/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	1/month
Zinc, Total	Sample Measurement				.045				mg/L	24-Hr Composite	1/month
	Permit Measurement				Monitor & Report Avg Mo					24-Hr Composite	1/month
Dichlorobromomethane	Sample Measurement				.0018				mg/L	Grab	1/month
	Permit Measurement				Monitor & Report Avg Mo					Grab	1/month

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

[illegible]

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
Daily Effluent Monitoring MAY 2016.xlsx	Daily Effluent Monitoring Form	2016-06-24T08:21:23-04:00	
Cryptographic Hash Value of File (SHA-512)	387360DBDC075174755731F4736983A80E3ABAF0ED153825E4111E22C9D4E0F8A177CF72C2AA91DC41987452864B948F2AB771ED22781DB5182B6BF188B5		
Hauled In Municipal Waste, MAY2016.xls	Hauled-In Municipal Waste Form	2016-06-24T08:22:29-04:00	
Cryptographic Hash Value of File (SHA-512)	BF39D4120265FC004D2CDE66932A91793C5C50032040B786474AE9E578457CE23AE8265235EF04131F181F78D0266E16E5E2C1D5C4C0AD6A76F1BE4		
Influent and Process Control MAY2016.xls	Influent and Process Control Form	2016-06-24T08:23:40-04:00	
Cryptographic Hash Value of File (SHA-512)	272E524B1841B9A6EBB9D056BA16DA1CFBD91DBAD5AE7F0B498E9F53901BDE0C8501DE2791A29D396C4D48A423BF1D0FAED2D08DCAC6FC0C69471737E6CDC1D582		
ALS_cBOD20_5-31-16.PDF	Laboratory Analytical Report	2016-06-24T08:34:36-04:00	
Cryptographic Hash Value of File (SHA-512)	281CA07773CDF06A5F942E30D33BDECDD88EC17C460748A7E0F64D355B8BEFA6C819C9D2EBD1B26CC563FFB23AD86232797B6C798BA14F1AD0A546A0C7050D840		
DMR Cover Letter May 2016.doc	Cover Letter	2016-06-27T10:13:52-04:00	
Cryptographic Hash Value of File (SHA-512)	E47FBA08D8D551C7A4F7B8F6848DC839397E7FCE547A7A7503778CD1805D1D90CC6547E86D0D1552AA5C9F6153A81C332D3D0415B9B93EC8EF1DFAE461EF33B08		
ALS_cBOD20_5-3-16.PDF	Laboratory Analytical Report	2016-06-24T08:28:48-04:00	
Cryptographic Hash Value of File (SHA-512)	1D87E1D2F898CE98D1B650923782E0EFB8E7A4FC39C132CCDFED350F9F04D1CD2B8CA8708EA434563AE1847CB085DD44CE2C3671A96E19FA7475AA1D1A38EDF0B		
ALS_cBOD20_5-5-16.PDF	Laboratory Analytical Report	2016-06-24T08:29:29-04:00	
Cryptographic Hash Value of File (SHA-512)	42FE882489A3F1A78B1BB947C1628800C7F538EEF984546C03315AA4A50B1A563C3510BFDD045301633B46F41AD1064E2A56FA88FA201F5820E7CB31599300E		
Sludge Production and Disposal_MAY 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-06-24T08:24:04-04:00	
Cryptographic Hash Value of File (SHA-512)	1B78F5CC585FEF93A2AF5F8C8F08F1D0DCDE8646294DD8608A752936881C531DC66A7673A6A8D9128DB1C345EF70B6199C2F4893A505E261B1835973C7164B02		
ALS_Effluent_May2016.PDF	Laboratory Analytical Report	2016-06-24T08:25:48-04:00	
Cryptographic Hash Value of File (SHA-512)	638AE934210307BB57328A32433904B8DC4259596A066B75F60832E8D7EAB161FB61CD6042D71C0C8F1FE32FF1E797C773ECE9A3608F5BF054C3DBC394BBDF		
WRTIP_Influent_May2016.pdf	Laboratory Analytical Report	2016-06-24T08:27:13-04:00	
Cryptographic Hash Value of File (SHA-512)	EE9224D75A9C234502A95D1999A8AB4A41C9C63D8F6A496F2C8F1837C00B432DBF7441C3A9E41934B86F5B1E6FA03410BF7DF9466FEB4563D18A2ED319899		
ALS_cBOD20_5-1-16.PDF	Laboratory Analytical Report	2016-06-24T08:28:03-04:00	
Cryptographic Hash Value of File (SHA-512)	12054555801FDD383706A59EE8FE4DB139001DC85A296682035EC784F74E39AFF16774DAC39D018DC4ACE586591BE930D67823FC03DF6C835B3D5033804C9D		
May 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-06-27T08:24:32-04:00	
Cryptographic Hash Value of File (SHA-512)	82087675D8A9CA1AA1488CE80AA5385A57364495E3BE4BE2A8D850B92B3478DB3235ACA2849F099862B9A613585BA02E390C70D35A97D289A5636C40116F1C38		
Hauled in Waste May2016.xlsx	Other	2016-06-24T08:23:20-04:00	Hauled in Waste May2016
Cryptographic Hash Value of File (SHA-512)	3A4872898D0A94848311D638E5902E4CC72824700529922289C63C36C074462F686CEE6502DA2F397D8C26E549886A55AC3E0E2E1C822C5073D9D0E010		
ALS_cBOD20_5-8-16.PDF	Laboratory Analytical Report	2016-06-24T08:29:51-04:00	
Cryptographic Hash Value of File (SHA-512)	80D21B7149D1C5A9F27A053CA7143302F46291AF074A812A909B41D14E8988F7D46862A7E0A43BDAA7055594F086C803F0CB8697D4E98084659A74C71CFDDE2		
ALS_cBOD20_5-12-16.PDF	Laboratory Analytical Report	2016-06-24T08:31:17-04:00	
Cryptographic Hash Value of File (SHA-512)	06D59A2A7F7D7388C580504C8980C7E0A9090C28D8C8731895742E79F7171F26F816D1684FB5D4849C4F8731689C34833BD12E0C909537DB24457F25B32DF5		
ALS_cBOD20_5-15-16.PDF	Laboratory Analytical Report	2016-06-24T08:31:41-04:00	
Cryptographic Hash Value of File (SHA-512)	A54A16612FBD4BD8162156C4D0094A27BB924DC59EF40C0911659D68078E2532FDDC2D2DA825F1FC251A009A32C5518E15AFC855F068D94A1B28226D08A93287DAF		
Cryptographic Hash Value of File (SHA-512)	B488857E67032BB05562C4BDB081AD7FA6A206BA8FD0EA552A23F8D4331B80AA4B46DA03084A6FB773E2452A7E3176B08DABD6028D09BAC55BAF5E148288184		
ALS_cBOD20_5-19-16.PDF	Laboratory Analytical Report	2016-06-24T08:32:28-04:00	
Cryptographic Hash Value of File (SHA-512)	4A837C48656A43DBBDE21FC8798F1484E10FE98F730F6CC46A60D2489768865F03871B540DCB4C05964B4F2EE8D0AA7243AA83C83160057021FE8D001EEF38E		
Hauled In Residual Wastes_MAY2016.xls	Hauled-In Residual Waste Form	2016-06-24T08:22:48-04:00	
Cryptographic Hash Value of File (SHA-512)	EA85FD581821DA7E884B918A43377FC55234CE54818844B9C2B0C533E40B5489FC481B844B9C2B0C533E40B5489FC481B847602878C5CDB9C74B06570DE6DF203B78A98307F4EA595E47C73B		
Daily Influent Monitoring MAY 2016.xlsx	Other	2016-06-24T08:22:08-04:00	Daily Influent Monitoring MAY 2016
Cryptographic Hash Value of File (SHA-512)	59340EE22689BD36570739124E7562B2E53145A1A508317A95D495B0C64B78C7D2DF02B02C8587F68B587CF0549882BD19A7185D690DA585E7DC4FFFE8DCAD5E54		
ALS_cBOD20_5-10-16.PDF	Laboratory Analytical Report	2016-06-24T08:30:54-04:00	
Cryptographic Hash Value of File (SHA-512)	D5C9000478F817B1956A42908C95A4530D6092D0B51382BFFD7E64279DE18E0FB68411BB3EA78D127F1F69C93BFC61862C7745C082D023EFOBCA1AC7D84B2		
ALS_cBOD20_5-24-16.PDF	Laboratory Analytical Report	2016-06-24T08:33:11-04:00	
Cryptographic Hash Value of File (SHA-512)	A87E3FACAE79E221C8DC37DDAC17804F4CC41F5119ECDA3B8BFB7FD264DAS319011BAFA0786A5A468E1EC0FEB4AC7DA489DF311D948AF4E598104219D7E46EA		
ALS_cBOD20_5-26-16.PDF	Laboratory Analytical Report	2016-06-24T08:33:37-04:00	
Cryptographic Hash Value of File (SHA-512)	4627320D25E361C8CC222EE2F04D3ABE1F5C1C1E9E02C2ADE18E51C1B7FEB27934BFC7170F0277A3A5DD296154B88B8E8E69E5FF663A0C4C1F0B2D578574E7		
ALS_cBOD20_5-22-16.PDF	Laboratory Analytical Report	2016-06-24T08:32:50-04:00	
Cryptographic Hash Value of File (SHA-512)	ACFD40DA0A09219C71C835955BFB7BBA800EE53669DAA27DF75C56443D6E755330D8E7C7D4550F8AD79E066A2EE6739B546D37970757C04E951A2B5A6A828C1		
DMR Laboratory Accreditation-ALS-May 2016.doc	Laboratory Accreditation Form	2016-06-24T08:24:25-04:00	
Cryptographic Hash Value of File (SHA-512)	9895E1ED47DBDD04E3B515FAA0833B920729242FA5A6D165A29A9076A8D9B1F57BD396C2A32192D9E7614CC8B847D6C286851FA030F4086A7646853232		

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

DMR Laboratory Accreditation-WRTP-May 2016.doc	Laboratory Accreditation Form	2016-06-24T08:24:43-04:00	
Cryptographic Hash Value of File (SHA-512)	1EB8AD19ABE52F6883D2BEEE3D4487CA1CCD898DEBD67521CF4D31B67DBD51134C9203625FDB7CCB7F8E774513AEDBCCA514FB4AAEA8F9FCFA7BD38E7806881		
ALS_ Biweekly N_May2016.PDF	Laboratory Analytical Report	2016-06-24T08:25:28-04:00	
Cryptographic Hash Value of File (SHA-512)	0AB1DEFBB71D0E160CFD0926F5D3CA9A1DB78403F0AFD2CDA255853EE0C63EB28DA179AD4FDF8EAE1E345784EDC3E06BC0FF7D7A00B22A9FBD0CDA16D161C32		
WRTP Lab_Influent & Process Control_MAY2016.pdf	Laboratory Analytical Report	2016-06-24T08:26:10-04:00	
Cryptographic Hash Value of File (SHA-512)	19827F6FE025B2BEC3B33AC7BE5788A668E1B513A64CFF17ADFB5C0F11953C7E6DC57FAE50D4118F7BA7461AFBD29CD011820AAF133E531FECA1C4C799887B		
WRTP_Effluent_May2016.pdf	Laboratory Analytical Report	2016-06-24T08:26:30-04:00	
Cryptographic Hash Value of File (SHA-512)	F918BC110BC715650231D6175E1E362AB46B6177D78441EDC6CD7F38D0ACF65880FA01819FA1B193C16F92EFFB14EEEE322B8F9C31D8DBC94825B387BA415D0		

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

PERMIT VIOLATIONS											
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments

UNAUTHORISED DISCHARGES											
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	Comments

OTHER PERMIT VIOLATIONS			
Non Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type
			Comments

COMMENTS DETAILS	
Comment	Operator Name
	Michael J. DiSantis
	Operator Certification Number
	T0403
	Operator Contact Number
	6108765523

SUBMISSION INFORMATION	
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	
Submitted By GreenPort User	DISANTISM
Email Address	disantism@delcora.org
Submitted By Full Name	Michael DiSantis
Document Generated	6/27/2016



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	05	01	TO 16 05 31
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
Copper, Total	EPA 200.7	ALS Environmental	PA 22-293				
Lead, Total	EPA 200.7	ALS Environmental	PA 22-293				
Zinc, Total	EPA 200.7	ALS Environmental	PA 22-293				
Dichlorobromomethane	EPA 624	ALS Environmental	PA 22-293				
BOD20/cBOD20	SM5210 B	ALS Environmental	PA 22-293				
Chlorodibromomethane	EPA 624	ALS Environmental	PA 22-293				
TKN-N	EPA 351.2	ALS Environmental	PA 22-293				
Ammonia as N	D6919-09	ALS Environmental	PA 22-293				
Nitrate as N	EPA 300.0	ALS Environmental	PA 22-293				
Total Cyanide	EPA 335.4	ALS Environmental	PA 22-293				
Total Cadmium	200.7	ALS Environmental	PA 22-293				
Nitrite as N	EPA 300.0	ALS Environmental	PA 22-293				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibly of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael-J. DiSantis

Date: 06/21/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	05	01	TO	16	05	31
PARAMETER		ANALYSIS METHOD		LAB NAME			LAB ID NUMBER²			
BOD5/cBOD5		SM5210 B		DELCORA - Central Laboratory			23-00671			
TSS		SM 2540 D		DELCORA - Central Laboratory			23-00671			
O&G		EPA 1664 A		DELCORA - Central Laboratory			23-00671			
Total Residual Cl		SM4500-Cl G		DELCORA - Central Laboratory			23-00671			
N-Nitrite		SM4500-NO2 B		DELCORA - Central Laboratory			23-00671			
NH3-N		EPA 350.1		DELCORA - Central Laboratory			23-00671			
TKN-N		SM4500-N-org B/SM4500-NH3 C		DELCORA - Central Laboratory			23-00671			
Fecal Coliform		SM 9222 D		DELCORA - Central Laboratory			23-00671			
BOD20/cBOD20		SM5210 B		DELCORA - Central Laboratory			23-00671			
pH		SM 4500 H+B		DELCORA - Central Laboratory			23-00671			
Ammonia as N		EPA 350.1		DELCORA - Central Laboratory			23-00671			
TDS		SM 2540 C		DELCORA - Central Laboratory			23-00671			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibly of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 06/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
 Municipality: **City Of Chester**
 Watershed: **3G**

County: Delaware

Month: **May** Year: **2016**
 NPDES Permit No.: **PA0027103**
 Renewal application due **180 days** prior to expiration
 This permit will expire on: **April 30, 2018**

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month

[illegible]**TOTAL:**

TOTAL:	847.810
---------------	----------------

TOTAL:	1.095.410
---------------	------------------

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Wicks Community Landfill and Recycling	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
 Title: **Dir. Of Operations and Maintenance**

License No.: T0403
Date: June 28, 2016



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

3800-FM-BPNPSM0436 3/2012

Facility Name: DELCORA WRTP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: May Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	39.03			178	57,941	4710.00	1.95	211640
2	34.09			610	173,429	4385.00	1.51	233570
3	46.60			167	64,904	2790.00	1.44	222510
4	36.55	427	130,517	364	111,261	4695.00	1.39	224960
5	35.21			336	98,667	5000.00	1.41	226410
6	58.74			400	195,957	4665.00	1.49	202640
7	51.00			226	96,127	3865.00	2.56	190010
8	40.70			126	42,769	4500.00	2.30	219870
9	38.59			294	94,621	4855.00	1.50	239850
10	34.87	363	105,566	382	111,092	4935.00	1.39	236950
11	34.88			328	95,415	5000.00	1.39	196890
12	33.39			314	87,440	5000.00	1.31	222270
13	34.45			438	125,843	5000.00	1.09	198160
14	33.62			258	72,341	5000.00	1.39	205070
15	32.29			146	39,318	5000.00	1.91	193030
16	33.66			368	103,307	4180.00	1.48	208680
17	34.30			414	118,430	4765.00	1.27	203330
18	32.14	409	109,631	370	99,178	4920.00	1.30	206480
19	31.84			513	136,225	4725.00	1.22	209360
20	30.93			384	99,055	4920.00	1.32	224870
21	43.85			306	111,907	4895.00	1.23	224380
22	53.31			102	45,350	3860.00	2.12	189210
23	44.56			262	97,367	4240.00	1.37	191930
24	39.47			340	111,921	4435.00	1.40	187880
25	36.52	282	85,891	314	95,637	4255.00	1.61	176640
26	33.37			430	119,671	4325.00	1.30	223990
27	32.11			258	69,092	4565.00	1.11	224440
28	30.76			182	46,690	4375.00	1.31	216940
29	33.94			182	51,517	4185.00	1.46	226160
30	63.75			206	109,525	2495.00	1.50	206310
31	43.80			232	84,748	3685.00	1.61	169990
Avg	38.788	370	107,901	304	95,701	4,459	2	210,143
Max	63.75	427	130,517	610	195,957	5,000	3	239,850

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis License No.: T0403
Title: Dir. Of Operations and Maintenance Date: 6/28/2016



pennsylvania

DEPARTMENT OF ENVIRONMENTAL PROTECTION

SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

3800-FM-BPNPSM0437 3/2012

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: May Year: 2016

NPDES Permit No.: PA0027103

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify): Package Plant				DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)	Gallons	BOD ₅ (lbs)
1												
2	43355			Headworks	61270			Sludge Thickening	127650		232,275	0
3	42575			Headworks	75544			Sludge Thickening	119100		237,219	0
4	31850			Headworks	91502			Sludge Thickening	99500		222,852	0
5	34350			Headworks	128009			Sludge Thickening	200900		363,259	0
6	39150			Headworks	120225			Sludge Thickening	102900		262,275	0
7	5600			Headworks	97500			Sludge Thickening			103,100	0
8												
9	25500			Headworks	85825			Sludge Thickening	154800		266,125	0
10	54000			Headworks	86527			Sludge Thickening	193400		333,927	0
11	33942			Headworks	98291			Sludge Thickening	109800		242,033	0
12	24050			Headworks	83697			Sludge Thickening	179900		287,647	0
13	43850			Headworks	69307			Sludge Thickening	108600		221,757	0
14	5500			Headworks							5,500	0
15												
16	33610			Headworks	79400			Sludge Thickening	100800		213,810	0
17	27250			Headworks	68430			Sludge Thickening	125500		221,180	0
18	25200			Headworks	72896			Sludge Thickening	171700		269,796	0
19	28250			Headworks	79657			Sludge Thickening	117632		225,539	0
20	23500			Headworks	70049			Sludge Thickening	128360		221,909	0
21	3000			Headworks							3,000	0
22												
23	42100			Headworks	59460			Sludge Thickening	106100		207,660	0
24	32500			Headworks	107955			Sludge Thickening	107250		247,705	0
25	30450			Headworks	60679			Sludge Thickening	147100		238,229	0
26	30100			Headworks	64428			Sludge Thickening	203800		298,328	0
27	34900			Headworks	39575			Sludge Thickening	89900		164,375	0
28	12860			Headworks	42935			Sludge Thickening			55,795	0
29												
30												
31	21400			Headworks	52014			Sludge Thickening	127700		201,114	0
Avg	29,154				78,630				134,563		Monthly Totals: 5,346,409	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 6/28/2016



Facility Name: **DELCORA STP**
Municipality: **City of Chester**
Watershed: **3G**

County: Delaware

Year: 2016

NPDES Permit No.: **PA0027103 A3**
 Renewal application due **180 days** prior to expiration.
 This permit will expire on: **April 30, 2018**

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Operations and Maintenance**

License No.: T0403
Date: 6/28/2016



SUPPLEMENTAL REPORT
DAILY EFFLUENT MONITORING

ASAP-144 SPRINGFIELD 12/01/17

Facility Name: DELCORA WRP
Municipality: City of Chester
Watershed: 3G
Laboratories: DELCORA/ALS Environmental

Month: 5 (check number)
Permit No.: PA0027103 A3
Renewal application due 180 days prior to expiration
This permit will expire on: April 30, 2018

Year: 2016
Outfall: 001

Flow	Fecal Coliform	pH	CBOD5	CBOD20	TSS	TSS	TDS	Oil and Grease	TRC	NH3-N	NO3-N	NO2-N	TKN	Total Copper	Total Lead
	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	36	6.36	8	10	57.11	12	471.00	5	0.54						
2	39	6.44	10	36	95.49	8	470.00	5	0.45						
3	178	6.45	11	36	95.49	10	636.00	5	0.21					0.009	0.005
4	33	6.50	11	14	87.14	8	636.00	5	0.47						
5	33	6.55	7	14	87.14	22	636.00	5	0.34						
6	37	6.58	10	12	94.28	18	636.00	5	0.39						
7	37	6.58	10	12	94.28	18	636.00	5	0.39						
8	37	6.72	6	12	94.28	9	636.00	5	0.31						
9	37	6.72	6	12	94.28	9	636.00	5	0.31						
10	100	6.82	6	12	94.28	30	636.00	5	0.26						
11	14	6.82	4	13	97.40	10	636.00	5	0.36						
12	5	6.88	4	13	97.40	10	636.00	5	0.36						
13	17	6.79	6	11	97.72	10	636.00	5	0.47						
14	5	6.88	4	13	97.40	10	636.00	5	0.36						
15	60	6.88	5	11	95.11	8	510.00	5	0.14						
16	30	6.83	4	11	95.11	7	510.00	5	0.22						
17	7	6.42	7	12	98.74	12	510.00	5	0.42						
18	40	6.78	7	20	95.05	13	493.00	5	0.42						
19	30	6.58	7	10	97.30	10	537.00	5	0.34						
20	30	6.58	7	10	97.30	12	537.00	5	0.34						
21	9	6.67	7	10	97.30	10	537.00	5	0.39						
22	35	6.84	7	10	97.40	10	537.00	5	0.47						
23	35	6.73	9	16	94.77	16	547.00	5	0.20						
24	118	6.82	11	21	98.78	19	547.00	5	0.45						
25	30	6.87	8	14	94.08	14	498.00	5	0.47						
26	28	6.70	8	10	98.89	14	498.00	5	0.34						
27	104	6.89	8	11	98.30	11	500.00	5	0.20						
28	19	6.51	7	21	98.77	11	517.00	5	0.32						
29	36	6.78	7	10	95.12	10	537.00	5	0.32						
30	2	6.80	5	10	94.51	10	537.00	5	0.21						
31	11	6.88	8	14	92.31	14	537.00	5	0.41						
32	120	6.52	8	19	90.78	19	508.00	5	0.60						
33	20	6.51	8	5	94.74	15	513.00	5	0.51						
34	23	6.58	4	8	88.75	7	514	5	0.16						
35	178	6.53	18	24	97.89	22	487	5	0.65						
36	23	6.58	7	16	95.78	13	527	5	0.4						
37	23	6.58	7	16	95.78	13	527	5	0.4						
38	40.74	6.57	6.75	4.89	97.18	4.83	1718.07	18.89	1.30	0.49	0.13	0.15	2.1	0.009	0.002
39	37.23	6.57	6.75	4.89	97.18	4.83	1718.07	18.89	1.30	0.49	0.13	0.15	2.1	0.009	0.002
40	1733.71	6.57	6.75	4.89	97.18	4.83	1718.07	18.89	1.30	0.49	0.13	0.15	2.1	0.009	0.002
41	28.85	6.57	6.75	4.89	97.18	4.83	1718.07	18.89	1.30	0.49	0.13	0.15	2.1	0.009	0.002
42	63.22	6.57	6.75	4.89	97.18	4.83	1718.07	18.89	1.30	0.49	0.13	0.15	2.1	0.009	0.002

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my review and the information submitted, I believe this document is true and accurate. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn declaration).

Prepared By: Michael DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 6/28/2016

DEPARTMENT OF ENVIRONMENTAL
PROTECTION

Month: 5 (select number)
 Permit No.: PA0027103 A3
 Renewal application due 180 days
 This permit will expire on:

Daily Minimum (Conc.):	
Daily Maximum (Conc.):	
Max Avg Weekly (Conc.):	
Avg Monthly (Conc.):	
Geometric Mean (Conc.):	
Max Avg Weekly (Load):	
Avg Monthly (Load):	
Total Monthly (Load):	
Daily Minimum (Load)	
Daily Maximum (Load):	

Prepared By: Micheal DiSantis
 Title: Dir. Of Operations and Maintenance
 License No.: T0403
 Date: 5/28/2016

Prepared By: Micheal DiSantis
Title: Dir. Of Operations and Maintenance



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name:
Municipality:
Watershed:

Delaware County Regional Water Quality Control Authority
City of Chester
3G

Month: May Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tighman	Yes	
009	2nd & Lloyd	Yes	
010	5th & Pusey	Yes	
011	2nd & Parker	Yes	
012	2nd & Edgmont	No	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	No	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	No	
			Total overflow from Outfalls 009 and 010 Discharges to Outfall 009 Regulator

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 6/8/2016

Bonnett, Barbara

From: depgreenporthelpdesk@state.pa.us
Sent: Wednesday, July 27, 2016 3:35 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 24683 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 24683
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 06/01/2016-06/30/2016
Monitoring Report Due Date : 07/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

July 27, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

William Collins
Water Quality Specialist – Water Management Program
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. Collins:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for June, 2016. All parameters were in compliance during the month.

Parameter averages for June, 2016 were: Flow – 32.24; cBOD₅ – 5 mg/L; TSS – 8 mg/L; cBOD₂₀ % removal – 97.07%; and cBOD₂₀ – 2,831 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:bab
enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELCORA STP
Permit Number:	PA0027103	Monitoring Period:	06/01/2016-06/30/2016
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O.BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	001		Stage Code		Final Effluent		No Discharge Indicator		N
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency
pH	Sample Measurement Permit Measurement	***	***	***	6.33 6.0 Inst Min	*** ***	6.34 9.0 IMAX	S.U.	Grab Grab	1/day 1/day
Total Suspended Solids	Sample Measurement Permit Measurement	2199 11000 Avg Mo	4419 16500 Wkly Avg	lbs/day	***	8 30 Avg Mo	13 45 Wkly Avg	mg/L	24-Hr Composite 24-Hr Composite	1/day 1/day
Oil and Grease	Sample Measurement Permit Measurement	<1372 5500 Avg Mo	***	lbs/day	***	<5 15 Avg Mo	8 30 IMAX	mg/L	Grab Grab	1/day 1/day
Ammonia-Nitrogen	Sample Measurement Permit Measurement	***	***	***	***	***	***	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Nitrite an N	Sample Measurement Permit Measurement	***	***	***	***	<.45 Monitor & Report Avg Mo	.50 Monitor & Report Daily Max	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Nitrate as N	Sample Measurement Permit Measurement	***	***	***	***	9.72 Monitor & Report Avg Mo	9.84 Monitor & Report Daily Max	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Total Kjeldahl Nitrogen	Sample Measurement Permit Measurement	***	***	***	***	1.87 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Cyanide, Total	Sample Measurement Permit Measurement	***	***	***	***	.015 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Chlorodibromomethane	Sample Measurement Permit Measurement	***	***	***	***	.0017 Monitor & Report Avg Mo	***	mg/L	Grab Grab	1/month 1/month
Cadmium, Total	Sample Measurement Permit Measurement	***	***	***	***	<.001 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Copper, Total	Sample Measurement Permit Measurement	***	***	***	***	.011 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Lead, Total	Sample Measurement Permit Measurement	***	***	***	***	<.003 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Zinc, Total	Sample Measurement Permit Measurement	***	***	***	***	.039 Monitor & Report Avg Mo	***	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Dichlorobromomethane	Sample Measurement Permit Measurement	***	***	***	***	.002 Monitor & Report Avg Mo	***	mg/L	Grab Grab	1/month 1/month

[illegible]

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

ATTACHMENT DETAILS			
File Name	Attachment Type	Uploaded Time	Attachment Comment
DMR Cover Letter June 2016.doc	Cover Letter	2016-07-27T15:34:36-04:00	
Cryptographic Hash Value of File (SHA-512)	4419DBF31504E1F2501D28812940C6954E2ACFB2B8C60A963E4D8E0E4969ACD78ED2AADB9D58A8A80387E620C0DE12E453FDAE06863A55286369074BF020		
Daily Effluent Monitoring JUNE 2016.xlsx	Daily Effluent Monitoring Form	2016-07-27T13:20:25-04:00	
Cryptographic Hash Value of File (SHA-512)	2CF0F8CA072FCBDC194D6B8185E05905932CF5FCAF983F006F08F7847C93B8E322496CF2D58D233926663F552C3862B8B24AD11328E013D4A238C046F0F0D56800A		
Daily Influent Monitoring JUNE 2016.xlsx	Daily Influent Monitoring Form	2016-07-27T13:20:25-04:00	[Daily Influent Monitoring JUNE 2016]
Cryptographic Hash Value of File (SHA-512)	7DCA10B690468ED35E8A7461ECEAB38BBBC13D7F69B4B8F454950D142B6D5815262103A633A693DC2BE9BD3D07766F12D3CC6746ACD7A1E55439B9F5E68E0340		
DMR Laboratory Accreditation-WRTP-June 2016.doc	Laboratory Accreditation Form	2016-07-27T13:24:42-04:00	
Cryptographic Hash Value of File (SHA-512)	126C84DE7F5E754809D7561F50AA1E50578648928337736C8AFBCC286624632A47F709DA4B273903BDB6CC5366E560FCC38D82B0DBD26006F3CC0DD02FC77AA986		
DMR Laboratory Accreditation-ALS-June 2016.doc	Laboratory Accreditation Form	2016-07-27T13:24:14-04:00	
Cryptographic Hash Value of File (SHA-512)	44E9FBC1D30682EDE471D602DA540091657F52572D3F813516761081DF876F7E5D7DC7093E91B505891B59A88FDB0279265A669A997F48E3E005E36CD53		
Hauled In Municipal Waste_June2016.xls	Hauled In Municipal Waste Form	2016-07-27T13:21:18-04:00	
Cryptographic Hash Value of File (SHA-512)	A19AAF1CEB0E45D8FEF7D3E52A95CD5A598E34824CF1081F2799D8DC0D022F3D0768DAD8E1475CA436B31C6425DBD89BC3147EC5A06D73F27335EDBDED0C92AA		
Hauled In Residual Wastes_JUNE2016.xls	Hauled In Residual Waste Form	2016-07-27T13:21:42-04:00	
Cryptographic Hash Value of File (SHA-512)	E7DB8EE2AF64C55145E6A32AAB8C5FC1B2B8E1298A05B21CE0A0EBF9B867B2F3DD118C31F20C6CCA199158E34FB0A46732BD81E8C639D5914283EB77B3EE502		
Influent and Process Control_JUNE2016.xls	Influent and Process Control Form	2016-07-27T13:22:25-04:00	
Cryptographic Hash Value of File (SHA-512)	88772B8FCE31AC5189C494CECC5C74B0DB3C10BABA61F56C805357B07090398D05C8A836CCB975E0181C73FAFFA58A8E9FB8A8B07254F7152E7199F6F85BF48		
Sludge Production and Disposal_June 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-07-27T13:23:47-04:00	
Cryptographic Hash Value of File (SHA-512)	0B9A9ED736CFB5B9048D57A636E4D331E7690016D5C6A7B9E9C32CA54E8BDD45EF026BAFEF67E5AE29903738EF24F1820EBDB969D9009A5ACEA2E4DD8E465A00E7		
June 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-07-27T13:23:25-04:00	
Cryptographic Hash Value of File (SHA-512)	3996178B54B22A955266452C6F4DE52333DE8978FA3791129457B4B69CEB71EF4146E0289590E6E45A2D95663DEA55F4E50604A9037829C8950F1B84176E615		
Hauled In Waste June 2016.xlsx	Other	2016-07-27T13:22:03-04:00	Hauled In Waste June 2016
Cryptographic Hash Value of File (SHA-512)	071F02A083778805844B08B3BFB4E32DDE5815A6FB6C2861D643A87FDD3E4279F7D49E7216C6485F20A8D588A6A5E3335844A52C6B7732D13C4F47620A841		
ALS_CBOD20_6-30-16.PDF	Laboratory Analytical Report	2016-07-27T13:37:42-04:00	
Cryptographic Hash Value of File (SHA-512)	2EC8DC14955902E501B77EA73E352BBE2AE6762A4CFB2D9EC173173A7C106391448D17CF30E405066F0745A1F497CFE141A02DB5F777B19E7E689D59FCB746		
ALS_CBOD20_6-21-16.PDF	Laboratory Analytical Report	2016-07-27T13:35:22-04:00	
Cryptographic Hash Value of File (SHA-512)	9C2EEA8BF6D67BA18D74ACABBD2F231326C272B50F64D7DF59607090ED433E62ACEAEECCDC067E817DB4F7D88E38609B5451435EA10F2E98F57C990F4E82679952		
ALS_CBOD20_6-21-16.PDF	Laboratory Analytical Report	2016-07-27T13:34:54-04:00	
Cryptographic Hash Value of File (SHA-512)	9C2EEA8BF6D67BA18D74ACABBD2F231326C272B50F64D7DF59607090ED433E62ACEAEECCDC067E817DB4F7D88E38609B5451435EA10F2E98F57C990F4E82679952		
WRTP_Influent_June2016.pdf	Laboratory Analytical Report	2016-07-27T13:27:18-04:00	
Cryptographic Hash Value of File (SHA-512)	DA78C266059D446F1446D69B385204AFDDBF5E6C37F9753F0BDC0D5BD109B317A4870625B36FC00158CD3F940841A8DB550CA26708D4535487FE4C3110796E1		
ALS_Effluent - Color_June2016.PDF	Laboratory Analytical Report	2016-07-27T13:25:37-04:00	
Cryptographic Hash Value of File (SHA-512)	E3BBF10637A71E1A0FE1CA7AD9E9A9C0DD432A8F3995DEEDCCD7F30636B14C66572A9CC611F9FF43B86B22A48725A275F0A42641527D0007A6311EFA9C9C87960		
ALS_CBOD20_6-7-16.PDF	Laboratory Analytical Report	2016-07-27T13:20:23-04:00	
Cryptographic Hash Value of File (SHA-512)	4CCEE3E05495F09D82D3E0651693099D3C138EEAD8C8107B1F0420342778B920A291CA1AF46653064A0F7B9C32A8DE481A1C9DB895EEBC05E509DFD70C08CE6088		
ALS_CBOD20_6-5-16.PDF	Laboratory Analytical Report	2016-07-27T13:30:02-04:00	
Cryptographic Hash Value of File (SHA-512)	EC88BF42A4B70990EC3CEC88A6C817864234DA74DD5445E30A4CF8A43744204950151DF618C688A793CCA1E87D3CECF5670C4C3D0D380761D497FD9094C2		
ALS_CBOD20_6-28-16.PDF	Laboratory Analytical Report	2016-07-27T13:36:55-04:00	
Cryptographic Hash Value of File (SHA-512)	316EC9D9F22C8C9166D09940B10F210A567177DE9E2E16ACE1121AF013E78DA48437534C2610A71A2C51ECD6307B3C4580406F7C85AAE4EEAC0058B761F2D366		
ALS_CBOD20_6-19-16.PDF	Laboratory Analytical Report	2016-07-27T13:34:28-04:00	
Cryptographic Hash Value of File (SHA-512)	7B36356E0E83947832490F98BEC556E40793C2828A4DE45060F92EF0F1BE0D776F3E3F153226C368E3041022A27F78C57500C33DFE9A8AC856EAF8892F899DD6		
WRTP_Process_June2016.pdf	Laboratory Analytical Report	2016-07-27T13:28:53-04:00	
Cryptographic Hash Value of File (SHA-512)	A180FAAD28E29D28F0D1C6381D51A548AD139C188F19E87BCBB8F947A2195891F49E003B9B5BF886F3303EFA6A0F9DC5284118322B888ED02C54F48FEE5014D8		
ALS_CBOD20_6-26-16.PDF	Laboratory Analytical Report	2016-07-27T13:36:12-04:00	
Cryptographic Hash Value of File (SHA-512)	5F1C0F4673717B4C22065676764F3355918E908E2B551BCB5A3A5A2391E39257C17574A8E70FC9AAAC33557F7022EBF189DAC1B029A5F712C65770A1DBFC5530		
Cryptographic Hash Value of File (SHA-512)	81033C3A90234682E005620B93B9FEFE10FC4E2F43E8F0557F2592CDEC1B73C4949B43E41B23CC604A166B2A1F44878F88F74061C797D50D8A869BE5762F5DB		
ALS_CBOD20_6-16-16.PDF	Laboratory Analytical Report	2016-07-27T13:33:26-04:00	
Cryptographic Hash Value of File (SHA-512)	BEB740431F7D476B50804D5D258327A452CCF2BC3B574F77128FBE95EA44FC3807A9D0BC803390C587B0595DC902AFBA342C1AF08F5A33A6C57E5A5850F6C		
ALS_CBOD20_6-14-16.PDF	Laboratory Analytical Report	2016-07-27T13:31:43-04:00	
Cryptographic Hash Value of File (SHA-512)	2EE128D99C9694815C9020541A2D809D408D99017B0C91C0858D81A5CCD05052B8E5CACAC204D1A33B4C7B9E8699CB56F6766399E49F89A953083A57606D		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ALS_CBOD20_6-12-16.PDF	Laboratory Analytical Report	2016-07-27T13:31:16-04:00	FB389F1A275FC2803415B8422ED15C354E89F2AE677BE9FA95FAB4DDE66CA82B4069D3843D84A68B61C5E41ADAD2AA242991A57E5A48F95524355
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-07-27T13:30:49-04:00	3C6F2DA9A9BE513BFFCA915EE1AC6CDB8EA32C3AE2A65B80561062775F146CE8E54CA39482BE35432E252E7FE8FFE7BC502BDB395546193DA0776B6C8265E453C
ALS_CBOD20_6-9-16.PDF	Laboratory Analytical Report	2016-07-27T13:29:39-04:00	0A08ED615367EBS4B9DC1F12CD448B0DD9B0949D1F5BDD793613354029236FB9C2F9E982EC4CC8642FE5EBF1AC1BF938DA7031A14B9C52614E06B1941696E1C9
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-07-27T13:28:06-04:00	C7F00B7A84E4B0D3176EFCB6F2D391E98B3532A21BD206EBDC01015D99AF7C8C23AE1D33462DDF538A4F2F1CD0D79C902BA27A984481B31BDC0D193F759E3E9D
WTRTP_Effluent_June2016.pdf	Laboratory Analytical Report	2016-07-27T13:26:28-04:00	1018647C2CE15D6C988EF8A009706AF0242C4261890E9CE54F9176876676841BB5D8EFD5C89FEFF315D5EA9E8B8363201C8007EAF44575F2D8B3385177A06679
Cryptographic Hash Value of File (SHA-512)	Laboratory Analytical Report	2016-07-27T13:26:01-04:00	BFF1B55AF81ED2EE8A48C3C741C6B3AE4279D6F98FBC3DC7DAC64FF340562E46AC6506B2F1D55C976DE602AB1471CE9B8FE363C1501D3A4459DF028BCA79C5B59

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

PERMIT VIOLATIONS												
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non Compliance ID	Stage Code (Sampling Point)	Reported Parameter	Non Compliance Type	Comments								
COMMENTS DETAILS												
Comment	Operator Name					Operator Certification Number		Operator Contact Number				
	Michael J. DiSantis					T0403		6108765523				
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User			DISANTISM		Submitted By Full Name			Michael DiSantis				
Email Address			disantism@delcora.org		Document Generated			7/27/2016				



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>										
Address: <u>P.O. Box 999</u>										
<u>Chester, PA 19016</u>										
<u>19016</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0027103				16	06	01	TO	16	06	30
PARAMETER	ANALYSIS METHOD	LAB NAME				LAB ID NUMBER²				
Copper, Total	EPA 200.7	ALS Environmental				PA 22-293				
Lead, Total	EPA 200.7	ALS Environmental				PA 22-293				
Zinc, Total	EPA 200.7	ALS Environmental				PA 22-293				
Dichlorobromomethane	EPA 624	ALS Environmental				PA 22-293				
BOD20/cBOD20	SM5210 B	ALS Environmental				PA 22-293				
Chlorodibromomethane	EPA 624	ALS Environmental				PA 22-293				
TKN-N	EPA 351.2	ALS Environmental				PA 22-293				
Ammonia as N	D6919-09	ALS Environmental				PA 22-293				
Nitrate as N	EPA 300.0	ALS Environmental				PA 22-293				
Total Cyanide	EPA 335.4	ALS Environmental				PA 22-293				
Total Cadmium	200.7	ALS Environmental				PA 22-293				
Nitrite as N	EPA 300.0	ALS Environmental				PA 22-293				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523Signature of Principal Executive Officer or
Authorized AgentMichael J. DiSantisDate: 07/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	06	01	TO 16 06 30
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
BOD5/cBOD5	SM5210 B	DELCORA - Central Laboratory	23-00671				
TSS	SM 2540 D	DELCORA - Central Laboratory	23-00671				
O&G	EPA 1664 A	DELCORA - Central Laboratory	23-00671				
Total Residual Cl	SM4500-Cl G	DELCORA - Central Laboratory	23-00671				
N-Nitrite	SM4500-NO2 B	DELCORA - Central Laboratory	23-00671				
NH3-N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TKN-N	SM4500-N-org B/SM4500-NH3 C	DELCORA - Central Laboratory	23-00671				
Fecal Coliform	SM 9222 D	DELCORA - Central Laboratory	23-00671				
BOD20/cBOD20	SM5210 B	DELCORA - Central Laboratory	23-00671				
pH	SM 4500 H+B	DELCORA - Central Laboratory	23-00671				
Ammonia as N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TDS	SM 2540 C	DELCORA - Central Laboratory	23-00671				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 07/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: June Year: 2016
 NPDES Permit No.: PA0027103
 Renewal application due 180 days prior to expiration
 This permit will expire on: April 30, 2018

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month

[illegible]**TOTAL:**

TOTAL: 478.790

TOTAL: 1,538.710

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill (Identify all sites where biosolids or ash were disposed or land applied)	Mostoller Landfill, INC	Yorks Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Business Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Of Operations and Maintenance**

License No.: T0403
Date: July 28, 2016



pennsylvania

DEPARTMENT OF ENVIRONMENTAL PROTECTION

SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

3800-FM-BPNPSM0436 3/2012

Facility Name: DELCORA W RTP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: June Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	37.45	212	66,215	262	81,831	3905.00	1.41	211800
2	35.53			312	92,452	3710.00	1.42	220540
3	36.77			318	97,518	3660.00	1.64	225200
4	33.82			232	65,438	3640.00	1.89	221560
5	38.76			210	67,884	3575.00	2.08	224950
6	37.93			354	111,983	3180.00	1.54	235340
7	35.65			647	192,367	3385.00	1.54	237650
8	32.22	284	76,315	350	94,050	3260.00	1.81	230690
9	32.98			372	102,320	3585.00	1.75	225610
10	33.37			496	138,040	3405.00	1.66	230100
11	31.98			194	51,742	3785.00	1.44	216710
12	31.69			178	47,044	3590.00	1.74	235360
13	31.60			280	73,792	2735.00	1.81	229540
14	31.23			446	116,164	3755.00	1.89	290250
15	31.02	333	86,149	382	98,826	3400.00	1.60	111800
16	36.48			494	150,296	3590.00	1.45	0
17	31.67			360	95,086	3645.00	1.28	228600
18	30.43			256	64,969	3565.00	1.66	224980
19	29.77			166	41,215	2655.00	2.25	238710
20	30.44			310	78,700	2830.00	1.41	239180
21	31.83			350	92,912	3625.00	1.37	454110
22	30.56	292	74,422	322	82,068	3495.00	1.24	473020
23	33.77			302	85,056	3595.00	1.27	185450
24	33.50			530	148,077	3300.00	1.41	216450
25	30.32			226	57,148	3320.00	1.51	221440
26	29.89			162	40,384	3180.00	1.86	215980
27	33.10			378	104,348	2810.00	1.50	122150
28	37.65			394	123,716	2840.00	1.61	149470
29	32.62	333	90,593	284	77,262	3065.00	1.47	196180
30	31.42			414	108,486	2930.00	1.23	179260
31								
Avg	33.182	291	78,739	333	92,706	3,361	2	223,069
Max	38.76	333	90,593	647	192,367	3,905	2	473,020

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 7/28/2016



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Facility Name: DELCORA STP
City of Chester
Watershed: 3G

SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Month: June Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

County: Delaware

Day	SEPTAGE			SLUDGE			OTHER (specify):			Package Plant			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)
1	38450			Headworks	62156			Sludge Thickening	176450			Headworks	277,056	0
2	29250			Headworks	112396			Sludge Thickening	177293			Headworks	318,939	0
3	52850			Headworks	55787			Sludge Thickening	106200			Headworks	214,837	0
4				Headworks	96700			Sludge Thickening	13000			Headworks	109,700	0
5														
6	50550			Headworks	85398			Sludge Thickening	97100			Headworks	233,048	0
7	18150			Headworks	92900			Sludge Thickening	159600			Headworks	270,650	0
8	57340			Headworks	75907			Sludge Thickening	170470			Headworks	303,717	0
9	49450			Headworks	60652			Sludge Thickening	191703			Headworks	301,805	0
10	22250			Headworks	74800			Sludge Thickening	112100			Headworks	209,150	0
11				Headworks	31000			Sludge Thickening	9500			Headworks	40,500	0
12														
13	23800			Headworks	87100			Sludge Thickening	87000			Headworks	197,900	0
14	41350			Headworks	88059			Sludge Thickening	134500			Headworks	263,909	0
15	55499			Headworks	56077			Sludge Thickening	122600			Headworks	234,176	0
16	43650			Headworks	39500			Sludge Thickening	150184			Headworks	233,334	0
17	48700			Headworks	59986			Sludge Thickening	97326			Headworks	206,012	0
18	6500								24000			Headworks	30,500	0
19														
20	31100			Headworks	59772			Sludge Thickening	35000			Headworks	125,872	0
21	39050			Headworks	78300			Sludge Thickening	176500			Headworks	293,850	0
22	29200			Headworks	106135			Sludge Thickening	127400			Headworks	262,735	0
23	41550			Headworks	73600			Sludge Thickening	74707			Headworks	189,857	0
24	42300			Headworks	70100			Sludge Thickening	65600			Headworks	178,000	0
25	10120			Headworks									10,120	0
26				Headworks										
27	41350			Headworks	54395			Sludge Thickening	158300			Headworks	254,045	0
28	24450			Headworks	92241			Sludge Thickening	100100			Headworks	216,791	0
29	35250			Headworks	81500			Sludge Thickening	77900			Headworks	194,650	0
30	40450			Headworks	74492			Sludge Thickening	149577			Headworks	264,519	0
31														
Avg	36,359				73,706				111,764			Monthly Totals:	5,435,672	

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 7/28/2016



SUPPLEMENTAL REPORT - HAULED IN RESIDUAL WASTES

3800-FM-BPNP SM0450 3/2012

Facility Name:

DELCORA STP

Municipality:

City of Chester

Watershed:

County: Delaware

Year: 2016

Month: June

NPDES Permit No.: PA0027103 A:

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).


Prepared By: Michael DiSantis

Michael DiSantis
Dir. Operations and Maintenance

License No.:

7/28/2016

T0403



3800-PM-SPWSP-0435 2/2012

SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

Facility Name: DELCORA WRTIP
City: Chester
County: Delaware
Laboratory: DELCORA ALS Environmental

Month: 6 (select number)
Year: 2016
Permit No.: PA0027103 A3
Outfall: 001
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Week	Day	Flow MGD	Fecal Coliform 1	pH	CBOD5 1	CBOD20 1	TSS K	TSS %	TDS mg/L	Oil and Grease 1	TRC 1	NH3-N 1	NO3-N 1	TKN 1	Total Copper 1	Total Lead 1
1	Sun	5/29/16	32.60		6		92.31									
	Mon	5/30/16	42.32		8		90.78									
	Tue	5/31/16	42.98		6		93.53									
	Wed	6/1/16	36.63		5		95.42									
	Thu	6/2/16	34.34		7	11	96.79		675.00		0.25					
	Fri	6/3/16	35.97		6		96.85				0.38					
	Sat	6/4/16	33.00		5		96.55				0.27					
	Sun	6/5/16	38.04		5	10	94.74		511.00		0.54					
	Mon	6/6/16	37.66		5		95.24		523.00		0.34					
	Tue	6/7/16	35.40		5	11	98.03		585.00		0.28					
	Wed	6/8/16	32.01		4		98.45		615.00		0.35					
	Thu	6/9/16	32.97		4	8	97.85		624.00		0.28					
	Fri	6/10/16	32.37		5		98.38				0.27					
	Sat	6/11/16	31.29		4		96.81				0.30					
	Sun	6/12/16	31.03		5	9	97.19		579.00		0.40					
	Mon	6/13/16	30.64		5		97.89		581.00		0.40					
	Tue	6/14/16	30.30		4	10	97.91		555.00		0.31					
	Wed	6/15/16	30.38		4		98.17		572.00		0.24					
	Thu	6/16/16	35.99		7	10	96.11		551.00		0.43					
	Fri	6/17/16	25.67		5		97.78				0.11					
	Sat	6/18/16	28.98		2		97.27		568.00		0.59					
	Sun	6/19/16	28.99		3	12	96.59		616.00		0.48					
	Mon	6/20/16	30.62		3	6	98.05		591.00		0.30					
	Tue	6/21/16	30.65		4	10	97.71		794.00		0.33					
	Wed	6/22/16	29.95		5		97.52		675.00		0.40					
	Thu	6/23/16	33.61		4	10	96.43				0.39					
	Fri	6/24/16	31.57		5		96.30		545.00		0.37					
	Sat	6/25/16	28.18		5		95.48		585.00		0.59					
	Sun	6/26/16	28.75		3	7	96.81		595.00		0.40					
	Mon	6/27/16	30.36		4		97.03		613.00		0.24					
	Tue	6/28/16	36.23		5	14	97.46		634.00		0.45					
	Wed	6/29/16	31.25		4		97.83		652.00		0.45					
	Thu	6/30/16	25.89		4	11	98.55									
	Fri	7/1/16	26.53		6		97.12									
	Sat	7/2/16	26.53		4	8	97.14									
	Sun	7/3/16	26.53		4	8	97.14									
Grand Totals																
Daily Maximum (Conc.):																
Daily Maximum (Load):																
Max Avg Weekly (Conc.):																
Max Avg Weekly (Load):																
Avg Monthly (Conc.):																
Avg Monthly (Load):																
Daily Minimum (Conc.):																
Daily Minimum (Load):																
Total																

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa.C.S. § 4904 (relating to document falsification).

Prepared By: Michael DiSantis
Title: Dir. Of Operations and Maintenance
License No.: 70403
Date: 7/28/2016



SUPPLEMENTAL REPORT DAILY EFFLUENT MONITORING

DELCOA WRTP	County:	6	Year:	2016
City of Chester	County:	36	Year:	2016
Facility Name:	County:	36	Year:	2016
Municipality:	County:	36	Year:	2016
Watershed:	County:	36	Year:	2016
Laboratories:	County:	36	Year:	2016
Permit No.:	County:	36	Year:	2016
Renewal application due	County:	36	Year:	2016
This permit will expire on:	County:	36	Year:	2016
Permit No.:	County:	36	Year:	2016
Renewal application due	County:	36	Year:	2016
This permit will expire on:	County:	36	Year:	2016

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my review and the review of others who I believe are qualified to judge the information's accuracy and completeness, I am satisfied that the information is true and complete. I am not aware of any falsification or omission of material or information or of any intentional or negligent misstatement of this information in this report. I further certify that I have not furnished any material or information knowingly false, deceptive, or misleading in this report.

Prepared By: Michael DiSantis
 Title: Dir. Of Operations and Maintenance
 License No.: 70403
 Date: 7/28/2016



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name:
Municipality:
Watershed:

Delaware County Regional Water Quality Control Authority
City of Chester
3G

Month: June Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tighman	Yes	
009	2nd & Lloyd	Yes	Total overflow from Outfalls 009 and 010
010	5th & Pusey	Yes	Discharges to Outfall 009 Regulator
011	2nd & Parker	Yes	
012	2nd & Edgmont	Yes	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	Yes	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	No	
033	Elkington Blvd. and Ridley Creek	Yes	

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 7/20/2016

Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Thursday, August 25, 2016 5:57 PM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 26886 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 26886
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 07/01/2016-07/31/2016
Monitoring Report Due Date : 08/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

August 25, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

William Collins
Water Quality Specialist – Water Management Program
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. Collins:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for July, 2016. All parameters were in compliance during the month.

Parameter averages for July, 2016 were: Flow –30.57 ; cBOD₅ –4 mg/L; TSS – 7 mg/L; cBOD₂₀ % removal –97.81 %; and cBOD₂₀ –2,496 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION

Facility ID:	482685	Facility Name:	DELCORA STP	Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
Permit Number:	PA0027103	Monitoring Period:	07/01/2016-07/31/2016	Mailing Address:	100 EAST FIFTH STREET P.O BOX 989, CHESTER PA, 19016-0989

PARAMETERS REPORTED VALUES

Sampling Point Parameter	Limit Type	001			Stage Code		Final Effluent		No Discharge Indicator	
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency
pH	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	S.U.	Grab Grab	1/day 1/day
Total Suspended Solids	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/day 1/day
Oil and Grease	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	Grab Grab	1/day 1/day
Ammonia-Nitrogen	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Nitrite as N	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Nitrate as N	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Total Kjeldahl Nitrogen	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	2/month 2/month
Cyanide, Total	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/day 1/month
Chlorobromomethane	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	Grab Grab	1/month 1/month
Cadmium, Total	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Copper, Total	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Lead, Total	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Zinc, Total	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	24-Hr Composite 24-Hr Composite	1/month 1/month
Dichlorobromomethane	Sample Measurement Permit Measurement	1826 11000 Avg Mo	2221 16500 Wkly Avg	lbs/day	6.37 6.0 Inst Min	6.92 9.0 IMAX	6.92 9.0 IMAX	mg/L	Grab Grab	1/month 1/month

•

Facility Comments

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comment
DMR Cover Letter July 2016.doc	Cover Letter	2016-08-25T17:56:12-04:00	
Cryptographic Hash Value of File (SHA-512)	A9B04A08D278E4E2D8BFAFA24D63FEEA574D007A561FF29A27B6647B03D03D029F364B2EFD7887B535BD324966DFA5031354B80C9B91CCECF3783B78AA7F93B49		
Daily Influent Monitoring JULY 2016.xlsx	Daily Effluent Monitoring Form	2016-08-25T10:23:20-04:00	Influent
Cryptographic Hash Value of File (SHA-512)	9175F067EA1E83BD1E62B83B40A8BE9291A4D548FC31A5C13D464C83019D2688954830C565BEEFD97E1AA9F930C3D247C18758650C510DF049D5B33086474934		
Daily Effluent Monitoring JULY 2016.xlsx	Daily Effluent Monitoring Form	2016-08-25T10:22:51-04:00	
Cryptographic Hash Value of File (SHA-512)	975C542552A09C5E197897BDA728C57B7D4F4A8988C31CD0490F8A5E435F517171279A0DD80517C6BD11AC53C3D3D0083CAAB1CE0B892792C247DFEBA8456C96581B		
DMR Laboratory Accreditation-WRTP-JULY 2016.doc	Laboratory Accreditation Form	2016-08-25T10:26:25-04:00	
Cryptographic Hash Value of File (SHA-512)	105A728D50CE7235B1B158A1D1F43F19FAE329D1411856631C0D73122E8932A0171435812D61583C1DD64572FBCB592815E1D3276B8FF303EE221EDF4B8B8EC8A		
DMR Laboratory Accreditation-ALS-JULY 2016.doc	Laboratory Accreditation Form	2016-08-25T10:26:06-04:00	
Cryptographic Hash Value of File (SHA-512)	8D54C5898FE9D0565AC57137892202285C5D859DA1B5DE9DEA1F03221F3DE25B305E3ED78238D2FF1B21F46D9CDD0222E3C1DBB9122B9A9851A1B63C147018CD64		
Hauled In Municipal Waste JULY 2016.xls	Hauled In Municipal Waste Form	2016-08-25T10:23:45-04:00	
Cryptographic Hash Value of File (SHA-512)	A1D03AA7A0BADA1876308B852E7C9BE0816FE22E08E9F337DE833CDD055CFC5C1EA92A3B65699B3D29020556155FAC192D13F0F15E7FBE4D23715D20E75CD36E		
Hauled In Residual Wastes JULY 2016.xls	Hauled In Residual Waste Form	2016-08-25T10:24:06-04:00	
Cryptographic Hash Value of File (SHA-512)	B084B8CC097F4DA07C80887D865FF68F05F8A5F7838687E3A200A369C1169DF89A1F46A23C138E574F567B15E9D1BFA53B658480E0FA8352E37BED3441A7D3		
Influent and Process Control JULY 2016.xls	Influent and Process Control Form	2016-08-25T10:24:26-04:00	
Cryptographic Hash Value of File (SHA-512)	73108C9E19FAF30E8BC5CAFE9711719F5562BBA488422B4F81314DD9FF4AB4C576060B2CEF921C83FD55B0266337723EF8B1BA2D346D8C302519239C1EA7E7		
Sludge Production and Disposal JULY 2016.xlsx	Sewage Sludge / Biosolids Production and Disposal Form	2016-08-25T10:25:22-04:00	
Cryptographic Hash Value of File (SHA-512)	CAC68F082E8595F772561D349956CA30DE2569DC778B718E41C8D825260E5EBD4C96EB944BD47D974D2DFC98E4B6CCFB90E2EC351C4D8841DEFBDF542FC		
July 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-08-25T10:25:00-04:00	
Cryptographic Hash Value of File (SHA-512)	8F5F1353534A9F9B4C1D0DA6AF01C5193D9BF545485AD2F268047640C7449ACD6E1043895FA03D58FA34E792E4583DD7002D9B2E0EF8D8A58966AD894B67D7		
Trucked Waste JULY 2016.xlsx	Other	2016-08-25T10:25:44-04:00	Trucked Waste July 2016
Cryptographic Hash Value of File (SHA-512)	928CEC0FD032FF883128B830441A2EE8608F0489910CBBB76185C7AB998DF2DFB3B7E39C39C6F81100A1E7DC46C9A365683F46E0D4B8711E7E50B27BA0DC2ED		
ALS_CBO020_7-21-16 Revised.PDF	Laboratory Analytical Report	2016-08-25T10:33:32-04:00	
Cryptographic Hash Value of File (SHA-512)	2FA0B074594B684CE145AD38F796AC4B457C90FFACF020B8554710622F0B0CAE6F1B5CF303F08C7FBA8E72BE561D9DDE90C37A8FE46E11857C2EC4B88EF68C7AED		
ALS_CBO020_7-12-16.PDF	Laboratory Analytical Report	2016-08-25T10:31:34-04:00	
Cryptographic Hash Value of File (SHA-512)	B0D741E07C4D15D87786B5170C089C3B8E8649C9016DA19A4F051B3E2355E86D5E265CD4171B5C04DCD3F18EDE563A9856C81C5D234F17718F1E503EAE33A3		
ALS_CBO020_7-10-16.PDF	Laboratory Analytical Report	2016-08-25T10:30:49-04:00	
Cryptographic Hash Value of File (SHA-512)	C1D956A74B37439E220A1DA70E99F80BCECB0E4E7D7F181D47F55B9E902C873F0D74A2F70B159CA0F210644413FB9725B30E7FF04EA496E3DF96BE85CBB18A9709		
Cryptographic Hash Value of File (SHA-512)	BFD66E08C953C5691A422A59C7B664B86B603E37231481FFA569320ACDF19E8E5846288024472E1785E70108264ED74F87E4F00247A5C896BEC16349BBF1		
ALS_CBO020_7-5-16.PDF	Laboratory Analytical Report	2016-08-25T10:29:52-04:00	
Cryptographic Hash Value of File (SHA-512)	67912D06032F9697D5688D8AC50AFA728320E4A48F4813507E538E9FFCF7F5ABD67DB16DC2CD99F73237DF604BA7C935301C84159A73EEB08050DE13378F1D801		
ALS_Effluent JULY 2016.PDF	Laboratory Analytical Report	2016-08-25T10:27:36-04:00	
Cryptographic Hash Value of File (SHA-512)	A2240086C0A6E8AF9E9816FCB8374B256C434547F8E39CAC3C0B71AD8A8C1F28DA8A20AA740C5951E85C02CF84D137B032CEA1F87BED9018EEB1033F5CF746A59C8		
ALS_CBO020_7-31-16.PDF	Laboratory Analytical Report	2016-08-25T10:35:37-04:00	
Cryptographic Hash Value of File (SHA-512)	ED4FA61680D72E3C87289C4409A755E7254E2FDF030B221C547A12A36E9FAC5F5E845D0DD3C45BDC1A952A4251CB3B96CF5A1AEC65432949EAC1980154B83A92		
ALS_CBO020_7-28-16.PDF	Laboratory Analytical Report	2016-08-25T10:35:07-04:00	
Cryptographic Hash Value of File (SHA-512)	9786E0919EDE1BA20071EC5B9E209C6F4A63403EA029B250524475B0C0A8DFAA1BC907A4C263572E51D3E7C6E8954598AB83F02422AC241D936D668CDDC51BCFE3B		
ALS_CBO020_7-24-16.PDF	Laboratory Analytical Report	2016-08-25T10:33:55-04:00	
Cryptographic Hash Value of File (SHA-512)	9D9CD2952905278A764DA048E98B97D9E3DCD4E6DD2CCD6C5634E33E3D9D4E8218E471D0F356854CE08F0B8CC0DFEE1A6755B61B20E1D9143DCB886BC208		
ALS_CBO020_7-19-16.PDF	Laboratory Analytical Report	2016-08-25T10:33:09-04:00	
Cryptographic Hash Value of File (SHA-512)	D8C04500D47838878F7A306D06332AE2C1F655F0C2097DDE9CA6D42C3F0AAB545FCD709611CE8853DF93B4D3C8C02C86380E341F18C30E242D0712D8FC51A		
WRTP_Process Lab JULY 2016.pdf	Laboratory Analytical Report	2016-08-25T10:28:59-04:00	
Cryptographic Hash Value of File (SHA-512)	A71E3C95E19A3C25A860B7E3F432DDB3A2EF03B2100CA80B7780F9862E7C77D8728785AF58EC3B68A4D2A98CE17DA97AD824886FB15AA031B4DA70E8684CE		
ALS_Biweekly N 1 JULY 2016.PDF	Laboratory Analytical Report	2016-08-25T10:26:59-04:00	
Cryptographic Hash Value of File (SHA-512)	3398C1E30B71A080DCA031E6495A960D9BC973A7FB13815321B6D01ECC7AD99C3D7F375704BF949DDFF2516EDB1430FC924416B97689DE1049B8F3DD17438035		
ALS_CBO020_7-26-16.PDF	Laboratory Analytical Report	2016-08-25T10:34:27-04:00	
Cryptographic Hash Value of File (SHA-512)	B6CD29973B5290CE461B874AF7FB50E8F081E5C64E479D9C8170C8E88068180AC4AA09F8B3287E41B3D31944A80302848F5B3F5FF82ACBFCDC55308F7169A		
ALS_CBO020_7-17-16.PDF	Laboratory Analytical Report	2016-08-25T10:32:42-04:00	
Cryptographic Hash Value of File (SHA-512)	F721955D27124FB6DFC1F903E8CE4C23F9F7FF425A0AB48212844949FA47E6B83EADD49BE207E5DFC2E2F486F56D057431B31DA1855D05F37E4329CFA36C47		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ALS_OBOD20_7-14-16.PDF	Laboratory Analytical Report	2016-08-25T10:32:00-04:00	C23F9D3FB1215265873BC0EDC0F43687DDEF3B48F6A2A351ED3D1DBB505B445E0F65FF6E43D31464BAF0AAD28CDD805A1DBFE11C743FB53355658B7E71EFAC460
Cryptographic Hash Value of File (SHA-512)			
WRTP_Influent_July2016.pdf	Laboratory Analytical Report	2016-08-25T10:26:27-04:00	
Cryptographic Hash Value of File (SHA-512)			
WRTP_Effluent_July2016.pdf	Laboratory Analytical Report	2016-08-25T10:28:00-04:00	D3A56FEFC7C327137DBDC6891BC99113A5D0ABC3F8864AE48CC26E31D48F888D5353D21D45BCDA568E395F7BD2E9472C2C78E6CDBF421EE7E250C08C208973419
Cryptographic Hash Value of File (SHA-512)			
	Laboratory Analytical Report	2016-08-25T10:28:00-04:00	243BAE7F12FB760967B333988218DF5F1547E12FDF6A4A0CB247E0A6CF0B9BC7976429A863EBC330A73BCD54FD5E95A97F0317ED9EA178C88F8569CA8FB8B0D
Cryptographic Hash Value of File (SHA-512)			

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

PERMIT VIOLATIONS												
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEP Notified	Comments
OTHER PERMIT VIOLATIONS												
Non Compliance ID	Stage Code (Sampling Point)			Reported Parameter	Non Compliance Type		Comments					
COMMENTS DETAILS												
Comment			Operator Name			Operator Certification Number			Operator Contact Number			
			Michael J. DiSantis			T0403			6108765523			
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, You are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User			DISANTISM			Submitted By Full Name			Michael DiSantis			
Email Address			disantism@delcoa.org			Document Generated			8/25/2016			



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	07	01	TO 16 07 31
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
Copper, Total	EPA 200.7	ALS Environmental	PA 22-293				
Lead, Total	EPA 200.7	ALS Environmental	PA 22-293				
Zinc, Total	EPA 200.7	ALS Environmental	PA 22-293				
Dichlorobromomethane	EPA 624	ALS Environmental	PA 22-293				
BOD20/cBOD20	SM5210 B	ALS Environmental	PA 22-293				
Chlorodibromomethane	EPA 624	ALS Environmental	PA 22-293				
TKN-N	EPA 351.2	ALS Environmental	PA 22-293				
Ammonia as N	D6919-09	ALS Environmental	PA 22-293				
Nitrate as N	EPA 300.0	ALS Environmental	PA 22-293				
Total Cyanide	EPA 335.4	ALS Environmental	PA 22-293				
Total Cadmium	200.7	ALS Environmental	PA 22-293				
Nitrite as N	EPA 300.0	ALS Environmental	PA 22-293				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer
Phone: 610.876.5523
**Signature of Principal Executive Officer or
Authorized Agent**
Michael J. DiSantis
Date: 08/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	07	01	TO 16 07 31
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
BOD5/cBOD5	SM5210 B	DELCORA - Central Laboratory	23-00671				
TSS	SM 2540 D	DELCORA - Central Laboratory	23-00671				
O&G	EPA 1664 A	DELCORA - Central Laboratory	23-00671				
Total Residual Cl	SM4500-Cl G	DELCORA - Central Laboratory	23-00671				
N-Nitrite	SM4500-NO2 B	DELCORA - Central Laboratory	23-00671				
NH3-N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TKN-N	SM4500-N-org B/SM4500-NH3 C	DELCORA - Central Laboratory	23-00671				
Fecal Coliform	SM 9222 D	DELCORA - Central Laboratory	23-00671				
BOD20/cBOD20	SM5210 B	DELCORA - Central Laboratory	23-00671				
pH	SM 4500 H+B	DELCORA - Central Laboratory	23-00671				
Ammonia as N	EPA 350.1	DELCORA - Central Laboratory	23-00671				
TDS	SM 2540 C	DELCORA - Central Laboratory	23-00671				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 08/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: July Year: 2016
 NPDES Permit No.: PA0027103
 Renewal application due 180 days prior to expiration
 This permit will expire on: April 30, 2018

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month[illegible]

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION
(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Wicks Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
Title: **Dir. Of Operations and Maintenance**

License No.: **T0403**
Date: **August 28, 2016**



Facility Name: DELCORA WRTTP
 Municipality: City of Chester
 Watershed: 3G

SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

Month: July Year: 2016
 NPDES Permit No.: PA0027103
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

County: Delaware

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	30.76			278	71,318	3090.00	1.30	175330
2	27.93			280	65,222	2420.00	1.48	
3	27.04			184	41,495	2775.00	2.13	0
4	31.19			222	57,748	2575.00	2.10	0
5	34.28			306	87,484	2405.00	1.53	179880
6	30.74	348	89,217	502	128,699	2495.00	1.26	219120
7	30.44			562	142,675	2670.00	1.20	204610
8	30.45			640	162,530	2845.00	1.19	184340
9	29.48			194	47,697	2945.00	1.48	124690
10	28.36			188	44,466	2850.00	1.92	0
11	28.65			278	66,426	3375.00	1.87	51140
12	28.60			314	74,897	2900.00	1.27	176920
13	30.84	330	84,878	370	95,166	3135.00	1.35	159100
14	30.94			314	81,024	3125.00	1.16	114000
15	29.89			362	90,240	3055.00	1.27	22050
16	30.41			254	64,419	3070.00	1.28	0
17	29.53			234	57,630	2935.00	2.08	143386
18	35.73			466	138,863	3185.00	1.20	186490
19	32.19			514	137,991	3190.00	1.31	154868
20	30.95	377	97,312	490	126,480	3115.00	1.40	153195
21	31.64			392	103,440	3340.00	1.32	217595
22	31.53			374	98,347	3435.00	1.15	0
23	30.29			374	94,479	3425.00	1.08	202926
24	28.79			196	47,061	3320.00	1.35	0
25	38.54			402	129,212	2600.00	0.85	0
26	37.94	172	54,424	242	76,574	2440.00	1.08	174680
27	31.99			318	84,841	3170.00	1.17	215019
28	38.90			316	102,519	2820.00	1.57	212536
29	42.29			258	90,996	2440.00	1.45	208909
30	33.98			194	54,978	3015.00	1.74	216948
31	34.69			170	49,183	3045.00	1.89	203127
Avg	31.903	307	81,458	329	87,552	2,942	1	130,029
Max	42.29	377	97,312	640	162,530	3,435	2	219,120

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Micheal DiSantis
 Title: Dir. Of Operations and Maintenance

License No.: T0403
 Date: 8/28/2016



Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

Month: July
NPDES Permit No.: PA0027103
County: Delaware
Year: 2016
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

Day	SEPTAGE			SLUDGE			OTHER (specify):			DAILY TOTALS	
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (lbs)	BOD ₅ (lbs)
1	27010			Headworks	87000			Sludge Thickening	72100		0
2				Headworks				Sludge Thickening			
3				Headworks				Sludge Thickening			
4				Headworks				Sludge Thickening			
5	46218			Headworks	64699			Sludge Thickening	114000		0
6	23450			Headworks	99587			Sludge Thickening	102600		0
7	23050			Headworks	99566			Sludge Thickening	133339		0
8	21910			Headworks	60733			Sludge Thickening	92100		0
9	3000			Headworks	65000			Sludge Thickening	12100		0
10				Headworks				Sludge Thickening			
11	68000			Headworks	79503			Sludge Thickening	57500		0
12	41750			Headworks	55904			Sludge Thickening	85400		0
13	38350			Headworks	70445			Sludge Thickening	120393		0
14	47000			Headworks	49265			Sludge Thickening	106094		0
15	39350			Headworks	51438			Sludge Thickening	85700		0
16	7800			Headworks				Sludge Thickening	18300		0
17				Headworks				Sludge Thickening			
18	39000			Headworks	94135			Sludge Thickening	51900		0
19	36300			Headworks	132175			Sludge Thickening	117300		0
20	47010			Headworks	70042			Sludge Thickening	101900		0
21	50450			Headworks	63264			Sludge Thickening	123800		0
22	38300			Headworks	46733			Sludge Thickening	77420		0
23				Headworks				Sludge Thickening	21500		0
24				Headworks				Sludge Thickening			
25	22550			Headworks	79379			Sludge Thickening	74000		0
26	24450			Headworks	75231			Sludge Thickening	121300		0
27	24250			Headworks	19000			Sludge Thickening	88100		0
28	22400			Headworks	42135			Sludge Thickening	193100		0
29	34300			Headworks	55600			Sludge Thickening	75500		0
30	7700			Headworks				Sludge Thickening			
31				Headworks				Sludge Thickening			
Avg	31,896				69,564				88,932		Monthly Totals: 4,239,878

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
 Title: **Dir. Operations and Maintenance**
 License No.: **T0403**
 Date: **8/28/2016**



Year: 2016

Renewal application due **180 days** prior to expiration.
This permit will expire on: **April 30, 2018**

Total	9,771,378
-------	-----------

License No.: T0403
Date: 8/28/2016



Facility Name: DELCORA WRTP
 Municipality: City of Chester
 Watershed: 3G
 Laboratories: DELCORA; ALS Environmental
 County: Delaware
 Permit No.: PA0027103.A3
 Month: 7 (see number)
 Year: 2016
 Cutoff: 001
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

Flow	Feast Coliform	pH	CBOD5	CBOD20	TSS	TSS	TSS	TDS	Oil and Grease	TRC	NH3-N	NO3-N	NO2-N	TKN	Total Copper	Total Lead
mgd	g	g	mgd	g	g	g	%	g	mgd	g	mgd	g	mgd	g	mgd	g
1	25.34	6.58	5		5	87.11			1	0.28						
2	25.34	6.58	5		5	87.11			1	0.28						
3	25.34	6.58	5		5	87.11			1	0.28						
4	25.34	6.58	5		5	87.11			1	0.28						
5	25.34	6.58	5		5	87.11			1	0.28						
6	25.34	6.58	5		5	87.11			1	0.28						
7	25.34	6.58	5		5	87.11			1	0.28						
8	25.34	6.58	5		5	87.11			1	0.28						
9	25.34	6.58	5		5	87.11			1	0.28						
10	25.34	6.58	5		5	87.11			1	0.28						
11	25.34	6.58	5		5	87.11			1	0.28						
12	25.34	6.58	5		5	87.11			1	0.28						
13	25.34	6.58	5		5	87.11			1	0.28						
14	25.34	6.58	5		5	87.11			1	0.28						
15	25.34	6.58	5		5	87.11			1	0.28						
16	25.34	6.58	5		5	87.11			1	0.28						
17	25.34	6.58	5		5	87.11			1	0.28						
18	25.34	6.58	5		5	87.11			1	0.28						
19	25.34	6.58	5		5	87.11			1	0.28						
20	25.34	6.58	5		5	87.11			1	0.28						
21	25.34	6.58	5		5	87.11			1	0.28						
22	25.34	6.58	5		5	87.11			1	0.28						
23	25.34	6.58	5		5	87.11			1	0.28						
24	25.34	6.58	5		5	87.11			1	0.28						
25	25.34	6.58	5		5	87.11			1	0.28						
26	25.34	6.58	5		5	87.11			1	0.28						
27	25.34	6.58	5		5	87.11			1	0.28						
28	25.34	6.58	5		5	87.11			1	0.28						
29	25.34	6.58	5		5	87.11			1	0.28						
30	25.34	6.58	5		5	87.11			1	0.28						
31	25.34	6.58	5		5	87.11			1	0.28						
32	25.34	6.58	5		5	87.11			1	0.28						
33	25.34	6.58	5		5	87.11			1	0.28						
34	25.34	6.58	5		5	87.11			1	0.28						
35	25.34	6.58	5		5	87.11			1	0.28						
36	25.34	6.58	5		5	87.11			1	0.28						
37	25.34	6.58	5		5	87.11			1	0.28						
38	25.34	6.58	5		5	87.11			1	0.28						
39	25.34	6.58	5		5	87.11			1	0.28						
40	25.34	6.58	5		5	87.11			1	0.28						
41	25.34	6.58	5		5	87.11			1	0.28						
42	25.34	6.58	5		5	87.11			1	0.28						
43	25.34	6.58	5		5	87.11			1	0.28						
44	25.34	6.58	5		5	87.11			1	0.28						
45	25.34	6.58	5		5	87.11			1	0.28						
46	25.34	6.58	5		5	87.11			1	0.28						
47	25.34	6.58	5		5	87.11			1	0.28						
48	25.34	6.58	5		5	87.11			1	0.28						
49	25.34	6.58	5		5	87.11			1	0.28						
50	25.34	6.58	5		5	87.11			1	0.28						
51	25.34	6.58	5		5	87.11			1	0.28						
52	25.34	6.58	5		5	87.11			1	0.28						
53	25.34	6.58	5		5	87.11			1	0.28						
54	25.34	6.58	5		5	87.11			1	0.28						
55	25.34	6.58	5		5	87.11			1	0.28						
56	25.34	6.58	5		5	87.11			1	0.28						
57	25.34	6.58	5		5	87.11			1	0.28						
58	25.34	6.58	5		5	87.11			1	0.28						
59	25.34	6.58	5		5	87.11			1	0.28						
60	25.34	6.58	5		5	87.11			1	0.28						
61	25.34	6.58	5		5	87.11			1	0.28						
62	25.34	6.58	5		5	87.11			1	0.28						
63	25.34	6.58	5		5	87.11			1	0.28						
64	25.34	6.58	5		5	87.11			1	0.28						
65	25.34	6.58	5		5	87.11			1	0.28						
66	25.34	6.58	5		5	87.11			1	0.28						
67	25.34	6.58	5		5	87.11			1	0.28						
68	25.34	6.58	5		5	87.11			1	0.28						
69	25.34	6.58	5		5	87.11			1	0.28						
70	25.34	6.58	5		5	87.11			1	0.28						
71	25.34	6.58	5		5	87.11			1	0.28						
72	25.34	6.58	5		5	87.11			1	0.28						
73	25.34	6.58	5		5	87.11			1	0.28						
74	25.34	6.58	5		5	87.11			1	0.28						
75	25.34	6.58	5		5	87.11			1	0.28						
76	25.34	6.58	5		5	87.11			1	0.28						
77	25.34	6.58	5		5	87.11			1	0.28						
78	25.34	6.58	5		5	87.11			1	0.28						
79	25.34	6.58	5		5	87.11			1	0.28						
80	25.34	6.58	5		5	87.11			1	0.28						
81	25.34	6.58	5		5	87.11			1	0.28						
82	25.34	6.58	5		5	87.11			1	0.28						
83	25.34	6.58	5		5	87.11			1	0.28						
84	25.34	6.58	5		5	87.11			1	0.28						
85	25.34	6.58	5		5	87.11			1	0.28						
86	25.34	6.58	5		5	87.11			1	0.28						
87	25.34	6.58	5		5	87.11			1	0.28						
88	25.34	6.58	5		5	87.11			1	0.28						
89	25.34	6.58	5		5	87.11			1	0.28						
90	25.34	6.58	5		5	87.11			1	0.28						
91	25.34	6.58	5		5	87.11			1	0.28						
92	25.34	6.58	5		5	87.11			1	0.28						
93	25.34	6.58	5		5	87.11			1	0.28						
94	25.34	6.58	5		5	87.11			1	0.28						
95	25.34	6.58	5		5	87.11			1	0.28						
96	25.34	6.58	5		5	87.11			1	0.28						
97	25.34	6.58	5		5	87.11			1	0.28						
98	25.34	6.58	5		5	87.11			1	0.28						
99	25.34	6.58	5		5	87.11			1	0.28						
100	25.34	6.58	5		5	87.11			1	0.28						
101	25.34	6.58	5		5	87.11			1	0.28						
102	25.34	6.58	5		5	87.11			1	0.28						
103	25.34	6.58	5		5	87.11			1	0.28						
104	25.34	6.58	5		5	87.11			1	0.28						
105	25.34	6.58	5		5	87.11			1	0.28						
106	25.34	6.58	5		5	87.11			1	0.28						
107	25.34	6.58	5		5	87.11			1	0.28						
108	25.34	6.58	5		5	87.11			1	0.28						
109	25.34	6.58	5		5	87.11			1	0.28						
110	25.34	6.58	5		5	87.11			1	0.28						
111	25.34	6.58	5		5	87.11			1	0.28						
112	25.34	6.58	5		5	87.11			1	0.28						
113	25.34	6.58	5		5	87.11			1	0.28						
114	25.34	6.58	5		5	87.11			1	0.28						
115	25.34	6.58	5		5	87.11			1	0.28						
116	25.34	6.58	5		5	87.11			1	0.28						
117	25.34	6.58	5		5	87.11			1	0.28						
118	25.34	6.58	5		5	87.11			1	0.28						

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 U.S.C. § 493a (relating to uniform national information).

License No.: T0403
Date: 8/28/2016



SUPPLEMENTAL REPORT
DAILY EFFLUENT MONITORING

2000-PH-SUP-SAM-03-2012

Facility Name: DELCORA WRTP
Municipality: City of Chester
Watershed: 30
Laboratories: DELCORA: ALS Environmental

County: Delaware

Month: 7 (select number)
Year: 2015
Permit No.: PA0027103 A3
Outfall: 001
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018

Week	Day	Date	Flow MGD	TSS mg/L	BOD5 mg/L	CBOD5 mg/L												
1	Fri	7/10/15	30.78	278		180												
	Sat	7/11/15	27.91	283		185												
	Sun	7/12/15	27.04	184		82												
	Mon	7/13/15	31.19	222		118												
	Tue	7/14/15	34.95	448		235												
	Wed	7/15/15	30.24	332		273												
	Thu	7/16/15	30.44	354		253												
2	Fri	7/17/15	30.45	348	348	153												
	Sat	7/18/15	30.45	348		118												
	Sun	7/19/15	30.45	184		129												
	Mon	7/20/15	30.45	158		159												
	Tue	7/21/15	30.45	278		200												
	Wed	7/22/15	30.45	370	330	241												
	Thu	7/23/15	30.45	354		216												
3	Fri	7/24/15	30.45	362		340												
	Sat	7/25/15	30.45	254		205												
	Sun	7/26/15	30.45	224		193												
	Mon	7/27/15	30.45	468		322												
	Tue	7/28/15	32.19	574		375												
	Wed	7/29/15	30.45	400	377	309												
	Thu	7/30/15	31.64	392		305												
4	Fri	7/31/15	31.64	374		317												
	Sat	8/1/15	30.39	374		225												
	Sun	8/2/15	28.29	168		127												
	Mon	8/3/15	30.45	432		340												
	Tue	8/4/15	37.44	542	172	147												
	Wed	8/5/15	31.89	318		147												
	Thu	8/6/15	43.39	318		151												
5	Fri	8/7/15	33.39	164		137												
	Sat	8/8/15	34.58	170		137												
	Sun	8/9/15	34.58	170		137												
	Mon	8/10/15	34.58	170		137												
	Tue	8/11/15	34.58	170		137												
	Wed	8/12/15	34.58	170		137												
	Thu	8/13/15	34.58	170		137												

Daily Minimum (Conc)
Daily Maximum (Conc)
Max Avg Weekly (Conc)
Avg Monthly (Conc)
Geometric Mean (Conc)
Max Avg Weekly (Load)
Avg Monthly (Load)
Daily Minimum (Load)
Daily Maximum (Load)

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my knowledge and belief, this document contains true and accurate information, and I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn declaration).

Prepared By: Michael DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 8/28/2016



CSO SUPPLEMENTAL REPORT MONTHLY INSPECTION REPORT

Facility Name: Delaware County Regional Water Quality Control Authority
 Municipality: City of Chester County: Delaware
 Watershed: 3G

Month: July Year: 2016
 NPDES Permit No.: PA0027103
 Renewal application due 180 days prior to expiration.
 This permit will expire on: April 30, 2018

CSO Outfall No.	Outfall Location*	Discharge?*	Comments
002	Front & Booth	Yes	
003	Front & Highland	Yes	
004	Front & Hayes	Yes	
005	Front & Townsend	Yes	
007	Delaware & Reaney	Yes	
008	2nd & Tighman	Yes	
009	2nd & Lloyd	Yes	Total overflow from Outfalls 009 and 010
010	5th & Pusey	Yes	Discharges to Outfall 009 Regulator
011	2nd & Parker	Yes	
012	2nd & Edgmont	Yes	
013	2nd & Welsh	Yes	
014	3rd & Upland	Yes	
015	4th & Melrose	Yes	
016	8th & McDowell	Yes	
017	9th & Campbell	Yes	
018	Sun Dr. & Hancock	Yes	
019	14th & Crozer Hospital	Yes	
020	Kerlin & Finland	Yes	
021	9th & Sproul	Yes	
022	6th & Sproul	Yes	
023	3rd & Edgmont	Yes	
024	3rd & Dock	Yes	
025	5th & Penn	Yes	
026	7th & Penn	Yes	
032	2nd & Avenue of the States	Yes	
033	Elkington Blvd. and Ridley Creek	Yes	

Copy this report as needed to include more CSO outfalls.

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael J. DiSantis
 Title: Dir. Of Operations and Maintenance

License No.: T0403
 Date: 8/16/2016

Foley, Sue

From: depgreenporthelpdesk@state.pa.us
Sent: Monday, September 26, 2016 9:24 AM
To: DiSantis, Michael
Subject: Original Monitoring Report Submission 29076 Received Confirmation

Submitted By : Michael DiSantis
Submission Id : 29076
Submission Status : Received
Facility Name : DELCORA STP
Permit Number : PA0027103
Report Type : Monthly
Monitoring Report Period : 08/01/2016-08/31/2016
Monitoring Report Due Date : 09/28/2016



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

September 25, 2016

SUBMITTED ONLINE VIA PADEP eDMR SYSTEM

William Collins
Water Quality Specialist – Water Management Program
PA Department of Environmental Protection
2 East Main Street
Norristown, PA 19401

Dear Mr. Collins:

Enclosed are DELCORA's Discharge Monitoring Report, Laboratory Data Reports, and CSO Report for August, 2016. All parameters were in compliance during the month.

Parameter averages for August, 2016 were: Flow –27.91 MGD ; cBOD₅ –4 mg/L; TSS – 7 mg/L; cBOD₂₀ % removal –98.04 %; and cBOD₂₀ –2,179 lbs/day.

Should any further information be required concerning this report, please contact me at (610) 876-5523, ext. 264.

Respectfully submitted,

Electronically submitted

Michael J. DiSantis
Director of Operations and Maintenance

MJD:smf
Enclosures

cc: w/enclosures
US EPA - NPDES DMR (3WP42) – can access through DEP website
Delaware River Basin Commission – can access through DEP website
S.J. Babylon via email with server link
File

ADMINISTRATION

☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING

☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES

☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE

☐ 610-876-5523
☐ FAX: 610-497-7950

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

HEADER INFORMATION			
Facility ID:	482685	Facility Name:	DELCORA STP
Permit Number:	PA0027103	Monitoring Period:	08/01/2016-08/31/2016
		Location Address:	3201 W FRONT ST, CHESTER PA, 19013-2320
		Mailing Address:	100 EAST FIFTH STREET P.O. BOX 999, CHESTER PA, 19016-0999

PARAMETERS REPORTED VALUES

Parameter	Limit Type	001			Stage Code			Final Effluent			No Discharge Indicator	
		Load 1	Load 2	Units	Conc 1	Conc 2	Conc 3	Units	Sample Type	Sample Frequency	N	
pH	Sample Measurement	6.57			6.57	7.07		S.U.	Grab	1/day		
	Permit Measurement				6.0	Inst Min	9.0	IMAX	Grab	1/day		
Total Suspended Solids	Sample Measurement	1634	2210	lbs/day		7	10	mg/L	24-Hr Composite	1/day		
	Permit Measurement	11000	16500	Wkly Avg		30	45		24-Hr Composite	1/day		
Oil and Grease	Sample Measurement	<1164		lbs/day		<5		mg/L	Grab	1/day		
	Permit Measurement	5500				15	30		Grab	1/day		
Ammonia-Nitrogen	Sample Measurement					1.78		mg/L	24-Hr Composite	2/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	2/month		
Nitrite an N	Sample Measurement					.27		mg/L	24-Hr Composite	2/month		
	Permit Measurement					Monitor & Report Avg Mo	Monitor & Report Daily Max		24-Hr Composite	2/month		
Nitrate as N	Sample Measurement					12.2	13	mg/L	24-Hr Composite	2/month		
	Permit Measurement					Monitor & Report Avg Mo	Monitor & Report Daily Max		24-Hr Composite	2/month		
Total Kjeldahl Nitrogen	Sample Measurement					3.35		mg/L	24-Hr Composite	2/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	2/month		
Cyanide, Total	Sample Measurement					.055		mg/L	24-Hr Composite	1/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	1/month		
Chlorodibromomethane	Sample Measurement					.014		mg/L	Grab	1/month		
	Permit Measurement					Monitor & Report Avg Mo			Grab	1/month		
Cadmium, Total	Sample Measurement					<.001		mg/L	24-Hr Composite	1/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	1/month		
Copper, Total	Sample Measurement					.0077		mg/L	24-Hr Composite	1/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	1/month		
Lead, Total	Sample Measurement					<.003		mg/L	24-Hr Composite	1/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	1/month		
Zinc, Total	Sample Measurement					.04		mg/L	24-Hr Composite	1/month		
	Permit Measurement					Monitor & Report Avg Mo			24-Hr Composite	1/month		
Dichlorobromomethane	Sample Measurement					.004		mg/L	Grab	1/month		
	Permit Measurement					Monitor & Report Avg Mo			Grab	1/month		

[illegible]

**PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)**

ATTACHMENT DETAILS			
File Name	Attachment Type	Uploaded Time	Attachment Comment
DMR Cover Letter AUG 2016.doc	Cover Letter	2016-09-26T09:22:30-04:00	
Cryptographic Hash Value of File (SHA-512)			8CC9F30420E59CF2E2D59B3F85A98CB2786814EC94DFE1FF465B678AA22A4A5A4515DC7F3D0A6A4225B0A1FAA46167B2EA06A1FD68945320B9F0BF1573B10574
Daily Effluent Monitoring AUG 2016.xlsx	Daily Effluent Monitoring Form	2016-09-22T14:36:52-04:00	
Cryptographic Hash Value of File (SHA-512)			81F4D78036438F8B069817734E1E7CD1879346F909A1DE64F012490465F63D6459AE05DE3B2FC976CB570AC3D2792A3EB2753270786479AFDE35041CA11A7796
Daily Influent Monitoring AUG 2016.xlsx	Daily Effluent Monitoring Form	2016-09-22T14:36:28-04:00	
Cryptographic Hash Value of File (SHA-512)			F27EAC9989C89984978EAE65FCB7B3B90C3A5652E1D6CC2CB92E394259F483A17D9BF20AE2F3E255C009E21F8E40C8A987E089CE5E9FF510D71603420DFF4D278
DMR Laboratory Accreditation-ALS-AUG 2016.doc	Laboratory Accreditation Form	2016-09-22T14:38:24-04:00	
Cryptographic Hash Value of File (SHA-512)			57B0836A64EDBF5018DAE341DC0CF7144F673CD1083A1BDE35409E36F805B8FADB7727993273DD132095E754E71AD604848220321D3B0A54E26AEE11A2111
DMR Laboratory Accreditation-WRTP-AUG 2016.doc	Laboratory Accreditation Form	2016-09-22T14:38:41-04:00	
Cryptographic Hash Value of File (SHA-512)			D3F5FD5176E8E291F0FE72344D83B904CF7ED207A89491CCD7C4A93290C325ACAB282B98EAE626DE50FC40CD3E2FE381490D278A5D889BC5501E19AF31D9E938D2
Hauled In Municipal Waste AUG2016.xls	Hauled-In Municipal Waste Form	2016-09-22T14:36:02-04:00	
Cryptographic Hash Value of File (SHA-512)			5AD097802BC7864F59B7FEE3786F93398E2C80228C4F7AFDF66A8D0DE13FB2D356C91E3004A5C7E24E03C8B799361EBDD5A063207B5288B86476F35D0E6EE422
Hauled In Residual Wastes AUG2016.xls	Hauled-In Residual Waste Form	2016-09-22T14:35:39-04:00	
Cryptographic Hash Value of File (SHA-512)			62D818FC0EF8A238331BF870D398BD4963A04BC9CE9966A1BD1E0DA0E159B9857BCB81EC963A68F66DDA8695FD00E1035C7648F39D6F61613724A31D2417F3
Influent and Process Control AUG2016.xls	Influent and Process Control Form	2016-09-22T14:35:19-04:00	
Cryptographic Hash Value of File (SHA-512)			4FB20861E3AAAF6A4F1435E0DD16891F8706F3B1D3212AB2EB22AB3FF1C784103D02F30DC5361EED8A637B25E09A8173A2E80CC0CCDC43856F6B8D76F19380D84D
Sludge Production and Disposal AUG 2016.xlsx	Sludge Production and Disposal Form	2016-09-22T14:34:56-04:00	
Cryptographic Hash Value of File (SHA-512)			05A24339BC08E089E5F2F3E7FB36471846E027C61CAD667B730D92A587F962EB11FDE60ACF1DA25B733939FF59FC2FFA4DD9D14340671886A4D41B46139
August 2016 SWMM Report.xlsx	CSO Detailed Outfall Report Form	2016-09-22T14:37:56-04:00	
Cryptographic Hash Value of File (SHA-512)			418EE7CE2A798D21E97C5902D9CEEE81F84D23888F0611782B686151034D904D5FAE4E8F99ACCT42349CDAA435B5ED4EAC341A315725EF3AD6C706EF2FC181F8A
Trucked Waste Aug2016.xlsx	Other	2016-09-22T14:34:27-04:00	Trucked Waste Aug2016
Cryptographic Hash Value of File (SHA-512)			6B9C0785B99BA0E09B32E5468F51A566AC49006C86C4043DD493B25A933AC1B65FAECB12E029C1FC1BD5C0F0B002DE4B0FD73998F142213E541CB674E397F5
ALS_CBO020_8-14-16.PDF	Laboratory Analytical Report	2016-09-22T14:41:11-04:00	
Cryptographic Hash Value of File (SHA-512)			A021C96F2337A49DE24D0258E88653C5C0D7F764157ED2D646E256BA5415191A1A80D5A92BD0CB9B90D17BA10DC43E16A6B8B0F6D02DBD1591D71CFBDD061C88C
ALS_CBO020_8-14-16.PDF	Laboratory Analytical Report	2016-09-22T14:43:06-04:00	
Cryptographic Hash Value of File (SHA-512)			D45F591D8272D5D976A5835A48323AD7EEC7834FE475590C7A78169371932431E1FDD0EB168BF69A24A8611D53A87DFD0D7E14A73ED26C2FD4FCFD235E0B03
ALS_CBO020_8-16-16.PDF	Laboratory Analytical Report	2016-09-22T14:42:41-04:00	
Cryptographic Hash Value of File (SHA-512)			49E2D46C314819A4A0ABD91718A73DC9CDBD07340A6491554AC395068F35ED7F83392C362887AD71E10E5865321A4FCDD3817CFAC315E7F85BC42CFFEA6C7FCFAE8
ALS_CBO020_8-16-16.PDF	Laboratory Analytical Report	2016-09-22T14:41:49-04:00	
Cryptographic Hash Value of File (SHA-512)			498BA86A5E50053D9D0D220F7E0431C868527A0BE188E7C06E491810A0CA4D524B15F78E5632956B8B939E4A02C51581257ECB450FD9B343BAAA3E880DCA0A4BC5F2
ALS_CBO020_8-16-16.PDF	Laboratory Analytical Report	2016-09-22T14:43:28-04:00	
Cryptographic Hash Value of File (SHA-512)			0855338C9C2883CFAAD21202B44C4991010EB988789CB7B0A071402B15F40F3EC4C12EEF87536E22A253D7A4B59C2339C7A768F10D1F139C571D58F4123FEB8692
ALS_CBO020_8-2-16.PDF	Laboratory Analytical Report	2016-09-22T14:41:03-04:00	
Cryptographic Hash Value of File (SHA-512)			6D4D2CBCT726D4289029875AE0DBA8D52A7F64F089AE25A57A6800463BEDFD93901DCCAF8CC351DAB98EA6B793F91C8168FAD4E1C6F31B01549B32C141F2F70F9
WRTP_Influent_Aug2016.pdf	Laboratory Analytical Report	2016-09-22T14:40:05-04:00	
Cryptographic Hash Value of File (SHA-512)			01E5F65D4AEC28CC5C98C1869D4F587C0CEBEC8600D32AAAA3645B47111CA41921E88D2A9AB55E5FB3CF87134EAT7B1D3E93769795336A88EAC0B7EBC3CE27
WRTP_Process Lab_AUG2016.pdf	Laboratory Analytical Report	2016-09-22T14:40:34-04:00	
Cryptographic Hash Value of File (SHA-512)			1F789F500AAAC2D4A805059C600A3051CB634AA1A5EAF14D8A523810B98BA68A7801D0BA049F168BC0DDFC1BC6EED167A46A914612ACAA412EEED77AFB98F5
ALS_CBO020_8-9-16.PDF	Laboratory Analytical Report	2016-09-22T14:42:17-04:00	
Cryptographic Hash Value of File (SHA-512)			86E4E28C315CA458939D9038132C66ACA61638BC945391852E70A60532B2F93DC4BD28145557217EDDDDD9746B3B41A02F9183AFAA8984D2054C03B7A536FA
ALS_CBO020_8-4-16.PDF	Laboratory Analytical Report	2016-09-22T14:41:28-04:00	
Cryptographic Hash Value of File (SHA-512)			C70D9C9C7242366B8EF65946FA47147D67E84088E70C914787157736579BEAF8FC2DE9D5E2CAB1161DCED42003602BEFB2699C55C72BFF45C130852CB17DAB5E
WRTP_Effluent_Aug2016.pdf	Laboratory Analytical Report	2016-09-22T14:39:44-04:00	
Cryptographic Hash Value of File (SHA-512)			42A4A83E571339427857189B846430D908E265E5EC8A5A8740EA75675AA4804B8E75EAF68ED3B5FC08A41C278C482D7F7239554142C87C286D0FE78B18193
ALS_Effluent_Aug2016.PDF	Laboratory Analytical Report	2016-09-22T14:39:23-04:00	
Cryptographic Hash Value of File (SHA-512)			750B7EBF5D98479529903E845211F971C5814BAFC6D407652187E5A1AA8377AEAE7E43A5FA779AA48944F0986408E7FDB1ADA3D5068BA4533DFF3791C7C4887
ALS_CBO020_8-30-16.PDF	Laboratory Analytical Report	2016-09-22T14:45:38-04:00	
Cryptographic Hash Value of File (SHA-512)			2D849B5148C5AAE73138D93CA44638A36DC0BDFDCCDBFA381B0908BEBAD5A16B9C2C025BD946385D83F6B7321133179CEA8B8C0487E2BFEA6A43C4B11F08A14
ALS_CBO020_8-25-16.PDF	Laboratory Analytical Report	2016-09-22T14:44:54-04:00	
Cryptographic Hash Value of File (SHA-512)			00B48ED01456A26B6552E753EE7A39BE75005E30E5B893C5841283AA48281B168703D164615BF06B14E674E1C469AC394C1C2DE89F8277A589B1002DE7096D2

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

ALS_CBOD20_8-28-16.PDF	Laboratory Analytical Report	2016-09-22T14:45:15-04:00	
Cryptographic Hash Value of File (SHA-512)	CCADE7B812FDCFEA025124C080E7FA96AC1E31CE6EF51616F8B7452F7378D46B8D91741B75D5052317B123DAE1ADD36D1105D36280051DE761C9962595028EA372		
ALS_CBOD20_8-23-16.PDF	Laboratory Analytical Report	2016-09-22T14:44:34-04:00	
Cryptographic Hash Value of File (SHA-512)	5D82AE3EEA5567AFF1B286FC216DE333323554AC0B68C3F932EC7977F79DA211DED24EA6730572048F9D5F3ADF9F3104D62872E55A7F782AFFDFD58BA5130683		
ALS_CBOD20_8-18-16.PDF	Laboratory Analytical Report	2016-09-22T14:43:48-04:00	
Cryptographic Hash Value of File (SHA-512)	99053A220B34B9B5BCD5800B371A207E4C57B3993B6476C7694E729CD64B820B5465DCD14A5F02CDB04F8901A399D0C2066E7F2547DF48111E996EE2186DEF86		

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DISCHARGE MONITORING REPORT (DMR)

PERMIT VIOLATIONS												
Non Compliance ID	Event Begin Date	Event End Date	Parameter	Limit Type	Reported Value	Permitted Value	Load Units	Sampling Point ID	Cause Of NC	Corrective Action	Comments	
UNAUTHORISED DISCHARGES												
Non Compliance ID	Event Begin Date	Event End Date	Time Discovered	Substance Discharged	Event Location	Volume	Duration	Receiving Waters	Impact On Water	Cause Of Discharge	DEF Notified	Comments
OTHER PERMIT VIOLATIONS												
Non Compliance ID	Stage Code (Sampling Point)		Reported Parameter	Non Compliance Type		Comments						
COMMENTS DETAILS												
Comment	Operator Name							Operator Certification Number		Operator Contact Number		
	Michael J. DiSantis							T0403		6108765523		
SUBMISSION INFORMATION												
*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).												
Submitted By GreenPort User	DISANTISM		Submitted By Full Name				Michael DiSantis					
Email Address	disantism@delcora.org		Document Generated				9/26/2016					



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>6DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	08	01	TO 16 08 31
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER ²				
Copper, Total	EPA 200.7	ALS Environmental	PA 22-293				
Lead, Total	EPA 200.7	ALS Environmental	PA 22-293				
Zinc, Total	EPA 200.7	ALS Environmental	PA 22-293				
Dichlorobromomethane	EPA 624	ALS Environmental	PA 22-293				
BOD20/cBOD20	SM5210 B	ALS Environmental	PA 22-293				
Chlorodibromomethane	EPA 624	ALS Environmental	PA 22-293				
TKN-N	EPA 351.2	ALS Environmental	PA 22-293				
Ammonia as N	D6919-09	ALS Environmental	PA 22-293				
Nitrate as N	EPA 300.0	ALS Environmental	PA 22-293				
Total Cyanide	EPA 335.4	ALS Environmental	PA 22-293				
Total Cadmium	200.7	ALS Environmental	PA 22-293				
Nitrite as N	EPA 300.0	ALS Environmental	PA 22-293				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

**Signature of Principal Executive Officer or
Authorized Agent**

Michael J. DiSantis

Date: 09/28/16

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>DELCORA</u>							
Address: <u>P.O. Box 999</u>							
<u>Chester, PA 19016</u>							
<u>19016</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0027103				16	08	01	TO 16 08 31
PARAMETER	ANALYSIS METHOD	LAB NAME		LAB ID NUMBER²			
BOD5/cBOD5	SM5210 B	DELCORA - Central Laboratory		23-00671			
TSS	SM 2540 D	DELCORA - Central Laboratory		23-00671			
O&G	EPA 1664 A	DELCORA - Central Laboratory		23-00671			
Total Residual Cl	SM4500-Cl G	DELCORA - Central Laboratory		23-00671			
N-Nitrite	SM4500-NO2 B	DELCORA - Central Laboratory		23-00671			
NH3-N	EPA 350.1	DELCORA - Central Laboratory		23-00671			
TKN-N	SM4500-N-org B/SM4500-NH3 C	DELCORA - Central Laboratory		23-00671			
Fecal Coliform	SM 9222 D	DELCORA - Central Laboratory		23-00671			
BOD20/cBOD20	SM5210 B	DELCORA - Central Laboratory		23-00671			
pH	SM 4500 H+B	DELCORA - Central Laboratory		23-00671			
Ammonia as N	EPA 350.1	DELCORA - Central Laboratory		23-00671			
TDS	SM 2540 C	DELCORA - Central Laboratory		23-00671			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 610.876.5523

Signature of Principal Executive Officer or Authorized Agent

Michael J. DiSantis

Date: 09/28/2016

¹ Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

SUPPLEMENTAL REPORT SEWAGE SLUDGE / BIOSOLIDS PRODUCTION AND DISPOSAL

Facility Name: **DELCORA STP**
Municipality: **City Of Chester**
Watershed: **3G**

County: Delaware

Month: **August** Year: **2016**
 NPDES Permit No.: **PA0027103**
 Renewal application due **180 days** prior to expiration
 This permit will expire on: **April 30, 2018**

SEWAGE SLUDGE / BIOSOLIDS PRODUCTION INFORMATION (Identify each off-site removal event and incineration event)

☐ Check here if there were no off-site removal events during the month

[illegible]**TOTAL:****TOTAL:**

TOTAL:	1,090.510
---------------	------------------

SEWAGE SLUDGE / BIOSOLIDS AND INCINERATOR ASH DISPOSAL AND BENEFICIAL USE INFORMATION

(Identify all sites where biosolids or ash were disposed or land applied)

Site Name	Cumberland County Landfill	Mostoller Landfill, INC	Sts Community Landfill and Recy	A & M Composting
Municipality	Hopewell and North Newton	Brothersvalley and Somerset	Cumru Township	Penn Township
County	Cumberland	Somerset	Berks	Lancaster
DEP Permit No.	265792	238935	451623	602247
Type of Material*	incinerator ash	incinerator ash	incinerator ash	sewage sludge
Dry Tons Applied/Disposed				
Type of Disposal/Use*	landfill	landfill	landfill	composting
Hauler Name	Interstate Waste Services	Interstate Waste Services	Interstate Waste Services	J. P. Mascaro & Sons

* See Instructions for explanation.

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: **Michael DiSantis**
 Title: **Dir. Of Operations and Maintenance**

License No.: **T0403**
Date: **September 28, 2016**



SUPPLEMENTAL REPORT - INFLUENT & PROCESS CONTROL

3800-FM-BPNPSM0436 3/2012

Facility Name: DELCORA WRTP
Municipality: City of Chester
Watershed: 3G

County: Delaware

Month: August Year: 2016

NPDES Permit No.: PA0027103

Renewal application due 180 days prior to expiration.

This permit will expire on: April 30, 2018

Day	Influent				Process Control			
	Flow (MGD)	BOD ₅ (mg/l)	BOD ₅ (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)
1	30.47			280	71,154	3170.00	1.20	168108
2	32.23			310	83,327	3555.00	1.53	197148
3	29.75	346	85,848	550	136,463	3725.00	1.46	211066
4	30.10			294	73,804	3520.00	1.46	154623
5	29.26			290	70,768	3515.00	1.41	212495
6	27.93			204	47,519	3625.00	1.39	222834
7	27.47			252	57,733	3660.00	1.96	228103
8	28.24			400	94,209	3125.00	1.42	189128
9	28.36			306	72,376	3090.00	1.32	200011
10	28.71	237	56,748	332	79,495	3110.00	1.23	250425
11	28.81			292	70,160	3165.00	1.11	250505
12	29.21			330	80,392	3250.00	1.08	174074
13	29.52			384	94,540	3265.00	1.25	178751
14	29.67			184	45,530	3660.00	1.72	248912
15	29.41			498	122,149	2725.00	1.29	148051
16	28.90			518	124,851	2895.00	1.43	214438
17	29.64	293	72,429	638	157,712	2820.00	1.28	242974
18	31.80			430	114,041	2935.00	1.37	219717
19	31.78			520	137,824	2900.00	1.43	270231
20	29.53			257	63,294	3110.00	1.72	200338
21	32.60			230	62,533	3580.00	1.93	196416
22	30.78			502	128,866	2695.00	1.51	193539
23	28.94			542	130,817	2365.00	1.40	204422
24	26.44	167	36,825	306	67,476	2685.00	1.21	188821
25	25.77			474	101,873	4040.00	1.11	206019
26	26.40			462	101,721	4010.00	1.07	221450
27	25.39			318	67,337	3800.00	1.30	224764
28	25.16			248	52,039	3725.00	1.42	200978
29	26.28			468	102,574	3325.00	1.18	230557
30	26.98			472	106,206	3850.00	1.12	228799
31	26.82	270	60,393	422	84,392	3910.00	1.06	221941
Avg	28.785	263	62,449	378	90,748	3,316	1	209,666
Max	32.6	346	85,848	638	157,712	4,040	2	270,231

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Of Operations and Maintenance

License No.: T0403
Date: 9/28/2016



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Facility Name: DELCORA STP
Municipality: City of Chester
Watershed: 3G

SUPPLEMENTAL REPORT - HAULED IN MUNICIPAL WASTES

3800-FM-BPNPSM0437 3/2012

Month: August Year: 2016
NPDES Permit No.: PA0027103
Renewal application due 180 days prior to expiration.
This permit will expire on: April 30, 2018


County: Delaware

Day	SEPTAGE			SLUDGE			OTHER (specify):			DAILY TOTALS		
	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Disposal Location	Gallons	BOD ₅ (mg/l)	BOD ₅ (lbs)	Gallons
1	26650			Headworks	63200			Sludge Thickening	48500			139,350
2	31450			Headworks	57538			Sludge Thickening	179500			268,488
3	42700			Headworks	113880			Sludge Thickening	152600			309,180
4	13200			Headworks	94239			Sludge Thickening	148514			255,953
5	15450			Headworks	96300				109200			220,950
6				Headworks	97500			Sludge Thickening				97,500
7				Headworks				Sludge Thickening	43700			43,700
8	26250			Headworks	64607			Sludge Thickening	110700			201,557
9	35700			Headworks	104897			Sludge Thickening	110900			251,497
10	41950			Headworks	71025			Sludge Thickening	127300			240,275
11	46750			Headworks	71218			Sludge Thickening	124400			242,368
12	18800			Headworks	56938				12600			88,338
13				Headworks				Sludge Thickening				
14				Headworks				Sludge Thickening				
15	20550			Headworks	73638			Sludge Thickening	30000			124,188
16	24500			Headworks	59023			Sludge Thickening	173300			256,823
17	30200			Headworks	66956			Sludge Thickening	105400			202,556
18	34400			Headworks	46500				98700			179,600
19	22650			Headworks	56500				94200			173,350
20				Headworks				Sludge Thickening				
21				Headworks				Sludge Thickening				
22	17200			Headworks	37460			Sludge Thickening	84800			139,460
23	27950			Headworks	94865			Sludge Thickening	115500			238,315
24	29250			Headworks	63300			Sludge Thickening	106500			199,050
25	25050			Headworks	64400			Sludge Thickening	177469			266,919
26	45950			Headworks	92360				96000			234,310
27	11500			Headworks				Sludge Thickening	12000			23,500
28				Headworks				Sludge Thickening				
29	24400			Headworks	79889			Sludge Thickening	190500			294,789
30	30560			Headworks	107480			Sludge Thickening	167600			305,640
31	27000			Headworks	80548			Sludge Thickening	86000			193,549
Avg	27,919				75,594				103,275			Monthly Totals: 5,191,205

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: Michael DiSantis
Title: Dir. Operations and Maintenance

License No.: T0403
Date: 9/28/2016



DEPARTMENT OF ENVIRONMENTAL PROTECTION

3800-FM-BPNPSM0450 3/2012

Year: 2016

NPDES Permit No.: PA0027103 A3

Renewal application due **180 days** prior to expiration.
This permit will expire on: **April 30, 2018**

[illegible]

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See Pa. C.S. § 4904 (relating to unsworn falsification).

Michael DiSantis
Dir. Operations and Maintenance

License No. _____

Date: 9/28/2016

SUPPLEMENTAL REPORT

Facility Name:
Municipality:
Watershed:
Laboratories:

DELORA WRTP
City of Chester
36
DELORA: ALSEN

100

Month 8 (Lapses Number)
Permit No.: PA0027103 A3
Renewal application due 180 d
This permit will expire on:

Year 2016
Outfall: 001
prior to expiration.

This permit will expire on:

APR 30, 2018

Exploration

Parameter	Flow	Fecl Collform	pH	CBOD5	CBOD20	TSS	TSS	TDS	Oil and Grease	TRC	NH3-N	NO3-N	TKN	Total Copper	Total Lead
1	33.92	7	6.53	7	7	56.85	56.85	680.00	15	0.54					
2	30.56	17	6.75	7	7	56.85	56.85	735.00	15	0.54				0.0077	0.003
3	31.43	18	6.87	8	8	56.85	56.85	735.00	15	0.54					
4	28.75	30	6.89	8	8	56.85	56.85	735.00	15	0.54					
5	29.07	30	6.89	8	8	56.85	56.85	735.00	15	0.54					
6	28.46	31	6.87	8	8	56.85	56.85	735.00	15	0.54					
7	27.10	32	6.75	8	8	56.85	56.85	735.00	15	0.54					
8	26.74	31	6.85	8	8	56.85	56.85	735.00	15	0.54					
9	27.63	31	6.85	8	8	56.85	56.85	735.00	15	0.54					
10	27.40	31	6.85	8	8	56.85	56.85	735.00	15	0.54					
11	27.92	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
12	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
13	27.61	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
14	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
15	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
16	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
17	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
18	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
19	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
20	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
21	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
22	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
23	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
24	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
25	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
26	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
27	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
28	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
29	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
30	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
31	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
32	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
33	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
34	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
35	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
36	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
37	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
38	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
39	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
40	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
41	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
42	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
43	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
44	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
45	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
46	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
47	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
48	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
49	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
50	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
51	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
52	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
53	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
54	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
55	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
56	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
57	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
58	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
59	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
60	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
61	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
62	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
63	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
64	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
65	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
66	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
67	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
68	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
69	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
70	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
71	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
72	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
73	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
74	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
75	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
76	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
77	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
78	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
79	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
80	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
81	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
82	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
83	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
84	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
85	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
86	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
87	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
88	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
89	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
90	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
91	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
92	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
93	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
94	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
95	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
96	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
97	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
98	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
99	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
100	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
101	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
102	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
103	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
104	27.53	32	6.85	8	8	56.85	56.85	735.00	15	0.54					
105	27.53	32	6.85												

cently under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my knowledge and belief, this information is true and accurate and I am aware that there are no significant penalties for supplying false or inaccurate information. See 18 U.S.C. § 9502 (relating to uniform notification).

Prepared By: Michael DiSantis
 Title: Dir. Of Operations and Maintenance
 License No.: T0403
 Date: 5/28/2016

License No : T0403
Date : 5/28/2016