

**Application of Pennsylvania-American Water Company for Acquisition of  
the Wastewater Assets of Upper Pottsgrove Township  
66 Pa. C.S. § 1329  
Application Filing Checklist – Water/Wastewater  
Docket No. A-2020-3021460**

15. Plant in Service.
- c. State the DEP-permitted productive or treatment capacity of sources or treatment facility and the pipe sizes and material used for construction for all transmission and distribution or collection facilities.

**AMENDED RESPONSE:**

- c. See Direct Testimony of Michael J. Guntrum, PAWC Statement No. 2, at pp. 4-5 enclosed at **Appendix A-14-a**. See also the Engineer's Assessment at **Appendix A-15-a**.

Please see also **Amended Appendix A-25** for the capacity purchase agreements between Upper Pottsgrove Township and Pottstown Borough Authority (PBA), which show the current allocated treatment capacity of 670,100 gpd as of September 2000. It should be noted that the Engineers Assessment reflects 670,100 gpd of purchased capacity in the PBA WWTP. In addition, it also includes the construction costs associated with the Lower Pottsgrove agreement to transport up to 192,000 gpd through their collection system to PBA.

Please refer to **Appendix A-20-b** for the Regal Oaks, Farmington Avenue West/Evans Road and Pine Ford/Heather Place pump station DEP permits, which indicate each pump stations permitted capacity. After a diligent search by Upper Pottsgrove Township and PAWC in consultation with DEP, it is believed that a permit for the Hollyberry pump station does not exist. PAWC is working with Upper Pottsgrove and DEP to obtain this permit prior to closing.

PAWC is working with DEP to locate any major interceptor permits and will provide them if they exist.