

Tori L. Giesler, Esq.
(610) 921-6658
(330) 315-9263 (Fax)

April 8, 2021

VIA E-FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

**Re: *Completed Restoration of Momentary and Sustained Interruptions –
Metropolitan Edison Company; Docket No. M-2021-3023564***

Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 67.1, Metropolitan Edison Company (“Met-Ed”) submits written notification of completed restoration efforts following an interruption that began on March 26, 2021 that caused multiple service interruptions in the Met-Ed service territory.

Attached please find the details relative to the impact of this recent outage event and the restoration activities that took place. It should be noted that the review and approval process of this outage information is still in progress at the time of filing this report and as such, all outage information contained in this report should be considered preliminary.

If you have any questions, please contact me at (610) 921-6658.

Sincerely,



Tori L. Giesler

Enclosures

c: Dan Searfoorce - PaPUC Bureau of Technical Utility Services (via electronic mail)
Derek Ruhl - PaPUC Bureau of Technical Utility Services (via electronic mail)
John Van Zant - PaPUC Bureau of Technical Utility Services (via electronic

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
P O BOX 3265
HARRISBURG, PA 17105-3265

1. Reporting Utility: Metropolitan Edison Company ("Met-Ed")
Address: 800 Cabin Hill Drive
Greensburg, PA 15601

2. Name and title of person making report:

Scott Wyman
(Name)

President, Pennsylvania Operations
(Title)

3. Telephone number: (724) 838-6150
(Telephone Number)

4. Date and time report was made to Commission:

March 26, 2021
(Date)

1340
(Time)

5. Interruption or Outage:

(a) Number of customers affected: 19,515 (Represents 3.4% of Met-Ed's total customers).

(b) Approximate number of outage cases and trouble cases for each county affected during event: See response to 5(c).

(c) Approximate number of outages for each county affected during the event:

| County | Outages | Outage Cases | Trouble Cases |
|--------------|---------------|--------------|---------------|
| Adams | 109 | 9 | 15 |
| Berks | 3,430 | 136 | 175 |
| Bucks | 1,743 | 30 | 27 |
| Chester | 21 | 4 | 1 |
| Cumberland | 2,255 | 12 | 6 |
| Dauphin | 71 | 11 | 8 |
| Lancaster | 290 | 5 | 2 |
| Lebanon | 386 | 20 | 27 |
| Lehigh | 78 | 7 | 11 |
| Monroe | 774 | 28 | 34 |
| Montgomery | 294 | 18 | 12 |
| Northampton | 571 | 38 | 38 |
| Pike | 256 | 5 | 7 |
| York | 9,237 | 94 | 111 |
| Total | 19,515 | 417 | 474 |

(d) Approximate number of outage cases exceeding 6 or more hours in duration: 196

(e) A listing of each outage case exceeding 6 or more hours in duration:
See Attachment A.

Reason for the interruption or outages: Beginning the morning of Friday, March 26, 2021, a cold front with high winds moved across Pennsylvania, including the Met-Ed service territory. The front formed a storm system which produced sustained high winds with maximum winds gusts up to 52 miles per hour. See Attachment B for the wind report for March 26, 2021.

Damage as a result of the high winds included downed trees and power lines, damaged and broken poles and crossarms. The York, Easton, Dillsburg, Reading and Boyertown areas were the hardest hit; however, the high winds impacted the entire service territory. Approximately 65% of the total outages that occurred were tree related.

Preliminary data indicates the reliability impact of the storm was 8.4 minutes of SAIDI, 0.03 of SAIFI, and an overall storm CAIDI of 246.29 minutes.

(f) Projected time of restoration: It was estimated that the majority of customers would be restored by 1800 on March 27, 2021.

See Attachment C for the restoration curve and Attachment D for the order restoration graphs.

- (g) The number of utility workers, contract workers and workers received as mutual aid assigned specifically to the repair work by general function:

| Company | # of Workers | General Function |
|-----------------------|--------------|------------------------------------|
| Met-Ed | 170 | Line Workers |
| Subtotal | 170 | |
| Haugland Energy | 4 | Line Contractor |
| Henkels & McCoy | 9 | Line Contractor |
| J.W. Didado | 27 | Line Contractor |
| Miller Brothers | 14 | Line Contractor |
| NG Gilbert | 8 | Line Contractor |
| Subtotal | 62 | |
| Asplundh Tree Experts | 8 | Forestry Contractor |
| Davey Tree Experts | 11 | Forestry Contractor |
| Lewis Tree Service | 70 | Forestry Contractor |
| Nelson Tree Service | 19 | Forestry Contractor |
| Penn Line Service | 23 | Forestry Contractor |
| Tree Smiths | 55 | Forestry Contractor |
| Wright Tree Service | 8 | Forestry Contractor |
| York Tree | 4 | Forestry Contractor |
| Subtotal | 198 | |
| Met-Ed | 43 | Hazard Responders/Damage Assessors |
| Subtotal | 43 | |
| Met-Ed | 113 | Supporting Roles |
| Contractors (Various) | 6 | Supporting Roles |
| Subtotal | 119 | |
| Grand Total | 592 | |

- (h) The date and time of the first information of a service interruption: March 26, 2021 at 1104.
- (i) The date and time that repair crews were assembled: Crews were on-duty at the time of the storm.

- (j) The actual time that service was restored to the last affected customer:
March 28, 2021 at 1600. Met-Ed was able to restore 84.8% of the impacted customers in less than six hours.
- (k) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

| Equipment | Number |
|------------------------------|---------------|
| Primary Spans Down | 196 |
| Secondary Spans Replaced | 21 |
| Crossarms Replaced | 40 |
| Cutouts Replaced | 79 |
| Poles Replaced | 34 |
| Transformers Replaced | 31 |
| Wire & Cable Replaced (feet) | 9,142 |

- (l) If the interruption/outage event was weather-related, the utility's weather reports, outlooks, or scenarios for the day before and the day of the interruption/outage event:

See Attachment E for the weather forecast reports.

- (m) If the interruption/outage event caused approximate outages that exceed 10% or more of customers in the utility's entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events.

The outages that were a result of this event did not exceed 10% or more of customers in the utility's entire service territory.

Remarks: The storm statistics contained in this report are preliminary. The review and approval of the storm statistics is still in progress at the time of filing this report.

Attachment A: A listing of each outage case exceeding six or more hours in duration, including the following information¹:

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|----------------|--------------------------------------|---|---|--|----------------------------------|
| 11511595-3 | York | 21 | 1,534 | 03/26/2021 1104 | 03/27/2021 1238 |
| 11514232-1 | Berks | 11 | 1,459 | 03/26/2021 1112 | 03/27/2021 1131 |
| 11511794-2 | Monroe | 18 | 362 | 03/26/2021 1124 | 03/26/2021 1726 |
| 11512052-1 | Adams | 11 | 425 | 03/26/2021 1145 | 03/26/2021 1850 |
| 11512107-3 | Lancaster | 141 | 1,448 | 03/26/2021 1150 | 03/27/2021 1158 |
| 11517403-1 | Adams | 11 | 478 | 03/26/2021 1150 | 03/26/2021 1948 |
| 11517179-1 | Berks | 1 | 1,709 | 03/26/2021 1151 | 03/27/2021 1620 |
| 11514000-3 | Berks | 8 | 1,763 | 03/26/2021 1152 | 03/27/2021 1715 |
| 11512135-2 | York | 1 | 1,282 | 03/26/2021 1152 | 03/27/2021 0914 |
| 11514000-2 | Berks | 28 | 938 | 03/26/2021 1152 | 03/27/2021 0330 |
| 11512209-3 | Lancaster | 1 | 1,823 | 03/26/2021 1200 | 03/27/2021 1823 |
| 11512205-1 | York | 1 | 584 | 03/26/2021 1200 | 03/26/2021 2144 |
| 11512265-2 | Berks | 107 | 532 | 03/26/2021 1208 | 03/26/2021 2100 |
| 11512293-1 | Adams | 1 | 469 | 03/26/2021 1211 | 03/26/2021 2000 |
| 11515312-1 | York | 4 | 361 | 03/26/2021 1211 | 03/26/2021 1812 |
| 11512335-2 | Lebanon | 1 | 1,856 | 03/26/2021 1216 | 03/27/2021 1912 |
| 11512370-1 | Berks | 1 | 604 | 03/26/2021 1219 | 03/26/2021 2223 |
| 11512477-2 | Lebanon | 112 | 1,369 | 03/26/2021 1227 | 03/27/2021 1116 |
| 11512477-2 | Lebanon | 1 | 1,443 | 03/26/2021 1227 | 03/27/2021 1230 |
| 11512524-1 | Berks | 2 | 1,624 | 03/26/2021 1231 | 03/27/2021 1535 |
| 11512584-1 | Berks | 26 | 1,384 | 03/26/2021 1235 | 03/27/2021 1139 |
| 11512646-2 | York | 10 | 1,399 | 03/26/2021 1237 | 03/27/2021 1156 |
| 11515368-1 | Lebanon | 7 | 1,754 | 03/26/2021 1240 | 03/27/2021 1754 |
| 11512624-1 | Berks | 4 | 1,556 | 03/26/2021 1240 | 03/27/2021 1436 |
| 11512631-2 | Berks | 6 | 1,470 | 03/26/2021 1240 | 03/27/2021 1310 |
| 11512628-1 | Berks | 7 | 1,395 | 03/26/2021 1240 | 03/27/2021 1155 |
| 11511673-2 | Berks | 26 | 1,641 | 03/26/2021 1243 | 03/27/2021 1604 |
| 11512673-3 | Berks | 4 | 1,507 | 03/26/2021 1244 | 03/27/2021 1351 |
| 11512708-2 | Montgomery | 1 | 1,514 | 03/26/2021 1248 | 03/27/2021 1402 |
| 11512748-1 | York | 14 | 378 | 03/26/2021 1252 | 03/26/2021 1910 |

¹ When applicable, the individual restoration steps for an order are provided for those customers that were out of service for 6 hours or more.

Met-Ed Storm Report

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|----------------|--------------------------------------|---|---|--|----------------------------------|
| 11512760-3 | Berks | 76 | 630 | 03/26/2021 1255 | 03/26/2021 2325 |
| 11515296-1 | Berks | 10 | 388 | 03/26/2021 1259 | 03/26/2021 1927 |
| 11513023-1 | York | 10 | 380 | 03/26/2021 1301 | 03/26/2021 1921 |
| 11512868-2 | Berks | 1 | 1,748 | 03/26/2021 1303 | 03/27/2021 1811 |
| 11516491-1 | Berks | 4 | 1,506 | 03/26/2021 1304 | 03/27/2021 1410 |
| 11512882-3 | York | 2 | 1,180 | 03/26/2021 1304 | 03/27/2021 0844 |
| 11513357-2 | Lehigh | 27 | 1,451 | 03/26/2021 1307 | 03/27/2021 1318 |
| 11515334-1 | Lehigh | 2 | 1,451 | 03/26/2021 1307 | 03/27/2021 1318 |
| 11512917-4 | York | 1 | 1,346 | 03/26/2021 1307 | 03/27/2021 1133 |
| 11513357-1 | Lehigh | 8 | 427 | 03/26/2021 1307 | 03/26/2021 2014 |
| 11512924-1 | Berks | 1 | 1,982 | 03/26/2021 1308 | 03/27/2021 2210 |
| 11515927-1 | Berks | 14 | 1,223 | 03/26/2021 1309 | 03/27/2021 0932 |
| 11512985-2 | Lehigh | 1 | 1,939 | 03/26/2021 1315 | 03/27/2021 2134 |
| 11513973-1 | Berks | 9 | 514 | 03/26/2021 1315 | 03/26/2021 2149 |
| 11513041-1 | Berks | 10 | 588 | 03/26/2021 1317 | 03/26/2021 2305 |
| 11518238-2 | Berks | 2 | 1,825 | 03/26/2021 1320 | 03/27/2021 1945 |
| 11513074-1 | Berks | 5 | 1,334 | 03/26/2021 1322 | 03/27/2021 1136 |
| 11513157-4 | York | 1 | 425 | 03/26/2021 1324 | 03/26/2021 2029 |
| 11515767-1 | Berks | 6 | 1,189 | 03/26/2021 1326 | 03/27/2021 0915 |
| 11513298-1 | Lehigh | 4 | 1,613 | 03/26/2021 1327 | 03/27/2021 1620 |
| 11513166-1 | Berks | 8 | 404 | 03/26/2021 1327 | 03/26/2021 2011 |
| 11513266-2 | Berks | 151 | 587 | 03/26/2021 1328 | 03/26/2021 2315 |
| 11513209-1 | Berks | 1 | 1,844 | 03/26/2021 1329 | 03/27/2021 2013 |
| 11513206-1 | Berks | 8 | 689 | 03/26/2021 1329 | 03/27/2021 0058 |
| 11513307-1 | Lebanon | 1 | 597 | 03/26/2021 1335 | 03/26/2021 2332 |
| 11513330-2 | Monroe | 41 | 1,339 | 03/26/2021 1337 | 03/27/2021 1156 |
| 11513341-1 | Berks | 3 | 1,727 | 03/26/2021 1338 | 03/27/2021 1825 |
| 11513356-1 | Chester | 1 | 1,721 | 03/26/2021 1339 | 03/27/2021 1820 |
| 11515862-1 | Berks | 616 | 508 | 03/26/2021 1341 | 03/26/2021 2209 |
| 11517164-2 | Berks | 14 | 1,577 | 03/26/2021 1342 | 03/27/2021 1559 |
| 11513537-1 | Berks | 42 | 1,470 | 03/26/2021 1351 | 03/27/2021 1421 |
| 11513522-1 | Berks | 46 | 1,296 | 03/26/2021 1352 | 03/27/2021 1128 |
| 11513524-1 | York | 1 | 380 | 03/26/2021 1352 | 03/26/2021 2012 |
| 11513523-3 | Northampton | 1 | 3,036 | 03/26/2021 1352 | 03/28/2021 1600 |
| 11513625-1 | Montgomery | 5 | 1,444 | 03/26/2021 1356 | 03/27/2021 1400 |

Met-Ed Storm Report

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|----------------|--------------------------------------|---|---|--|----------------------------------|
| 11513624-1 | Berks | 1 | 1,778 | 03/26/2021 1358 | 03/27/2021 1936 |
| 11513618-1 | York | 4 | 901 | 03/26/2021 1358 | 03/27/2021 0459 |
| 11513648-1 | Dauphin | 1 | 1,043 | 03/26/2021 1400 | 03/27/2021 0723 |
| 11516676-1 | York | 1 | 589 | 03/26/2021 1400 | 03/26/2021 2349 |
| 11513655-1 | Northampton | 1 | 1,242 | 03/26/2021 1401 | 03/27/2021 1043 |
| 11513665-2 | Berks | 1 | 1,307 | 03/26/2021 1402 | 03/27/2021 1149 |
| 11514418-1 | Montgomery | 7 | 1,307 | 03/26/2021 1404 | 03/27/2021 1151 |
| 11513715-2 | York | 1 | 1,281 | 03/26/2021 1405 | 03/27/2021 1126 |
| 11515791-1 | Montgomery | 10 | 1,207 | 03/26/2021 1408 | 03/27/2021 1015 |
| 11513751-2 | Bucks | 5 | 540 | 03/26/2021 1409 | 03/26/2021 2309 |
| 11516198-1 | Montgomery | 3 | 1,526 | 03/26/2021 1411 | 03/27/2021 1537 |
| 11513810-2 | York | 4 | 1,369 | 03/26/2021 1413 | 03/27/2021 1302 |
| 11513810-1 | York | 6 | 491 | 03/26/2021 1413 | 03/26/2021 2224 |
| 11516837-1 | Berks | 3 | 1,233 | 03/26/2021 1414 | 03/27/2021 1047 |
| 11513850-1 | Northampton | 1 | 1,738 | 03/26/2021 1418 | 03/27/2021 1916 |
| 11513849-1 | Berks | 2 | 1,646 | 03/26/2021 1418 | 03/27/2021 1744 |
| 11513880-2 | Berks | 6 | 1,208 | 03/26/2021 1421 | 03/27/2021 1029 |
| 11513939-3 | Montgomery | 7 | 1,719 | 03/26/2021 1421 | 03/27/2021 1900 |
| 11513939-3 | Montgomery | 82 | 1,719 | 03/26/2021 1421 | 03/27/2021 1900 |
| 11513939-3 | Montgomery | 40 | 1,665 | 03/26/2021 1421 | 03/27/2021 1806 |
| 11515750-5 | York | 1 | 1,456 | 03/26/2021 1428 | 03/27/2021 1444 |
| 11515750-5 | York | 25 | 1,363 | 03/26/2021 1428 | 03/27/2021 1311 |
| 11517653-2 | Dauphin | 4 | 1,221 | 03/26/2021 1429 | 03/27/2021 1050 |
| 11513986-2 | Berks | 8 | 1,166 | 03/26/2021 1429 | 03/27/2021 0955 |
| 11514243-2 | Berks | 30 | 1,450 | 03/26/2021 1433 | 03/27/2021 1443 |
| 11514071-1 | Berks | 2 | 1,441 | 03/26/2021 1433 | 03/27/2021 1434 |
| 11514100-1 | Montgomery | 4 | 1,445 | 03/26/2021 1436 | 03/27/2021 1441 |
| 11514428-4 | Dauphin | 4 | 1,366 | 03/26/2021 1441 | 03/27/2021 1327 |
| 11518064-1 | Berks | 5 | 1,327 | 03/26/2021 1445 | 03/27/2021 1252 |
| 11514202-2 | Berks | 1 | 1,271 | 03/26/2021 1445 | 03/27/2021 1156 |
| 11518590-1 | Berks | 54 | 1,506 | 03/26/2021 1453 | 03/27/2021 1559 |
| 11518105-1 | Berks | 5 | 1,177 | 03/26/2021 1453 | 03/27/2021 1030 |
| 11514298-1 | Lebanon | 10 | 361 | 03/26/2021 1454 | 03/26/2021 2055 |
| 11514320-1 | Lebanon | 1 | 727 | 03/26/2021 1455 | 03/27/2021 0302 |
| 11514419-3 | Lebanon | 15 | 1,540 | 03/26/2021 1459 | 03/27/2021 1639 |

Met-Ed Storm Report

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|----------------|--------------------------------------|---|---|--|----------------------------------|
| 11514731-4 | Lebanon | 21 | 1,424 | 03/26/2021 1501 | 03/27/2021 1445 |
| 11518403-1 | Northampton | 4 | 1,617 | 03/26/2021 1506 | 03/27/2021 1803 |
| 11516866-1 | Berks | 9 | 1,604 | 03/26/2021 1507 | 03/27/2021 1751 |
| 11514480-1 | Lebanon | 1 | 366 | 03/26/2021 1507 | 03/26/2021 2113 |
| 11514523-1 | Berks | 5 | 1,406 | 03/26/2021 1511 | 03/27/2021 1437 |
| 11514583-4 | Pike | 54 | 1,500 | 03/26/2021 1512 | 03/27/2021 1612 |
| 11515448-1 | Berks | 6 | 1,299 | 03/26/2021 1512 | 03/27/2021 1251 |
| 11514524-1 | Berks | 2 | 1,289 | 03/26/2021 1512 | 03/27/2021 1241 |
| 11514574-1 | Bucks | 1 | 757 | 03/26/2021 1516 | 03/27/2021 0353 |
| 11514644-1 | Northampton | 4 | 669 | 03/26/2021 1521 | 03/27/2021 0230 |
| 11514654-1 | Bucks | 84 | 490 | 03/26/2021 1521 | 03/26/2021 2331 |
| 11514706-2 | Northampton | 1 | 1,685 | 03/26/2021 1526 | 03/27/2021 1931 |
| 11514871-2 | Monroe | 99 | 1,184 | 03/26/2021 1528 | 03/27/2021 1112 |
| 11514793-1 | Montgomery | 51 | 1,043 | 03/26/2021 1530 | 03/27/2021 0853 |
| 11513537-2 | Berks | 58 | 1,370 | 03/26/2021 1531 | 03/27/2021 1421 |
| 11514790-3 | Berks | 1 | 1,949 | 03/26/2021 1533 | 03/28/2021 0002 |
| 11514806-2 | Berks | 7 | 1,156 | 03/26/2021 1534 | 03/27/2021 1050 |
| 11514808-1 | Dauphin | 5 | 476 | 03/26/2021 1534 | 03/26/2021 2330 |
| 11515367-1 | Northampton | 18 | 403 | 03/26/2021 1537 | 03/26/2021 2220 |
| 11514868-2 | Monroe | 1 | 1,134 | 03/26/2021 1539 | 03/27/2021 1033 |
| 11515778-2 | Monroe | 1 | 1,517 | 03/26/2021 1542 | 03/27/2021 1659 |
| 11515009-1 | Lebanon | 2 | 367 | 03/26/2021 1545 | 03/26/2021 2152 |
| 11517879-1 | Chester | 6 | 1,370 | 03/26/2021 1546 | 03/27/2021 1436 |
| 11515063-1 | Berks | 1 | 1,173 | 03/26/2021 1547 | 03/27/2021 1120 |
| 11515082-1 | York | 14 | 474 | 03/26/2021 1548 | 03/26/2021 2342 |
| 11516694-2 | Bucks | 3 | 1,483 | 03/26/2021 1555 | 03/27/2021 1638 |
| 11515328-1 | Northampton | 1 | 2,793 | 03/26/2021 1602 | 03/28/2021 1435 |
| 11515393-3 | York | 8 | 993 | 03/26/2021 1608 | 03/27/2021 0841 |
| 11515489-4 | Northampton | 1 | 1,326 | 03/26/2021 1614 | 03/27/2021 1420 |
| 11515482-1 | Montgomery | 4 | 1,184 | 03/26/2021 1615 | 03/27/2021 1159 |
| 11515511-1 | Montgomery | 29 | 980 | 03/26/2021 1616 | 03/27/2021 0836 |
| 11515880-1 | Bucks | 6 | 589 | 03/26/2021 1617 | 03/27/2021 0206 |
| 11515668-1 | Chester | 13 | 1,065 | 03/26/2021 1619 | 03/27/2021 1004 |
| 11518353-1 | Northampton | 4 | 736 | 03/26/2021 1636 | 03/27/2021 0452 |
| 11515818-1 | Northampton | 7 | 537 | 03/26/2021 1642 | 03/27/2021 0139 |

Met-Ed Storm Report

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|------------|-------------------------------|------------------------------------|----------------------------------|-------------------------------------|---------------------------|
| 11515838-2 | Monroe | 1 | 1,637 | 03/26/2021 1643 | 03/27/2021 2000 |
| 11515836-1 | Northampton | 5 | 599 | 03/26/2021 1643 | 03/27/2021 0242 |
| 11515887-1 | Northampton | 4 | 612 | 03/26/2021 1647 | 03/27/2021 0259 |
| 11515950-1 | Berks | 1 | 1,643 | 03/26/2021 1652 | 03/27/2021 2015 |
| 11517582-2 | Bucks | 16 | 1,115 | 03/26/2021 1655 | 03/27/2021 1130 |
| 11516016-2 | Berks | 1 | 1,647 | 03/26/2021 1659 | 03/27/2021 2026 |
| 11516037-1 | Northampton | 32 | 544 | 03/26/2021 1659 | 03/27/2021 0203 |
| 11516731-2 | Bucks | 40 | 1,531 | 03/26/2021 1707 | 03/27/2021 1838 |
| 11516102-2 | Lehigh | 1 | 1,435 | 03/26/2021 1707 | 03/27/2021 1702 |
| 11516151-3 | York | 2 | 1,462 | 03/26/2021 1711 | 03/27/2021 1733 |
| 11517459-2 | Northampton | 7 | 1,378 | 03/26/2021 1712 | 03/27/2021 1610 |
| 11516230-1 | Bucks | 2 | 1,461 | 03/26/2021 1718 | 03/27/2021 1739 |
| 11516262-4 | Berks | 14 | 1,179 | 03/26/2021 1721 | 03/27/2021 1300 |
| 11516346-3 | York | 25 | 1,016 | 03/26/2021 1726 | 03/27/2021 1022 |
| 11517846-1 | Berks | 2 | 1,109 | 03/26/2021 1731 | 03/27/2021 1200 |
| 11516447-2 | Chester | 1 | 1,188 | 03/26/2021 1733 | 03/27/2021 1321 |
| 11516463-1 | Northampton | 1 | 1,286 | 03/26/2021 1734 | 03/27/2021 1500 |
| 11516465-2 | Northampton | 4 | 1,187 | 03/26/2021 1734 | 03/27/2021 1321 |
| 11518646-1 | Berks | 2 | 1,413 | 03/26/2021 1738 | 03/27/2021 1711 |
| 11516608-1 | Berks | 4 | 1,083 | 03/26/2021 1748 | 03/27/2021 1151 |
| 11516618-2 | Northampton | 1 | 1,485 | 03/26/2021 1749 | 03/27/2021 1834 |
| 11516177-2 | Berks | 17 | 1,295 | 03/26/2021 1755 | 03/27/2021 1530 |
| 11516578-1 | Bucks | 1 | 1,353 | 03/26/2021 1805 | 03/27/2021 1638 |
| 11515923-2 | Berks | 3 | 1,189 | 03/26/2021 1805 | 03/27/2021 1354 |
| 11516927-1 | Northampton | 2 | 744 | 03/26/2021 1821 | 03/27/2021 0645 |
| 11518076-2 | Bucks | 19 | 1,072 | 03/26/2021 1824 | 03/27/2021 1216 |
| 11517036-3 | York | 7 | 1,451 | 03/26/2021 1830 | 03/27/2021 1841 |
| 11517079-1 | Bucks | 1 | 1,226 | 03/26/2021 1840 | 03/27/2021 1506 |
| 11517078-1 | Bucks | 2 | 458 | 03/26/2021 1840 | 03/27/2021 0218 |
| 11517086-2 | Monroe | 4 | 1,444 | 03/26/2021 1841 | 03/27/2021 1845 |
| 11517086-2 | Monroe | 1 | 1,444 | 03/26/2021 1841 | 03/27/2021 1845 |
| 11517481-1 | York | 1 | 1,474 | 03/26/2021 1902 | 03/27/2021 1936 |
| 11517250-1 | Dauphin | 1 | 786 | 03/26/2021 1902 | 03/27/2021 0808 |
| 11517279-2 | Pike | 1 | 1,472 | 03/26/2021 1907 | 03/27/2021 1939 |
| 11517281-2 | Northampton | 2 | 816 | 03/26/2021 1907 | 03/27/2021 0843 |


Met-Ed Storm Report

| Order # | Approximate Location (County) | Total Number of Customers Affected | Duration of the Outage (minutes) | Initial Date and Time of the Outage | Restoration Date and Time |
|----------------|--------------------------------------|---|---|--|----------------------------------|
| 11517314-1 | Bucks | 1 | 942 | 03/26/2021 1912 | 03/27/2021 1054 |
| 11517348-1 | Berks | 2 | 904 | 03/26/2021 1918 | 03/27/2021 1022 |
| 11517429-1 | Berks | 1 | 1,564 | 03/26/2021 1933 | 03/27/2021 2137 |
| 11517664-1 | Montgomery | 4 | 993 | 03/26/2021 1943 | 03/27/2021 1216 |
| 11517446-3 | Berks | 23 | 1,120 | 03/26/2021 1946 | 03/27/2021 1426 |
| 11517486-1 | Berks | 1 | 1,045 | 03/26/2021 1946 | 03/27/2021 1311 |
| 11517541-1 | York | 1 | 424 | 03/26/2021 1959 | 03/27/2021 0303 |
| 11517655-2 | Northampton | 1 | 1,016 | 03/26/2021 2034 | 03/27/2021 1330 |
| 11517871-1 | Northampton | 1 | 760 | 03/26/2021 2058 | 03/27/2021 0938 |
| 11517883-2 | Berks | 1 | 1,130 | 03/26/2021 2103 | 03/27/2021 1553 |
| 11517940-2 | Berks | 1 | 2,538 | 03/26/2021 2132 | 03/28/2021 1550 |
| 11517946-5 | Berks | 1 | 2,315 | 03/26/2021 2137 | 03/28/2021 1212 |
| 11518025-1 | Lebanon | 1 | 1,012 | 03/26/2021 2150 | 03/27/2021 1442 |
| 11518063-2 | Berks | 1 | 859 | 03/26/2021 2201 | 03/27/2021 1220 |
| 11518329-2 | Berks | 2 | 606 | 03/27/2021 0711 | 03/27/2021 1717 |
| 11518443-1 | Berks | 1 | 694 | 03/27/2021 0826 | 03/27/2021 2000 |
| 11518465-1 | Bucks | 1 | 985 | 03/27/2021 0850 | 03/28/2021 0115 |
| 11518493-3 | Montgomery | 1 | 576 | 03/27/2021 0909 | 03/27/2021 1845 |
| 11518529-1 | Berks | 1 | 499 | 03/27/2021 0932 | 03/27/2021 1751 |
| 11519036-1 | Berks | 56 | 369 | 03/27/2021 1006 | 03/27/2021 1615 |
| 11518929-2 | Berks | 18 | 555 | 03/27/2021 1421 | 03/27/2021 2336 |
| 11518941-2 | Northampton | 1 | 1,406 | 03/27/2021 1431 | 03/28/2021 1357 |
| 11519236-2 | Monroe | 1 | 934 | 03/27/2021 1848 | 03/28/2021 1022 |
| 11519353-2 | Cumberland | 12 | 464 | 03/27/2021 2052 | 03/28/2021 0436 |
| 11519516-2 | Dauphin | 1 | 363 | 03/28/2021 0728 | 03/28/2021 1331 |
| 11519547-2 | Berks | 1 | 379 | 03/28/2021 0848 | 03/28/2021 1507 |


Attachment B: FirstEnergy Wind Report

Wind Report: The graphic below illustrates the maximum wind gusts in the Met-Ed service territory on March 26, 2021. The graphic is from the National Oceanic and Atmospheric Administration (“NOAA”).



Maximum Wind Gusts: Friday, March 26, 2021



Attachment C: Restoration Curve



Attachment D: Order Restoration Graphs



Attachment E: FirstEnergy Meteorologist Reports

Tuesday, March 23, 2021 at 1246

New Issuance:

A strong storm system appears likely to affect most of FirstEnergy with strong gusts throughout the day on Friday. Strong wind gusts are expected to move into southern Ohio and West Virginia early Friday morning, and spread northeast across most of the FirstEnergy footprint throughout the day.

Quick thoughts:


--In general, wind gusts of 45-55 mph, with occasional higher gusts appear possible, but the magnitude of these gusts could change as the event gets closer.

--The strongest gusts are expected across central Ohio, the Lake Erie shoreline, and potentially the higher elevations of West Virginia and Maryland early in the day Friday—but this too may change in the coming days.

--Periods of heavy rain, and perhaps a strong thunderstorm or two, are possible across areas of West Virginia and Maryland early Friday as well.

--There is still some uncertainty regarding the magnitude, location and timing of the winds, but there is good consensus that strong wind gusts will occur.

See graphic below for further details.



Wednesday, March 24, 2021 at 1033

Update:

--General increase of expected wind gusts in western FirstEnergy, especially across Ohio and northwest Pennsylvania. A period of strong winds (55-60+ mph gusts, sustained winds of 30-40 mph) is possible in these areas.

--Added more information on expected wind gust magnitudes and timing across FirstEnergy for Friday.

--Introduced the risk of strong/severe thunderstorms across western FirstEnergy Thursday evening. This is before the passage of the cold front and strong wind event on Friday.

--Updated areas that could see heavy rainfall and localized flash flooding late Thursday into Friday.

General storm information:

--A strong storm system will approach and move through FirstEnergy late Thursday through the day on Friday.



--The storm will drag a sharp cold front across the area, generally in a west-to-east fashion, beginning early Friday in western FirstEnergy and moving through far eastern FirstEnergy early Friday afternoon.



--Strong wind gusts are possible with the passage, and a few hours immediately after, of the front. The strongest gusts are expected across portions of Ohio and western Pennsylvania.

--A band of thunderstorms or heavy rain showers may be riding along the front. These will increase the likelihood of strong gusts.

--In a separate event, thunderstorms are likely to develop Thursday evening across western FirstEnergy, before the arrival of the main storm system.

See graphics below for further details.





Thursday, March 25, 2021 at 1018

Update:

--Increase in expected wind gusts for most of FirstEnergy—this is most relevant for areas of Ohio, Pennsylvania, and New Jersey.

--Updated thunderstorm forecast and introduced a second risk area for strong thunderstorms across western FirstEnergy—there are now two thunderstorm threats across these areas:

1) A small risk of isolated strong thunderstorms Thursday evening

2) A risk of severe thunderstorms capable of significant wind gusts along/ahead of the cold front early Friday.

--Removed areas of heavy rainfall—although areas across Ohio and western West Virginia could see >1 inch of rain from multiple rounds of storms Thursday evening & Friday morning.

--Small adjustments to timing of cold front and expected winds.

Additional Details:

--At any given location, wind speeds will likely increase very quickly as the cold front (or any thunderstorms) arrives.

--At any given location, the strongest winds (i.e. ‘peak winds’) will likely last for 1-3 hour period after the front passes. However ‘general wind gusts’ (>40+ mph) may linger for 4-8 hours after the front.



--The exception to this is in the elevations of eastern West Virginia, western Maryland, and southern Pennsylvania, where wind gusts will last a bit longer.



--Thunderstorms may not get the chance to develop along the cold front in Ohio/Pennsylvania early Friday, but:

A) Wind gusts of 55-60+ mph will still be possible with the front itself

B) Any storms that do develop in this window will be capable of significant localized wind gusts (60-70 mph)

See graphics below for further details.





Thursday, March 25, 2021 at 1502

Update:

Only small changes this afternoon; no major changes to the forecast.

--Small adjustments to the timing of the cold front and peak winds—moving them an hour or two earlier than discussed in this morning’s alert.

--Updated thunderstorm forecast to include a bit more area in Pennsylvania and West Virginia, and also to mention the possibility of a few tornados early Friday morning—tornado risk is mainly for central Ohio.

No changes to the rest of the forecast.

Additional Details:

--At any given location, wind speeds will likely increase very quickly as the cold front (or any thunderstorms) arrives.

--At any given location, the strongest winds (i.e. ‘peak winds’) will likely last for 1-3 hour period after the front passes. However ‘general wind gusts’ (>40+ mph) may linger for 4-8 hours after the front.



--The exception to this is in the elevations of eastern West Virginia, western Maryland, and southern Pennsylvania, where wind gusts will last a bit longer.



--Thunderstorms may not get the chance to develop along the cold front in Ohio/Pennsylvania early Friday, but:

A) Wind gusts of 55-60+ mph will still be possible with the front itself

B) Any storms that do develop in this window will be capable of significant localized wind gusts (60-70 mph)

See graphics below for further details.





Friday March 26, 2021 at 0841

Update: *No major changes to the forecast this morning. The small changes:*

- Removed all mention of thunderstorms along the cold front for the rest of the event.
- Expanded 45-55 mph wind gust area to include all of Potomac Edison.
- Small changes to the timing details for central and eastern FirstEnergy.

Additional Details:

- Given current observations this morning, the 'peak wind' period has lasted for roughly 2-3 hours after the arrival of the cold front.
- Winds will stay gusty (40-50 mph) for 5-8 hours after the passage of the front.
- Winds will generally relax across all of the FirstEnergy footprint after sunset tonight; this will occur earlier (this afternoon) across the western half of FirstEnergy.

See graphics below for further details.

Last Scheduled Update

