

DESCRIPTION OF DAILY WEATHER FACTOR (DWF) FORMULA

Prior to estimating future peak loads, it is necessary to adjust actual historical peak loads to a standard weather condition. This aids in determining what actual growths have been and in checking if the growth pattern of future estimates is reasonable.

Analyses to date indicate that the weather variable most highly correlated with daily peak demands consists of 29 hours of weighted dry bulb temperatures and one hour of weighted wet bulb temperature. The formula for this weather variable referred to as DWF (daily weather factor) follows:

$$DWF = \left[ \frac{1}{29} \sum_{n=1}^{29} T_{DB}^{(n)} \frac{n+27}{56} \right] + 0.5 T_{WB}^{(29)}$$

$T_{DB}^{(29)}$  = Dry Bulb Temp. @ hour of peak weather

$T_{DB}^{(1)}$  = Dry Bulb Temp. 28 hours prior

$T_{WB}^{(29)}$  = Wet Bulb Temp. @ hour of peak weather

Daily peaks have a high correlation with this DWF. Generally, during hot weather, the higher the DWF, the higher will be the daily peak load.

USE OF DAILY WEATHER FACTOR (DWF) FORMULA IN ANALYZING HISTORICAL PEAKS

Exhibit A is a plot of peak load vs. daily weather factor for all weekdays, excluding holidays, of April through October 1984. Examination of similar plots for past years indicated a constant demand value for daily weather factors between 64 and 77 and a uniformly rising trend for all daily weather factors above 86. The sloping line of Exhibit A is the linear regression for all points above 86 DWF. A vertical dashed line is drawn at the most probable peak weather value (standard weather) as determined from analysis of past weather records. The intersection of the sloping line and the vertical dashed line is defined as the regression demand. The most probable peak demand (standard demand) for a year has been determined to be a value slightly above the regression demand. Data for calculating standard weather is given in Exhibit B.

Exhibit C is a tabulation of the historical relationships between the regression demands and actual peak demands. The next to the last column shows the difference in percent between the actual peak demand that occurred in each year and the regression demand at standard weather. The "running average" difference is given in the last column. The standard demand for a year is determined by increasing the regression demand by the standard demand (running average) factor.

The inter-relationships of the above discussed factors are shown in Exhibit D. The solid sloping line is the linear regression line for 1984. Its intersection with the standard weather line gives a regression demand of 5885 MW. The standard demand for 1984 is 3.6% above this, or 6097 MW. The actual peak demand for 1984 was 5925 MW.



MAXIMUM DWF BETWEEN 10 AM AND TIME OF PEAK DEMAND

	<u>DWF</u>	<u>Date</u>	<u>Standard Weather (Running Average)</u>
1968	102.7	7/18	
1969	104.0	7/17	
1970	102.8	9/23	
1971	100.7	7/1	
1972	104.3	7/20	
1973	104.7	8/30	
1974	101.6	7/9	
1975	104.5	8/4	
1976	96.9	6/28	
1977	106.3	7/21	
1978	101.6	8/17	102.7
1979	101.7	8/1	102.7
1980	105.4	7/21	102.9
1981	104.3	7/9	103.0
1982	103.4	7/19	103.0
1983	100.4	9/6	102.8
1984	98.7	6/13	102.6

NOTE: 102.7 has been established as the standard weather to be used for forecasting purposes.


STANDARD DEMAND FACTOR

	<u>Regression Demand @ 102.7 DWF</u>	<u>Net Actual Peak Demand</u>	<u>Corrected Peak Demand</u>	<u>Corrected Demand @ 102.7 DWF</u>	<u>Standard Demand Factor (Running Average)</u>
1968	4316	4375	(4445)	1.030	
1969	4661	4592	(4746)	1.018	
1970	4750	4712	(4954)	1.043	
1971	4878	4922	(5034)	1.032	
1972	5162	5313	5313	1.029	
1973	5448	5760	5760	1.057	
1974	5434	5431	(5492)	1.011	
1975	5344	5530	(5545)	1.038	
1976	5462	5346	5346	.979	
1977	5397	5888	5888	1.091	
1978	5445	5667	5667	1.041	1.034
1979	5562	5641	5641	1.014	1.032
1980	5598	6095	(6145)	1.098	1.037
1981	5522	5731	5731	1.038	1.037
1982	5407	5691	5691	1.053	1.038
1983	5821	5879	5879	1.010	1.036
1984	5885	5925	5925	1.007	1.034*

( ) Corrected for voltage reduction and load curtailment.

NOTE: Latest Running average standard Demand Factor used for determining current year's standard demand and for forecasting future demands.

\* Because of unresolved meter error during summer regression period, it was decided to retain 1.036 as the standard demand factor for this forecast.



## USE OF DWF APPROACH IN ESTIMATING FUTURE PEAKS

The demand weather characteristic line for 1983 (Exhibit E) illustrates the foundation for the development of the demand forecast procedure. The horizontal segment is defined as base demand. The sloping segment is a function of weather sensitive demand. Coincident weather sensitive demand is derived by subtracting base demand from the regression demand.

The base demand as defined above has been found to have a high correlation with the average April and October output.

The coincident weather sensitive demand has been found to have reasonably good correlation with the estimates of actual MW's of connected air conditioning.

Exhibit F is a tabulation of historical average total monthly outputs of April and October. Also shown in Exhibit F in the last column is a historical tabulation of the ratio of base demand to base output. These historical ratios and extrapolation into the future are plotted in Exhibit G. A flat projection is used because of economic uncertainties. The extrapolated base demand factors are applied to the forecast of base output to compute the base demand forecast. The base output forecasts do not include any off-peak sales which result from new, non-typical loads such as off-peak electric car charging.

Exhibit H shows how the coincident weather sensitive demand as developed for the years 1968 through 1984. The last column shows estimates of connected air conditioning load for all years. These estimates of connected load are year-end values and are obtained from the Commercial Operations Department.


Exhibit I is a plot of a multiplier showing the relationship between coincident weather sensitive demand and connected air conditioning load for the years 1968-1984. The multiplier is determined by dividing the coincident weather sensitive demand by the connected air conditioning each year. During the 1969-78 period this multiplier has decreased and then shown a tendency to increase from 1978 to 1984. For forecast purposes the current value of .478 was used throughout.

This multiplier is applied to the forecast of connected air conditioning load to compute the coincident weather sensitive demand forecast.

The sum of the base demand and coincident weather sensitive demand produced a forecast of the regression demand (value of demand on the regression line at standard weather). As noted earlier, the regression demand must be increased by 3.6% (Standard Demand Factor) to obtain a forecast of most probable (standard) demand.

# DEMAND - WEATHER CHARACTERISTIC

1984




PHILADELPHIA ELECTRIC COMPANY SYSTEM  
ACTUAL AVERAGE OF APRIL AND OCTOBER OUTPUT

	<u>Base Output-GWH</u>	<u>Base Demand-MW</u>	<u>Demand ÷ Output</u>
1968	1734.2	2998	1.729
1969	1840.1	3142	1.708
1970	1906.3	3255	1.707
1971	1938.5	3326	1.716
1972	2059.6	3493	1.696
1973	2168.8	3668	1.691
1974	2138.4	3612	1.689
1975	2126.7	3632	1.708
1976	2209.9	3723	1.685
1977	2196.2	3763	1.713
1978	2246.2	3813	1.698
1979	2311.5	3830	1.657
1980	2246.0	3739	1.665
1981	2210.2	3696	1.672
1982	2190.0	3644	1.664
1983	2242.0	3697	1.649
1984	2290.0 (est.)	3781 (est.)	1.651

# BASE DEMAND FACTOR


$$\text{BASE DEMAND (MW)} = \text{BASE DEMAND FACTOR} \times \text{MONTHLY OUTPUT (GWHR)}$$



WEATHER SENSITIVE DEMAND - MW

	<u>Regression Demand</u>	-	<u>Base Demand</u>	=	<u>Coincident Weather Sensitive Demand</u>	<u>Connected Air Cond.</u>	<u>Multiplier</u>
1968	4316		2998		1318	2470	.534
1969	4661		3142		1519	2755	.551
1970	4750		3255		1495	3041	.492
1971	4878		3326		1552	3298	.471
1972	5162		3493		1669	3524	.474
1973	5448		3668		1780	3758	.473
1974	5434		3612		1822	3966	.459
1975	5344		3632		1712	4050	.428
1976	5462		3723		1738	4085	.426
1977	5397		3763		1634	4124	.395
1978	5445		3813		1632	4200	.388
1979	5562		3830		1732	4289	.405
1980	5598		3739		1859	4352	.429
1981	5522		3696		1826	4387	.416
1982	5407		3644		1763	4351	.405
1983	5821		3697		2124	4400	.483
1984	5885		3781 (est.)		2104	4393	.478

AIR CONDITIONING MULTIPLIER



AIR CONDITIONING MULTIPLIER

TIME - YEARS

SAMPLE CALCULATION OF 1985 PEAK DEMAND FORECAST

Base Demand

Base Monthly Output		2307 GWHRS
Base Demand Factor	x	<u>1.66</u>
Base Demand		3829 MW

Coincident Weather Sensitive Demand

Connected Air Conditioning Load	=	4381 MW
Coincident Weather Sensitive Demand obtained from Exhibit I (.478 x 4381)	=	2094 MW

Base Demand + Weather Sensitive Demand = Regression Demand

3829	+	2094	=	5923 MW
------	---	------	---	---------

Regression Demand x Standard Demand Factor = Standard Demand

5923	x	1.036	=	6136 MW
------	---	-------	---	---------

6140 MW (rounded)

## MAXIMUM, MINIMUM AND PROBABLE TWENTY YEAR DEMAND FORECAST

The twenty year probable forecast in Exhibit J was computed using the same procedure as described for the ten year forecast.

The maximum and minimum demand forecasts were computed by observing the ratios of maximum and minimum annual energy forecasts to the probable annual energy forecast and applying these ratios to the probable demand forecast.

The twenty year projections are more approximate than the ten year and are presented merely to indicate present thinking as to the range in load demand that could occur in the nineteen nineties.


PHILADELPHIA ELECTRIC COMPANY SYSTEM  
ANNUAL PEAK DEMAND  
20 YEAR FORECAST - MW

---

	<u>Probable</u>	<u>Maximum</u>	<u>Minimum</u>
1985	6140	6310	5970
1986	6160	6450	5910
1987	6180	6590	5850
1988	6200	6730	5790
1989	6220	6870	5730
1990	6240	7010	5670
1991	6260	7150	5610
1992	6320	7330	5580
1993	6380	7510	5550
1994	6440	7690	5520
1995	6500	7870	5490
1996	6560	8050	5460
1997	6620	8230	5430
1998	6700	8440	5430
1999	6780	8650	5430
2000	6860	8860	5430
2001	6940	9070	5430
2002	7020	9280	5430
2003	7100	9490	5430
2004	7180	9700	5430


# 1983-84 MONTHLY PJM CAPACITY PROFILE

Total Capacity = System Capacity - Misc. Capacity




# PERCENT LOAD

## PECO - DAILY LOAD CYCLE



# PECO Composite Daily Load Cycle With Generation Type



## PECO LOAD &amp; CAPACITY PROGRAM

## LIMERICK 2 (7-90)

1984-1994 (Year ending June 1)

YEAR	MW	DATE	CHANGES	REASON	CAPACITY	LOAD	PERCENT RESERVE	MW EXCESS OR DEFICIT OVER 25%
1984					7282	6100	19	-343
	12	9-84	Eddy. 1	Rerate				
	471	1-85	Salem 2	End of Sale to GPU				
1985	-166	5-85	Retire Richmond 9	Econ Retirement	7599	6140	24	-76
	-338	12-85	Retire Swk. 1,2&D	Econ Ret. 38 Yr				
	1055	2-86	Limerick 1	Service Date				
1986	-458	4-86	Retire Misc CT's	Econ Retirement	7858	6160	28	158
1987					7858	6180	27	133
1988					7858	6200	27	108
	-253	12-88	Retire Del. 7,8&D	End of 35 Yr Life				
1989	-12	12-88	Retire Sch. 3	End of 50 Yr Life	7593	6220	22	-182
1990					7593	6240	22	-207
	1055	7-90	Limerick 2	Service Date				
1991	-201	12-90	Retire Crowley 2	End of 35 Yr Life	8447	6260	35	622
1992					8447	6320	34	547
1993					8447	6380	32	472
1994	-169	12-93	Retire Sch. 1&D	End of 35 Yr Life	8278	6440	29	228

PECO 1986 Capacity &  
Energy Projections With and  
Without Limerick #1

	No Limerick #1 Unit and No 1985/86 Retirements*				Limerick #1 Unit In Service with Scheduled Retirements			
	Capacity		Energy		Capacity		Energy	
	MW	%	GWh	%	MW	%	GWh	%
IMPORTS	-	-	7937	26.2	-	-	3275	10.8
<u>Peaking Units</u>								
Non reheat oil steam	336		137	0.4	0		0	
Internal Combustion	1280		425	1.4	820		88	0.3
Pumped Hydro Gen.	880		1111	3.7	880		1147	3.8
	2496	32.8	1673	5.5	1700	21.6	1235	4.1
Pumped Hydro Load	-	-	(1620)	(5.3)	-	-	(1672)	(5.5)
Hydro**	410	5.4	1785	5.9	410	5.2	1785	5.9
<u>Intermediate Units</u>								
Reheat oil steam	1389	18.3	2309	7.6	1389	17.7	1873	6.2
<u>Base Units</u>								
Coal	1488		7709		1488		7569	
Nuclear	1816		10512		2871		16240	
	3304	43.5	18221	60.1	4359	55.5	23809	78.5
Total	7599	100	30305	100	7858	100	30305	100

\* Southwark 1&2, Combustion Turbines

\*\* The hydro (Conowingo) will vary from base to peaking depending on the time of the year. For most of the summer peak load season, the hydro will be peaking.

Economic Comparisons

<u>Date</u>	<u>Study Description</u>
7-19-76	Limerick Economic Comparison 2-1055 MW Units Service Dates 1984-86
10-21-76	Limerick Economic Comparison 2-1055 MW Units Service Dates 1983-85
6-2-77	Pencil Update of 10-21-76 Comparison. Uses Peach Bottom Actual Fuel and O&M Costs
7-3-78	Fossil-Nuclear Economic Comparison 2400 MW Station 1232(C) Service Dates 1983-85 2-1200 MW Nuclear Units 3-800 MW Fossil Units
5-27-80	V.S.B. statement to U.S. House of Representative Committee of Interior & Insular Affairs
5-28-80	PECO Annual Review (Part 2) (Presentation of Limerick history costs and savings as part of a 4 part presentation to PUC)
9-5-80	Comparison of the Limerick Nuclear Station compared with other alternatives updated to September 1980
10-9-80	35 Year Life Cycle Cost Limerick 2-1055 MW Nuclear Units 1985-87 Service Dates vs. 3-703 MW Generic Coal-Fired Units 1985-86 87 Service Dates
11-17-80	Economic Comparison 1083(A) - Limerick 2-1055 BWR's vs. Generic Coal 3-703 MW With Limestone Scrubbing

<u>Date</u>	<u>Study Description</u>
1-27-81	Comparison of the Limerick Nuclear Station with other alternatives updated to January 1981
1-29-81	Limerick Briefing Book
3-9-81	Outline of Need for Limerick 4 Plans