



June 2, 2021

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street, 2<sup>nd</sup> Floor – 1 North  
PO Box 3265  
Harrisburg, PA 17120

**SUBJECT: SUEZ Water Bethel Inc. AWWA Water Audit Report – Docket M-2021-3023555**

Dear Secretary Chiavetta:

Enclosed please find the SUEZ Bethel Inc. AWWA Water Audit Report for the year 2020.

This is in reference to Docket M-2021-3023555.

Please contact me at (302)252-3035 or via email at [larry.finnicum@suez.com](mailto:larry.finnicum@suez.com) for any questions or further information relating to the filing.

Best regards,

A handwritten signature in black ink, appearing to be "Larry Finnicum", written in a cursive style.

Larry Finnicum  
Director of Operations

Enclosures



# AWWA Free Water Audit Software: Water Balance

WAS v5.0  
American Water Works

Water Audit Report for:	Suez Water Bethel	
Reporting Year:	2020	1/2020 - 12/2020
Data Validity Score:	75	

		Water Exported 193.895	Billed Water Exported			Revenue Water 193.895
Own Sources (Adjusted for known errors)	System Input 454.703	Water Supplied 260.808	Authorized Consumption 180.865	Billed Authorized Consumption 177.605	Billed Metered Consumption (water exported is removed) 177.605	Revenue Water 177.605
					Billed Unmetered Consumption 0.000	
0.000				Unbilled Authorized Consumption 3.260	Unbilled Metered Consumption 0.000	Non-Revenue Water (NRW)
					Unbilled Unmetered Consumption 3.260	
Water Imported 454.703			Water Losses 79.943	Apparent Losses 4.721	Unauthorized Consumption 0.652	83.203
					Customer Metering Inaccuracies 3.625	
					Systematic Data Handling Errors 0.444	
				Real Losses 75.222	Leakage on Transmission and/or Distribution Mains <i>Not broken down</i>	
					Leakage and Overflows at Utility's Storage Tanks <i>Not broken down</i>	
					Leakage on Service Connections <i>Not broken down</i>	