

Jennedy S. Johnson
Assistant General Counsel

Telephone 215.841.4353
Fax 215.568-3389
Jennedy.Johnson@exelconcorp.com

PECO Energy
2301 Market Street / S23-1
Philadelphia, PA 19103

August 31, 2021

Via Electronic Mail

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

RE: Letter of Notification of PECO Energy Company for Approval to Replace an Existing Transmission Structure on the 130-35 138kV Transmission Line in Plymouth Township, Montgomery County, Pennsylvania
Docket No. A-2021-3027998
Utility Code: 110550

Dear Secretary Chiavetta:

Pursuant to the Commission's August 30, 2021 Secretarial Letter in the above-referenced docket, enclosed please find PECO Energy Company's ("PECO") Responses to the Data Requests of the Bureau of Technical Utility Services.

If you have any questions, feel free to contact me directly at (215) 841-5777.

Respectfully submitted,



Jennedy S. Johnson
Enclosures

cc: Per Certificate of Service
Jordan Van Order – Email Only (jvanorder@pa.gov)

BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION

LETTER OF NOTIFICATION OF	:	
PECO ENERGY COMPANY, FILED	:	
PURSUANT TO 52 PA CODE	:	
CHAPTER 57 SUBCHAPTER G, FOR	:	DOCKET NO.: A-2021-3027998
APPROVAL TO REPLACE	:	UTILITY CODE: 110550
ONE TRANSMISSION	:	
STRUCTURE IN PLYMOUTH	:	
TOWNSHIP, MONTGOMERY	:	
COUNTY, PENNSYLVANIA	:	

CERTIFICATE OF SERVICE

I hereby certify that on this date, a true and correct copy of the foregoing *Responses to Data Requests of the Bureau of Technical Services* has been served upon the following persons, in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant):

VIA ELECTRONIC MAIL OR HARD COPY (WHERE NO EMAIL IS LISTED):

Christopher G. Manero, Council President, Chair Plymouth Township Counsel 700 Belvoir Road Plymouth Meeting, PA 19462 cmanero@plymouthtownship.org	James Wallace, Code Enforcement Director Plymouth Township 700 Belvoir Road Plymouth Meeting, PA 19462 jwallace@plymouthtownship.org
Karen B. Weiss, Township Manager Plymouth Township 700 Belvoir Road Plymouth Meeting, PA 19462 kweiss@plymouthtownship.org	David Conroy, Zoning/Planning Officer Plymouth Township 700 Belvoir Road Plymouth Meeting, PA 19462 dconroy@plymouthtownship.org

<p>Dr. Valerie A. Arkoosh, Chair Montgomery County Board of Commissioners P.O. Box 311 Norristown, PA 19404 val@montcopa.org</p>	<p>Department of Environmental Protection Rachel Carson State Office Building 400 Market Street Harrisburg, PA 17101</p>
<p>Yassmin Gramian, Secretary Department of Transportation Keystone Building 400 North Street, 5th Floor Harrisburg, PA 17120</p>	<p>Nancy Moses, Chair Pennsylvania Historical and Museum Commission State Museum Building 300 North Street Harrisburg, PA 17120</p>
<p>Richard A. Kanaskie, Director Pennsylvania Public Utility Commission Bureau of Investigation & Enforcement Commonwealth Keystone Building 400 North Street Harrisburg, PA 17120 rkanaskie@pa.gov</p>	<p>Teresa Reed Wagner, Executive Director Office of Small Business Advocate 555 Walnut Street 1st Floor, Forum Place Harrisburg, PA 17101 tereswagne@pa.gov</p>
<p>Christine M. Hoover, Esq. Office of Consumer Advocate 555 Walnut Street 5th Floor, Forum Place Harrisburg, PA 17101-1923 choover@paoca.org</p>	



Dated: August 31, 2021

Jennedy S. Johnson (PA No. 203098)
PECO Energy Company
2301 Market Street, S23-1
Philadelphia, PA 19103
Phone: 215.841.4353
Fax: 215.568.3389
Jennedy.Johnson@exeloncorp.com

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission

Letter of Notification of PECO Energy Company,
for Approval to Replace an Existing Transmission Structure
on the 130-35 138kV Transmission Line in
Plymouth Township, Montgomery County, Pennsylvania

Docket No. A-2021-3027998
Utility Code: 110550

Responses of PECO Energy Company
To Data Requests of the
Bureau of Technical Utility Services

August 31, 2021

TUS-A-1:

Reference the Application, Paragraph 8. Please state the year the structure to be removed was constructed.

Response:

The structure was constructed in 1964.

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission

Letter of Notification of PECO Energy Company,
for Approval to Replace an Existing Transmission Structure
on the 130-35 138kV Transmission Line in
Plymouth Township, Montgomery County, Pennsylvania

Docket No. A-2021-3027998
Utility Code: 110550

Responses of PECO Energy Company
To Data Requests of the
Bureau of Technical Utility Services

August 31, 2021

TUS-A-2:

Reference the Letter of Notification, Paragraph 8. Please state the anticipated service life for the structure to be removed.

Response:

The anticipated service life of the structure to be removed is fifty (50) years.

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission

Letter of Notification of PECO Energy Company,
for Approval to Replace an Existing Transmission Structure
on the 130-35 138kV Transmission Line in
Plymouth Township, Montgomery County, Pennsylvania

Docket No. A-2021-3027998
Utility Code: 110550

Responses of PECO Energy Company
To Data Requests of the
Bureau of Technical Utility Services

August 31, 2021

TUS-A-3:

Reference the Letter of Notification, Paragraph 12. Please provide the approximate in-service date for the proposed project.

Response:

The approximate in-service date for the proposed project is November 22, 2021.

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission

Letter of Notification of PECO Energy Company,
for Approval to Replace an Existing Transmission Structure
on the 130-35 138kV Transmission Line in
Plymouth Township, Montgomery County, Pennsylvania

Docket No. A-2021-3027998
Utility Code: 110550

Responses of PECO Energy Company
To Data Requests of the
Bureau of Technical Utility Services


August 31, 2021

TUS-A-4:

Reference the Letter of Notification, Attachment 1, page 1. Please provide a copy of the diagram depicting the location of the existing structure on the 130-35 Transmission Line to be removed, the existing right-of-way, and the proposed location of the new transmission line structure.

Response:

Per section 9, the new structure is located 25' north of the existing structure.



**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

LETTER OF NOTIFICATION OF	:	
PECO ENERGY COMPANY, FILED	:	
PURSUANT TO 52 PA CODE	:	
CHAPTER 57 SUBCHAPTER G, FOR	:	DOCKET NO.: A-2021-3027998
APPROVAL TO REPLACE	:	UTILITY CODE: 110550
ONE TRANSMISSION	:	
STRUCTURE IN PLYMOUTH	:	
TOWNSHIP, MONTGOMERY	:	
COUNTY, PENNSYLVANIA	:	

VERIFICATION

I, Brian D. Crowe, hereby state that the facts set forth in PECO's Responses to the Bureau of Technical Utility Services' Data Requests, A-1 through A-5, are true and correct to the best of my knowledge, information, and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are subject to the penalties of 18 Pa. C.S. § 4904 (relating to false statements to authorities).

Date: August 31, 2021



Brian D. Crowe
Vice President of Transmission and Substations
PECO Energy Company

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission

Letter of Notification of PECO Energy Company,
for Approval to Replace an Existing Transmission Structure
on the 130-35 138kV Transmission Line in
Plymouth Township, Montgomery County, Pennsylvania

Docket No. A-2021-3027998
Utility Code: 110550

Responses of PECO Energy Company
To Data Requests of the
Bureau of Technical Utility Services

August 31, 2021

TUS-A-5:

Reference the Letter of Notification, Attachment 3, Section 3. Please provide the approximate right-of-way width for the proposed project.

Response:

The structure is located inside of PECO's pole yard property. The typical ROW for the 130-35 line at this location is 315'-0" as it shares the ROW with two 230kV circuits.